



**American Water Works
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA C215-10
(Revision of ANSI/AWWA C215-04)

AWWA Standard

Extruded Polyolefin Coatings for the Exterior of Steel Water Pipelines



Effective date: April 1, 2010.

First edition approved by AWWA Board of Directors June 19, 1988.

This edition approved Jan. 17, 2010.

Approved by American National Standards Institute Jan. 26, 2010.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
Science and Technology
Sections



Documents
Document Sharing Hub

Copyright © 2010 American Water Works Association. All Rights Reserved.

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2010 by American Water Works Association
Printed in USA

Committee Personnel

The SWPMTAC Task Group for AWWA C215, which developed this standard, had the following personnel at the time:

Mark S. Soloninka, *Chair*

F.D. Barnes, Barnes Group International, Windsor, Calif.	(AWWA)
S. Barnes, Scapa North American, Renfrew, Ont.	(AWWA)
R.M. Buchanan, Canusa-CPS, Toronto, Ont.	(AWWA)
A. Fletcher, TYCO Water, Melbourne, Australia	(AWWA)
D. Kathrein, Tapecoat Company, Evanston, Ill.	(AWWA)
A. Mamish, Berry Plastics, Lexington, Mass.	(AWWA)
M.P. Murphy, Ameron International, Rancho Cucamonga, Calif.	(AWWA)
D. Seals, JCM Industries, Nash, Texas	(AWWA)
M.S. Soloninka, ShawCor Pipe Protection, Houston, Texas	(AWWA)
J.A. Wise, Canus International Sales Inc., Surrey, B.C.	(AWWA)

The AWWA Standards Committee on Steel Pipe, which reviewed and approved this standard, had the following personnel at the time of approval:

John H. Bambei Jr., *Chair*

Dennis Dechant, *Vice-Chair*

John Luka, *Secretary*

General Interest Members

W.R. Brunzell, Brunzell Associates Ltd., Skokie, Ill.	(AWWA)
R.J. Card, Lockwood Andrews & Newnam, Houston, Texas	(AWWA)
R.L. Coffey, HDR Engineering Inc., Omaha, Neb.	(AWWA)
H.E. Dunham, MWH Americas Inc., Bellevue, Wash.	(AWWA)
S.N. Foellmi, Black & Veatch Corporation, Irvine, Calif.	(AWWA)
M.B. Horsley,* Black & Veatch Corporation, Kansas City, Mo.	(AWWA)
J.K. Jeyapalan, Pipeline Consultant, New Milford, Conn.	(AWWA)
R.A. Kufas, Norske Corrosion & Inspection Services Ltd., Surrey, B.C.	(AWWA)
J.L. Mattson, Corrosion Control Technologies, Sandy, Utah	(AWWA)
D.L. McPherson,* MWH Americas Inc., Cleveland, Ohio	(AWWA)
W.J. Moncreif,* HDR Engineering Inc., San Diego, Calif.	(AWWA)
R. Ortega,* Lockwood Andrews & Newnam, Houston, Tex.	(AWWA)

* Alternate

E.S. Ralph,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
A.E. Romer, AECOM, Newport Beach, Calif.	(AWWA)
H.R. Stoner, Consultant, North Plainfield, N.J.	(AWWA)
C.C. Sundberg, CH2M HILL, Issaquah, Wash.	(AWWA)
G.J. Tupac, G.J. Tupac & Associates Inc., Pittsburgh, Pa.	(AWWA)
W.R. Whidden, Post Buckley Schuh & Jernigan, Orlando, Fla.	(AWWA)
K.E. Wilson,† Standards Council Liaison, Post Buckley Schuh & Jernigan, Tampa Fla.	(AWWA)

Producer Members

S.A. Arnaout, Hanson Pressure Pipe Inc., Dallas, Texas	(AWWA)
H.H. Bardakjian, Consultant, Glendale, Calif.	(AWWA)
M. Bauer, Themec Company Inc., North Kansas City, Mo.	(AWWA)
R.R. Carpenter, American SpiralWeld Pipe Company, Birmingham, Ala.	(MSS)
D. Dechant, Dechant Infrastructure Services, Aurora, Colo.	(AWWA)
W.B. Geyer, Steel Plate Fabricators Association, Lake Zurich, Ill.	(AWWA)
B.D. Keil, Northwest Pipe Company, Portland, Ore.	(AWWA)
J.L. Luka,† American SpiralWeld Pipe Company, Columbia, S.C.	(AWWA)
R.D. Mielke,† Northwest Pipe Company, Raleigh, N.C.	(AWWA)
J. Olmos, Ameron International, Rancho Cucamonga, Calif.	(AWWA)
J.A. Wise, Canus International Sales Inc., Surrey, B.C.	(AWWA)

User Members

G.A. Andersen, New York City Bureau of Water Supply, Little Neck, N.Y.	(AWWA)
J.H. Bambei Jr., Denver Water Department, Denver, Colo.	(AWWA)
D.W. Coppes, Massachusetts Water Resources Authority, Southborough, Mass.	(AWWA)
R.V. Frisz, US Bureau of Reclamation, Denver, Colo.	(USBR)
G. George, Tacoma Water, Tacoma, Wash.	(AWWA)
T.J. Jordan, Metropolitan Water District of Southern California, LaVerne, Calif.	(AWWA)
M. McReynolds, Metropolitan Water District of Southern California, Oak Park, Calif.	(AWWA)
G. Oljaca, Metro Vancouver, Burnaby, B.C.	(AWWA)
V.B. Soto, Los Angeles Department of Water & Power, Los Angeles, Calif.	(AWWA)
G.P. Stine, San Diego County Water Authority, Escondido, Calif.	(AWWA)
J.V. Young, City of Richmond, Richmond, B.C.	(AWWA)

* Liaison, non-voting

† Alternate

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
<i>Foreword</i>			
I	Introduction..... vii	4.5	Coating Repair..... 11
I.A	Background..... vii	4.6	Field Procedures 12
I.B	History..... vii	4.7	Coating of Field Joints..... 13
II	Special Issues..... vii	4.8	Holiday Testing..... 13
III	Use of This Standard vii	5	Verification
III.A	Purchaser Options and Alternatives vii	5.1	Coating Materials Prequalification .. 13
III.B	Modification to Standard viii	5.2	Quality Assurance and Records..... 15
IV	Major Revisions..... viii	5.3	Inspection and Testing by the Purchaser 15
V	Comments ix	5.4	Quality Control Requirements of Coating Systems (Type A, B, and C)..... 16
<i>Standard</i>			
1	General	5.5	Rejection 17
1.1	Scope 1	6	Delivery
1.2	Purpose..... 2	6.1	Packaging and Marking 18
1.3	Application..... 2	6.2	Loading, Shipping, Handling, and Outdoor Storage..... 18
2	References 2	6.3	Affidavit of Compliance 18
3	Definitions 4	<i>Tables</i>	
4	Requirements	1	Physical Properties of Adhesive (Type A)..... 5
4.1	Equipment 4	2	Physical Properties of Adhesive (Type B and C) 5
4.2	Materials and Workmanship 4	3	Physical Properties of Polyolefin Resin for Polyolefin Sheath (Types A, B, and C) 5
4.3	Coating System 4		
4.4	Coating Application 8		

4	Physical Properties of the Liquid Adhesives (Primer) for Type C.....	5	6	Quality Control Properties of Coating Systems (Types A, B, and C).....	6
5	Prequalification Requirements of Coating Systems (Types A, B, and C).....	6			

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C215.

I. Introduction.

I.A. *Background.* Extruded polyolefin pipe-coating systems were first applied on steel pipe in 1956 using a crosshead-die extrusion system. In 1965, side extrusion was introduced in Europe and became available in the United States in 1972.

I.B. *History.* The first edition of ANSI/AWWA C215 was approved by the AWWA Board of Directors on June 19, 1988, and had an effective date of Jan. 1, 1989. The second edition of ANSI/AWWA C215 was approved on Jan. 30, 1994, and had an effective date of Nov. 1, 1994. The third edition incorporated the latest technology and requirements. It was approved on June 20, 1999. The fourth edition of ANSI/AWWA C215 was approved on Jan. 18, 2004. The fifth edition incorporates the latest technology and requirements. It was approved on Jan. 17, 2010.

II. Special Issues. ANSI/AWWA C215 is intended to govern the exterior coating of steel water pipelines for underground or underwater installation under normal conditions. It is based on current experience, but it is not intended for unqualified use under all conditions. The applicability of its use for any installation must be reviewed by the purchaser.

Currently, significant experience in extruded polyolefin coatings applied to steel water pipe is limited to polyethylene (PE) material.

Extruded polyolefin coatings described in ANSI/AWWA C215 can be shop-applied to straight lengths of steel water pipe up to 144 in. (3,650 mm) diameter. Three coating-application systems are described in the standard: the crosshead-die system (Type A) up to 36 in. (900 mm) diameter; and the side-extrusion system with and without primer for Type B and C up to 144 in. (3,650 mm) diameter.

Future air emission rules may regulate the use of liquid adhesives (primers) described in this standard. If this occurs, consult the manufacturer for equivalent alternatives.

III. Use of Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following items should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C215, Extruded Polyolefin Coatings for the Exterior of Steel Water Pipelines, of latest revision.

2. Any exceptions to the standard.
3. Diameter, length, weld configuration, and location of pipeline.
4. Temperature of conveyed water (Sec. 1.1.2).
5. Requirements for coating thickness (Sec. 4.3.1.4).
6. Certified reports for each lot of adhesive (Sec. 4.3.2.1).
7. Certified reports for each resin for sheath (Sec. 4.3.2.3).
8. Requirements for coating application at pipe ends (coating cutback) (Sec. 4.4.3.4, 4.4.4.4, and 4.4.5.5).
9. Requirements for coating repair (Sec. 4.5).
10. Requirements for pipe bedding and trench backfill (Sec. 4.6.3).
11. Requirements for coating of field joints (Sec. 4.7).
12. Requirements for inspection and testing (Sec. 5.1, 5.2, and 5.3).
13. Requirements for loading, shipping, handling, and outdoor storage (Sec. 6.2).
14. Affidavit of compliance (Sec. 6.3).

III.B. *Modification to Standard.* Any modification of the provisions, definitions, or terminology in this standard must be specified by the purchaser.

IV. Major Revisions. The major revisions made to the standard in this edition include the following:

1. Added future air emissions rules in the foreword.
2. Added a Type C coating system to the Scope of the standard (Sec. 1.1) and under Sec. 4.3, which included revisions to Sec. 4.3.1 and the addition of new Sec. 4.3.1.2 and Sec. 4.3.2.2 covering Type C adhesives.
3. Section 2, 4.5, and 4.7 were revised to exclude reference to ANSI/AWWA C203, which is no longer applicable.
4. Deleted definition of abrasive blast cleaning (Section 3).
5. Sec. 4.3 and 4.4 were revised to include Type C coating applications.
6. Sec. 4.4.2, Pipe Preparation, was renamed Surface Preparation and revised.
7. Addition of Table 4, Physical properties of the liquid adhesives (Primer) for Type C.
8. Addition of Table 5, Prequalification requirements of coating systems (Type A, B, and C).
9. Addition of Table 6, Quality control properties of coating systems (Type A, B, and C).
10. Added a new section (Sec. 4.4.5) on Type C coating application.
11. Revisions were made to Sec. 4.5, Coating Repair.
12. Sec. 4.6, Field Procedures, was rewritten.

13. The laboratory tests section under Section 5, Verification, was retitled as Sec. 5.1, Coating Materials Prequalification, and a new paragraph on prequalification of coating materials was added.

14. Added a new section on adhesion testing (Sec. 5.1.16).

15. Added a new section on cathodic disbondment qualification test (Sec. 5.1.17).

16. The coated pipe tests section was revised and renamed to Sec. 5.4, Quality Control Requirements of Coating Systems (Type A, B, and C).

17. A new section on adhesion testing was added (Sec. 5.4.4.)

V. Comments. If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standards@awwa.org.

This page intentionally blank.

