

American Water Works Association

ANSI/AWWA C218-99

(Revision of ANSI/AWWA C218-95)



AWWA STANDARD
FOR
COATING THE EXTERIOR
OF ABOVEGROUND STEEL WATER
PIPELINES AND FITTINGS

Effective date: January 1, 2000.

First edition approved by AWWA Board of Directors Jan. 27, 1991.

This edition approved Jan. 24, 1999.

Approved by American National Standards Institute October 1, 1999.

AMERICAN WATER WORKS ASSOCIATION

6666 West Quincy Avenue, Denver, Colorado 80235

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 11 W. 42nd St., New York, NY 10036; (212) 642-4900.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 1999 American Water Works Association
Printed in USA

Committee Personnel

The SWPTAC Task Group for AWWA C218, which developed this standard, had the following personnel at the time of approval:

Henry R. Stoner, *Chair*

R.M. (Mike) Bauer, Tnemec Company Inc., Kansas City, Mo.	(AWWA)
Randy Newby, Devoe Coating Company, Portland Ore.	(AWWA)
H.R. Stoner, Consultant, North Plainfield, N.J.	(AWWA)

The AWWA Standards Committee on Steel Pipe, which reviewed and approved this standard, had the following personnel at the time of approval:

George J. Tupac, *Chair*
 John H. Bambei Jr., *Vice-Chair*
 Dennis Dechant, *Secretary*

Consumer Members

G.A. Andersen, New York City Bureau of Water Supply, Corona, N.Y.	(AWWA)
J.H. Bambei Jr., Denver Water, Denver, Colo.	(AWWA)
B.R. Bullert,* Council Liaison, City of St. Paul Water Utility, St. Paul, Minn.	(AWWA)
R.V. Frisz, US Bureau of Reclamation, Denver, Colo.	(USBR)
T.J. Jordan, Metropolitan Water District of Southern California, Los Angeles, Calif.	(AWWA)
W.M. Kremkau, Washington Suburban Sanitary Commission, Laurel, Md.	(AWWA)
T.A. Larson, Tacoma Water Division, Tacoma, Wash.	(AWWA)
A.L. Linard, Los Angeles Department of Water and Power, Los Angeles, Calif.	(AWWA)
G.M. Snyder,† Metropolitan Water District of Southern California, Los Angeles, Calif.	(AWWA)
G.P. Stine, San Diego County Water Authority, Escondido, Calif.	(AWWA)

General Interest Members

Ergun Bakall, AKM Consulting Engineers, Irvine, Calif.	(AWWA)
W.R. Brunzell, Brunzell Associates Ltd., Skokie, Ill.	(AWWA)
R.L. Coffey, Kirkham Michael Consulting Engineers, Omaha, Neb.	(AWWA)
L.J. Farr, CH2M Hill Inc., Redding, Calif.	(AWWA)
K.G. Ferguson, Montgomery Watson, Las Vegas, Nev.	(AWWA)
S.N. Foellmi, Black & Veatch LLP, Irvine, Calif.	(AWWA)
J.W. Green, Alvord Burdick & Howson, Lisle, Ill.	(AWWA)

*Liaison, nonvoting

†Alternate

K.D. Henrichsen, HDR Engineering Inc., Denver, Colo.	(AWWA)
M.B. Horsley,* Black & Veatch LLP, Kansas City, Mo.	(AWWA)
J.K. Jeyapalan, Engineering Consultant, New Milford, Conn.	(AWWA)
R.Y. Konyalian, Engineering Consultant, Huntington Beach, Calif.	(AWWA)
Rafael Ortega, Lockwood Andrews & Newman Inc., Houston, Texas	(AWWA)
A.E. Romer, Boyle Engineering Corporation, Newport Beach, Calif.	(AWWA)
H.R. Stoner, Consultant, North Plainfield, N.J.	(AWWA)
C.C. Sundberg,* CH2M Hill Inc., Bellevue, Wash.	(AWWA)
G.J. Tupac, G.J. Tupac & Associates Inc., Pittsburgh, Pa.	(AWWA)
J.S. Wailes,† Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
L.W. Warren, KCM Inc., Seattle, Wash.	(AWWA)
W.R. Whidden, Post Buckley Schuh & Jernigan, Winter Park, Fla.	(AWWA)

Producer Members

H.H. Bardakjian, Ameron Concrete & Steel Pipe, Rancho Cucamonga, Calif.	(AWWA)
T.R. Brown, Sensus Technologies Inc., Uniontown, Pa.	(AWWA)
R.J. Card, Brico Industries Inc., Atlanta, Ga.	(AWWA)
Dennis Dechant, Northwest Pipe, Denver, Colo.	(AWWA)
F.C. Pausic, American Cast Iron Pipe Company, Birmingham, Ala.	(MSS)
J.C. Taylor, North American Pipe Inc., Saginaw, Texas	(SPFA)
Bruce Vanderploeg,* Northwest Pipe Company, Portland, Ore.	(AWWA)
J.A. Wise, Canus Industries Inc., Port Coquitlam, B.C.	(AWWA)

*Alternative

†Liaison, nonvoting

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.		PAGE	SEC.		PAGE
Foreword			4	Requirements	
I	Introduction.....	vi	4.1	Materials	3
I.A	Background.....	vi	4.2	Coating Systems	3
I.B	History	vi	4.3	Coating Material Information	
I.C	Acceptance	vi		Requirements.....	10
II	Special Issues	vi	4.4	Surface Preparation	11
II.A	Advisory Information on		4.5	Coating Application.....	12
	Product Use.....	vi	4.6	Safety Precautions.....	14
III	Use of This Standard.....	vii	4.7	Field Procedures	15
III.A	Purchaser Options and		5	Verification	
	Alternatives	vii	5.1	Inspection	15
III.B	Modification to Standard.....	viii	5.2	Testing.....	15
IV	Major Revisions.....	viii	5.3	Rejection.....	16
V	Comments.....	viii	6	Delivery	
Standard			6.1	Handling and Storage	16
1	General		6.2	Packaging and Marking.....	17
1.1	Scope	1	6.3	Affidavit of Compliance.....	17
1.2	Purpose	1	Table		
1.3	Application.....	1	1	Summary of Coating Systems	
2	References	2		for the Exterior Surfaces of	
3	Definitions	3		Aboveground Steel Pipe and	
				Fittings.....	4

Foreword

This foreword is for information only and is not a part of AWWA C218.

I. Introduction.

I.A. *Background.* Preventing the corrosion of aboveground steel water pipe subjected to atmospheric weathering has become an increasing concern over the years. The increasing incidence of atmospheric corrosive conditions, such as acid rain, has prompted water suppliers to evaluate the paint and coating systems used to protect aboveground steel water pipe.

Although not all aboveground steel water pipe is subjected to the same atmospheric corrosive conditions, a review of the paint and coating systems currently available to the industry has become necessary. The purchasers must have the option of selecting a system that best suits their needs. These needs may be based on current surface preparation; the types of volatile organic compound (VOC) allowances permitted by regulatory agencies; and regulatory requirements for lead abatement. The paint and coating systems in this standard are designed to assist the user in producing specifications to meet these needs.

I.B. *History.* In November 1986, the AWWA Standards Council authorized AWWA's Steel Pipe Committee to develop a new standard for coatings to be used on aboveground steel water pipe exposed to the atmosphere. The first edition of this standard was published as ANSI/AWWA C218-91, Standard for Coating the Exterior of Aboveground Steel Water Pipelines and Fittings, with an effective date of Nov. 1, 1991. The second edition of this standard was approved by the Board of Directors on June 17, 1995. This is the third edition of the standard, approved on Jan. 24, 1999.

I.C. *Acceptance.* This standard has no applicable information for this section.

II. Special Issues.

II.A. *Advisory Information on Product Use.* This standard defines the performance and quality of external pipe coatings and coating systems designed to protect and prevent atmospheric corrosion. This standard applies to the exterior coating of aboveground steel water pipelines and the associated fittings installed aboveground, outdoors, or inside an associated pump station, valve chamber, or other water facilities. The coating systems cited in this standard are not all-inclusive but are those most commonly used with an accepted performance record. Before selecting and specifying any of these coating systems, the purchaser should determine their suitability for the intended service.

II.A.1. *General.* This standard presents several alternative coating systems currently in use in the water industry, often serving dual functions of corrosion protection and aesthetics. Another function of coating systems may be to color code the pipe to identify the type of service.

To comply with federal, state, provincial, and local environmental regulations, most coating manufacturers are reformulating their coatings to comply with the current regulations. Some of the coatings discussed in this standard have been used successfully as solvent-base coatings for the last 20 to 30 years but are now available as water-based coatings. Others have been reformulated to reduce the amount of solvents, resulting in coatings with much lower VOCs. In some cases, high solids coatings have been developed in which the solids content exceeds 80 percent and may reach 100 percent. Primers are being reformulated to remove heavy metals and toxic inhibitors.

In many instances, these changes have altered the application, curing, adhesion, and inhibiting characteristics of coating systems. The manufacturer should be consulted for the technical data and material safety data sheets, which provide the prospective user with the information necessary to select the coating system that best satisfies the purchaser's requirements.

Materials. Code of Federal Regulations 29,* Labor-Part 1910, Occupational Safety and Health Administration (OSHA) regulations establish restrictive limits on the constructor regarding inhaling or absorbing lead and chromate-bearing pigments and solvents through the skin. This regulation refers to shop applications, and it can significantly increase the cost of shop coating applications.

Whenever coating materials are referenced to federal, military, or other standards, the reference identifies a generic type of coating material or system.

Selecting coating systems. Several generic coating systems (see Table 1 on page 4) are included in this standard, because no single coating or coating system is appropriate for all service applications. Often it is impractical for an occasional coatings user to make sufficient laboratory tests to verify and compare the relative performance characteristics of various coating systems to a given set of performance criteria. Consequently, it is necessary for the purchaser to consider the atmospheric and environmental conditions of service to which the coating or coating system will be exposed. Refer to Sec. 6 and Table 3, SSPC† Painting Manual Vol. 2, *Systems and Specifications*, Seventh edition (1995), Chap. 1, for definitions of atmospheric and environmental conditions of service.

The coatings listed in this standard have been used extensively and have provided excellent corrosion protection and weathering endurance. In recent years, the development of new polymers, pigments, and solvents has contributed to the rapid advancement of materials technology for painting and coating of steel structures. These advancements, coupled with regulatory agency concerns about air pollution by VOCs, have led to the development of many new paint formulations. Although not listed in this standard, many of these new products provide performance equal to or better than the systems presented in this standard.

III. Use of This Standard. AWWA has no responsibility for the suitability or compatibility of the provisions of this standard to any intended application by any user. Accordingly, each user of this standard is responsible for determining that the standard's provisions are suitable for and compatible with the user's intended application.

III.A. *Purchaser Options and Alternatives.* The following items should be included in the purchaser's specifications:

1. Standard used, that is, ANSI/AWWA C218-99, Standard for Coating the Exterior of Aboveground Steel Water Pipelines and Fittings, of latest revision.
2. Any exceptions to the standard that may be required.
3. Diameter, length, and location of the pipeline.
4. Affidavit of compliance, if required (Sec. 6.3).
5. Coating system to be supplied (Sec. 4.2).
6. Color, if special color is specified (Sec. 4.2.2, 4.2.3, 4.2.4, 4.2.5, 4.2.6, 4.2.8, 4.2.9, and 4.2.10).

*Available from the US Government Printing Office, Superintendent of Documents, Washington, DC 20402.

†SSPC: The Society for Protective Coatings, 40 24th St., Pittsburgh, PA 15222-4656.

7. Verification of film thickness of the coating or coating system (Sec. 4.3.2.4).
8. Surface preparation (Sec. 4.4).
9. Requirements for visual comparative standards for blast cleaning (Sec. 4.4.2.1).
10. Application (Sec. 4.5).
11. Coating of special pipe fittings and appurtenances (Sec. 4.5.12).
12. Inspection (Sec. 5.1).
13. Previously coated pipe (Sec. 4.4.1.2).
14. Stacking (Sec. 6.1.1).

III.B. *Modification to Standard.* Any modification of the provisions, definitions, and terminology in this standard must be provided in the purchaser's specifications.

IV. Major Revisions. Major revisions made to the standard in this edition include the following:

1. The format has been changed to AWWA standard style.

V. Comments. If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group, (303) 794-7711 ext. 6283, FAX (303) 795-7603, or write to the department at 6666 W. Quincy Ave., Denver, CO 80235.



AWWA STANDARD FOR

COATING THE EXTERIOR OF

ABOVEGROUND STEEL WATER

PIPELINES AND FITTINGS

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard covers nine coating systems designed to protect the exterior surfaces of steel pipelines and the associated fittings used by the water supply industry in aboveground locations. The coating systems described may not perform or cost the same, but they are presented so that the appropriate coating system can be selected for the site-specific project requirements.

1.1.1 *Conditions not covered in this standard.* The coating systems described in this standard are not intended for underground applications, nor are they intended for external pipe surfaces that will be in contact with potable water.

1.1.2 *Maximum temperatures.* The maximum service temperature of the coating systems listed in this standard is based on the maximum service temperature of potable water. Consult the coating manufacturer for conditions and limitations.

Sec. 1.2 Purpose

The purpose of this standard is to define the minimum requirements for coating the exterior of aboveground steel water pipelines and fittings, including coating systems, surface preparation, coating material information requirements, coating application, inspection, and testing.

Sec. 1.3 Application

This standard can be referenced in specifications for coating or recoating the exterior of aboveground steel water pipelines and fittings. The stipulations of this standard apply when this standard has been referenced and then only to coating the exterior of aboveground steel water pipelines and fittings where exterior surfaces are not in contact with potable water.