



**American Water Works
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA C542-09
(First Edition)

AWWA Standard

Electric Motor Actuators for Valves and Slide Gates



Effective date: Nov. 1, 2009.

First edition approved by AWWA Board of Directors Jan. 25, 2009.

Approved by American National Standards Institute Sept. 11, 2009.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
Science and Technology
Sections



Documents

Document Sharing Hub

Copyright © 2009 American Water Works Association. All Rights Reserved.

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2009 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Subcommittee on Electric Actuators, which reviewed and approved this standard, had the following personnel at the time of approval:

Dave Montgomery, *Chair*

General Interest Members

W.H. Peffley, Crawford Murphy & Tilly, Springfield, Ill. (AWWA)

Producer Members

A. Abuellet, Henry Pratt Company, Aurora, Ill. (AWWA)

R. Arnold, Rochester, N.Y. (MSS)

L.H. Elliott, EIM Company Inc. Valve Controls, Missouri City, Texas (VMA)

P. Janagan, DeZURIK Water Controls, Sartell, Minn. (AWWA)

D.M. Montgomery, Flowserve Limitorque, Lynchburg, Va. (AWWA)

R.D. Oaks, AUMA Actuators Inc., Canonsburg, Pa. (AWWA)

T. O'Shea, Val-matic Valve & Manufacturing Corporation, Elmhurst, Ill. (AWWA)

User Members

A. Ali, Metro Vancouver, Burnaby Vancouver, B.C. (AWWA)

D.C. Stone, Denver Water Department, Denver, Colo. (AWWA)

The AWWA Standards Committee on Power-Actuating Devices for Valves and Slide Gates, which reviewed and approved this standard, had the following personnel at the time of approval:

Fred L. Hinker, *Chair*

Amzad Ali, *Vice-Chair*

General Interest Members

G.A. Aldworth, Aldworth Engineering Inc., Toronto, Ont. (AWWA)

B.E. Bosserman, Engineering Consultant, Mission Viejo, Calif. (AWWA)

F.L. Hinker, Consulting Engineer, Santa Rosa, N.M. (AWWA)

T.J. McCandless,* Standards Engineer Liaison, AWWA, Denver, Colo. (AWWA)

C.L. McLain,† Moorhead Public Service, Moorhead, Minn. (AWWA)

J.P. Musich, Wright-Pierce, Topsham, Maine (NEWWA)

* Liaison, nonvoting

† Alternate

W.H. Peffley, Crawford Murphy & Tilly, Springfield, Ill. (AWWA)

Producer Members

R. Arnold, Rotork Controls Inc., Rochester, N.Y. (MSS)

J.V. Ballun, Val-Matic Valve & Manufacturing Corporation, Elmhurst, Ill. (AWWA)

P.E. Brunelle, Rodney Hunt Company, Orange, Mass. (AWWA)

L.H. Elliott, EIM Company Inc. Valve Controls, Missouri City, Texas (VMA)

R.D. Oaks, AUMA Actuators Inc., Canonsburg, Pa. (AWWA)

M.D. Rooney,* Lynchburg, Va. (AWWA)

User Members

A. Ali, Metro Vancouver, Burnaby Vancouver, B.C. (AWWA)

T.M. Curry, URS Washington Division, Columbia, Md. (AWWA)

T.W. Knowlton, Salem & Beverly Water Supply Board, Beverly, Mass. (NEWWA)

D.M. Reidy, Veolia Water, Indianapolis, Ind. (AWWA)

D.C. Stone, Denver Water, Denver, Colo. (AWWA)

* Alternate

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		4	Requirements
I	Introduction..... vii	4.1	Materials 4
I.A	Background..... vii	4.2	Data to Be Supplied by Actuator Manufacturer 5
I.B	History..... vii	4.3	Actuator Sizing..... 6
II	Special Issues vii	4.4	Electric-Motor Actuators—General Design..... 6
II.A	Discussion..... vii	4.5	Painting and Coatings 11
III	Use of This Standard viii	5	Verification
III.A	Purchaser Options and Alternatives viii	5.1	General 12
III.B	Modification of Standard..... xi	5.2	Proof-of-Design Tests 12
IV	Major Revisions..... xi	5.3	Performance Tests..... 13
V	Comments xi	5.4	Test Certification..... 14
Standard		5.5	Inspection and Testing..... 14
1	General	6	Delivery
1.1	Scope 1	6.1	Marking 15
1.2	Purpose 2	6.2	Packaging, Shipping, and Storage.. 15
1.3	Application..... 2	6.3	Affidavit of Compliance 15
2	References 2		
3	Definitions 3		

This page intentionally blank.



Foreword

This foreword is for information only and is not a part of ANSI/AWWA C542.*

I. Introduction.

I.A. *Background.* This standard covers electric motor actuators that are externally mounted on gate, ball, plug, cone, globe, and butterfly valves, and on slide gates suitable for use in water, wastewater, and reclaimed water utilities. This standard does not cover pilot and control apparatus used to actuate the operating device.

I.B. *History.* The first edition of the ANSI/AWWA C540 standard, published in 1987, was the result of 12 years of effort by the AWWA Standards Committee on Power-Actuating Devices for Valves and Sluice Gates. The committee was formed by AWWA in 1974 and charged with the development of standards on prime movers for valves and sluice gates, including electric motors and cylinders employing air, water, and oil. The second edition of the ANSI/AWWA C540 standard was approved by the AWWA Board of Directors on June 6, 1993, and added quarter-turn actuators. The third edition was approved on June 16, 2002. It added vane-type actuators and digital controls. In 2006, the original single standard was split into two separate standards, one for electric motor actuators (ANSI/AWWA C542) and one for hydraulic and pneumatic cylinders and vane-type actuators (ANSI/AWWA C541). Both of these standards replace the ANSI/AWWA C540 standard. This first edition of ANSI/AWWA C542 was approved on Jan. 25, 2009.

II. Special Issues.

II.A. *Discussion.* At the time this standard was approved, nine AWWA standards define valves or slide gates that may be operated by electric actuators. The standards listed do not include electric actuator sections. The nine standards are: ANSI/AWWA C500, Metal-Seated Gate Valves; ANSI/AWWA C504, Rubber-Seated Butterfly Valves; ANSI/AWWA C507, Ball Valves, 6 In. Through 48 In. (150 mm Through 1,200 mm); ANSI/AWWA C509, Resilient-Seated Gate Valves; ANSI/AWWA C513, Open-Channel, Fabricated-Metal Slide Gates; ANSI/AWWA C517, Resilient-Seated Cast-Iron Eccentric Plug Valves; ANSI/AWWA C560, Cast-Iron Slide Gates; ANSI/AWWA C561, Fabricated Stainless Steel Slide Gates; and ANSI/AWWA C563, Fabricated Composite Slide Gates.

ANSI/AWWA C542 describes only the design and performance of those actuating devices applied to systems with operating pressures normally encountered in water

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

utilities. Purchasers of electric motor actuators should carefully review the requirements of this standard, evaluate the information to be provided to the manufacturer, and review the data to be supplied by the manufacturer. Such evaluations are essential to ensure proper application of the electric motor actuator for the intended use.

ANSI/AWWA C542 references the National Electrical Manufacturers Association standard (NEMA),* which publishes standards and application guides for electrical equipment, enclosures, and components for various hazardous and nonhazardous service. Users of ANSI/AWWA C542 are cautioned to clearly specify the application requirements for the service. Such service may include depth and duration for submerged application, explosion-proof, and outdoor application.

Specific requirements for controls and accessories and other items not covered by this standard must be included in the purchase documents.

Users of this standard should consult the National Electrical Code® and local codes for circuit breakers/disconnect switch requirements.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered. There are numerous lists throughout this standard describing various features of electric motor actuators. These lists are intended to be nonlimiting in nature.

This standard includes certain options that must be selected and specified by the purchaser to completely describe and obtain the actuator desired. In addition to the factors in Sec. III.A, Purchaser Options and Alternatives, other factors to be considered when sizing an actuator are described in Sec. 4.3, Actuator Sizing. The following summarizes the options that must be selected and the data that should be covered in the purchase documents covering actuators manufactured in accordance with this standard:

III.A. *Purchaser Options and Alternatives.* The following items should be provided by the purchaser:

1. Standard used—that is ANSI/AWWA C542, Electric Motor Actuators for Valves and Slide Gates, of latest revision.
2. The purchaser should note that corrosion-resistant metals must be carefully selected and required to be compatible with the environmental conditions to which they are exposed in a given application (Section 3 item 3).

* National Electrical Manufacturers Association, 1300 North 17th Street, Suite 1752, Rosslyn, VA 22209.

3. Details of other federal, state or provincial, and local requirements (Sec. 4.1).
4. Modifications to manufacturer delivery requirements (Sec. 4.2).
5. Valve and slide gate physical characteristics (Sec. 4.3).
 - a. Size and type of valve or slide gate to be operated by the actuator.
 - b. Stem or shaft diameter at point of attachment.
 - c. Rising stem, nonrising stem, or quarter turn.
 - d. Pitch, lead, hand of thread, or keyway dimensions.
 - e. Weight of gate and stem for slide gate.
 - f. Seating/unseating torque in foot-pounds (newton-meters), maximum dynamic torque in foot-pounds (newton-meters), and when applicable, thrust in pounds (newtons) (Sec. 4.3.1.2).
 - g. Maximum torque/thrust capability of the valve or slide gate (Sec. 4.3.2).
 - h. Actuator orientation in relation to valve or slide gate.
 - i. Actuator mounting: directly mounted or remotely mounted on a floor-stand and coupled with extension shafting.
6. Lost-motion device requirement (Sec. 4.4.3).
7. Lubricant requirements (Sec. 4.4.5).
8. Direction of rotation of actuator handwheel to open valve or slide gate if other than counterclockwise (Sec. 4.4.6).
9. Supply voltage with maximum and minimum variation, phase, and frequency (Sec. 4.4.7).
10. Required type of service (Sec. 4.4.7).
 - a. Open—close. Frequency of operation and travel time duty cycle.
 - b. Throttling/Modulating. Operating conditions, input signal to actuator, and starts per hour.

Class 1—60 starts per hour, maximum

Class 2—100 starts per hour, maximum

Class 3—600 starts per hour, maximum

Class 4—1,200 starts per hour, maximum

1. Ambient temperature and humidity ranges.
2. Installation location: outdoors, indoors in a pit, in a vault, or in any hazardous location if applicable, as defined by the National Electrical Code. If submergence is expected, give depth and length of time of submergence.