

American Water Works Association

ANSI/AWWA C652-02

(Revision of ANSI/AWWA C652-92)



AWWA STANDARD
FOR
**DISINFECTION OF WATER-STORAGE
FACILITIES**



Effective date: Aug. 1, 2002.

First edition approved by AWWA Board of Directors June 15, 1980.

This edition approved Jan. 20, 2002.

Approved by American National Standards Institute Inc., May 21, 2002.

AMERICAN WATER WORKS ASSOCIATION

6666 West Quincy Avenue, Denver, Colorado 80235

www.awwa.org

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 W. 43rd St., Fourth Floor, New York, NY 10036; (212) 642-4900.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2002 American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Disinfection of Facilities which reviewed and approved this standard, had the following personnel at the time of approval:

M.S. Solomon, *Chair*

Consumer Members

J.E. French, Belleair Bluffs, Fla.	(AWWA)
L.A. Hensley, GDS Associates Inc., Marietta, Ga.	(AWWA)
R.C. Lorenz, Westerville Water Plant, Westerville, Ohio	(AWWA)
T.W.D. MacDonald, Cambridge Water Department, North Andover, Mass.	(AWWA)
P.M. Marchand, Pawtucket Water Supply Board, Pawtucket, R.I.	(NEWWA)
E.D. Schwartz, Elizabethtown Water Company, Plainfield, N.J.	(AWWA)
C.H. Smith, Savoy, Ill.	(AWWA)
J.L. Stapf, City of Wyoming Water Department, Wyoming, Mich.	(AWWA)

General Interest Members

K.C. Choquettes, Iowa Department of Public Health, Des Moines, Iowa	(AWWA)
D.J. Hartman, Standards Council Liaison, Cincinnati, Ohio	(AWWA)
C.B. Hagar, Carollo Engineers, Phoenix, Ariz.	(AWWA)
T. Lambert, Florida Department of Environmental Protection, Orlando, Fla.	(AWWA)
M.S. Solomon, Winzler & Kelly Consulting Engineers, Santa Rosa, Calif.	(AWWA)
T.W. Walker, New York State Department of Health, Victor, N.Y.	(AWWA)
M.L. Wentink, Nebraska Department of Health, North Platte, Neb.	(AWWA)
J.H. Wilber,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)

Producer Members

W.B. Huebner, The Capital Controls Group, Colmar, Pa.	(AWWA)
M.L. Johnsen, Johnsen Corrosion Engineering, Greenwood, Neb.	(AWWA)

*Liaison, nonvoting

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		4.4	Disinfection Procedures When Conducting Underwater Inspection of Potable-Water-Storage Facilities..... 7
I	Introduction..... vii	5	Verification
I.A	Background..... vii	5.1	Bacteriological Sampling and Testing 11
I.B	History vii	6	Delivery 11
I.C	Acceptance vii	Appendixes	
II	Special Issues viii	A	Chlorine Residual Testing 13
II.A	Information on Application of This Standard..... viii	B	Chlorine Dosages 15
III	Use of This Standard..... x	C	Disposal of Heavily Chlorinated Water..... 17
III.A	Purchaser Options and Alternatives... xi	Tables	
III.B	Modification to Standard..... xi	B.1	Amounts of Chemicals Required to Give Various Chlorine Concentrations in 100,000 gal (378.5 m ³) of Water 15
IV	Major Revisions..... xi	B.2	Amounts of Chemicals Required to Give Various Chlorine Concentrations of 200 mg/L in Various Volumes of Water 15
V	Comments xi	C.1	Amounts of Chemicals Required to Neutralize Various Residual Chlorine Concentrations in 100,000 gal (378.5 m ³) of Water..... 17
Standard			
1	General		
1.1	Scope 1		
1.2	Purpose 1		
1.3	Application..... 1		
2	References 2		
3	Definitions 2		
4	Requirements		
4.1	Materials..... 3		
4.2	Forms of Chlorine for Disinfection 3		
4.3	Methods of Chlorination..... 4		

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of AWWA C652.

I. Introduction.

I.A. *Background.* This standard describes methods of disinfecting water storage tanks. The disinfecting agents discussed in this standard are chlorine solutions, and several combinations of free chlorine residual and contact time (*CT*) are provided. The chlorine solutions may be derived from liquid chlorine (Cl_2), calcium hypochlorite ($\text{Ca}(\text{OCl})_2$), or sodium hypochlorite (NaOCl).

I.B. *History.* This standard was first approved on June 15, 1980, under the designation AWWA D105, Standard for Disinfection of Water Storage Facilities. The 1980 edition was developed from information originally contained in AWWA D102-64, modified to include disinfection of water-storage facilities constructed of steel or other materials. The standard was redesignated AWWA C652 with the 1986 edition. It was revised in 1992. This edition was approved on Jan. 20, 2002.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the consortium included the American Water Works Association Research Foundation (AWWARF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.

*Persons in Canada, Mexico, and non-North American countries should contact the appropriate authority having jurisdiction.

3. Two standards developed under the direction of NSF, ANSI*/NSF[†] 60, Drinking Water Treatment Chemicals—Health Effects, and ANSI/NSF 61, Drinking Water System Components—Health Effects.

4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[‡] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with ANSI/NSF 60. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to ANSI/NSF 60 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

AWWA C652 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Information on Application of This Standard.* Utilities are increasingly focusing on water storage reservoir management and maintenance as part of preserving distribution system water quality. As more frequent inspections and cleaning of reservoirs are required, utilities are turning to methods, which minimize downtime and wasted water. Utilities are utilizing inspection methods such as divers,

*American National Standards Institute, 25 W. 43rd St., Fourth Floor, New York, NY 10036.

†NSF International, 789 N. Dixboro Rd., Ann Arbor, MI 48105.

‡Both publications available from National Academy of Sciences, 2102 Constitution Ave. N.W., Washington, DC 20418.

float down, remotely operated vehicles for both inspection and sediment removal. Sec. 4.4 of this standard describes the disinfection procedures and operational considerations for conducting in-service inspection and cleaning in potable-water-storage facilities. Originally this standard addressed inspection of storage tanks by diving but has been expanded to address all forms of inspection and cleaning that are performed while the tanks are full of water.

It should be noted that any underwater retrieval of remotely operated vehicles with divers must be performed in accordance with all aspects of this standard.

Although, Sec. 4.4 specifically addresses water quality protection, the diving subcommittee felt it was very important to communicate the critical aspects of contractor safety, which should be incorporated into any project of this type. Utilities must be aware that it is their responsibility to determine if contractors working on their property are following proper OSHA procedures. When selecting a contractor to perform this type of work, it is essential to evaluate their experience, safety procedures, and methods. Each bidder should be willing to meet the minimums set by this standard for safe performance of the work.

This standard includes references to pertinent OSHA regulations.

It should be recognized that there are specific technical skills a utility should look for when considering a firm for this type of work:

- Qualifications for conducting in-service operations in compliance with OSHA
- Qualifications for inspecting and evaluating steel/concrete/wood or membrane-covered reservoirs
- Resumes for those specific personnel who will perform underwater inspection

Sec. 4.4 does not address the following items, each of which must be specified by the purchaser:

1. The type of inspection to be performed (structural, coating, bottom sediment, cathodic protection, bacteriological, and so forth).
2. The technical requirements of the inspection.

For additional guidance:

Refer to AWWA M42 Manual of Water Supply Practices *Steel Water-Storage Tanks*.

Sec. 4.4 does not attempt to rewrite existing safety standards and relies on the existing applicable OSHA Standards, including but not limited to

OSHA, 29 CFR, Subpart T Commercial Diving Operations 1910.401 through 1910.441

OSHA, 29 CFR, Permit Required Confined Spaces, 1910.146

III. Use of This Standard. This standard describes methods of disinfecting water-storage facilities that are newly constructed, have been entered for construction or inspection purposes, or that continue to show the presence of coliform bacteria during normal operation. In addition, the standard defines disinfection procedures for underwater inspections because water utilities increasingly are employing divers to conduct underwater inspections of on-line potable-water-storage facilities to minimize water loss and downtime normally associated with necessary maintenance inspections. The standard does not describe the type and technical requirements of underwater inspection or the required skill level of the diving inspector.

A storage facility is defined as a reservoir from which water, without further treatment other than booster disinfection, is supplied directly to the distribution piping system for domestic use. From a practical standpoint, this standard applies to the disinfection of covered storage facilities constructed of steel, concrete, or materials that would provide a similar structure from a water quality standpoint. Because wood may support the growth of coliform bacteria, it is recommended that any submerged wood surface (columns, baffles, and so forth) be coated with epoxy or other durable, effectively impermeable paint or coating approved for domestic water use.

Parts of this standard may be applicable to the disinfection of large, finished-water, open storage reservoirs, such as reservoirs formed by concrete or earth dams, but these applications are incidental, and this standard is not intended to cover those kinds of storage facilities.

Three methods of chlorinating storage facilities are described in this standard. Each utility should decide which method is most suitable for a given situation. In selecting the method to be used, the utility should consider the availability of materials and equipment for disinfection, the training of personnel who will perform the disinfection, and safety. For example, gas chlorination should be used only when properly designed and constructed equipment is available; makeshift equipment is not acceptable when liquid-chlorine cylinders are used. Spray equipment should be used inside the storage facility only when thorough ventilation is assured or when appropriate protection is provided using canister-type gas masks or self-contained breathing units. If a chlorination method is selected that requires the draining of a