

ANSI/AWWA **C655-25**
(Revision of ANSI/AWWA C655-18)

AWWA Standard



Field Dechlorination

Effective date: Nov. 1, 2025.

First edition approved by Board of Directors June 14, 2009.

This edition approved Mar. 27, 2025.

Approved by American National Standards Institute Apr. 14, 2025.



Documents

Document Sharing Hub


AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by writing the American National Standards Institute, 1180 Avenue of the Americas, 10th Floor, New York, NY 10036; calling 212.642.4900; or emailing info@ansi.org.



ISBN-13, print: 978-1-64717-280-0

ISBN-13, electronic: 978-1-61300-801-0

DOI: <http://dx.doi.org/10.12999/AWWA.C655.25>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher.

Copyright © 2025 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Subcommittee on Field Dechlorination, which developed revisions to this standard, had the following personnel at the time:

Timothy J. Trocha, *Chair*

A. Dail (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.

P.J. Freeman, City of Fort Smith, Fort Smith, Ark.

D.M. O'Connor, USEPA, Philadelphia, Pa.

B. Reilley, Tyngsboro, Mass.

T.J. Trocha, Miles & Miles of Texas, Buda, Tex.

T. Walski, Bentley Systems Inc., Philadelphia, Pa.

The AWWA Standards Committee on Disinfection of Facilities, which reviewed and approved this standard, had the following personnel at the time of approval:

Gerald J.R. Rhoads, *Chair*

Timothy J. Trocha, *Vice-Chair*

General Interest Members

S. Adams, Jacobs, Philomath, Ore.

K.C. Choquette, Des Moines, Iowa

A. Dail (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.

J.M. Henderson, West Linn, Ore.

D. O'Connor, USEPA, Philadelphia, Pa.

A.A. Rosenblatt, Gordon & Rosenblatt LLC, New York, N.Y.

G.R. Stein (*liaison, nonvoting*), Standards Council Liaison, Tank Industry Consultants, Indianapolis, Ind.

S. Vidika, Dixon Engineering Inc., Medina, Ohio

J.S. Wailes, Grand Junction, Colo.

Producer Members

M.P. Parker, Statewide Aquastore Inc., East Syracuse, N.Y.

P.L. Smith, Smith LaSalle Inc., Western Springs, Ill.

T.J. Trocha, Miles & Miles of Texas, Buda, Tex.

User Members

Z. Bukhari, American Water Company, Camden, N.J.
M. Crawford, Bristol County Water Authority, Cumberland, R.I.
M. Daneshparvar, Dallas Water Utilities, Dallas, Tex.
P.J. Freeman, City of Fort Smith, Fort Smith, Ark.
R. Kopansky, City of Philadelphia, Philadelphia, Pa.
R.C. Lorenz, Kewadin, Mich.
J.A. Nilson, Seattle Public Utilities, Seattle, Wash.
B. Reilley, Tyngsboro, Mass.
G.J.R. Rhoads, Metropolitan Water District of Southern California, Granada Hills, Calif.
E.D. Schwartz (*alternate*), New Jersey American Water Company, Farmingdale, N.J.
A. Waldron, Meridian Metropolitan District, Englewood, Colo.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		1.2	Purpose 1
I	Introduction..... vii	1.3	Application..... 1
I.A	Background..... vii	2	References 2
I.B	History..... vii	3	Definitions 2
I.C	Acceptance vii	4	Requirements
II	Special Issues viii	4.1	Materials 4
II.A	US Regulations viii	4.2	Nonchemical and Chemical Dechlorination..... 4
II.B	Canadian Regulations ix	4.3	Disinfection and Dechlorination Plan and Procedures 8
II.C	Determination of Method for Dechlorination..... x	5	Verification
II.D	Chemical Handling Precautions x	5.1	Residual Chlorine Level 9
III	Use of This Standard x	5.2	Residual Testing 9
III.A	Purchaser Options and Alternatives x	6	Delivery 10
III.B	Modification to Standard xi	Appendixes	
IV	Major Revisions xi	A	Disinfection and Dechlorination Plan..... 11
V	Comments xii	B	Field Dechlorination Chemicals 17
Standard		C	Field Dechlorination Equipment..... 19
1	General		
1.1	Scope 1		

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI /AWWA C655.*

I. Introduction.

I.A. *Background.* This standard describes procedures, materials, and requirements for the dechlorination of chlorinated water discharges or discharges of water treated with chloramines. It includes nonchemical and chemical dechlorination, disinfection and dechlorination planning, dechlorination methods and procedures, and verification.

I.B. *History.* The first version of this standard was approved by the AWWA Board of Directors on June 14, 2009, and the last edition was approved on Jan. 20, 2018. This edition was approved on Mar. 27, 2025.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or contact with, drinking water rests with individual states.[†] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. Specific policies of the state or local agency.
2. Four standards developed under the direction of NSF:[‡] NSF/ANSI/CAN[§] 60, Drinking Water Treatment Chemicals—Health Effects; NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects; NSF/ANSI/CAN 372, Drinking Water System Components—Lead Content; and NSF/ANSI/CAN 600, Health Effects Evaluation and Criteria for Chemicals in Drinking Water.

* American National Standards Institute, 1180 Avenue of the Americas, 10th Floor, New York, NY 10036.

[†] Persons outside of the United States should contact the appropriate authority having jurisdiction.

[‡] NSF International, 789 North Dixboro Road, Ann Arbor, MI 48105.

[§] Standards Council of Canada, 55 Metcalfe Street, Suite 600, Ottawa, ON K1P 6L5 Canada.

3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,⁴ and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI/CAN 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

NSF/ANSI/CAN 600 (which formerly appeared in NSF/ANSI/CAN 60 and 61 as Annex A, “Toxicology Review and Evaluation Procedures”) does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of NSF/ANSI/CAN 600 procedures may not always be identical, depending on the certifier.

ANSI/AWWA C655 does not address additives requirements. Users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. US Regulations.

1. USEPA has established water quality criteria (WQC) for total residual chlorine (TRC) concentrations permissible in receiving waters to protect aquatic life and water quality. These concentrations are based on acute and chronic toxicity effects for aquatic life. Under the acute toxicity criterion, the 1-h average chlorine concentration of the stream should not exceed 0.019 mg/L (19 µg/L) more than once every 3 years, on average. Under the chronic toxicity criterion, the 4-day average concentrations should not exceed 0.011 mg/L (11 µg/L) more than once every 3 years, on average.

Most states in the United States use 0.019 mg/L (19 µg/L) as the acute criterion and 0.011 mg/L (11 µg/L) as the chronic criterion for TRC for receiving streams. Some states have adopted a toxicity-based criterion for water quality for TRC. The

⁴ Both publications available from National Academies Press, 500 Fifth Street, NW, Washington, DC 20001.

state regulatory agencies require water utilities to abide by the receiving water quality criterion while discharging chlorinated waters. In addition, the regulatory agencies use WQC to develop maximum allowable chlorine concentrations while issuing general or individual permits for discharge of chlorinated water into streams.

2. In addition to residual chlorine concentrations, other water quality parameters may need to be monitored during disposal of chlorinated waters. For example, dechlorination of chloramine residuals may result in the release of ammonia. USEPA has determined the maximum allowable acute and chronic concentrations of ammonia based on the pH, temperature, and the type of aquatic habitat present (warm-water versus cold-water species) in receiving waters. Under the most stringent conditions (cold-water species, pH of 9, 30°C), a 1-day average total ammonia concentration must not exceed 0.58 mg/L as NH_3 and a 4-day average must not exceed 0.08 mg/L as NH_3 .

Most states have adopted the USEPA criteria as the water quality standards for ammonia. Water utilities using combined chlorine often maintain a residual chlorine concentration of less than 1.5 mg/L in potable waters, with a chlorine-to-ammonia ratio of 4:1 to 5:1 by mass, which will result in a total ammonia concentration of approximately 0.4–0.5 mg/L. This concentration is less than the acute criterion of 0.58 mg/L for total ammonia under the worst-case scenario. A tenfold dilution of water treated with chloramines in the receiving stream will result in compliance with the chronic ammonia concentration criterion (0.08 mg/L as NH_3) under the most stringent conditions.

For the majority of dechlorination operations, ammonia released from chloramines is likely to be within regulatory requirements. However, some states may have regulations more stringent than the USEPA criteria for selected waters. Caution must be exercised in releasing water treated with chloramines into receiving streams under such conditions.

II.B. *Canadian Regulations.*

1. Canadian Environmental Quality Guidelines (1987) propose a water quality criterion of 0.020 mg/L of total residual chlorine for receiving streams. Many provincial regulatory agencies have adopted this chlorine concentration as the WQC. However, the criteria for chlorine and chloramine concentrations are currently being reviewed under the 1999 water quality guidelines.

Like US states, each province has set its own discharge regulations to dechlorinate before discharge into receiving streams.

2. In general, the water quality criteria for ammonia, dissolved oxygen, and pH in Canada are similar to those in the United States. For example, in Newfoundland, the pH of the released water should be between 5.5 and 9.0. In Saskatchewan, total ammonia concentrations in the receiving water can be as high as 2.6 mg/L at pH 6.0 and 0°C to as low as 0.06 mg/L at pH 9.0 and 30°C.

Caution must be exercised in complying with ammonia, pH, and dissolved oxygen regulations during dechlorination activities.

II.C. *Determination of Method for Dechlorination.* Development of a Disinfection and Dechlorination Plan is needed for work performed under standards ANSI/AWWA C651 (Disinfecting Water Mains), ANSI/AWWA C652 (Disinfection of Water Storage Facilities), ANSI/AWWA C653 (Disinfection of Water Treatment Plants), and ANSI/AWWA C654 (Disinfection of Wells). The method of dechlorination should be determined by the performance requirements dictated by site-specific conditions. Other issues such as the impact of dechlorination on dissolved oxygen and pH may also be of concern, depending on the quantities involved and the operational characteristics of the dechlorinating equipment. For all practical purposes, nonchemical dechlorination is limited to low chlorine discharges. Where it can be used, it is the least costly method. Chemical dechlorination methods and equipment differ in capability, and the purchaser must confirm the proposed equipment meets the discharge requirements. For information regarding equipment to apply dechlorination chemicals, refer to Appendix C. The dechlorination method must meet all applicable chlorine residual discharge limits after accounting for dilution in the receiving water. The entire volume of discharged water must meet mixing, reaction time, and residual chlorine concentration requirements.

II.D. *Chemical Handling Precautions.* The chemicals used for dechlorination can cause skin, eye, nose, throat, and lung irritation. Personnel are advised to use caution and to wear protective clothing (including, but not limited to, gloves, apron, goggles, and a suitable vapor mask) when handling the chemicals. Refer to the manufacturers' safety data sheets (SDS) for information on specific hazards and procedures for the proper storage and handling of each chemical.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* This standard is written as though the dechlorination work will be performed by the purchaser's personnel. Where the

work is to be done for a separate contract or as part of a contract for installing mains,** appropriate provisions should be included in the purchase documents to ensure that the contractor is specifically instructed concerning the contractor's responsibilities. The following items should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C655, Field Dechlorination, of latest revision.
2. Whether compliance with NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects, is required.
3. Approval requirements before use.
4. Those procedures included in the standard, which are designated as optional, that are to be included in the purchase documents.
5. Method of dechlorination.
6. Flushing locations, rates of flushing, and locations of drainage facilities.
7. Responsibility for tapping existing mains and connections to new mains.
8. The number and frequency of samples for bacteriological tests.
9. Details of federal, state, provincial, territorial, and local requirements (Sec. 4.1).
10. Method of testing for residual chlorine (Sec. 5.2).

III.B. *Modification to Standard.* Any modification of the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major revisions made to the standard in this edition include the following:

1. A requirement for preparing a Disinfection and Dechlorination Plan was added to the foreword (II.C) and the revised Sec. 4.3; and guidance was added in new Appendix A. Previous Appendix A was renamed Appendix B.
2. A new Sec. II.D Chemical Handling Precautions was added to the foreword.
3. The Scope, Purpose, and Application sections were revised to clarify use for field dechlorination only, and the Scope now includes examples of the types of water discharges where this standard may be applicable (Sec. 1.1, Sec. 1.2, and Sec. 1.3).
4. The definitions for *chloraminated water*, *loss of control*, and *low-chloraminated water* were removed, and definitions for *chloramines*, *oxygen scavenger*, and *reclaimed water* were added. The terms and definitions for *free chlorine* and *total residual chlorine* were clarified. The definitions for *highly chlorinated water* and *low-chlorinated water*

** Refer to other AWWA standards and manuals for design criteria and installation procedures for various pipe materials.