

American Water Works Association

ANSI/AWWA C710-95

(Revision of ANSI/AWWA C710-90)



AWWA STANDARD
FOR
**COLD-WATER METERS—
DISPLACEMENT TYPE,
PLASTIC MAIN CASE**



Effective date: June 1, 1996.

First edition approved by AWWA Board of Directors Jan. 25, 1988.

This edition approved June 17, 1995.

Approved by American National Standards Institute Jan. 12, 1996.

AMERICAN WATER WORKS ASSOCIATION

6666 West Quincy Avenue, Denver, Colorado 80235

Copyright (C) 1998 American Water Works Association, All Rights Reserved.

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 11 W. 42nd St., New York, NY 10036; (212) 642-4900.

Copyright © 1996 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Subcommittee on Displacement-Type Meters, Plastic Main Case, which developed this standard, had the following personnel at the time:

Michael J. Kebles, *Chair*
 Donald H. Strobel, *Vice-Chair*
 John W. Benson
 Roger C. Graff
 Leslie E. Simmonds
 John P. Sullivan

The AWWA Standards Committee on Water Meters, which reviewed and approved this standard, had the following personnel at the time of approval:

Roger C. Graff, *Chair*
 Donald J. Kullmann, *Secretary*

Consumer Members

G.A. Delgado, Los Angeles Department of Water and Power, Los Angeles, Calif.	(AWWA)
Frank Fenton, Denver Water Department, Denver, Colo.	(AWWA)
R.C. Graff, San Diego Water Utilities, San Diego, Calif.	(AWWA)
K.W. Grant, Louisville Water Company, Louisville, Ky.	(AWWA)
M.J. Kebles, Elizabethtown Water Company, Plainfield, N.J.	(AWWA)
T.E. Kjartanson, City of Winnipeg Waterworks, Winnipeg, Man.	(AWWA)
Jean-Pol Mahieu, Kansas City Water Department, Kansas City, Mo.	(AWWA)
C.A. Mattis, Washington Suburban Sanitation Commission, Laurel, Md.	(AWWA)
R.L. Miller, Arizona Water Company, Casa Grande, Ariz.	(AWWA)
King Moss II, Dallas Water Utilities, Dallas, Texas	(AWWA)
S.J. Pagley, City of Wilson, Wilson, N.C.	(AWWA)
A.A. Piasecki, City of Phoenix, Phoenix, Ariz.	(AWWA)
E.M. Poaches Jr., Philadelphia Water Department, Philadelphia, Pa.	(AWWA)
K.M. Poe, Memphis Light Gas & Water, Memphis, Tenn.	(AWWA)
L.M. Scott, Lincoln Water System Distribution, Lincoln, Neb.	(AWWA)
J.W. Smith, Gary-Hobart Water Corporation, Gary, Ind.	(AWWA)
R.A. Stehmeier, Milwaukee Water Works, Milwaukee, Wis.	(AWWA)
J.P. Sullivan, Commissioners of Public Works, Charleston, S.C.	(AWWA)
J.P. Sullivan Jr., Boston Water and Sewer Commission, Boston, Mass.	(NEWWA)

General Interest Members

K.R. Johnson, Packwood, Wash.	(AWWA)
M.S. Marcotte,* Dallas Water Utilities, Dallas, Texas	(AWWA)
R.C. McPherson, Rochester, N.Y.	(AWWA)
D.S. Morrow, Utility Technical Services, Denver, Colo.	(AWWA)
E.S. Ralph,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
Richard San Giacomo, R&D Engineering, P.C., Buffalo, N.Y.	(AWWA)
L.E. Simmonds, Lafayette, Calif.	(AWWA)
D.A. Wheadon, International Water Consultants, Inc., Frisco, Colo.	(AWWA)

Producer Members

G.D. Anderson, Sensus Technologies, Inc., Uniontown, Pa.	(AWWA)
P.A. Bennett,† Kent Meters, Inc., Ocala, Fla.	(AWWA)
Les Engelmänn, Ames Company, Inc., Woodland, Calif.	(AWWA)
Don Faber,† Schlumberger Industries, Tallassee, Ala.	(AWWA)
L.W. Fleury Jr., Hersey Products, Inc., Cranston, R.I.	(AWWA)
T.H. Gerardi, Kent Meters, Inc., Ocala, Fla.	(AWWA)
R.T. Huth, Water Specialties Corp., Porterville, Calif.	(AWWA)
M.N. Kavouklis,† Hersey Products, Athens, Ga.	(AWWA)
J.H. Kennedy,† Badger Meter, Inc., Dallas, Texas	(AWWA)
R.N. Koch, Master Meter, Inc., Sewickley, Pa.	(AWWA)
D.J. Kullmann, Schlumberger Industries, Roswell, Ga.	(AWWA)
D.C. Pinney, Precision Meters, Inc., Orlando, Fla.	(AWWA)
Jerry Potter,† Master Meter, Inc., Longview, Texas	(AWWA)
F.S. Salser Jr., Floyd S. Salser Jr., & Associates, Ocala, Fla.	(AWWA)
Paul Sandhu, Sparling Instruments Co., Inc., El Monte, Calif.	(AWWA)
Clay Spence,† Ketema/McCrometer Division, Hemet, Calif.	(AWWA)
D.H. Strobel, Badger Meter, Inc., Milwaukee, Wis.	(AWWA)
G.M. Voss, McCrometer Division of Ketema, Hemet, Calif.	(AWWA)

*Liaison, nonvoting

†Alternate

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		6	Delivery
I	Introduction..... vi	6.1	Marking..... 11
I.A	Background vi	6.2	Packaging and Shipping 12
I.B	History..... vi	6.3	Affidavit of Compliance..... 12
I.C	Acceptance..... vii	Appendixes	
II	Special Issues..... viii	A	Bibliography..... 13
II.A	Materials viii	B	Supplemental Information
III	Use of This Standard viii	B.1	Units of Measure 15
III.A	Purchaser Options and Alternatives viii	B.2	Tests..... 15
III.B	Modification to Standard ix	B.3	Testing Equipment 16
IV	Major Revisions ix	B.4	Registration Accuracy 16
V	Comments ix	B.5	Periodic Tests..... 18
Standard		B.6	Meter Storage 18
1	General	B.7	Materials 19
1.1	Scope..... 1	B.8	Installation 19
1.2	Purpose..... 1	Tables	
1.3	Application 1	1	Characteristics of Displacement- Type Meters..... 8
2	References	2	Dimensional Design Limits for Meters and External Connections 9
2.1	Standards 2	3	Maximum Indication on Initial Dial and Minimum Register Capacity..... 10
2.2	ASTM Test Standards 3	B.1	Most Frequently Used Intervals Between Meter Tests 18
3	Definitions 4		
4	Requirements		
4.1	Materials 5		
4.2	General Design 7		
4.3	Detailed Design 10		
5	Verification		
5.1	Rejection..... 11		

Foreword

This foreword is for information only and is not a part of C710.

I. Introduction

I.A. *Background.* Material goods molded from plastics have been a part of everyday life for many decades, but in the early 1960s a new group of plastics better suited to meet more demanding applications was discovered. These materials have greatly improved properties, such as strength and stiffness, and are known as engineering plastics. With the introduction of this new class of plastics, engineers were able to achieve design objectives that previously had seemed almost beyond reach.

The water meter industry as a whole began underwriting experiments with plastic materials as far back as the 1950s. From 1963 to 1968, two principal research programs were sponsored by the meter suppliers under the auspices of AWWA at the Armour Research Institute, Chicago, and later at Columbia University, New York City. These programs primarily focused on plastic meter main-case designs and materials.

Plastic material research in the water meter industry has paid great dividends and has resulted in the design of many meter components from engineering plastics. Significant improvements, such as corrosion resistance, dimensional stability, self-lubrication, low mass, and superior surface finishes have resulted in improved meter accuracies with longer life.

When designing meter components from plastic, today's engineer has a choice of more than 4,500 plastic compound formulations. Although many plastics look the same, there are often vast differences in their physical properties, and it takes considerable know-how to select the one best suited for a particular application. In addition, plastics used in water meter design often contain various enhancing or reinforcing agents to give components greater rigidity, strength, and dimensional stability.

I.B. *History.* The extensive use of plastic in the design of plastic water meter parts was recognized in the Jan. 24, 1971, revision of AWWA C700, *Standard for Cold-Water Meters—Displacement Type, Bronze Main Case*. The use of synthetic polymers as an alternative material for all parts except the main case was one of the major revisions.

At the 1972 AWWA annual convention, the first domestic positive-displacement water meter with a plastic main case rather than the traditional bronze main case was introduced. During the next 10 years, three more meter suppliers introduced plastic main-case meters.

The subject of plastic main-case materials not meeting the then-current standard was discussed at the 1974 meeting of the AWWA Meter Standards Committee. The committee chairman stated that the manufacturers of these meters should initiate a request for change at the next revision.

The revision of AWWA C700 in 1977 did not include synthetic polymers as an alternative main-case material because the subcommittee could not reach agreement. The subject was tabled to be considered at the next revision in 1982. Between 1982 and 1985, revising AWWA C700 to include synthetic polymers as a main-case alternative became an issue. To resolve this controversy, an ad hoc committee was appointed by the Standards Council. A Mar. 4, 1985, ad hoc committee report recommended that the Standards Council direct the Water Meter Committee to "appoint a

new subcommittee. . .to develop a new standard for displacement-type water meters with plastic main cases, including consideration of appropriate allowable nutation speed for this type of meter.” This recommendation was accepted by the Standards Council in June 1985.

Because of the diversity of available materials and the continual development of new and improved materials, this standard will not specify any one material but will use the term *suitable engineering plastic*. For reference purposes only, typical materials used presently for water meter designs and found in ASTM* specifications are cited.

The first edition of C710 was approved by the AWWA Board of Directors Jan. 25, 1988. The second edition was approved on Jan. 28, 1990.

I.C. Acceptance. In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the consortium included the American Water Works Association Research Foundation (AWWARF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[†] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF, ANSI[‡]/NSF[§] 60, *Drinking Water Treatment Chemicals—Health Effects*, and ANSI/NSF 61, *Drinking Water System Components—Health Effects*.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,** and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with ANSI/NSF 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

*American Society for Testing and Materials, 100 Barr Harbor Dr., West Conshohocken, PA 19428-2959.

[†]Persons in Canada, Mexico, and non-North American countries should contact the appropriate authority having jurisdiction.

[‡]American National Standards Institute, 11 W. 42nd St., New York, NY 10036.

[§]NSF International, 3475 Plymouth Rd., Ann Arbor, MI 48106.

**Both publications available from National Academy of Sciences, 2102 Constitution Ave. N.W., Washington, D.C. 20418.

Appendix A, “Toxicology Review and Evaluation Procedures,” to ANSI/NSF 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Appendix A procedures may not always be identical, depending on the certifier.

AWWA C710-95 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues

II.A. *Materials.* The materials section of this standard recognizes the advances that have been made in the development of nonmetallic materials for water meter construction. Plastic materials are currently being used successfully for water meter components, and because of the continual development of new and improved materials, this standard does not require any one specific material but cites examples of materials defined by ASTM specifications typically used at this time in the construction of water meters by manufacturers.

III. **Use of This Standard.** AWWA has no responsibility for the suitability or compatibility of this standard to any intended application by any user. Accordingly, each user of this standard is responsible for determining that the standard’s provisions are suitable for and compatible with that user’s intended application.

III.A. *Purchaser Options and Alternatives.* This standard provides for several options and alternatives that purchasers must designate if they wish to exercise the options or if they have a preference among the alternatives. Also, several items must be specified by purchasers to describe completely the type, size, and quantity of meters required. All such items, options, and alternatives are summarized in the following itemized list. Purchasers should review each one and then make the appropriate provisions in the purchaser’s specifications to describe specific requirements.

1. Standard used—that is, AWWA C710, *Standard for Cold-Water Meters—Displacement Type, Plastic Main Case*, of latest revision.
2. If meters are to be furnished with nutating discs or oscillating pistons (Sec. 1.1), if there is a preference.
3. If meters are to be furnished with cast-iron, stainless-steel, copper alloy, or suitable engineering plastic top or bottom covers (Sec. 4.1.9), if there is a preference.
4. Size of meter (Sec. 4.2.1 and Tables 1 and 2) and quantity required.
5. Special materials required, if any, to resist corrosion if water is highly aggressive.
6. Modifications of test specifications (Sec. 4.2.8), if operating water temperature will exceed 80°F (27°C) (Sec. A.4.2).
7. If ½-in. (13-mm), ½-in. × ¾-in. (13-mm × 19-mm), 5/8-in. (16-mm), 5/8-in. × ¾-in. (16-mm × 19-mm), ¾-in. (19-mm), and 1-in. (25-mm) meters are to be furnished with coupling nuts and tailpieces (Sec. 4.3.2.1).
8. Details of register (Sec. 4.3.3) to be furnished, where there is a preference, with regard to the following:
 - a. if the registers should read in US gallons, cubic feet, or cubic metres

b. if the registers should be permanently sealed or have replaceable change gears

9. If a generator-type register or an encoder-type remote register is required (Sec. 4.3.3), specify in detail.

10. If warranty requirements will be specified (Sec. 5.1.1).

11. If an affidavit of compliance (Sec. 6.3) and certificate of testing for accuracy (Sec. B.2.3) are required.

12. If the size of individual meters will be permanently marked on the register dial face (Sec. 6.1).

III.B. *Modification to standard.* Any modifications to the provisions, definitions, or terminology in this standard must be provided in the purchaser's specifications.

IV. Major Revisions. Major revisions made to the standard in this edition include the following:

1. The format has been changed to reflect current AWWA standard style.

2. The acceptance clause (Sec. I.C) has been added and the definitions of parties (Sec. 3) have been revised to approved wording.

3. "Soft" metric equivalents in the text and tables have been added.

4. The rejection section has been revised (Sec. 5.1).

5. Appendix B, Future Revisions, has been deleted and an item on register markings has been added to Sec. 6.1 and to the foreword (Sec. III.A.12).

6. A new appendix B, Bibliography, has been added.

V. Comments. If you have any comments or questions about this standard, please call the AWWA Standards and Materials Development Department, (303) 794-7711 ext. 6283, FAX (303) 795-1440, or write to the department at 6666 W. Quincy Ave., Denver, CO 80235.

This page intentionally blank.