



**American Water Works
Association**

The Authoritative Resource on Safe WaterSM

ANSI/AWWA C800-05
(Revision of ANSI/AWWA C800-01)

AWWA Standard

Underground Service Line Valves and Fittings



Effective date: June 1, 2005.

First edition approved by AWWA Board of Directors June 23, 1991.

This edition approved Jan. 16, 2005.

Approved by American National Standards Institute Apr. 14, 2005.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
► **Science and Technology**
Sections

 **Documents**
Document Sharing Hub

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

Science and Technology

AWWA unites the entire water community by developing and distributing authoritative scientific and technological knowledge. Through its members, AWWA develops industry standards for products and processes that advance public health and safety. AWWA also provides quality improvement programs for water and wastewater utilities.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2005 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Water Service Line Fittings, which reviewed and approved this standard, had the following personnel at the time of approval:

Savas C. Danos, *Chair*

General Interest Members

Tom Arnbrister, Wyoming Association of Rural Water Systems, Glenrock, Wyo.	(AWWA)
L.E. Beck, Hilo, Hawaii	(AWWA)
L.R. Faulkner, Wheat Ridge, Colo.	(AWWA)
J.W. Hellums, Booth, Hellums and Associates LLC, Lake Charles, La.	(AWWA)
J.M. Stubbart,* Standards Group Liaison, AWWA, Denver, Colo.	(AWWA)
R.A. Waggenpack, Owen & White Inc., Baton Rouge, La.	(AWWA)

Producer Members

Terry Agness,† Ford Meter Box Company Inc., Wabash, Ind.	(AWWA)
Mark Anderson, Ford Meter Box Company Inc., Wabash, Ind.	(AWWA)
J.L. Daghe, A.Y. McDonald Manufacturing Company, Dubuque, Iowa	(AWWA)
G.F. Denison, Romac Industries Inc., Bothell, Wash.	(AWWA)
L.W. Fleury, Mueller Company, Smithfield, R.I.	(AWWA)
Dennis Humes,† Mueller Company, Decatur, Ill.	(AWWA)
T.J. Moulton, Cambridge Brass, Cambridge, Ont.	(AWWA)
Steve Tefft,† A.Y. McDonald Manufacturing Company, Dubuque, Iowa	(AWWA)

User Members

T.M. Bowen, Manchester Water Works, Manchester, N.H.	(AWWA)
S.C. Danos, Littleton Electric Light & Water Departments, Littleton, Mass.	(AWWA)
R.J. Dudas, Orange County Public Utilities, Orlando, Fla.	(AWWA)
R.J. Krol, South Bend Water Works, South Bend, Ind.	(AWWA)
Matt Turney, Denver Water, Denver, Colo.	(AWWA)

* Liaison, nonvoting

† Alternate

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		5	Verification
I.	Introduction..... vii	5.1	Inspection 15
I.A	History..... vii	5.2	Testing..... 16
I.B	Acceptance..... viii	5.3	Notice of Nonconformance 16
II	Special Issues..... ix	6	Delivery
II.A	Lead Fittings ix	6.1	Marking..... 16
III	Use of This Standard ix	6.2	Packing and Shipping..... 16
III.A	Purchaser Options and Alternatives ix	6.3	Affidavit of Compliance..... 16
III.B	Modification to Standard..... x	Appendixes	
IV	Major Revisions. x	A	Collected Standards for Service Line Materials
V	Comments x	A.1	Materials Covered..... 17
Standard		A.2	Copper Water Tube 17
1	General	A.3	Red Brass Pipe 18
1.1	Scope 1	A.4	Steel Pipe 19
1.2	Purpose 2	A.5	Plastic Pipe and Tube 20
1.3	Application 2	B	Field Testing
2	References 2	B.1	Field Tests 23
3	Definitions 3	C	Installation
4	Requirements	C.1	Installation Requirements 25
4.1	Materials 4	Figures	
4.2	General Design 5	1	Curb Valve Heads..... 7
4.3	Detailed Design 5	2	Standard AWWA Corporation Stop Inlet Thread 11
4.4	End Connections 9		
4.5	Fabrication..... 15		

SEC.	PAGE	SEC.	PAGE
3	Coupling Nut for Use With Flared Copper Service Tube, Types <i>K</i> and <i>L</i> 12	5	Coupling Nut for Use With Flared Copper Service Tube 9
4	Outlet End of Corporation Stop Showing Increased-Size NPT External Threads and Internal Driving Threads 12	6	Corporation Stop Outlet Special-Purpose Coupling Threads 10
5	Flared Fitting End Showing Threads for Use With Flared Copper Service Tube 12	7	Standard AWWA Corporation Stop Inlet Threads and Corresponding Internal Threads for Saddles 10
6	Outlet End of Corporation Stop Showing Special-Purpose Coupling Threads and Internal Driving Threads 12	8	Tapered External Iron Pipe (NPT) Threads for Outlet End of Corporation Stops 13
7	Meter Coupling Nut 14	9	Internal Driving Thread for Corporation Stops 13
8	Meter Flange 15	10	Meter Coupling Nut 14
		11	Meter Flanges 15
		A.1	Dimensions, Weights, and Tolerances in Diameter and Wall Thickness for Nominal or Standard Copper Water Tube Sizes 18
<i>Tables</i>		A.2	Dimensions, Weights, and Tolerances for Standard Sizes of Seamless Red Brass Pipe 19
1	Maximum Drill Sizes for Installation of Corporation Stops in Service Clamps or Saddles With a Drilling Machine 6	A.3	Standard Weights and Dimensions of Welded and Seamless Steel Pipe 20
2	Maximum Overall Body Dimensions for Corporation Stops for Use With Tapping Machine 6		
3	Curb Valve Head Dimensions 7		
4	Fitting Thread for Use With Flared Copper Service Tube 9		

Foreword

This Foreword is for information only and is not a part of ANSI/AWWA C800.

I. Introduction.

I.A. *History.* In 1929, the development of a standard for threads for underground service fittings was undertaken by the American Standards Association (ASA). In 1932, the subcommittee that had been appointed for the task asked to be discharged after it had submitted its proposed standards in the form of two drawings. No action was taken by ASA on these proposed standards.

The American Water Works Association (AWWA) recognized the need for standardization of these threads and appointed a committee in 1940 to prepare a standard. The New England Water Works Association (NEWWA) also appointed a committee to prepare a standard for these threads. The AWWA and NEWWA committees cooperated closely in developing a tentative standard in 1947. This was approved as a standard by AWWA on Sept. 1, 1948, and by NEWWA on Sept. 14, 1948. Revisions to the standard were made effective Jan. 17, 1955. In July 1963, a committee was formed to revise C800-55 regarding the evaluation of types K and L copper tubing for water services. In the revision, published in 1966, threads representing current practice were established for those fittings generally used in the water utility field. Sizes $\frac{1}{2}$ in. and $\frac{5}{8}$ in. were added for inlet and outlet threads for fittings and couplings for use with flared copper service tubing. The 1966 revision introduced an appendix that was not part of the standard, but which listed standards for water service line materials. The appendix was provided for information only because the materials were covered by other standards. The appendix also contained specifications for copper water tubing, red brass pipe, cast-iron pipe, and steel pipe.

In 1974, a standing committee was formed to revise and update C800-66. The committee recognized the need to expand the scope of this standard beyond being a standard covering only threads for underground service fittings. All previous versions of C800 described only the threads for fittings that were in common use in water distribution systems. Subsequently, the scope of the standard was changed to include performance standards for underground service line fittings as well as for the threads. The 1984 revision to C800 was approved by the AWWA Board of Directors on Jan. 29, 1984. The 1989 revision to C800 was approved by the AWWA Board of Directors on Jan. 1, 1990. The 2001 revision was approved by the AWWA Board of Directors

on Jan. 21, 2001. This revision was approved by the AWWA Board of Directors on Jan. 16, 2005.

I.B. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state, provincial, and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state, provincial, or local agency.
3. Two standards developed under the direction of NSF, NSF[†]/ANSI[‡] 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[§] and other standards considered appropriate by the state, provincial, or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states, provinces, or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

*Persons outside the US should contact the appropriate authority having jurisdiction.

†NSF International, 789 N. Dixboro Rd., Ann Arbor, MI 48105.

‡American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

§Both publications available from National Academy of Sciences, 500 Fifth St., N.W., Washington, DC 20001.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C800 does not address additives requirements. Users of this standard should consult the appropriate state, provincial, or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Lead Fittings*. All references to lead fittings have been removed from C800 and the attached appendices. The AWWA Standards Department has available to users of C800 copies of C800-84 information that contains references to lead fittings.

III. **Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives*. The following items should be included in the purchaser’s specifications:

1. Standard used—that is, ANSI/AWWA C800, Standard for Underground Service Line Valves and Fittings, of latest revision.
2. The purchaser should state whether compliance with NSF/ANSI 61 Drinking Water System Components—Health Effects is to be required, in addition to the requirements of the Safe Drinking Water Act.
3. The size and type of fitting or valve.
4. Quantity required.
5. Details of other federal, state, provincial, local, and provincial requirements (Sec. 4.1.1).
6. Working pressures under which the valve or fitting will be operated after installation—normal or high pressure (Sec. 4.2).

7. Minimum inside diameter of waterway through corporation stops (Sec. 4.3.1.1).

8. If meter setter spacing is other than shown to accommodate meter lengths listed in Tables 10 or 11 (Sec. 4.3.14).

9. Type of inlet thread (Sec. 4.4).

10. Size and type of outlet thread (Sec. 4.4).

11. If meter flanges other than oval are required (Sec. 4.4.12).

12. Whether records of factory tests are to be provided (Sec. 5.2.1).

13. Description of special castings or patterns, if required. Special casting markings, if required, should be stated, including location of these markings (Sec. 6.1).

14. Whether an affidavit of compliance is to be provided (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchasers.

IV. **Major Revisions.** Major revisions made to the standard in this edition include the following:

1. The format has been changed to AWWA standard style.

2. Approved wording has been added in Sec. I, III, and V of the Foreword and Sec. 1 and Sec. 4 of the Standard.

3. Addition of meter setters to standard.

V. **Comments.** If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at (303) 794-7711, FAX (303) 795-7603, or write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standards@awwa.org.



American Water Works
Association

ANSI/AWWA C800-05
(Revision of ANSI/AWWA C800-01)

AWWA Standard

Underground Service Line Valves and Fittings

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard covers valves, fittings, service saddles, and meter setters for use in service line from the main through the meter valve or meter setting appurtenance. Valves, fittings, and meter setters described in this standard include $\frac{1}{2}$ in. (12.5 mm) through 2 in. (50.8 mm). Service saddles described have outlet sizes $\frac{1}{2}$ in. (12.5 mm) through 2 in. (50.8 mm) and fit mains of 2 in. (50.8 mm) through 12 in. (304.8 mm). Valves include corporation stops and curb stops. Fittings include various types of couplings and adapters. Service saddles include various types of devices circumferentially attached to the main. Meter setters include various configurations of copper tubing, valves, and fittings for the holding of $\frac{5}{8}$ -in. (15.875 mm) through 2-in. (50.8 mm) meters.

1.1.1 *Installation.* The performance of products depends on proper installation. The purchaser must follow instructions supplied by or available from the manufacturer. If these instructions are not available, good installation practices shall be followed.