

General requirements for rotating electrical machines —

Part 142: Specification for mechanical performance: vibration

UDC 621.313-13:534.22-6

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW



Document Sharing Hub

Committees responsible for this British Standard

The preparation of this British Standard was entrusted by the Power Electrical Engineering Standards Committee (PEL/-) to Technical Committee PEL/1, upon which the following bodies were represented:

- Association of Consulting Engineers
- Association of Electrical Machinery Trades
- Association of Manufacturers Allied to the Electrical and Electronic Industry (BEAMA Ltd.)
- Association of Supervisory and Executive Engineers
- British Coal
- Bureau of Engineer Surveyors
- ERA Technology Ltd.
- Electricity Supply Industry in England and Wales
- Engineer Surveyors Section of the ASTMS
- Engineering Equipment and Materials Users' Association
- Health and Safety Executive
- Ministry of Defence
- Power Generation Association (BEAMA Ltd.)
- Rotating Electrical Machines Association (BEAMA Ltd.)
- South of Scotland Electricity Board

This British Standard, having been prepared under the direction of the Power Electrical Engineering Standards Committee, was published under the authority of the Board of BSI and comes into effect on 27 February 1987

© BSI 01-2000

First published as BS 4999-50 May 1972
First revision January 1978
Second revision as BS 4999-142 February 1987

The following BSI references relate to the work on this standard:
Committee reference PEL/1
Revision announced in *BSI News* October 1986

ISBN 0 580 15782 2

Amendments issued since publication

Amd. No.	Date of issue	Comments
6542	November 1990	Indicated by a sideline in the margin

Contents

	Page
Committees responsible	Inside front cover
Foreword	ii
1 Scope	1
2 References	1
Section 1. Machines with shaft centre heights not exceeding 400 mm	
3 Introduction	1
4 Measurement quantity	1
5 Measuring equipment	1
6 Machine mounting	1
7 Conditions of measurement	2
8 Maximum limits of vibration severity	2
Section 2. Machines with shaft centre heights exceeding 400 mm	
9 Limits of vibration	4
Figure 1 — Sensitivity-frequency characteristic for the vibration measuring system	2
Figure 2 — Recommended measuring points	3
Table 1 — Limits of vibration severity	3
Table 2 — Limits of vibration amplitude (peak to peak, in millimetres)	4
Publications referred to	Inside back cover