

Specification for

Acceptance tests for centrifugal, mixed flow and axial pumps —

Part 2: Class B tests

[ISO title: Centrifugal, mixed flow and axial pumps — Code for acceptance tests — Class B]

UDC 621.67:620.1

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

BSI
Documents

AVA

Document Sharing Hub

Cooperating organizations

The Mechanical Engineering Standards Committee, under whose direction this British Standard was prepared, consists of representatives from the following Government departments and scientific and industrial organizations:

Associated Offices Technical Committee	Department of Transport
Association of Consulting Engineers	Electricity Supply Industry in England and Wales*
Association of Hydraulic Equipment Manufacturers	Engineering Equipment Users' Association
Association of Mining Electrical and Mechanical Engineers	Federation of Manufacturers of Construction Equipment and Cranes
British Compressed Air Society	Health and Safety Executive
British Electrical and Allied Manufacturers' Association (BEAMA)	Institution of Gas Engineers
British Gas Corporation	Institution of Mechanical Engineers*
British Gear Manufacturers' Association	Institution of Plant Engineers
British Internal Combustion Engine Manufacturers' Association	Institution of Production Engineers
British Pump Manufacturers' Association*	London Transport Executive
British Steel Corporation	Machine Tool Trades Association
Chartered Institution of Building Services	Ministry of Defence
Crown Agents for Oversea Governments and Administrations	National Coal Board
Department of Industry, Mechanical Engineering	Process Plant Association
Department of Industry, National Engineering Laboratory*	Railway Industry Association of Great Britain
Department of the Environment	Telecommunication Engineering and Manufacturing Association (TEMA)
Department of Trade (Marine Division)	The Society of Motor Manufacturers and Traders Limited
	Water-tube Boilermakers' Association

The organizations marked with an asterisk in the above list, together with the following, were directly represented on the committee entrusted with the preparation of this British Standard:

Council of British Manufacturers of Petroleum Equipment	Rotating Electrical Machines Association (BEAMA)
---	--

This British Standard, having been prepared under the direction of the Mechanical Engineering Standards Committee, was published under the authority of the Executive Board on 30 September 1977

© BSI 08-1999

The following BSI references relate to the work on this standard:
Committee reference MEE/29/4
Draft for comment 75/71020 DC

ISBN 0 580 09616 5

Amendments issued since publication

Amd. No.	Date of issue	Comments

Contents

	Page
Cooperating organizations	Inside front cover
Foreword	iii
0 Introduction	1
1 Scope and field of application	1
2 Symbols	2
2.1 List of symbols used in the test code	2
2.2 Alphabetical lists of basic letters and subscripts	3
3 Definitions	4
3.1 General definitions	4
3.2 Definitions peculiar to the test code	4
4 Guarantees	6
4.1 Subjects of guarantees	6
4.2 Other conditions of guarantee	6
4.3 Fulfilment of guarantee	7
5 Tests	7
5.1 Organization of tests	7
5.2 Test arrangements	7
5.3 Test conditions	8
5.4 Accuracy of measurement	11
6 Procedure for measurement of rate of flow, head, speed of rotation and power input	11
6.1 Measurement of flow rate	11
6.2 Measurement of head	12
6.3 Measurement of the speed of rotation	18
6.4 Measurement of pump power input	18
6.5 Measurement of pumping unit overall efficiency	19
7 Cavitation testing	20
7.1 General	20
7.2 Determination of (NPSH) required by the pump	20
7.3 Limits of error in determination of (NPSH)	20
7.4 Measurement of pump head, outlet flow rate, speed of rotation, power input (if necessary) and vapour pressure	21
8 Tests on pumps for liquids other than clean cold water	24
8.1 Characteristics of "clean cold water"	24
8.2 Characteristics of liquids for which clean cold water tests are acceptable	24
9 Analysis of tests	24
9.1 Test data required for the analysis	24
9.2 Translation of the test results to the guarantee basis	24
9.3 Measuring inaccuracies	25
9.4 Verification of guarantee	26
9.5 Test report	26
Annex A Effect of pre-swirl induced by the pump	28
Annex B Pumping installation under non-standard conditions	29
Annex C Friction losses	29
Annex D Costs and repetition of tests	33
Annex E List of reference documents	33
Annex F Conversion to SI units	34
Annex G Check lists	35

	Page
Annex H Pump test sheet	36
Figure 1 — Zanker flow straightener	9
Figure 2 — Test of a centrifugal pump by means of liquid column gauges	14
Figure 3 — Test of a centrifugal pump by means of Bourdon gauges	15
Figure 4 — Measurement of pump total head H for various types of submerged pumps	16
Figure 5 — Requirements for static head tapplings	16
Figure 6 — Direct measurement of pump total head	19
Figure 7 — Cavitation tests — Variation of (NPSH) by means of a closed loop	21
Figure 8 — Cavitation tests — Variation of (NPSH) by control of liquid level at inlet	22
Figure 9 — Cavitation tests — Variation of (NPSH) by means of a throttle valve at inlet	22
Figure 10 — Methods of determining required (NPSH) for $\Delta H/H = (3 + x) \%$	23
Figure 11 — Curve $q_v H$ for the verification of the guarantee	25
Figure 12 — Example of installation with pre-swirl	28
Figure 13 — Correction of measured inlet head	28
Figure 14 — Chart showing velocities above which loss corrections are required	30
Figure 15 — Friction factor chart	31
Figure 16 — Values of friction factor λ Moody chart	32
Table 1 — Symbols	2
Table 2 — Letters used as symbols	3
Table 3 — Letters and figures used as subscripts	3
Table 4 — Maximum permissible amplitude of oscillations as a percentage of mean value of quantity being measured	9
Table 5 — Limits of variation between repeated measurements of the same quantity (based on 95 % confidence limits)	10
Table 6 — Permissible systematic errors of measuring instruments	11
Table 7 — Maximum limits of overall error	11
Table 8 — Specification of “clean cold water”	24
Table 9 — Characteristics of liquids	24
Table 10 — Absolute roughness k for pipes	31
Table 11 — Conversion factors	34
Publications referred to	Inside back cover

Foreword

Part 2 of this British Standard was prepared under the direction of the Mechanical Engineering Standards Committee and is identical with ISO 3555 “*Centrifugal, mixed flow and axial pumps — Code for acceptance tests — Class B*” prepared by the International Organization for Standardization (ISO). For the sake of clarity Figure 16 has been enlarged.

Part 2 of this standard replaces all the requirements for class B tests (which are now withdrawn) of BS 599:1966 “*Methods of testing pumps*”.

NOTE This standard deals only with testing the performance of pumps, and does not include requirements for pressure testing for which reference to clause 5 of BS 599:1966 or clause 6 of BS 5257:1975 “*Horizontal end-suction centrifugal pumps (16 bar)*”, as appropriate, should be made.

Part 1 of this standard, covering class C tests, is already published and a further Part, covering class A tests, is under preparation in ISO. As and when the latter is complete, it is intended that it will be implemented as the third and final Part of this standard to supersede the class A tests of BS 599 which will eventually be withdrawn.

Terminology and conventions. The text of the international standard has been accepted as suitable for publication, without deviation, as a British Standard. Certain terminology and conventions are used, however, that are not identical with those used in British Standards. Attention is therefore drawn to the following.

Wherever the words “International Standard”, relating to this publication, appear, they should be interpreted as “British Standard”.

The comma has been used throughout as a decimal marker. In British Standards it is current practice to use a full point (full stop on the baseline) as the decimal marker.

Reference to British Standards. Some of the subjects dealt with by the international standards listed in Annex E are covered by British Standards but in no case is there an equivalent British Standard to any of the international standards.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages i to iv, pages 1 to 36, an inside back cover and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.

WARNING — Terms used in this International Standard like “guarantee” or “acceptance” shall be understood in a technical but not in a legal sense. The term “guarantee”, therefore, specifies values for checking purposes determined in the contract, but does not say anything about the rights or duties arising, if these values are not reached or fulfilled. The term “acceptance” does not have any legal meaning here, either. Therefore, an acceptance test carried out successfully alone does not represent an “acceptance” in the legal sense.

0 Introduction

This International Standard is the second of a set of three dealing with acceptance tests of centrifugal, mixed flow and axial pumps¹⁾; they correspond to three classes of tests A, B and C²⁾; class A is the most accurate and class C is the least accurate; the use of classes A and B is restricted to special cases when there is need to have the pump performance more precisely defined.

Attention is drawn to the fact that class B and A tests require more accurate apparatus and methods, which increase the cost of such tests.

The standard arrangements and procedures described are those to be employed for testing a pump individually, without reference to its final installation conditions or the effect upon it of any associated fittings, these being the usual conditions in which a pump is tested at the manufacturer's works.

Pump performance may be affected by conditions of the final site installation, and procedures are described for carrying out “standard tests” on certain types of installations of which an overall performance is required.

The conditions in which pumps are finally installed, however, often do not permit reliable tests measurements, and recommendations are made concerning the procedure to be adopted where the layout precludes tests in conformity with the standards, or where the tests cover the pump and the plant ancillary to the pump itself.

In this test code, all formulae are given in coherent units.

1 Scope and field of application

This International Standard constitutes a code for acceptance testing of pumps, defining the terms and quantities that are used, establishing the methods of testing and the ways of measuring the quantities involved according to class B so as to ascertain the performances of the pump and to compare them with the manufacturer's guarantee.

In general this code applies to any sizes of pumps tested with clean cold water and other liquids behaving as clean cold water such as defined in clause 8.

This code is not concerned with the structural details of the pump nor with the mechanical properties of their components.

¹⁾ In the rest of the text these types of pumps will be simply designated as “pumps”.

²⁾ ISO 2548.

2 Symbols

2.1 List of symbols used in the test code

Table 1 — Symbols

Reference number in ISO 31 ^a	Reference number in ISO 3555	Quantity	Symbol	Dimensions ^b	SI units
3.1.1		Mass	m	M	kg
1.3.1		Length	l	L	m
1.6.1		Time	t	T	s
4.2.1		Temperature	θ	Θ	°C
1.4.1		Area	A	L^2	m ²
1.5.1		Volume	V	L^3	m ³
1.8.1		Angular velocity	ω	T^{-1}	rad/s
1.10.1		Velocity	v	LT^{-1}	m/s
1.11.2		Acceleration of free fall	g	LT^{-2}	m/s ²
2.3.2		Speed of rotation	n	T^{-1}	s ⁻¹
3.2.1		Density	ρ	ML^{-3}	kg/m ³
3.11.1		Gauge pressure	p_e	$ML^{-1}T^{-2}$	Pa
3.19.1		Viscosity (dynamic viscosity)	μ	$ML^{-1}T^{-1}$	Pa.s
3.20.1		Kinematic viscosity	ν	L^2T^{-1}	m ² /s
3.22.2		Energy	E	ML^2T^{-2}	J
3.23.1		Power (general term)	P	ML^2T^{-3}	W
12.1		Reynolds number	Re	pure number	
		Diameter	D	L	m
	3.2.1.1	Mass rate of flow	q_m	MT^{-1}	kg/s
	3.2.1.2	Volume rate of flow	q_v	L^3T^{-1}	m ³ /s
	3.2.3.2	Distance to reference plane	z	L	m
	3.2.3.8	Pump total head	H	L	m
	3.2.3.6	Inlet total head	H_1	L	m
	3.2.3.7	Outlet total head	H_2	L	m
	3.2.3.9	Specific energy	y	L^2T^{-2}	J/kg
	3.2.3.10	Loss of head at inlet	H_{J1}	L	m
	3.2.3.11	Loss of head at outlet	H_{J2}	L	m
	3.2.3.12	Net positive suction head	(NPSH) ^c	L	m
		Atmospheric pressure (absolute)	p_b	$ML^{-1}T^{-2}$	Pa
		Vapour pressure (absolute)	p_v	$ML^{-1}T^{-2}$	Pa
	3.2.4.2	Pump power input	P_a	ML^2T^{-3}	W
	3.2.4.1	Pump power output	P_u	ML^2T^{-3}	W
	3.2.4.3	Motor power input	P_{gr}	ML^2T^{-3}	W
	3.2.5.1	Pump efficiency	η	pure number	
	3.2.5.2	Transmission efficiency	η_{int}	pure number	
	3.2.5.3	Motor efficiency	η_{mot}	pure number	
	3.2.5.4	Overall efficiency	η_{gr}	pure number	
	3.2.6	Type number	K	pure number	
	6.2.1.2	Friction factor	λ	pure number	

^a ISO 31 (See Annex E.)^b M = Mass L = length T = Time Θ = Temperature^c An optional symbol for net positive suction head is H_H .

2.2 Alphabetical lists of basic letters and subscripts

Table 2 — Letters used as symbols

Symbol	Quantity	SI units
<i>A</i>	Area	m ²
<i>D</i>	Diameter	m
<i>E</i>	Energy	J
<i>g</i>	Acceleration of free fall	m/s ²
<i>H</i>	Head	m
<i>H_J</i>	Losses in terms of head of liquid	m
<i>K</i>	Type number	pure number
<i>k</i>	Absolute roughness	m
<i>l</i>	Length	m
<i>m</i>	Mass	kg
<i>n</i>	Speed of rotation	s ⁻¹
(NPSH)	Net positive suction head	m
<i>p</i>	Pressure	Pa
<i>P</i>	Power	W
<i>q_m</i>	Mass rate of flow	kg/s
<i>q_v</i>	Volume rate of flow	m ³ /s
<i>Re</i>	Reynolds number	pure number
<i>t</i>	Time	s
<i>v</i>	Velocity	m/s
<i>V</i>	Volume	m ³
<i>X</i>	Tolerance	pure number
<i>y</i>	Specific energy	J/kg
<i>z</i>	Distance to reference plane	m
<i>η</i>	Efficiency	pure number
<i>θ</i>	Temperature	°C
<i>λ</i>	Friction factor	pure number
<i>μ</i>	Dynamic viscosity	Pa s
<i>ν</i>	Kinematic viscosity	m ² /s
<i>ρ</i>	Density	kg/m ³
<i>ω</i>	Angular velocity	rad/s

Table 3 — Letters and figures used as subscripts

Subscript	Meaning
0	value at the specified speed
1	inlet
2	outlet
a	absorbed
av	available
b	atmospheric
e	effective
G	guaranteed
gr	unit (overall)
int	intermediate
J	loss
m	1) general case: mean 2) related to <i>q</i> : mass
M	manometric
mot	motor
P	pump
r	required
S	eye
sp	specified ^a
t	total
u	useful
v	1) general case: vapour 2) related to <i>q</i> : volume

^a This indication applies to the values of quantities relating to the guarantee point.

3 Definitions

3.1 General definitions

in order to avoid any error of interpretation it has seemed preferable to reproduce here the definitions of quantities and units as given in ISO 31 and to supplement these definitions by some specific information on their use in this test code

g — **acceleration of free fall**³⁾

n — **speed of rotation**

the quotient of the number of rotations by the time

ρ — **density**

mass per unit volume

p — **pressure**

the quotient of force by area. Unless otherwise specified, all pressures are gauge pressures, i.e. measured with respect to the atmospheric pressure

μ — **viscosity** (dynamic viscosity, sometimes called absolute viscosity) is defined by the expression

$$\tau = \mu \frac{u_o}{h}$$

where

u_o is the velocity of a flat plate moving in its own plane while keeping parallel to a fixed flat wall;
 h is the distance from the flat plate to the fixed flat wall;

τ is the friction force of the fluid on the unit area of the flat plate during its motion.

NOTE h should be small enough to obtain laminar flow of the fluid between the flat plate and the fixed flat wall.

ν — **kinematic viscosity**

the quotient of the viscosity (dynamic viscosity) by the density

$$\nu = \frac{\mu}{\rho}$$

P — **power**

the quotient of the energy transferred during a time interval by the duration of this interval

Re — **Reynolds number** is defined by the expression

$$Re = \frac{vD}{\nu}$$

3.2 Definitions peculiar to the test code

This sub-clause gives the definitions of concepts used in this test code, together with the associated symbols, if any have been allocated.

Concepts, even though in current use, which are not strictly necessary to the application of this code are not here defined.

3.2.1 Flow rates

3.2.1.1

q_m —

in this test code, **mass rate of flow** designates the external mass rate of flow of the pump, i.e. the rate of flow discharged into the pipe from the outlet branch of the pump

NOTE Losses or abstractions inherent to the pump, i.e. :

- a) discharge necessary for hydraulic balancing of axial thrust;
- b) cooling of bearings of the pump itself;
- c) water seal to the packing;
- d) leakage from the fittings, internal leakage, etc.;

are not to be reckoned in the quantity delivered. On the contrary, if they are taken at a point before the flow measuring section, all derived quantities used for other purposes, such as:

- e) cooling of the motor bearings;
- f) cooling of a gear-box (bearings, oil cooler), etc., should be added to the measured rate of flow.

3.2.1.2

q_v —

the **outlet volume rate of flow** has the following value:

$$q_v = \frac{q_m}{\rho_2}$$

in this test code, this symbol may also designate the volume rate of flow in a given section⁴⁾; it is the quotient of the mass rate of flow in this section by the density. (The section may be designated by the proposed subscripts)

3.2.2

v — **velocity of flow**

the mean velocity of flow equal to the volume rate of flow divided by the pipe cross-section⁴⁾

$$v = \frac{q_v}{A}$$

3.2.3

head

the energy per unit weight of fluid

3.2.3.1

reference plane

the horizontal plane through the centre of the circle described by the external point of the entrance edges of the impeller blades; in the case of double inlet pumps the plane should be taken through the higher centre

³⁾ For class B tests, the local value of g should be used. Nevertheless, in most cases, a value of 9,81 m/s² would not involve significant error. The local value should be calculated by the formula:

$$g = 9,806\,17 (1 - 2,64 \times 10^{-3} \cos 2\varphi + 7 \times 10^{-6} \cos^2 2\varphi) - 3,086 \times 10^{-6} Z$$

where φ and Z are respectively the latitude and altitude.

⁴⁾ Attention is drawn to the fact that in this case q_v may vary for different reasons across the circuit.

the manufacturer should indicate the position of this plane with respect to precise reference points on the pump

3.2.3.2

z designates the difference between the level of the horizontal plane under consideration and the level of the reference plane. Its value is

- positive, if the plane in question is above the reference plane;
- negative, if the plane in question is below the reference plane.

3.2.3.3

p_e — **gauge pressure**

the effective pressure, relative to atmospheric pressure. The head corresponding to this pressure is

$$\frac{p_e}{\rho g}$$

its value is

- positive if this pressure is greater than the atmospheric pressure;
- negative if this pressure is less than the atmospheric pressure.

3.2.3.4

velocity head

the kinetic energy per unit weight of the liquid in movement. It is expressed by:

$$\frac{v^2}{2g}$$

where v is the mean velocity of the liquid in the section considered

3.2.3.5

total head

in any section, the total head is given by:

$$z + \frac{p}{\rho g} + \frac{v^2}{2g}$$

this is related to atmosphere. The absolute total head in any section is given by:

$$z + \frac{p}{\rho g} + \frac{p_b}{\rho g} + \frac{v^2}{2g}$$

3.2.3.6

H_1 — **inlet total head**

the total head in the inlet section of the pump:

$$H_1 = z_1 + \frac{p_1}{\rho_1 g} + \frac{v_1^2}{2g}$$

3.2.3.7

H_2 — **outlet total head**

the total head in the outlet section of the pump

$$H_2 = z_2 + \frac{p_2}{\rho_2 g} + \frac{v_2^2}{2g}$$

3.2.3.8

H — **pump total head**

the algebraic difference between the outlet total head, and the inlet total head

$$H = H_2 - H_1$$

if the variation of density of the pumped liquid is not significant,

$$H = z_2 - z_1 + \frac{p_2 - p_1}{\rho g} + \frac{v_2^2 - v_1^2}{2g}$$

if the variation of density of the pumped liquid is significant, ρ should be replaced by the mean value

$$\rho_m = \frac{\rho_1 + \rho_2}{2}$$

3.2.3.9

y — **specific energy**

the energy per unit mass of liquid. It is given by the equation

$$y = gH$$

3.2.3.10

H_{J1} — **loss of total head at inlet**

the difference between the total head of the liquid at the measuring point, or possibly of the liquid without velocity in the suction chamber, and the total head of the liquid in the inlet section of the pump

3.2.3.11

H_{J2} — **loss of total head on delivery**

the difference between the total head of the liquid in the outlet section of the pump, and the total head of the liquid at the measuring point.

3.2.3.12

(NPSH) — **net positive suction head**

the total inlet head, plus the head corresponding to the atmospheric pressure, minus the head corresponding to the vapour pressure:

$$(NPSH) = H_1 + \frac{p_b}{\rho g} - \frac{p_v}{\rho g}$$

thus (NPSH), as well as inlet total head, is referred to the reference plane

it is necessary to make a distinction between

- the (NPSH) *required* at given flow and speed of rotation for a given pump; it is specified by the manufacturer;
- the (NPSH) *available* for the same flow which is determined by the installation.
- the value (NPSH) determined during the cavitation test. This value is that which causes in the first stage a drop of $(3 + K/2)$ % in total head of the first stage or in efficiency at a given rate of flow, or in a rate of flow or efficiency at a given total head.

subscripts may be used to differentiate these quantities (for example $(\text{NPSH})_r$ when the required value is concerned and $(\text{NPSH})_{av}$ when the available value is concerned)

3.2.4 Power

3.2.4.1

P_u — **pump power output**

the power transferred to the liquid at its passage through the pump:

$$P_u = q_m g H = q_m \gamma = \rho q_v g H$$

3.2.4.2

P_a — **pump power input**

the power measured at the pump coupling

3.2.4.3

P_{gr} — **motor power input**

the power absorbed by the pump driver

3.2.5 Efficiency

3.2.5.1

η — **pump efficiency**

$$\eta = \frac{\text{Pump power output}}{\text{Pump power input}}$$

3.2.5.2

η_{int} — **transmission efficiency**
(shafting, coupling, gears, etc.)

$$\eta_{int} = \frac{\text{Pump power input}}{\text{Power at motor shaft}}$$

3.2.5.3

η_{mot} — **motor efficiency**

$$\eta_{mot} = \frac{\text{Power at motor shaft}}{\text{Motor power input}}$$

3.2.5.4 η_{gr} — overall efficiency

$$\eta_{gr} = \eta_{int} \eta_{mot} = \frac{\text{Pump power output}}{\text{Motor power input}}$$

3.2.6

type number K

the type number, a dimensionless quantity, is defined by the following formula⁵⁾

$$K = \frac{2 \pi n (q'_v)^{1/2}}{(gH')^{3/4}}$$

where

q'_v is the volume rate of flow per eye;

H' is the head per stage.

NOTE Attention is drawn to the fact that, in this International Standard, the type number applies to the guaranteed flow rate, which is not in conformity with common practice where K is calculated from the flow rate corresponding to the maximum efficiency.

4 Guarantees

4.1 Subjects of guarantees

One or more of the following quantities may be guaranteed by the manufacturer under the specified conditions and speed of rotation:

- a) total head of the pump, H_G , at the agreed flow rate q_{vG} , or flow rate of the pump q_{vG} at the agreed total head H_G (see 9.4.1);
- b) power input or efficiency of the pump or combined pump-motor unit at the guaranteed $q_{vG}H_G$ point;
- c) NPSH required by the pump at the agreed flow rate q_{vG} ;
- d) other points of the q_vH curve may be indicated by guaranteeing the total head at a reduced or increased flow rate, in which case separately agreed increased tolerances will apply.

4.2 Other conditions of guarantee

Unless specifically agreed otherwise in the contract, it shall be taken that the following conditions apply to the guarantee values:

- a) unless the chemical and physical properties of the liquid are stated, it shall be taken that the guarantee points apply to clean cold water;

⁵⁾ This formula is the same as the basic formula $K = \frac{\omega q'_v^{1/2}}{Y^{3/4}}$

- b) the relation between the guarantee values under clean cold water conditions and the likely performance under other liquid conditions shall be agreed in the contract;
- c) guarantees shall apply only to the pump as tested by the methods and in the test arrangements specified, in this International Standard;
- d) the pump manufacturer shall not be responsible for the specification of the guarantee point.

4.3 Fulfilment of guarantee

The nominated guarantee for any quantity shall be deemed to have been met if, when tested according to this International Standard, the measured performance falls within the tolerance specified in clause 9 for the particular quantity. Other points on the $q_v H$ curve shall not be guaranteed unless the points and tolerances for fulfilment of guarantee are agreed in the contract.

5 Tests

5.1 Organization of tests

5.1.1 Place of testing

Acceptance tests shall be carried out at the manufacturer's works, or alternatively at a place to be mutually agreed between the manufacturer and the purchaser.

5.1.2 Time of testing

The time of testing shall be mutually agreed by the manufacturer and the purchaser.

When tests are not carried out in the manufacturer's works, time shall be allowed for preliminary adjustments by both the manufacturer and the installer.

5.1.3 Staff

Accurate measurements depend not only on the quality of the measuring instruments used but also on the ability and skill of the persons operating and reading the measuring devices during the tests. The staff entrusted with effecting the measurements must be selected just as carefully as the instruments to be used in the test.

Specialists with adequate experience in measuring operations in general shall be charged with operating and reading complicated measuring apparatus. Reading simple measuring devices may be entrusted to such helpers who – upon short prior instruction – can be assumed to effect the readings with proper care and the accuracy required.

A chief of tests shall be appointed, possessing adequate experience in measuring operations. Normally, when the test is carried out at the manufacturer's works, the chief of tests is a staff member of the manufacturing firm.

All persons charged with effecting the measurements are subordinated during the tests to the chief of tests, who conducts and supervises the measurements, reports on test conditions and the results of the tests and then drafts the test report. All questions arising in connection with the measurements and their execution are subject to his decision.

The parties concerned shall provide all assistance that the chief of tests considers necessary.

5.1.4 Test programme

Only the guaranteed operational data shall form the basis of the test; other data determined by measurement during the tests shall have merely an indicative (informative) function and it shall be so stated if they are included in the programme.

5.1.5 Testing equipment

The chief of tests shall be responsible for the selection and operation of measuring equipment. All of the measuring equipment shall be covered by reports showing, by calibration or by comparison with other International Standards, that it complies with the requirements of 5.4. These reports shall be presented if required.

5.1.6 Test reports

All test records and record charts shall be initialled by the chief of tests and by the representatives of both the purchaser and the manufacturer, each of whom shall be provided with a copy of all records and charts.

The evaluation of the test results, including graphical plotting of the pump performance curve, shall be made as far as possible while the tests are in progress and, in any case, before the installation and instrumentation are dismantled in order that suspect measurements can be repeated without delay.

5.2 Test arrangements

5.2.1 Standard test arrangements

All practical steps shall be taken to ensure that flow through the measuring section shall result in

- a) an axially symmetric velocity distribution;
- b) a uniform static pressure distribution;
- c) freedom from swirl induced by the installation.

Some methods for ensuring these conditions for standard test arrangements are suggested below.

Acceptance tests may be carried out under standard test conditions for pumps where the type number is less than or equal to 1,5.

When the type number is greater than 1,5, it must be agreed contractually that the results of such tests will be held to apply only to specified conditions. The purpose of such tests will be to provide an assurance that the pump will, if suitably installed, perform the specified duty.

It is recommended that for standard test circuits leading from reservoirs with a free surface, or from large stilling vessels in a closed circuit, the inlet straight length L shall be determined by the expression:

$$\frac{L}{D} = K + 5$$

where D is the pipe diameter.

This expression is also valid for an arrangement that includes, at a distance L upstream, a simple medium-radius right angle bend that is not fitted with guide vanes. Under these conditions, flow straighteners are not necessary in the pipe between the bend and the pump.

However, in a closed circuit where there is neither a reservoir nor a stilling vessel immediately upstream of the pump, it is necessary to ensure that the flow into the pump is free from swirl induced by the installation and has a normal symmetrical velocity distribution.

Significant swirl can be avoided by:

- careful design of the test circuit upstream of the measurement section;
- judicious use of a flow straightener;
- suitable arrangement of the pressure tapplings to minimize their influence on the measurement.

5.2.2 Simulated test arrangements

When pumps are tested under simulated site conditions flow straighteners shall not be installed immediately before the pump. It is important that the characteristics, of flow to the simulated circuit should be controlled; that the flow should, as far as possible, be free from significant swirl induced by the installation and have a symmetrical velocity distribution. If necessary, the velocity distribution of the flow into the simulated circuit shall be determined by careful pitot tube traverses, in order to establish that the required flow characteristics exist. If not the required characteristics can be obtained by the installation of suitable means, such as the Zanker flow straightener (see Figure 1); but care must be taken to ensure that the conditions of test will not be affected by the high, irrecoverable pressure losses associated with efficient straightening devices.

5.2.3 Pumps tested with fittings

If specified in the contract, standard tests can be carried out on a combination of a pump and:

- 1) associated fittings at the final site installation; or
- 2) an exact reproduction thereof; or
- 3) fittings introduced for testing purposes and taken as forming part of the pump itself (see for example 5.2.4, 5.2.5, etc.).

Connection on the inlet and outlet sides of the whole combination shall be made in accordance with 6.2.2.

Measurements shall then be taken in accordance with 5.3.2.2 and 5.3.2.3.

5.2.4 Pumping installation under submerged conditions

Where a pump, or a combination of a pump and its fittings, is tested or installed in conditions where the standard pipe connection on either inlet or outlet as described in 6.2.2, cannot be made owing to inaccessibility or submergence, measurements shall be taken in accordance with 6.2.1.6.

5.2.5 Borehole and deep-well pumps

Borehole and deep-well pumps cannot usually be tested with their complete lengths of delivery main and, consequently, the loss of head in the portions omitted, and the power absorbed by any shafting therein, cannot be measured. Any thrust bearing, would also be more lightly loaded during the test than it would be in the final installation. (See 6.2.1.6.)

5.2.6 Self-priming pumps

In principle the priming ability of self-priming pumps shall always be verified at the contractual static suction head with the attached inlet piping equivalent to that in the final installation. When the test cannot be carried out in the described manner, the test arrangement to be used shall be specified in the contract.

5.3 Test conditions

5.3.1 Execution of tests

The duration of the test shall be sufficient to obtain consistent results having regard to the degree of accuracy to be achieved.

Where multiple readings are taken to reduce the error margin (see 5.3.2), they shall be taken at unequal intervals of time.

All measurements shall be made under steady conditions of operation but a decision to make measurements when such conditions cannot be obtained shall be a matter of agreement between the parties concerned.