

Insulating and sheathing materials of electric cables

Part 1. Methods of test for general application

Section 1.2 Thermal ageing methods

(Implementation of HD 505.1.2 S2)

Committees responsible for this British Standard

The preparation of this British Standard was entrusted by the Cables and Insulation Standards Policy Committee (CIL/-) to Technical Committee CIL/20, upon which the following bodies were represented:

- Aluminium Federation
- Association of Consulting Engineers
- Association of Manufacturers of Domestic Electrical Appliances
- British Approvals Service for Cables
- British Cable Makers' Confederation
- British Plastics Federation
- British Steel Industry
- British Telecommunications plc
- Department of the Environment (Property Services Agency)
- Department of Trade and Industry (Consumer Safety Unit, CA Division)
- Electricity Association
- Engineering Equipment and Materials Users' Association
- Institution of Electrical Engineers
- London Regional Transport

The following bodies were also represented in the drafting of the standard, through subcommittees and panels:

- British Railways Board
- British Rubber Manufacturers' Association Ltd.
- ERA Technology Ltd.
- GAMBICA (BEAMA Ltd.)
- Institution of Incorporated Executive Engineers
- London Underground Ltd.
- Queen Mary and Westfield College
- Telecommunications Cables Group of BCMC

This British Standard, having been prepared under the direction of the Cables and Insulation Standards Policy Committee, was published under the authority of the Standards Board and comes into effect on 15 August 1992

© BSI 1992

Amendments issued since publication

Amd. No.	Date	Text affected

The following BSI references relate to the work on this standard:
Committee reference CIL/20
Draft announced in *BSI News* December 1991

ISBN 0 580 20839 7

Contents

	Page
Committees responsible	Inside front cover
National foreword	i
Foreword	2
Text of HD 505.1.2 S2	3
National annex NA (informative)	18
National annex NB (informative)	18
National annex NC (informative)	Inside back cover

National foreword

This Section of BS 6469 has been prepared under the direction of the Cables and Insulation Standards Policy Committee. BS 6469 : Parts 1 to 5 and Part 99 supersede BS 6469 : 1990 which is withdrawn.

Parts 1 to 5 implement CENELEC HD 505 : Parts 1 to 5 which were derived from IEC 811 : Parts 1 to 5. Part 99 describes test methods having the national applicability only.

The International Electrotechnical Commission has completed its comprehensive update of the test methods previously given in IEC 538, IEC 538A and IEC 540, which are now largely brought together in IEC 811. Electrical tests from IEC 540 have been incorporated into IEC 885. The technical changes introduced during this update, and endorsed by CENELEC in HD 505, are now included in BS 6469.

BS 6469 : Section 4.2 includes a number of test methods described in BS 6234. Other test methods from BS 6234, from BS 6746 and from BS 6899 have been incorporated in BS 6469 : Part 99. The status of these test methods in BS 6234, BS 6746 and BS 6899 will be reviewed separately.

BS 6469 describes methods of test, but does not specify requirements for products or materials. These will be specified in the relevant cable standards or cable material standards.

This Section of BS 6469 implements CENELEC Harmonization Document HD 505.1.2 S2 : 1991, which is identical with IEC 811-1-2 : 1985 plus Amendment No. 1 (1989) plus Corrigendum 1986.

Definitions of terms relating to electric cables are given in BS 4727 : Part 2 : Group 08.

It has been assumed in the preparation of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

WARNING. The methods of test described in this British Standard do not necessarily detail all precautions necessary to meet the requirements of the Health and Safety at Work etc. Act 1974. Attention should be paid to any appropriate safety precautions and the tests should be carried out only by trained personnel.

The complete IEC standard (IEC 811) will eventually replace IEC Publications 538 and 540. To enable users to compare the relevant clauses in all three publications, a table of cross-references is given in appendix A.

Cross-references between the relevant clauses in BS 6469 : 1990 and those in BS 6469 : Parts 1 to 5 and Part 99 are given in table NB.1. Tests included in BS 6469 : Sections 1.3 and 5.1 which were not given in BS 6469 : 1990 are listed in table NC.1.

References to page numbers in the text relate to the IEC page numbers and should be ignored.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

UDC 621.315.6 : 621.315.2 : 620.199.94

Descriptors: Electric cable, insulated cable, electrical insulation, sheath, ageing treatment, ageing

English version

Common test methods for insulating and sheathing materials of electric cables

Part 1. Methods for general application
Section two — Thermal ageing methods

(IEC 811-1-2 : 1985 + Amendment 1 : 1989)

Méthodes d'essais communes pour les matériaux d'isolation et de gainage des câbles électriques
Première partie: Méthodes d'application générale
Section deux — Méthodes de vieillissement thermique
(CEI 811-1-2 : 1985 + Modification 1 : 1989)

Allgemeine Prüfungen für Isolier- und Mantelwerkstoffe für Kabel und isolierte Leitungen
Teil 1: Allgemeine Prüfverfahren
Hauptabschnitt 2: Thermische Alterungsarten
(IEC 811-1-2 : 1985 + Änderung 1 : 1989)

This Harmonization Document was approved by CENELEC on 1990-12-10. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document on a national level.

Up-to-date lists and bibliographical references concerning national implementation may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B-1050 Brussels

Foreword

The CENELEC questionnaire procedure, performed for finding out whether or not the International Standard IEC 811-1-2 : 1985 and its amendment 1 : 1989 could be accepted without textual changes, has shown that no CENELEC common modifications were necessary for the acceptance as Harmonization Document.

The reference document was submitted to the CENELEC members for formal vote and was approved by CENELEC as HD 505.1.2 S2 on 10 December 1990.

The following dates were fixed:

- latest date of (doa) 1991-06-01
announcement of the HD
at national level
- latest date of publication (dop) 1991-12-01
of a harmonized national
standard
- latest date of withdrawal (dow) 1991-12-01
of conflicting national
standards

CONTENTS

	Page
Clause	
1. Scope	4
2. Test values	4
3. Applicability	4
4. Type tests and other tests	4
5. Pre-conditioning	4
6. Test temperature	4
7. Median value	4
8. Thermal ageing methods	5
8.1 Ageing in an air oven	5
8.2 Ageing in an air bomb	10
8.3 Ageing in an oxygen bomb	10
8.4 Methods of measuring air flow in ovens	11
FIGURES	13
APPENDIX A — Corresponding clauses and sub-clauses in IEC Publications 538 and 540 and IEC Publication 811	15

COMMON TEST METHODS FOR INSULATING AND SHEATHING MATERIALS OF ELECTRIC CABLES

Part 1: Methods for general application

SECTION TWO – THERMAL AGEING METHODS

1. Scope

This standard specifies the test methods to be used for testing polymeric insulating and sheathing materials of electric cables for power distribution and telecommunications including cables used on ships.

This Section Two of Part 1 gives the thermal ageing methods which apply to the most common types of insulating and sheathing compounds (elastomeric, PVC, PE, PP, etc.).

2. Test values

Full test conditions (such as temperatures, durations, etc.) and full test requirements are not specified in this standard; it is intended that they should be specified by the standard dealing with the relevant type of cable.

Any test requirements which are given in this standard may be modified by the relevant cable standard to suit the needs of a particular type of cable.

3. Applicability

Conditioning values and testing parameters are specified for the most common types of insulating and sheathing compounds and of cables, wires and cords.

4. Type tests and other tests

The test methods described in this standard are intended, in the first instance, to be used for type tests. In certain tests, where there are essential differences between the conditions for type tests and those for more frequent tests, such as routine tests, these differences are indicated.

Note. – For multicore cables and cords, not more than three cores (of different colours, if any) need be tested unless otherwise specified in the relevant cable standard.

5. Pre-conditioning

All the tests shall be carried out not less than 16 h after the extrusion or vulcanization (or cross-linking), if any, of the insulating or sheathing compounds.

6. Test temperature

Unless otherwise specified, tests shall be carried out at room temperature.

Note. – In the UK room temperature is defined as 20 ± 5 °C.