

Bushings up to 1 kV and from 250 A to 5 kA, for liquid filled transformers —

Implementation of
CENELEC HD 596 S1:1996

ICS 29.180

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW



Document Sharing Hub

Committees responsible for this British Standard

The preparation of this British Standard was entrusted to Technical Committee PEL/36, Insulators for power systems, upon which the following bodies were represented:

- Association of Consulting Engineers
- Association of Manufacturer Allied to the Electrical and Electronic Industry (BEAMA Ltd.)
- British Industrial Ceramic Manufacturers' Association
- British Railways Board
- Electrical and Electronic Insulation Association (BEAMA Ltd.)
- Electricity Association
- Overhead Transmission Line Contractors (BEAMA Ltd.)
- Transmission and Distribution Association (BEAMA Limited)

The following bodies were also represented in the drafting of the standard, through subcommittees and panels:

- British Cable Makers Confederation
- Electrical Installation Equipment Manufacturers' Association (BEAMA Ltd.)

This British Standard, having been prepared under the direction of the Electrotechnical Sector Board, was published under the authority of the Standards Board and comes into effect on 15 August 1996

© BSI 03-2000

The following BSI references relate to the work on this standard:
Committee reference PEL/36
Draft for comment 94/202405 DC

ISBN 0 580 26105 0

Amendments issued since publication

Amd. No.	Date	Comments

Contents

	Page
Committees responsible	Inside front cover
National foreword	ii
Foreword	2
Introduction	3
1 Scope	3
2 Requirements	3
2.1 Application	3
2.2 Standard value of rated voltage (U_r)	3
2.3 Standard values of rated current (I_r)	3
2.4 Minimum nominal creepage distance	3
2.5 Dielectric characteristics	3
2.6 Dimensions and components	3
Figure 1 — Type 1 – 3 bushings (250 A to 630 A)	4
Figure 2 — Type 4 – 8 bushings (1 250 A to 5 000 A)	4
Table 1 — Minimum nominal creepage distance	3
Table 2 — Standard dimensions	4
Table 3 — List of components	5
List of references	Inside back cover

National foreword

This British Standard has been prepared by Technical Committee PEL/36 and implements HD 596 S1:1996 *Bushings up to 1 kV and from 250 A to 5 kA, for liquid filled transformers*, published by the European Committee for Electrotechnical Standardization (CENELEC).

Cross-references

Publication referred to	Corresponding British Standard
HD 428.1:1992	BS 7281 <i>Three phase oil-immersed distribution transformers, 50 Hz, from 50 to 2 500 kVA with highest voltage for equipment not exceeding 36 kV</i> Part 1:1995 <i>General requirements and requirements for transformers with highest voltage for equipment not exceeding 24 kV</i> (Identical)

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, the HD title page, pages 2 to 6, an inside back cover and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.