



BSI Standards Publication

Fixed firefighting systems — Components for sprinkler and water spray systems

Part 14: Sprinklers for residential applications

National foreword

This British Standard is the UK implementation of EN 12259-14:2020+A2:2024. It supersedes BS EN 12259-14:2020+A1:2022, which is withdrawn.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to CEN text carry the number of the CEN amendment. For example, text altered by CEN amendment A1 is indicated by A1 A1.

The UK participation in its preparation was entrusted to Technical Committee FSH/18/2, Sprinkler Systems.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient’s own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2024
Published by BSI Standards Limited 2024

ISBN 978 0 539 33235 3

ICS 13.220.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 January 2020.

Amendments/corrigenda issued since publication

Date	Text affected
31 August 2022	Implementation of CEN amendment A1:2022
31 August 2024	Implementation of CEN amendment A2:2024
30 September 2024	Correction to Amendments/corrigenda issued since publication table in national foreword

English Version

Fixed firefighting systems - Components for sprinkler and water spray systems - Part 14: Sprinklers for residential applications

Installations fixes de lutte contre l'incendie -
Composants des systèmes d'extinction du type
sprinkleur et à pulvérisation d'eau - Partie 14:
Sprinkleurs pour applications résidentielles

Ortsfeste Brandbekämpfungsanlagen - Bauteile für
Sprinkler- und Sprühwasseranlagen - Teil 14: Sprinkler
für die Anwendung im Wohnbereich

This European Standard was approved by CEN on 4 November 2019 and includes Amendment 1 approved by CEN on 13 March 2022 and Amendment 2 approved by CEN on 14 July 2024.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Construction and performance	8
4.1 General	8
4.2 Dimensions and pressure rating	8
4.3 Nominal operating temperature	8
4.4 Operating temperatures	9
4.5 Water flow and distribution	9
4.6 Function	10
4.7 Fire Test	10
4.8 Strength of sprinkler body and deflector	11
4.9 Strength of release element	11
4.10 Leak resistance and hydrostatic strength	12
4.11 Heat exposure	12
4.12 Corrosion	13
4.13 Water hammer	13
4.14 Thermal response	14
4.15 Resistance to vibration	14
4.16 Resistance to impact	14
4.17 Resistance to low temperature	14
4.18 Resistance to heat	14
4.19 Test conditions	14
5 Marking	14
5.1 General	14
5.2 Identification number	14
5.3 Nominal operating temperature and year of manufacture	15
5.4 Manufacturing location	15
5.5 Heat sensitive element supplier	15
5.6 Protective covers	15
5.7 Sidewall sprinklers	15
5.8 Concealed sprinklers	15
5.9 Removable recessed housing	16
6 Instruction charts	16
6.1 General	16
6.2 Installation Instructions	16
Annex A (normative) Conditions for tests	18
Annex B (normative) Water flow test	19
Annex C (normative) Water distribution test	21
Annex D (normative) Fire test	27
Annex E (normative) Function test	37

Annex F (normative) Strength of sprinkler body and deflector 39

Annex G (normative) Strength of release elements test..... 41

Annex H (normative) Leak resistance tests 44

Annex I (normative) Heat exposure..... 45

Annex J (normative) Glass bulb sprinkler thermal shock test 46

Annex K (normative) Exposure and corrosion tests 47

Annex L (normative) Water hammer test..... 51

Annex M (normative) Thermal response test..... 52

Annex N (normative) Vibration test..... 57

Annex O (normative) Impact test..... 58

Annex P (normative) Resistance to low temperature test..... 59

Annex Q (normative) Resistance to high temperature test..... 60

Bibliography 61

European foreword

This document (EN 12259-14:2020+A2:2024) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2025, and conflicting national standards shall be withdrawn at the latest by February 2025.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 13 March 2022 and Amendment 2 approved by CEN on 14 July 2024.

This document supersedes A1 EN 12259-14:2020+A1:2022 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1 and A2 A2.

A2 In comparison with EN 12259-14:2020, technical modifications have been made to clarify the types of sprinkler seal that are covered by this document in Amendment 1. In Amendment 2 the pressure values in C.1.1 and C.2.1 were corrected as well as the unit for the force increase in G.1. A2

It is included in a series of European Standards planned to cover:

- automatic sprinkler systems (EN 12259 and EN 12845);
- gas extinguishing systems (EN 12094);
- powder systems (EN 12416);
- foam systems (EN 13565);
- hydrant and hose reel systems (EN 671);
- smoke and heat control systems (EN 12101).

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

[A1] This document specifies requirements for the construction and performance of residential sprinklers as well as test methods for their type approval, which are operated by a change of state of an element or bursting of a glass bulb under the influence of heat and incorporating the following types of water seals:

- conical metal spring with a PTFE gasket or coating;
- metal cap or disc with PTFE gasket or coating;
- copper gasket, with or without a PTFE coating.

Sprinklers in accordance with this document are only used in automatic sprinkler systems for domestic and residential applications as defined in EN 16925. **[A1]**

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

[A1] EN 12259-1:1999+A1:2001¹ **[A1]**, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 1: Sprinklers*

EN 13501-1, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 16925, *Fixed firefighting systems - Automatic residential sprinkler systems - Design, installation and maintenance*

ISO 7-1, *Pipe threads where pressure-tight joints are made on the threads — Part 1: Dimensions, tolerances and designation*

ISO 49, *Malleable cast iron fittings threaded to ISO 7-1*

ISO 65, *Carbon steel tubes suitable for screwing in accordance with ISO 7-1*

ISO 5658-2:2006, *Reaction to fire tests — Spread of flame — Part 2: Lateral spread on building and transport products in vertical configuration*

ISO 5660-1:2015, *Reaction-to-fire tests — Heat release, smoke production and mass loss rate — Part 1: Heat release rate (cone calorimeter method) and smoke production rate (dynamic measurement)*

UL 723, *Standard for test for surface burning characteristics of building materials*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>

¹ **[A1]** As impacted by EN 12259-1:1999+A1:2001/A2:2004 and EN 12259-1:1999+A1:2001/A3:2006. **[A1]**

— ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

concealed sprinkler

unit (pre-assembled or assembled on site) consisting of a nozzle with a thermally sensitive sealing device, a housing and a cover plate, that ensures that the sprinkler will be installed with all or part of the thermally sensitive element behind the plane of the ceiling

3.2

recessed sprinkler

unit (pre-assembled or assembled on site) consisting of a nozzle with a thermally sensitive sealing device and a housing, that ensures that the sprinkler will be installed with all or part of the thermally sensitive element above the plane of the ceiling

3.3

discharge coefficient

known as K-factor

coefficient of discharge in the formula,

$$Q = K \sqrt{p} \quad (1)$$

where

Q is the flow in litres per minute, and

p is the pressure in bar

3.4

dry-type sprinkler

nozzle with a thermally sensitive sealing device secured in an extension nipple that has a seal at the inlet end to prevent water from entering the nipple until the sprinkler operates

3.5

flush sprinkler

unit consisting of a nozzle with a thermally sensitive sealing device and housing, that ensures that the sprinkler will be installed partly behind, but with the temperature sensitive element before, the finished plane of the ceiling or wall

3.6

heat responsive element

portion of a sprinkler that breaks, melts, or otherwise functions to initiate the automatic operation of the sprinkler when exposed to sufficient heat

3.7

heptane

commercial grade heptane having the following characteristics:

- a) minimum Initial Boiling Point of 88 °C;
- b) maximum Dry Point of 100 °C; and
- c) specific Gravity (15,6 °C/15,6 °C) of 0,68 - 0,73.

3.8**orifice**

opening that controls the amount of water discharged from a sprinkler at a given pressure

3.9**pendent sprinkler**

nozzle with a thermally sensitive sealing device intended to be installed so that its deflector is located below the orifice and the water flows downward through the orifice

3.10**residential sprinkler**

nozzle with a thermally sensitive sealing device intended to be installed only in residential occupancies as defined in EN 16925

3.11**sidewall sprinkler**

nozzle with a thermally sensitive sealing device intended for installation on or near the wall

3.12**upright sprinkler**

nozzle with a thermally sensitive sealing device intended to be installed so that its deflector is located above the orifice

3.13**response time index****RTI**

measure of the thermal sensitivity of the sprinkler expressed in $(\text{meters.seconds})^{1/2} (\text{m}\times\text{s})^{1/2}$

Note 1 to entry: Unlike in EN12259-1, the RTI value is calculated without considering the conductivity factor

3.14**design lower tolerance limit****DLTL**

glass bulb supplier's specified and assured lowest lower tolerance limit

3.15**design upper tolerance limit****DUTL**

sprinkler supplier's specified and assured highest upper tolerance limit

3.16**fusible link sprinkler**

nozzle with a thermally sensitive sealing device which opens when an element provided for that purpose melts

3.17**glass bulb sprinkler**

nozzle with a thermally sensitive sealing device which opens when a liquid-filled glass bulb bursts

3.18**mean design service load**

sprinkler supplier's specified and assured highest mean service load for any batch of 10 or more sprinklers

3.19

mean design strength

glass bulb supplier's specified and assured lowest mean bulb strength for any batch of 55 or more bulbs

3.20

horizontal sprinkler

nozzle with a thermally sensitive sealing device in which the nozzle directs the water horizontally

3.21

lower tolerance limit

LTL

glass bulb lowest strength determined by test and statistical analysis of a batch of 55 or more bulbs

3.22

supplier

company responsible for the design, manufacture and quality assurance of a product

3.23

upper tolerance limit

UTL

highest service load determined by test and statistical analysis of a batch of 20 or more sprinklers

3.24

frame arms

part of a sprinkler that maintains the thermally sensitive element in load bearing contact with the sprinkler head valve

4 Construction and performance

4.1 General

Sprinklers shall only be assembled in such a way that adjustment or dismantling will result in destruction of an element of construction.

It shall be possible to remove the cover of a concealed sprinkler without having to use special tools, e.g. for visual inspections.

4.2 Dimensions and pressure rating

4.2.1 Dimensions

Nominal thread sizes shall be suitable for fittings threaded in accordance with ISO 7-1.

It shall be possible for a sphere of (5,0 +0,01/-0) mm diameter to pass through the orifice of the sprinkler.

4.2.2 Pressure ratings

A residential sprinkler shall have a maximum operating pressure of at least 12 bar.

4.3 Nominal operating temperature

When tested in accordance with "Test to determine operating temperatures of fusible link sprinklers and glass bulb sprinklers" of [\[A1\]](#) EN 12259-1:1999+A1:2001 [\[A1\]](#), sprinklers shall operate at a temperature within the range:

$T_{\text{test}} = [t \pm (0,035 t + 0,62)] \text{ }^{\circ} \text{C}$

where

t is the nominal operating temperature.

When cover plates are tested in accordance with the “Test to determine operating temperatures of fusible link sprinklers and glass bulb sprinklers” of [A1](#) EN 12259-1:1999+A1:2001 [A1](#), cover plates shall operate at a temperature within the range:

$T_{\text{test}} = [t_{\text{cover}} \pm (0,035 t + 0,62)] \text{ }^{\circ} \text{C}$

where

t_{cover} is the nominal operating temperature of the cover.

This temperature t_{cover} shall be 8 °C to 20 °C lower than the nominal operating temperature of its sprinkler head.

4.4 Operating temperatures

The temperature classification, temperature rating, and colour coding of a residential sprinkler shall be as specified in Table 1.

Table 1 — Nominal operating temperatures and colour codes

Glass bulb sprinklers		Fusible link sprinklers	
Nominal operating temperature °C	Liquid colour code	Nominal operating temperature within range °C	Frame arms colour code
57	Orange	57 to 77	uncoloured white
68	Red	80 to 107	
79	Yellow		
93	Green		
100	Green		

4.5 Water flow and distribution

4.5.1 K-factor

The nominal K-factor shall be specified by the supplier. The K-factor of the sprinklers shall be within the nominal value ± 5 % for other than dry sprinklers and ± 8 % for dry sprinklers, when determined in accordance with Annex B.

4.5.2 Water distribution

4.5.2.1 Water distribution test – Horizontal surface

When installed in accordance with the installation instructions and tested as described in C.1 a residential sprinkler shall distribute water over a horizontal surface so that the discharge density for any pan within the design area (the maximum area the sprinkler is intended to protect) shall be at least 0,8 mm/min except that:

- a) no more than 2 pans (0,5 m × 0,5 m) or not more than 4 pans (0,3m × 0,3m) for each quadrant shall be allowed to be at least 0,6 mm/min for upright and pendant sprinklers; and
- b) no more than 8 pans (0,3 m × 0,3 m) or 3 pans (0,5 m × 0,5 m) shall be allowed to be at least 0,6 mm/min for each half (split along the sprinkler centreline) of the maximum area a sidewall sprinkler is intended to protect

4.5.2.2 Water distribution test – Vertical surface

When installed in accordance with the installation instructions and tested as described in C.2, a residential sprinkler shall distribute water in a uniform manner over vertical surfaces as follows:

- a) walls within the coverage area shall be completely wetted to at least within 711 mm of the ceiling with one sprinkler discharging water at the specified design flow rate;
- b) for square coverage areas, each wall within the coverage area shall be wetted with at least 5 % of the sprinkler flow; for rectangular coverage areas, each wall within the coverage area shall be wetted with a proportional water amount based on 20 % of the total sprinkler discharge in accordance with the following formula

$$WW = 20 \% (D / P) \quad (2)$$

where

WW is required amount of water collected on a wall, in %;

D is wall length, in m;

P is total perimeter of coverage area, in m.

4.5.3 Water Impingement Test

When tested in accordance with Annex C and while discharging water at a service pressure of 5,2 bar less than the maximum operating pressure, a residential sprinkler shall not prevent the operation of an adjacent residential sprinkler.

4.6 Function

When tested in accordance with Annex E each of the residential sprinklers shall operate at service pressures of 0,5 bar to the maximum operating pressure. The sprinkler shall open and within 5 s of release of the thermally sensitive element shall operate satisfactorily. Any lodgement of released parts shall be cleared within 60 s of the release of the thermally sensitive element. After testing in accordance with Annex E the sprinkler shall conform to the requirements of 4.5.2.

NOTE In most instances visual examination of the equipment will be sufficient to establish conformity with the requirements of 4.5.2.

4.7 Fire Test

When fire tested as described in Annex D a residential sprinkler shall limit temperatures as specified below when tested at each spacing referenced in the installation instructions. Additionally, a maximum of two residential sprinklers shall operate and the third sprinkler, located near the 1 000 mm wide doorway, shall not operate. The sprinklers shall limit temperatures as follows:

- a) The maximum temperature measured 76 mm below the ceiling at locations 4 and 5 as illustrated in Figure D.1, Figure D.2 and Figure D.3 shall not exceed 316 °C.

- b) The maximum temperature measured 1,6 m above the floor at location 4 shall not exceed 93 °C.
- c) The temperature at the location described in (b) shall not exceed 54 °C for more than any continuous 2 min period.
- d) The maximum ceiling material temperature measured 6 mm behind the finished ceiling surface shall not exceed 260 °C.

NOTE The thermocouple 76 mm below the ceiling, located above the fire source, is for reference purposes only.

See Figure D.1, (pendant, upright, flush, recessed pendant, and concealed sprinklers) or Figure D.2 and Figure D.3 (sidewall sprinklers) for temperature measuring locations.

4.8 Strength of sprinkler body and deflector

4.8.1 Strength of frame

The sprinkler body shall not show permanent elongation of more than 0,2 % between the load-bearing parts when subjected to twice the average service load when tested in accordance with F.1.

4.8.2 Flow endurance

A residential sprinkler shall withstand for 30 min, without evidence of cracking, deformation, or separation of any part when tested in accordance with F.2.

4.8.3 Strength of deflector


The sprinkler deflector and its supporting parts shall withstand an applied force of 70 N without permanent deformation when tested in accordance with F.3.

4.9 Strength of release element

4.9.1 Glass bulb sprinklers

When evaluated and tested in accordance with Annex G, glass bulb sprinklers shall have:

- a) a mean design bulb strength of at least six times the mean design service load;
- b) a mean bulb strength not less than the mean design bulb strength;
- c) a mean service load not more than the mean design service load;
- d) a design lower tolerance limit (DLTL) on the distribution curve of at least two times the design upper tolerance limit (DUTL) of the service load distribution curve;
- e) an upper tolerance limit (UTL) less than or equal to the design upper tolerance limit (DUTL);
- f) a lower tolerance limit (LTL) greater than or equal to the design lower tolerance limit (DLTL) see Figure 1.

**Key**

- 1 service load distribution curve
- 2 bulb strength distribution curve
- 3 mean service load
- 4 mean bulb strength
- 5 upper tolerance limit (UTL)
- 6 lower tolerance limit (LTL)
- A number of samples
- B strength (N)

Figure 1 — Graph of service load and bulb strength distribution curves

4.9.2 Fusible link sprinklers

It shall be determined that:

- a) the temperature sensitive elements withstand a load of 15 times the maximum design load for a period of 100 h, without failure; or
- b) the estimated time to failure of temperature sensitive elements is not less than 876 600 h at the design load, when tested in accordance with Annex G.

4.10 Leak resistance and hydrostatic strength

Twenty residential sprinklers shall be tested and not leak when tested in accordance with H.1 and, subsequently, shall not rupture, operate or release, when tested in accordance with H.2.

4.11 Heat exposure

4.11.1 General

A residential sprinkler shall withstand for 90 days, without evidence of weakness or malfunction, an exposure to the high-ambient temperature in accordance with I.1.

After the exposure period four sprinklers shall be tested in accordance with E.2; the sprinklers shall operate such that the waterway is cleared. Any lodgements shall be disregarded. Four sprinklers shall be leak tested in accordance with H.1. Four sprinklers shall be tested in accordance with “Test to determine operating temperatures of fusible link sprinklers and glass bulb sprinklers” of [EN 12259-1:1999+A1:2001](#).

Additionally, after the exposure period four recessed, concealed and flush sprinklers shall be tested in accordance with M.2. Their mean operating time shall be equal to or less than a 1,30 multiple of the mean operating time of the sprinkler tested in accordance with M.2 for compliance with 4.14.2.

4.11.2 Additional heat exposure of glass bulb sprinklers

There shall be no damage to the glass bulb when sprinklers are tested in accordance with I.2.

A1 deleted text A1

4.11.3 Thermal shock

When glass bulb sprinklers are tested in accordance with Annex J, the glass bulbs shall either:

- break correctly on cooling such that the waterway is cleared; or
- remain intact. After immersion when subjected to a function test in accordance with E.2, the sprinkler shall operate in such way that the waterway is cleared; any lodgements shall be disregarded.

4.12 Corrosion

4.12.1 Stress corrosion

After being subjected for 10 days to a moist ammonia exposure as described in K.1 a residential sprinkler having copper alloy parts shall:

- a) show no evidence of cracking, delamination, or degradation; and
- b) perform as intended when tested as described in K.1.

If the application of a 12 bar water pressure to the inlet of the sprinkler increases the assembly load by more than 10 %, the additional load is to be applied during the moist ammonia-air mixture exposure specified in K.1.

4.12.2 Sulphur dioxide corrosion

Residential sprinklers shall be subjected to a sulphur dioxide corrosion test in accordance with K.2. After exposure, when subjected to a function test in accordance with E.2 the sprinkler shall operate such that the waterway is cleared; any lodgements shall be disregarded.

4.12.3 Salt mist corrosion

Residential sprinklers shall be subjected to a salt mist corrosion test in accordance with K.3. After exposure, when subjected to a function test in accordance with E.2, the sprinkler shall operate such that the waterway is cleared; any lodgements shall be disregarded.

4.12.4 Moist air

Residential sprinklers shall withstand an exposure to moist air atmospheres when tested in accordance with K.4.

4.13 Water hammer

Sprinklers shall not leak when subjected to pressure surges in accordance with Annex L. After the test, when subjected to a function test in accordance with E.2, the sprinkler shall operate such that the waterway is cleared; any lodgements shall be disregarded.

4.14 Thermal response

4.14.1 Oven test

When tested in accordance with M.1, upright, pendent and horizontal sprinklers, other than flush, recessed and concealed sprinklers, shall release within a maximum time which is to be calculated from the formula in M.1, based on a response time index (RTI) 50.

4.14.2 Room response test

When tested in accordance with M.2, flush, recessed and concealed sprinklers shall release within 75 s.

4.15 Resistance to vibration

A residential sprinkler shall withstand the effects of vibration without deterioration of its performance characteristics when tested in accordance with Annex N.

4.16 Resistance to impact

A residential sprinkler, except for dry-type sprinklers, shall be tested as described in Annex O and shall not be damaged or leak.

4.17 Resistance to low temperature

The sprinkler shall not operate before the function test, when tested in accordance with Annex P. After the low temperature exposure it shall show no visible evidence of damage. Following examination, when subjected to a function test in accordance with E.2, the sprinkler shall operate such that the waterway is cleared; any lodgements shall be disregarded.

4.18 Resistance to heat

When tested in accordance with Annex Q, the sprinkler body, deflector and its supporting parts shall show no significant deformation or breakage.

4.19 Test conditions

For sprinkler testing conditions, see Annex A.

5 Marking

5.1 General

Sprinklers shall be marked with the name or trade mark of the supplier.

An identification number as defined in 5.2 is considered to satisfy this requirement.

5.2 Identification number

A four- to six-character identification number, with no intervening spaces, should be used to identify the supplier and sprinkler operating characteristics. The number, if used, shall be cast or die-stamped on the sprinkler deflector or on a visible non-operating part, which is not used to install the sprinkler. The identification number is permitted to be located behind the cover plate which is removable with common tools, provided the number will be visible after the sprinkler is installed and the cover plate is removed.

The identification number, if used, shall consist of one or two characters which identify the supplier, followed by three or four digits to identify a unique sprinkler identification for orifice size or shape, deflector characteristic, pressure rating and thermal sensitivity classification.

5.3 Nominal operating temperature and year of manufacture

A residential sprinkler shall be permanently marked on a visible non-operating part with the temperature rating and year of manufacture.

Exception: The nominal operating temperature may be marked on a visible operating part instead of being marked on a visible non-operating part.

A sprinkler produced in the last 3 months of a calendar year may be marked with the following year as the date of manufacture, and one produced in the first 6 months of a calendar year may be marked with the preceding year as the date of manufacture.

The frame arms of residential sprinklers of the various nominal operating temperatures shall be coloured in accordance with the colour code designated in Table 1.

Exception No. 1: Frame arm colour identification is not required for painted sprinklers, flush sprinklers, or similar decorative types.

Exception No. 2: Frame arm colour identification is not required for sprinklers having frangible bulb heat responsive elements colour coded in accordance with Table 1.

5.4 Manufacturing location

If a supplier produces sprinklers at more than one factory, each sprinkler shall have a distinctive marking to identify it as the product of a particular factory.

5.5 Heat sensitive element supplier

When sprinklers are made with more than one supplier of the heat sensitive element, i.e. the glass bulb or the fusible link, each sprinkler shall have a distinctive marking to identify the heat sensitive element supplier.

5.6 Protective covers

Protective covers, if used, shall be marked to indicate that the cover shall be removed before the sprinkler system is placed in service. The marking shall be placed on the protective cover so that it is visible after sprinkler installation.

5.7 Sidewall sprinklers

5.7.1 General

The deflector of a sidewall sprinkler shall clearly show its intended orientation with regard to the direction of flow. If an arrow is employed, it shall indicate the direction of flow and be accompanied by the word "FLOW."

5.7.2 Horizontal sidewall sprinklers

A residential sprinkler intended for horizontal sidewall installation shall be marked with the word "TOP."

5.8 Concealed sprinklers

The cover plate for a concealed sprinkler shall be marked with the words: "Do not paint" on the exterior surface.

Any housing intended for installation with concealed sprinkler assemblies and not attached by the supplier shall be marked as follows: "FOR USE WITH [SPRINKLER IDENTIFICATION description]."

5.9 Removable recessed housing

An escutcheon intended for installation with recessed and concealed type sprinkler assemblies and not attached by the supplier shall be marked as follows: "FOR USE WITH [SPRINKLER IDENTIFICATION NUMBER(S) AND SPRINKLER TEMPERATURE RATING(S)]."

6 Instruction charts

6.1 General

An instruction chart, giving the recommended method of installation and instructions on care and replacement, shall be available with each type of sprinkler.

6.2 Installation Instructions

Each package of residential sprinklers shall be provided with installation instructions that shall include the following:

- a) coverage area dimensions;
- b) minimum water flow rate in accordance with Table 2;
- c) K-factor;
- d) minimum distance between sprinklers;
- e) installation position;
- f) distance of sprinkler deflector from ceiling and / or wall;
- g) minimum operating pressure;
- h) distance between the sprinkler and obstructions;
- i) indication as to whether a recessed or concealed sprinkler is vented or unvented;
- j) indication whether concealed sprinklers are allowed to be installed in concrete or other solid materials;
- k) a reference to EN 16925 for design and installation; and
- l) a statement that the minimum flow for each sprinkler shall be such that both the associated length and width spacings given in the supplier's table shall be equal to or greater than the sprinkler's length and width spacings in the actual installation.

If the installation instructions do not only refer to EN 16925, it shall be clearly indicated which clauses, parts and values relate to EN 16925.

Guidance for locating sprinklers away from obstructions shall be provided.

For dry-type sprinklers intended to be installed in dry systems, information shall be provided on the appropriate sprinkler-fitting compatibility, to minimize the potential to accumulate water, scale, and sediment of the sprinkler inlet and provide for an unobstructed flow path upon operation.

The minimum water flow rates shall not be less than those given in Table 2 for typical spacings. The minimum flow rate for a sprinkler shall be the same for single and multiple operating sprinklers.

Table 2 — Minimum sprinkler flow rates for typical spacings

Upright, pendant, recessed pendant, flush, and concealed sprinklers		Sidewall sprinklers	
Typical spacing m	Minimum flow l/min	Typical spacing m	Minimum flow l/min
3,7 × 3,7	28	3,7 × 3,7	28
4,3 × 4,3	38	4,3 × 4,3	38
4,9 × 4,9	49	4,9 × 4,9	49
5,5 × 5,5	62	5,5 × 5,5	62
6,1 × 6,1	76	6,1 × 6,1	76
		4,9 × 5,5	55
		4,9 × 6,1	61
		5,5 × 6,1	69
[A1] <i>deleted text</i> [A1] The maximum spacing shall not be more than 37,2 m ² . If another spacing as stated above is used, the minimum flow shall not be less than that required to provide a minimum design discharge density of 2,1 mm/min.			

Annex A (normative)

Conditions for tests

See 4.19 for the corresponding requirement.

Except where specified otherwise, carry out tests at (20 ± 10) °C. Examine sprinklers for visually obvious defects before testing.