

Building acoustics — Estimation of acoustic performance of buildings from the performance of elements —

Part 2: Impact sound insulation between rooms

The European Standard EN 12354-2:2000 has the status of a
British Standard

ICS 91.120.20

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

National foreword

This British Standard is the official English language version of EN 12354-2:2000.

The UK participation in its preparation was entrusted by Technical Committee B/209, General building codes, to Subcommittee B/209/18, Sound insulation, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled “International Standards Correspondence Index”, or by using the “Find” facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 33 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

This British Standard, having been prepared under the direction of the Sector Committee for Building and Civil Engineering was published under the authority of the Standards Committee and comes into effect on 15 July 2000

© BSI 07-2000

ISBN 0 580 35181 5

Amendments issued since publication

Amd. No.	Date	Comments

English version

**Building acoustics – Estimation of acoustic performance of
buildings from the performance of elements – Part 2: Impact
sound insulation between rooms**

Acoustique du bâtiment – Calcul de la performance
acoustique des bâtiments à partir de la performance des
éléments – Partie 2: Isolement acoustique au bruit de choc
entre des locaux

Bauakustik – Berechnung der akustischen Eigenschaften
von Gebäuden aus den Bauteileigenschaften – Teil 2:
Trittschalldämmung zwischen Räumen

This European Standard was approved by CEN on 20 August 1999.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Central Secretariat: rue de Stassart, 36 B-1050 Brussels

Contents

Foreword	3
1 Scope	4
2 Normative references	4
3 Relevant quantities	5
3.1 Quantities to express building performance	5
3.2 Quantities to express element performance	6
3.3 Other terms and quantities	8
4 Calculation models	8
4.1 General principles	8
4.2 Detailed model	10
4.2.1 Input data	10
4.2.2 Transfer of input data to in-situ values	10
4.2.3 Determination of direct and flanking transmission	13
4.2.4 Interpretation for several types of elements	13
4.2.5 Limitations	13
4.3 Simplified model	13
4.3.1 Calculation procedure	13
4.3.2 Input data	14
4.3.3 Limitations	15
5 Accuracy	15
Annex A (normative) Symbols	16
Annex B (informative) Homogeneous floor constructions	19
Annex C (informative) Floating floors	23
Annex D (informative) Laboratory measurement of flanking transmission	26
Annex E (informative) Calculation examples	28
Bibliography	33

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 126, Acoustic properties of building products and of buildings, the Secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2000, and conflicting national standards shall be withdrawn at the latest by September 2000.

It is the first version of a series of standards, specifying calculation models in building acoustics. Although the standard covers the main types of building construction it cannot as yet cover all variations in the construction of buildings. It sets out an approach for gaining experience for future improvements and developments.

During the preparation of this standard and the related EN 12354-1:2000, it became clear that some of the element data necessary based on standardized measurement methods are not yet available, hence some informative annexes have been added to explain what is needed, to indicate possible measurement methods and to illustrate this with some indicative acoustical data. These annexes should form the basis for new or revised standards for building elements, which would replace these annexes. This standard includes six annexes. Annex A is normative and annexes B to F are informative.

The accuracy of this standard can only be specified in detail after widespread comparisons with field data, which can only be gathered over a period of time after establishing the prediction model. To help the user in the mean time, indications of the accuracy have been given, based on earlier comparisons with comparable prediction models. It is the responsibility of the user (i.e. a person, an organization, the authorities) to address the consequences of the accuracy, inherent for all measurement and prediction methods, by specifying requirements for the input data and/or applying a safety margin to the results or applying some other correction.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard specifies calculation models designed to estimate the impact sound insulation between rooms in buildings, primarily on the bases of measured data which characterizes direct or indirect flanking transmission by the participating building elements and theoretically derived methods of sound propagation in structural elements.

A detailed model is described for calculation in frequency bands; the single number rating of buildings can be determined from the calculation results. A simplified model with a restricted field of application is deduced from this, calculating directly the single number rating, using the single number ratings of the elements.

This European Standard describes the principles of the calculation scheme, lists the relevant quantities and defines its applications and restrictions. It is intended for acoustical experts and provides the framework for the development of application documents and tools for other users in the field of building construction, taking into account local circumstances.

The calculation models described use the most general approach for engineering purposes, with a clear link to measurable quantities that specify the performance of building elements. The known limitations of these calculation models are described in this standard. Users should, however, be aware that other calculation models also exist, each with their own applicability and restrictions.

The models are based on experience with prediction for dwellings; they could also be used for other types of buildings, provided the construction systems and dimensions of elements are not too different from those in dwellings.

2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

EN ISO 140-1, *Acoustics – Measurement of sound insulation in buildings and of building elements – Part 1: Requirements for laboratory test facilities with suppressed flanking transmission* (ISO 140-1:1997).

EN ISO 140-3, *Acoustics – Measurement of sound insulation in buildings and of building elements – Part 3: Laboratory measurements of airborne sound insulation of building elements* (ISO 140-3:1995).

EN ISO 140-6, *Acoustics – Measurement of sound insulation in buildings and of building elements – Part 6: Laboratory measurements of impact sound insulation of floors* (ISO 140-6:1998).

EN ISO 140-7, *Acoustics – Measurement of sound insulation in buildings and of building elements – Part 7: Field measurements of impact sound insulation of floors* (ISO 140-7:1998).

EN ISO 140-8, *Acoustics – Measurement of sound insulation in buildings and of building elements – Part 8: Laboratory measurements of the reduction of transmitted impact noise by floor coverings on a heavyweight standard floor* (ISO 140-8:1997).

EN ISO 140-12, *Acoustics – Measurement of sound insulation in buildings and of building elements – Part 12: Laboratory measurement of room-to-room airborne and impact sound insulation of an access floor* (ISO 140-12:2000).

EN ISO 717-1, *Acoustics – Rating of sound insulation in buildings and of building elements – Part 1: Airborne sound insulation* (ISO 717-1:1996).

EN ISO 717-2:1996, *Acoustics – Rating of sound insulation in buildings and of building elements – Part 2: Impact sound insulation* (ISO 717-2:1996).

EN 12354-1:2000, *Building acoustics – Estimation of acoustic performance of buildings from the performance of elements – Part 1: Airborne sound insulation between rooms*.

prEN ISO 10848-1, *Acoustics – Laboratory measurement of flanking transmission of airborne and impact sound between adjoining rooms – Part 1: Frame document (ISO/DIS 10848-1:1999)*.

3 Relevant quantities

3.1 Quantities to express building performance

The impact sound insulation between rooms in accordance with EN ISO 140-7 can be expressed in two related quantities. These quantities are determined in frequency bands (one-third octave bands or octave bands) from which the single number rating for the building performance can be obtained in accordance with EN ISO 717-2:1996, for instance $L'_{n,w}$, $L'_{nT,w}$ or $(L'_{nT,w} + C_1)$.

3.1.1 Normalized impact sound pressure level L'_n : The impact sound pressure level corresponding to the reference equivalent absorption area in the receiving room:

$$L'_n = L_i + 10 \lg \frac{A}{A_0} \text{ dB} \quad (1)$$

where

L_i is the impact sound pressure level measured in the receiving room, in decibels;

A is the measured equivalent absorption area of the receiving room, in square metres;

A_0 is the reference equivalent absorption area; for dwellings $A_0 = 10 \text{ m}^2$.

This quantity is to be determined in accordance with EN ISO 140-7.

3.1.2 Standardized impact sound pressure level L'_{nT} : The impact sound pressure level corresponding to a reference value of the reverberation time in the receiving room:

$$L'_{nT} = L_i - 10 \lg \frac{T}{T_0} \text{ dB} \quad (2)$$

where

T is the reverberation time in the receiving room, in seconds;

T_0 is the reference reverberation time (for dwellings: $T_0 = 0,5 \text{ s}$).

This quantity is to be determined in accordance with EN ISO 140-7.

3.1.1.1 Relation between quantities

The relation between the quantities L'_{nT} and L'_n is given by:

$$L'_{nT} = L'_n - 10 \lg \frac{0,16V}{A_0 T_0} = L'_n - 10 \lg 0,032V \text{ dB} \quad (3)$$

where

V is the volume of the receiving room, in cubic metres.

It is sufficient to estimate one of these quantities to deduce the other one. In this document the normalized impact sound pressure level L'_n is chosen as the prime quantity to be estimated.

3.2 Quantities to express element performance

The quantities expressing the element performance are used as part of the input data to estimate building performance. These quantities are determined in one-third octave bands and can also be expressed in octave bands. In relevant cases a single number rating for the element performance can be obtained from this, in accordance with EN ISO 717-2:1996, for instance $L_{nw}(C_i)$, $\Delta L_w(C_{i\Delta})$ or ΔL_{in} and $R_w(C; C_{tr})$.

3.2.1 Normalized impact sound pressure level L_n : The impact sound pressure level corresponding to the reference equivalent sound absorption area in the receiving room:

$$L_n = L_i + 10 \lg \frac{A}{A_0} \text{ dB} \quad (4)$$

where

L_i is the impact sound pressure level measured in the receiving room by using the standard tapping machine in accordance with EN ISO 140-7, in decibels;

A is the measured equivalent absorption area of the receiving room, in square metres;

A_0 is the reference equivalent absorption area with $A_0 = 10 \text{ m}^2$.

This quantity is to be determined in accordance with EN ISO 140-6.

3.2.2 Reduction of impact sound pressure level ΔL (improvement of impact sound insulation): The reduction in normalized impact sound pressure level resulting from installation of the test floor covering:

$$\Delta L = L_{n0} - L_n \text{ dB} \quad (5)$$

where

L_{n0} is the normalized impact sound pressure level in the absence of floor covering, in decibels;

L_n is the normalized impact sound pressure level when the floor covering is in place, in decibels.

This quantity is to be determined in accordance with EN ISO 140-8.

3.2.3 Reduction of impact sound pressure level ΔL_d : The reduction of impact sound pressure level by an additional layer on the receiving side of the separating element (floor). This quantity has to be determined in accordance with EN ISO 140-8.

3.2.4 Normalized flanking impact sound pressure level $L_{n,f}$: The space and time average sound pressure level in the receiving room produced by a standardized tapping machine operating at different positions on the element in the source room, normalized to the reference equivalent sound absorption area (A_0) in the receiving room; $A_0 = 10 \text{ m}^2$. Transmission is only considered to occur through a specified flanking element, e.g. access floor:

$$L_{n,f} = L_i + 10 \lg \frac{A}{A_0} \text{ dB} \quad (6)$$

This quantity is to be determined in accordance with prEN ISO 10848-1.

NOTE For access floors see EN ISO 140-12.

3.2.5 Airborne sound reduction index R : Ten times the common logarithm of the ratio of the sound power W_1 incident on a test specimen to the sound power W_2 transmitted through the specimen:

$$R = 10 \lg \frac{W_1}{W_2} \text{ dB} \quad (7)$$

This quantity is to be determined in accordance with EN ISO 140-3.

3.2.6 Sound reduction improvement index ΔR : The difference in sound reduction index between a basic structural element with an additional layer (e.g. a suspended ceiling) and the basic structural element without this layer for direct transmission.

Annex D of EN 12354-1:2000 gives information on the determination and the use of this quantity.

3.2.7 Vibration reduction index K_{ij} : This quantity is related to the vibrational power transmission over a junction between structural elements, normalized in order to make it an invariant quantity. It is determined by normalizing the direction-averaged velocity level difference over the junction, to the junction length and the equivalent absorption length, if relevant, of both elements in accordance with the following equation:

$$K_{ij} = \frac{D_{v,ij} + D_{v,ji}}{2} + 10 \lg \frac{l_{ij}}{\sqrt{a_i a_j}} \text{ dB} \quad (8)$$

where

$D_{v,ij}$ is the junction velocity level difference between elements i and j , when element i is excited, in decibels;

$D_{v,ji}$ is the junction velocity level difference between elements j and i , when element j is excited, in decibels;

l_{ij} is the common length of the junction between element i and j , in metres;

a_i is the equivalent absorption length of element i , in metres;

a_j is the equivalent absorption length of element j , in metres.

The equivalent absorption length is given by:

$$a = \frac{2,2\pi^2 S}{c_0 T_s} \sqrt{\frac{f_{\text{ref}}}{f}} \quad (9)$$

where

T_s is the structural reverberation time of the element i or j , in seconds;

S is the area of element i or j , in square metres;

f is the centre band frequency, in Hertz;

f_{ref} is the reference frequency; $f_{\text{ref}} = 1\,000$ Hz;

c_0 is the speed of sound in air, in metres per second.

NOTE 1 The equivalent absorption length is the length of a fictional totally absorbing edge of an element if its critical frequency is assumed to be 1 000 Hz, giving the same loss as the total losses of the element in a given situation.

The quantity K_{ij} is to be determined in accordance with prEN ISO 10848-1.

NOTE 2 For the time being values for this quantity can be taken from annex E of EN 12354-1:2000 or be deduced from available data on the junction velocity level difference according to that annex.

3.2.8 Other element data

For the calculation additional information on the elements can be necessary, e.g.:

- mass per unit area, m' , in kilograms per square metre;
- type of element;
- material;
- type of junction.

3.3 Other terms and quantities

Direct transmission: Transmission due to impact excitation and sound radiation from a separating element.

Indirect structure-borne transmission (flanking transmission): Transmission of sound energy from an excited element in the source room to a receiving room via structural (vibrational) paths in the building construction, e.g. walls, floors, ceilings.

Direction-averaged junction velocity level difference $\overline{D}_{v,ij}$: The average of the junction level difference from element i to j and from element j to i:

$$\overline{D}_{v,ij} = \frac{D_{v,ij} + D_{v,ji}}{2} \quad (10)$$

Flanking normalized impact sound pressure level $L_{n,ij}$: Average sound pressure level in the receiving room due to impact excitation of element i (floor) in the source room and sound radiation only by element j in the receiving room, normalized to the reference equivalent absorption area of $A_0 = 10 \text{ m}^2$.

Further symbols used in this standard appear in annex A.

4 Calculation models

4.1 General principles

The sound power radiated into the receiving room is due to sound radiated by each structural element in that room. The sound radiated by each of the structural elements is caused by sound transmitted to that element due to impact on a structural element in the source room. It is assumed that the transmission via each of these paths can be considered to be independent and that the sound and vibrational fields behave statistically, so that the impact sound pressure level L'_n can be obtained by addition of the energy transmitted via each path. The transmission paths considered are defined in Figure 1, where d indicates the direct impact sound transmission and f flanking impact sound transmission.

For rooms above each other the total impact sound pressure level L'_n in the receiving room is determined by:

$$L'_n = 10 \lg \left(10^{L_{n,d}/10} + \sum_{j=1}^n 10^{L_{n,ij}/10} \right) \text{ dB} \quad (11)$$

where

$L_{n,d}$ is the normalized impact sound pressure level due to direct transmission, in decibels;

$L_{n,ij}$ is the normalized impact sound pressure level due to flanking transmission, in decibels;

n is the number of elements.




Figure 1 — Definition of sound transmission paths between two rooms, above each other and next to each other respectively

For rooms next to each other the total impact sound pressure level L'_n in the receiving room is determined by:

$$L'_n = 10 \lg \sum_{j=1}^n 10^{L_{n,ij}/10} \text{ dB} \quad (12)$$

NOTE 1 For common situations the number of flanking elements to consider is $n = 4$ for rooms above each other and $n = 2$ for rooms next to each other.

The detailed model calculates the building performance in frequency bands, based on acoustic data for the building elements in frequency bands (one-third octave bands or octave bands). As a minimum the calculation has to be performed for octave bands from 125 Hz to 2 000 Hz or for one-third octave bands from 100 Hz to 3 150 Hz. From this the single number rating for the building performance can be obtained in accordance with EN ISO 717-2:1996.

NOTE 2 The calculations can be extended to higher or lower frequencies if element data are available for these frequencies. However, no information is available at this time on the accuracy of calculations for the extended lower frequency regions.

The detailed model is described in 4.2.

The simplified model calculates the building performance directly as a single number rating, based on the single number ratings of the performance of the elements involved.

The simplified model is described in 4.3.