

Trenchless construction and testing of drains and sewers

The European Standard EN 12889:2000 has the status of a
British Standard

ICS 93.030;

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW



Document Sharing Hub

National foreword

This British Standard is the official English language version of EN 12889:2000.

The UK participation in its preparation was entrusted by Technical Committee B/505, Wastewater engineering, to Subcommittee B/504/505/1, Structural design of buried pipelines, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled “International Standards Correspondence Index”, or by using the “Find” facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 22, an inside back cover and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

This British Standard, having been prepared under the direction of the Sector Committee for Building and Civil Engineering, was published under the authority of the Standards Committee and comes into effect on 15 June 2000

© BSI 06-2000

ISBN 0 580 36023 7

Amendments issued since publication

Amd. No.	Date	Comments

English version

Trenchless construction and testing of drains and sewers

Mise en oeuvre sans tranchée et essai des branchements
et collecteurs d'assainissement

Grabenlose Verlegung und Prüfung von Abwasserleitungen
und -kanälen

This European Standard was approved by CEN on 15 November 1999.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Central Secretariat: rue de Stassart, 36 B-1050 Brussels

Contents

	Page
Foreword	3
1 Scope	4
2 Normative references	4
3 Definitions	4
4 General	5
5 Construction components and materials	5
5.1 General	5
5.2 Pipes and joints	5
5.3 Manholes and inspection chambers	6
5.4 Delivery, handling and transportation on site	6
5.5 Storage	6
6 Techniques	6
6.1 Unmanned techniques	8
6.2 Manned techniques	15
7 Requirements	15
7.1 Safeguarding design assumptions	15
7.2 Special requirements	15
7.3 Safeguarding design assumptions	15
7.4 Information about ground conditions	16
7.5 Data collection during installation	16
7.6 Stability during construction	17
7.7 Overcut	17
7.8 Overbreak	17
7.9 Settlement and heave	17
7.10 Deviation in line and level	17
8 Inspection and/or testing of pipelines after installation	17
8.1 Visual inspection	18
8.2 Leaktightness	18
9 Procedures and requirements for testing gravity pipelines	18
9.1 General	18
9.2 Testing with air (method "L")	18
9.3 Testing with water (method "W")	21
9.4 Testing of each individual joint	21
10 Testing of pressure pipelines	21
11 Qualification	21
Annex A (informative) Abstract from Council Directive of 17 September 1990 on the procurement procedures of entities operating in the water, energy, transport and telecommunication sectors	22

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 165, Waste water engineering, the Secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2000, and conflicting national standards shall be withdrawn at the latest by July 2000.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following This European Standard has countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

Annex A is informative.

1 Scope

This European Standard is applicable to the trenchless construction and testing of new drains and new sewers in the ground, which are normally operating as gravity pipelines, formed using prefabricated pipes and their joints. The trenchless construction and testing of drains and sewers operating under pressure is also covered by this European Standard together with prEN 805:1999 as appropriate.

This European Standard also applies to trenchless replacement techniques. Renovation techniques for existing sewers and drains are not covered by this European Standard.

Methods of trenchless construction include

- manned and unmanned techniques;
- steerable and non-steerable techniques.

NOTE 1: Mining or tunnelling (e.g. in situ construction or the use of prefabricated segments) are not covered by this European Standard although some parts may apply to these methods. Additional requirements apply for mining and tunnelling methods for the construction of drains and sewers.

Additionally other local or national regulations should be taken into account, e.g. concerning health and safety, pavement installation, tolerances for deviation in line and level and requirements for leaktightness testing.

NOTE 2: Requirements for associated pipeline installation work other than trenchless construction, e.g. for manholes and inspection chambers, are given in EN 1610, Construction and testing of drains and sewers.

2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

EN 752-5:1997
Drain and sewer systems outside buildings – Part 5: Rehabilitation

prEN 805:1999
Water supply – Requirements for systems and components outside buildings

3 Definitions

For the purposes of this European Standard the following definitions apply.

3.1 cutting head a tool or system of tools on a common support, which excavates at the face of a bore. The term usually applies to mechanical methods of excavation

3.2 expander a tool which enlarges a bore by displacement of the surrounding ground rather than by excavation

3.3 gravity pipeline pipeline where flow is caused by the force of gravity and where the pipeline is designed normally to operate partially full

3.4 overbreak the extent by which the excavated void including accidental ground losses initially exceeds the outside dimension of the pipe

3.5 overcut the annular space around the pipe deliberately created by using a cutting head or shield of greater dimension than the outside dimension of the pipe

3.6 pipe jacking a system of directly installing pipes behind a cutting head and/or shield, by hydraulic jacking from a drive shaft, such that the pipes form a string in the ground

3.7 reamer a cutting head attached to the end of a drill string or pilot rod to enlarge the pilot diameter during a pull-back or pushing operation, to enable a pipe or pipes to be installed

3.8 renovation work incorporating all or part of the original fabric of the pipeline by means of which its current performance is improved (EN 752-5:1997)

3.9 replacement construction of a new drain or sewer, on or off the line of an existing drain or sewer, the function of the new drain or sewer incorporating that of the old (EN 752-5:1997)

3.10 spoil material excavated and removed in the course of installation

3.11 trenchless construction technique any technique for constructing pipelines in the ground without opening trenches

3.12 manned technique technique involving the use of personnel working in the excavated bore during installation

3.13 unmanned technique technique avoiding the use of personnel working in the excavated bore during installation.

4 General

Pipelines, manholes and inspection chambers are essentially engineering structures in which the combined performance of construction components, bedding, and fill or the surrounding ground constitute the basis for stability and safety in operation. The pipes, fittings and components for jointing supplied, together with the work carried out at site, are all important factors in achieving a structure with adequate performance.

5 Construction components and materials

5.1 General

Construction components and materials shall conform to national standards, transposing European Standards as available, or to European technical approvals, or, in the absence of these, the components and materials shall comply with the requirements of the specifier.

Any supplementary instructions of the manufacturer shall be observed.

5.2 Pipes and joints

Installation shall not commence before the following criteria have been agreed between the specifier and installer. These may be obtained from appropriate product standards or from the pipe manufacturer:

- internal pipe diameter;
- external pipe diameter;
- pipe length;
- tolerances on dimensions;
- safe jacking load or pulling force;
- type and performance of joints;
- longitudinal flexibility (acceptable bending radius or angular deflection).

5.3 Manholes and inspection chambers

Manholes and inspection chambers shall be in accordance with product standards or appropriate specifications.

5.4 Delivery, handling and transportation on site

Pipes, pipeline components and jointing accessories shall be inspected on delivery to ensure that they are appropriately marked and comply with the design requirements.

Any instructions from the manufacturer shall be adhered to.

Products shall be examined both on delivery and immediately prior to installation to ensure that they are free from damage.

5.5 Storage

Any instructions from the manufacturer and the requirements of the appropriate product standards shall be adhered to.

All materials should be stored in such a manner to keep them clean and to avoid contamination or degradation, for example elastomeric jointing components should be kept clean and be protected from sources of ozone (e.g. electrical equipment), sunlight and oil, where necessary.

Pipes shall be secured to prevent rolling. Excessive stacking heights should be avoided so that pipes in the lower part of the stacks are not overloaded. Stacks of pipes shall not be placed close to open trenches.

Pipes with protective coatings shall be stored where necessary, on supports which keep them clear of the ground to avoid damage to coatings and joints. All pipes should be stored on supports in very cold weather to avoid freezing to the ground.

6 Techniques

A schematic classification of trenchless techniques is given in Figure 1, representing techniques available at the time of publication of this European Standard.