

Ventilation for buildings — Terminals — Performance testing of louvres subjected to simulated rain

The European Standard EN 13030:2001 has the status of a
British Standard

ICS 91.140.30

National foreword

This British Standard is the official English language version of EN 13030:2001.

The UK participation in its preparation was entrusted to Technical Committee RHE/2, Air distribution and air diffusion, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled “International Standards Correspondence Index”, or by using the “Find” facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

This British Standard, having been prepared under the direction of the Engineering Sector Policy and Strategy Committee, was published under the authority of the Standards Policy and Strategy Committee on 30 November 2001

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 31 and a back cover.

The BSI copyright date displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

© BSI 30 November 2001

ISBN 0 580 38739 9

English version

Ventilation for buildings - Terminals - Performance testing of louvres subjected to simulated rain

Ventilation des bâtiments - Bouches d'air - Essai de
performance des grilles d'air extérieur soumises à une pluie
simulée

Lüftung von Gebäuden - Endgeräte - Leistungsprüfung von
Wetterschutzblenden bei Beanspruchung durch Beregnung

This European Standard was approved by CEN on 18 August 2001.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Foreword	3
1 Scope.....	4
2 Normative references.....	4
3 Terms and definitions	5
4 Symbols and subscripts.....	6
4.1 Symbols	6
4.2 Subscripts.....	6
5 Instrumentation	7
5.1 Air flow rate measurement	7
5.2 Wind Velocity Measurement	7
5.3 Pressure Measurement.....	7
5.4 Temperature measurement	8
5.5 Water flow meters	8
5.6 Timers.....	8
5.7 Rain gauge	8
6 Test apparatus.....	8
6.1 General.....	8
6.2 Wind simulation equipment	8
6.3 Weather section.....	9
6.4 Rain simulation equipment	9
6.5 Collection duct	9
6.6 Water collection.....	9
6.7 Aerodynamic measurement section	9
6.8 Mechanical ventilation section	10
6.9 Test specimen and calibration plate	10
7 Test methods	10
7.1 Water penetration test	10
7.2 Discharge and entry loss coefficient/pressure loss.....	13
8 Classification of weather louvres	14
8.1 General	14
8.2 Penetration classification.....	14
8.3 Discharge and Entry loss coefficient.....	15
8.4 Classification nomenclature	15
Annex A (normative) Simulated rain spray nozzles.....	16
Annex B (normative) Water eliminator performance test.....	17
B.1 General.....	17
B.2 Installation	17
B.3 Procedure.....	17
Annex C (normative) Diagrams of apparatus and typical graphs	18
Annex D (informative) Typical calculation examples.....	25
D.1 Test results	25
D.2 Entry loss coefficient of entry.....	27
D.3 Louvre effectiveness.....	31
D.4 Classification	31

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 156 "Ventilation for buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2002, and conflicting national standards shall be withdrawn at the latest by April 2002.

The annexes A, B and C are normative. Annex D is informative.

Warning

Attention is drawn to the possible risks associated with legionella, if recirculated water is used or biofilms are allowed to develop within the facility during weather louvre testing, in order that appropriate precautions are taken to safeguard the health of those involved.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard specifies a method for measuring the water rejection performance of louvres subject to simulated rain and wind pressures, both with and without air flow through the louvre under test. For the purpose of tests in this standard, a 1000 mm × 1000 mm section of weather louvre or the nearest possible blade increment is considered.

Weather louvres are designed to restrict the passage of water during rainfall while allowing the passage of air into or from an air distribution system or part of a building. They are used in a wide range of applications, where there may be differences in wind speed and direction, levels of local turbulence, rate and droplet size, distribution of rainfall and surface water flow from the surrounding structure. It is impractical to consider a standard test procedure simulating the whole range of likely conditions, but this standard provides for heavy rainfall directed on to the louvre surface, with simulated wind pressures. This provides a common basis on which to compare the water rejection performance of weather louvres of different designs. This standard is not intended for the evaluation of weather performance of pressure relief dampers.

The purpose of tests incorporated in this European Standard is as follows:

a) Weather tests

To establish the weather louvre effectiveness when subjected to wind pressure at various air flow rates.

b) Discharge and Entry loss coefficient/Pressure requirements

To establish the air pressure loss through the weather louvre at various air flow rates and by calculation the Discharge and Entry Loss Coefficient.

2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references the subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

EN 24185, *Measurement of liquid flow in closed conduits — Weighing method (ISO 4185:1980)*

CR 12792, *Ventilation for buildings — Symbols and Terminology*

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices — Part 1 orifice plates, nozzles and venturi tubes inserted into circular section conduits running full (ISO 5167-1:1991)*

ISO 5221, *Air distribution and air diffusion — Rules to methods of measuring air flow rate in an air handling duct*

ISO 5801, *Industrial fans — Performance testing using standardized airways*

3 Terms and definitions

For the purposes of this European Standard the terms and definitions given in CR 12792, together with the following, apply.

3.1

weather louvre

device intended to allow the passage of supply or exhaust air while minimising the ingress of rain; louvres can have either fixed or adjustable blades

3.2

insertion loss

difference in simulated rain penetration between the test specimen (weather louvre) and the calibration plate at the same test conditions

3.3

weather louvre core area

product of the minimum height H and minimum width W of the front opening in the weather louvre assembly with the louvre blades removed (see Figure C.5)

3.4

louvre calibration plate

plate having an opening of the same geometric shape and dimensions as the core area of the test specimen

3.5

discharge or entry loss coefficient of a louvre

actual air flow rate divided by the theoretical air flow rate at a given pressure difference across the louvre. For louvres tested with air flow in the reverse direction then the coefficient of discharge becomes the coefficient of entry

3.6

theoretical air flow

product of the louvre core area and the air velocity calculated using the pressure difference across the louvre as the velocity pressure, assuming C_D or $C_E = 1$

3.7

weather louvre effectiveness

quotient resulting from the value of the insertion loss of the louvre assembly at any air velocity divided by the amount of water penetration of the calibration plate at that velocity

4 Symbols and subscripts

4.1 Symbols

Symbol	Quantity	Unit
A	Louvre core area/area of the hole in calibration plate	m^2
C_D	Discharge Loss Coefficient	
C_E	Entry Loss Coefficient	
p_{sa}	Absolute static pressure	Pa
p_a	Atmospheric pressure	Pa
p_d	Dynamic (velocity) pressure $\frac{1}{2} \rho \cdot v^2$	Pa
p_{ta}	Stagnation or absolute total pressure	Pa
p_s	Static gauge pressure ($p_{sa} - p_a$)	Pa
p_t	Total pressure ($p_{ta} - p_a$)	Pa
Δp	Flow meter pressure difference	Pa
Δp_t	Conventional total pressure differential for an air density of $1,2 \text{ kg} \cdot \text{m}^{-3}$ at the inlet to the louvre or valve under test	Pa
q_v	Volume flow rate of air at the flow meter	$\text{m}^3 \text{ s}^{-1}$
q_s	Water supply rate to the nozzles	l h^{-1}
q_u	Water rejection rate collected upstream of the test louvre	l h^{-1}
q_d	Water penetration rate collected downstream of the test louvre	l h^{-1}
v_w	Wind velocity	m s^{-1}
v_c	Core velocity	m s^{-1}
ε	Effectiveness	%
ρ	Air density	kg m^{-3}
θ	Temperature	$^{\circ}\text{C}$

4.2 Subscripts

1	outlet of the weather louvre under test
m	measuring point at the air flow meter
n	value at selected point of air flow rate/static pressure curve
o	measured value with calibration plate
corr nom	(used to show correct values against references values)

5 Instrumentation

5.1 Air flow rate measurement

5.1.1 The air flow rate shall be measured using instruments and techniques in accordance with ISO 5221, EN ISO 5167-1 and ISO 5801.

5.1.2 Air flow meters shall have ranges and accuracies as specified in Table 1.

Table 1 — Range and accuracy of air flow meters

Range $\text{m}^3 \text{s}^{-1}$	Error limit %
0,07 to 7	$\pm 2,5$
0,007 to 0,07	$\pm 5,0$

NOTE Flow meters can be calibrated in situ by means of pitot static tube traverse techniques described in ISO 3966.

5.1.3 Flow meters shall be checked at intervals as appropriate but not exceeding 12 months. This check can take the form of one of the following:

- a dimensional check for all flow meters not requiring calibration;
- a check calibration over their full range using the original method employed for initial calibration or meters calibrated in situ;
- a check against a flow meter which meets the flow meter specification ISO 5221.

5.2 Wind Velocity Measurement

The wind velocity shall be measured using a pitot tube, vane anemometer or other similar style instrument for which the measuring error does not exceed 2,0 %

5.3 Pressure Measurement

5.3.1 Pressure in the duct shall be measured by means of a liquid-filled calibrated pressure gauge, or any other device conforming to 5.3.2.

5.3.2 The maximum scale interval shall not be greater than the values given in Table 2 for the appropriate range of pressure gauges.

Table 2 — Range and maximum scale interval for pressure measurement

Range Pa	Max. scale interval Pa
≤ 25	1,0
> 25 to ≤ 250	2,5
> 250 to ≤ 500	5,0
> 500	25,0

5.3.3 For air flow measurements, the minimum pressure differential shall be:

- a) 25 Pa with an inclined tube pressure gauge or micro-pressure gauge;
- b) 500 Pa with a vertical tube pressure gauge.

5.3.4 Calibration standards shall be as follows:

- a) for instruments with the range ≤ 25 Pa, a pressure gauge with an error limit of $\pm 0,5$ Pa;
- b) for instruments with the range $> 25 \leq 500$ Pa, a pressure gauge with an error limit of $\pm 2,5$ Pa (vertical pressure gauge).

5.4 Temperature measurement

Measurement of temperature shall be by means of mercury-in-glass thermometers, resistance thermometers, or thermo-couples. Instruments shall be graduated to give readings in intervals not greater than 0,5 K and calibrated up to the nearest 0,25 K.

5.5 Water flow meters

5.5.1 The measurement error of water flow meters shall not exceed 0,5 % of the indicated flow rate.

5.5.2 Water flow meters shall be calibrated against a known weight of water flowing for a measurement time period as specified in EN 24185.

5.6 Timers

The error limit for timers for determining water flow rates shall not exceed 0,2 s.

5.7 Rain gauge

The error limit for rain gauges shall not exceed 2 % of the indicated reading.

6 Test apparatus

6.1 General

A diagram of the test apparatus is shown in Figure C.1 and the requirements for the various elements described in 6.2 to 6.8.

6.2 Wind simulation equipment

An external fan shall be fitted to direct the air perpendicular to the weather louvre test plane, as illustrated in Figure C.2.

The air outlet of the fan and any silencing or straightening section shall not be less than 1 m diameter.

The fan shall be capable of producing an air velocity of $13 \text{ m}\cdot\text{s}^{-1}$ at a distance 1 m in front of the test plane of the weather louvre.

An air straightener section shall be assembled to the outlet of the fan to avoid swirling air currents.

A suitable air straightener is illustrated in Figure C.2. Other air straighteners (such as are described in ISO 5801 for fan tests) can also be used.

6.3 Weather section

The weather louvre or calibration plate to be tested shall be mounted and fixed in the centre of a 3 m × 3 m square wall at the rear of the weather section (see Figure C.2).

The weather louvre or the calibration plate as appropriate shall be tightly sealed to the wall, as recommended by the manufacturer.

The outside face of the weather louvre shall be facing the wind and rain simulation equipment.

6.4 Rain simulation equipment

The simulated rain shall be produced by at least 4 nozzles in an array close to the discharge of the wind effect fan to suit the spread of rain required. A suitable spray can be achieved by using the nozzles and control system as shown in Figures C.2 and C.4 and annex A.

The rain simulation equipment shall satisfy the following requirements with the calibration plate mounted in the test opening.

- a) The equipment shall be capable of producing a simulated rain penetration through the calibration plate of $75 \text{ l}\cdot\text{h}^{-1}$ (+ 10 % / 0 %) per square metre of opening;
- b) The simulated rainfall rate measured using the rain gauge in the positions shown in Figure C.5 shall not deviate from the mean value by more than 15 %;
- c) The water penetration through the calibration plate measured in the collection section shall be at least 80 % of the total water collected in both the weather section at the base, in front of the calibration plate, and the collection duct.

6.5 Collection duct

The collection duct (see Figure C.3) shall be sealed against the back of the weather section.

The collection duct shall have a water droplet elimination section at the downstream end to prevent carry over of airborne water droplets from the collection duct (see annex B).

The collection duct shall have an airtight connection to the air flow measuring plenum.

6.6 Water collection

6.6.1 Water collection at the collection duct

Water shall be collected at the drain from the collection duct in order to measure the penetration for the test period (see Figure C.3).

6.6.2 Water collection in front of the louvre

Water shall be collected in the weather section at the base in front of the weather louvre or calibration plate in order to measure the water rejection during the test period (see Figure C.2).

6.7 Aerodynamic measurement section

6.7.1 Air flow rate measurement

The air flow rate shall be measured using an inlet cone or similar device positioned at the end of the discharge end of the section (see Figure C.6). Uniform flow approaching the conical inlet shall be obtained by fitting resistance screens.