BS EN 2794-001:2023

BSI Standards Publication

Aerospace series — Circuit breakers, single-pole, temperature compensated, rated currents 20 A to 50 A

Part 001: Technical specification

Documents
Document Sharing Hub

Full document details: BS EN 2794-001:2023

National foreword

This British Standard is the UK implementation of EN 2794-001:2023. It supersedes BS EN 2794-001:2014, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee ACE/6, Aerospace avionic electrical and fibre optic technology.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 14672 1

ICS 49.060

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2023.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS EN 2794-001:2023

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN 2794-001

November 2023

ICS 49.060

Supersedes EN 2794-001:2014

English Version

Aerospace series - Circuit breakers, single-pole, temperature compensated, rated currents 20 A to 50 A - Part 001: Technical specification

Série aérospatiale - Disjoncteurs unipolaires compensés en température, intensités nominales 20 A à 50 A - Partie 001 : Spécification technique

Luft- und Raumfahrt - Schutzschalter, einpolig, temperaturkompensiert, Nennströme von 20 A bis 50 A - Teil 001: Technische Lieferbedingungen

This European Standard was approved by CEN on 23 July 2023.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2023 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. EN 2794-001:2023 E

Documents
Document Sharing Hub

Full document details: BS EN 2794-001:2023

Contents

Page

European foreword ... 3
1 Scope ... 4
2 Normative references ... 4
3 Terms and definitions ... 4
4 Description ... 4
5 Design ... 5
5.1 Materials ... 5
5.1.1 Metallic materials ... 5
5.1.2 Insulation materials ... 5
5.2 Design ... 5
5.2.1 Insulating box ... 5
5.2.2 Free release mechanism ... 5
5.2.3 Attachment ... 5
5.2.4 Electrical connection units ... 5
5.2.5 Control actuator ... 5
5.2.6 Rating inviolability ... 6
5.2.7 Leakage lines ... 6
5.2.8 Protection against non-release ... 6
6 Characteristics ... 6
6.1 General characteristics ... 6
6.2 Ratings ... 6
6.3 Nominal voltage of operational circuits ... 6
6.4 Dimensional characteristics ... 7
6.5 Recommended panel mounting dimensions ... 7
7 Tests ... 7
7.1 Mechanical tests ... 7
7.2 Environmental tests ... 7
7.3 Electrical tests ... 13
8 Qualification tests ... 15
8.1 Sampling ... 15
8.2 Material tests ... 19
8.3 Periodic checks for qualification maintenance ... 19
9 Quality assurance ... 19
10 Marking ... 19
11 Delivery conditions ... 19
12 Packaging ... 20
13 Storage ... 20
13.1 Definition ... 20
13.2 Storage conditions ... 20
13.3 Storage duration ... 20
Bibliography ... 21

Documents
Document Sharing Hub
Full document details: BS EN 2794-001:2023

European foreword

This document (EN 2794-001:2023) has been prepared by the Aerospace and Defence Industries Association of Europe — Standardization (ASD-STAN).

After enquiries and votes carried out in accordance with the rules of this Association, this document has received the approval of the National Associations and the Official Services of the member countries of ASD-STAN, prior to its presentation to CEN.

This document shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2024, and conflicting national standards shall be withdrawn at the latest by May 2024.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 2794-001:2014.

The main changes with respect to the previous edition are as follows:

— prEN 2794-001 (P2), 02/2012 — Editorial revision of this document: g_n replaced by g-PK for sinusoidal and low frequencies, g_n replaced by Grms for random.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this document: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Documents
Document Sharing Hub
Full document details: BS EN 2794-001:2023

1 Scope

This document specifies the single-pole temperature compensated circuit breakers rated from 20 A to 50 A and used in aircraft on-board circuits. It describes specific environmental, electrical and mechanical characteristics and the stringency of tests to be applied according to test methods of EN 3841-100.

These circuit breakers are intended for use in aircraft with electrical supplies in accordance with EN 2282 (all categories).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 2083, *Aerospace series — Copper or copper alloy conductors for electrical cables — Product standard*

EN 2282,[1] *Aerospace series — Characteristics of aircraft electrical supplies*

EN 2825, *Aerospace series — Burning behaviour of non-metallic materials under the influence of radiating heat and flames — Determination of smoke density*

EN 2826, *Aerospace series — Burning behaviour of non-metallic materials under the influence of radiating heat and flames — Determination of gas components in the smoke*

EN 3841-*, *Aerospace series — Circuit breakers — Test methods*

EN 3844-1, *Aerospace series — Flammability of non-metallic materials — Part 1: Small burner test, vertical — Determination of the vertical flame propagation*

TR 6083,[2] *Aerospace series — Cut-outs for installation of electrical components*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 3841-100 apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp/

— IEC Electropedia: available at https://www.electropedia.org/

4 Description

These circuit breakers are operated by a “push-pull” type single push button (actuator) and with delayed action “trip-free” tripping. Their function is ensured up to the short-circuit current.

---

[1] Published as ASD-STAN Standard at the date of publication of this document by AeroSpace and Defence industries Association of Europe — Standardization (ASD-STAN), https://www.asd-stan.org/.

* All parts quoted in this document.

[2] Published as ASD-STAN Technical Report at the date of publication of this document. http://www.asd-stan.org/.

Documents
Document Sharing Hub
Full document details: BS EN 2794-001:2023

5 Design

5.1 Materials

5.1.1 Metallic materials

All metallic parts shall be resistant to corrosion or finished against corrosion. When dissimilar materials are in close contact, an adequate protection against corrosion shall be used so that the electromotive force of the galvanic couple does not exceed 0,25 V.

When bimetals are used, an eventual corrosion shall not affect the good operation of the circuit breaker.

5.1.2 Insulation materials

The insulating parts shall be made of auto-extinguishing or non-flammable materials; they shall not emit damaging or explosive vapours, even in presence of fire or internal electric arc.

They shall be insensitive to moulds and microorganisms action.

Application of any material or protective coating which might crack, break on flake shall be forbidden.

Materials which are not specified, or which are not specially described shall be as light as possible for the requested use.

Materials shall be selected according to security criteria (toxicity, smoke density) as defined in contractual documents.

5.2 Design

5.2.1 Insulating box

The insulating box shall integrate besides the mechanism, the connection and attachment unit.

5.2.2 Free release mechanism

Design of circuit breaker mechanism shall allow free release, i.e. the circuit breaker cuts out in case of overload and remains cut out even if the actuator is kept by force in engaged position.

A new engagement of circuit breaker is only possible after a first total release of the control actuator.

The operation in these conditions shall not affect further performances of the circuit breaker.

5.2.3 Attachment

All visible parts shall be black-coloured and non-reflective.

5.2.4 Electrical connection units

They shall be able to receive the lugs.

5.2.5 Control actuator

In engaged position, the visible part of the control actuator shall be of the colour stated in the product standard. In disengaged (or opened) position, the control actuator shall show a white strip.

The outer part of this actuator shall be isolated from all undervoltage parts.

The control actuator shall not stay in a transition position or give a false indication about the circuit breaker condition. It shall not be removable.

AVA Documents
Document Sharing Hub

Full document details: BS EN 2794-001:2023

When pushing it, power contacts of the circuit breaker engage.

When pulling it, power contacts of the circuit breaker open.

The circuit breaker rating is indicated in indelible white colour on the front part of the control actuator.

The product standard gives the digits positioning.

5.2.6 Rating inviolability

The circuit breaker shall be designed in such a way that the calibration unit cannot be reached without breaking a sealing.

5.2.7 Leakage lines

The leakage lines and the minimal space to be foreseen between the undervoltage parts and any other part of the circuit breaker made of non-insulating material, as well as between the undervoltage parts of opposite polarity, shall be sufficient to avoid any default or arcing in all uses and climatic conditions.

5.2.8 Protection against non-release

Electrical overload happening on a circuit breaker locked in its engaged position (sticked contacts or non-operating release mechanism), shall cause the opening of the circuit-by-circuit breaker destruction without any fire or important smoke release.

6 Characteristics

6.1 General characteristics

See Table 1.

Table 1 — General characteristics

Designation	Requirements
Assembly	See product standard.
Mass	See product standard.
Operational altitude	See product standard.
One input terminal on power supply side (identified by digit 1)	See product standard.
One output terminal on distribution side (identified by digit 2)	
Operational ambient temperatures limits	From −55 °C to 125 °C
Temperature compensation	From −55 °C to 125 °C See product standard.
Rating marking	On control actuator (indelible white)

6.2 Ratings

See product standard.

6.3 Nominal voltage of operational circuits

See product standard.

Documents
Document Sharing Hub

Full document details: BS EN 2794-001:2023