

Guide for procurement of power station equipment —

Part 2-6: Electrical equipment — Generators

The European Standard EN 45510-2-6:2000 has the status of a
British Standard

ICS 27.100; 29.160.20

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

BSI
Documents

AVA

Document Sharing Hub

National foreword

This British Standard is the official English language version of EN 45510-2-6:2000.

The UK participation in its preparation was entrusted to Technical Committee E/-20, Power engineering steering committee, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled “International Standards Correspondence Index”, or by using the “Find” facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 38, an inside back cover and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

This British Standard, having been prepared under the direction of the Engineering Sector Committee, was published under the authority of the Standards Committee and comes into effect on 15 June 2000

© BSI 06-2000

ISBN 0 580 34503 3

Amendments issued since publication

Amd. No.	Date	Comments

English version

Guide for procurement of power station equipment - Part 2-6: Electrical equipment - Generators

Guide pour l'acquisition d'équipements destinés aux
centrales de production d'électricité - Partie 2-6 :
Equipements électriques - Alternateurs

Leitfaden für die Beschaffung von Ausrüstungen für
Kraftwerke - Teil 2-6: Elektrische Ausrüstung - Generatoren
stungsumrichter

This European Standard was approved by CEN/CENELEC on 1 February 2000.

CEN/CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN/CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN/CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN/CENELEC members are the national standards bodies and national electrotechnical committees, respectively, of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



CENELEC

CEN Central Secretariat:
rue de Stassart, 36 B-1050 Brussels

CENELEC Central Secretariat:
rue de Stassart, 35 B-1050 Brussels

Contents

	Page
Foreword.....	5
1 Scope.....	7
2 Normative references	7
3 Definitions	8
3.1 Organizational terms.....	8
3.2 Technical terms	8
3.3 General terms	8
4 Brief overall project description	9
4.1 Role and organization of purchaser.....	9
4.2 Site location	9
4.3 Equipment task.....	10
4.4 Equipment to be purchased.....	10
4.5 Control and instrumentation.....	10
4.6 Electrical supplies and other services	10
4.7 Other interfaces	11
4.8 Project programme	11
4.9 Equipment identification systems	11
5 Extent of supply	11
6 Terminal points	12
7 Operational requirements	13
7.1 Operating environment	13
7.2 Manning levels.....	13
7.3 Normal operation	13
7.4 Operating hours	14
7.5 Start-up and shut-down	14
7.6 Abnormal conditions	14
7.7 Further operational requirements	14
8 Life expectancy.....	15
8.1 Design life.....	15
8.2 Components requiring periodic maintenance	15

9	Performance requirements	15
9.1	Duty	15
9.2	Performance	16
9.3	Equipment margins.....	16
9.4	Availability.....	16
9.5	Levels of component redundancy.....	16
9.6	Further performance requirements.....	17
10	Design and fabrication	17
10.1	Specific equipment features	17
10.2	Design justification.....	18
10.3	Material selection.....	19
10.4	Safety.....	19
10.5	Interchangeability.....	19
10.6	Fabrication methods	19
11	Maintenance requirements	20
11.1	Planned maintenance	20
11.2	Personnel safety	20
11.3	Requirements for access.....	20
11.4	Lifting requirements	20
11.5	Special tools	20
11.6	Test equipment.....	20
11.7	Spare parts strategy	20
11.8	Special precautions	21
12	Technical documentation requirements.....	21
12.1	Tender documentation.....	21
12.2	Contract documentation.....	21
13	Applicable legislation, regulations, standards and further requirements	22
13.1	Legislation and regulations.....	22
13.2	Standards	22
13.3	Further requirements	22
14	Evaluation criteria	22
14.1	General.....	22
14.2	Technical criteria.....	23

15	Quality measures	23
15.1	General	23
15.2	Approvals procedure.....	24
15.3	Inspection requirements	24
15.4	Non-conformity	24
16	Site factors.....	24
16.1	Access	24
16.2	Facilities.....	24
16.3	Site specific requirements	25
17	Verification of specified performance	25
17.1	General	25
17.2	Works tests.....	25
17.3	Tests during installation and commissioning	25
17.4	Technical conditions for trial run	26
17.5	Functional and performance tests	26
	Annex A (informative) Bibliography	28
	Annex B (informative) Technical information schedule.....	29
	Annex C (informative) List of required performances (example)	38

Foreword

This standard takes the form of a recommendation and is therefore entitled a "Guide".

This Guide for procurement has been prepared by the CEN/CENELEC Joint Task Force Power Engineering (JTFPE) of which the secretariat is held by the British Standards Institution.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2000, and conflicting national standards shall be withdrawn at the latest by September 2000.

Annexes designated "informative" are given for information only. In this standard, annexes A, B and C are informative.

This Guide for procurement has been prepared under mandates given to CEN and CENELEC by the European Commission and the European Free Trade Association.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

This Guide for procurement is a part of a series of Guides mandated to cover the procurement of power station plant and equipment in conformity with European Procurement Directives. The Guides are:

EN 45510: Guide for procurement of power station equipment

Part 1: Common clauses

Part 2-1: Electrical equipment - Power transformers

Part 2-2: Electrical equipment - Uninterruptible power supplies

Part 2-3: Electrical equipment - Stationary batteries and chargers

Part 2-4: Electrical equipment - High power static converters

Part 2-5: Electrical equipment - Motors

Part 2-6: Electrical equipment - Generators

Part 2-7: Electrical equipment - Switchgear and controlgear

Part 2-8: Electrical equipment - Power cables

Part 2-9: Electrical equipment - Cabling systems

Part 3-1: Boilers - Water tube boilers

Part 3-2: Boilers - Shell boilers

Part 3-3: Boilers - Boilers with fluidized bed firing

Part 4-1: Boiler auxiliaries - Equipment for reduction of dust emissions

Part 4-2: Boiler auxiliaries - Gas-air, steam-air and gas-gas heaters

Part 4-3: Boiler auxiliaries - Draught plant

Part 4-4: Boiler auxiliaries - Fuel preparation equipment

Part 4-5: Boiler auxiliaries - Coal handling and bulk storage plant

Part 4-6: Boiler auxiliaries - Flue gas desulphurization (De-SO_x) plant

Part 4-7: Boiler auxiliaries - Ash handling plant

Part 4-8: Boiler auxiliaries - Dust handling plant

Part 4-9: Boiler auxiliaries - Sootblowers

Part 4-10: Boiler auxiliaries - Flue gas denitrification (De-NO_x) plant

Part 5-1: Turbines - Steam turbines
Part 5-2: Turbines - Gas turbines
Part 5-3: Turbines - Wind turbines
Part 5-4: Turbines - Hydraulic turbines, storage pumps and pump-turbines

Part 6-1: Turbine auxiliaries - Deaerators
Part 6-2: Turbine auxiliaries - Feedwater heaters
Part 6-3: Turbine auxiliaries - Condenser plant
Part 6-4: Turbine auxiliaries - Pumps
Part 6-5: Turbine auxiliaries - Dry cooling systems
Part 6-6: Turbine auxiliaries - Wet and wet/dry cooling towers
Part 6-7: Turbine auxiliaries - Moisture separator reheaters
Part 6-8: Turbine auxiliaries - Cranes
Part 6-9: Turbine auxiliaries - Cooling water systems

Part 7-1: Pipework and valves - High pressure piping systems
Part 7-2: Pipework and valves - Boiler and high pressure piping valves

Part 8-1: Control and instrumentation

*EN 45510 Part 1 contains those clauses common to all the above Guides giving the provisions of a non-**equipment** specific nature for use in the procurement of power station plant. EN 45510 is the responsibility of JTFPE. The so called "common clauses", as appropriate, also appear in italics in the documents specific to particular **equipment**.*

Where paragraphs of "common clauses" are omitted, each paragraph omitted is indicated by the symbol *****.

In this Guide, words in bold type indicate that they have the meaning given in the definitions, clause 3.

In this Guide, words and sentences not in italics are specific to this Guide and refer to the particular **equipment** covered.

1 Scope

*This standard gives guidance on writing the technical **specification** for the procurement of turbine-driven generators and their auxiliaries for use in electricity generating stations (power stations). This Guide for procurement is not applicable to **equipment** for use in the nuclear reactor plant area of nuclear power stations. Other possible applications of such **equipment** have not been considered in the preparation of this Guide.*

The generators may be air, hydrogen, or liquid-cooled. The excitation system may be of the static or rotating rectifier type fed by a static or rotating power supply.

*The **equipment** covered by this Guide is defined by its function rather than design type. Therefore, the guidance to the **specification** is stated in performance terms rather than being specified by a detailed description of the **equipment** to be supplied.*

*This Guide indicates to potential **purchasers** how their **specification** should be prepared so that*

- *the **equipment** type and capacity interfaces correctly with other elements of the systems;*
- *predicted performance is achieved'*
- *ancillary **equipment** is properly sized,*
- ***reliability, availability** and safety requirements are achieved,*
- *proper consideration is given to the evaluation process and the quality measures to be applied.*

*This Guide does not determine the type of **specification** (e.g. detailed, performance, functional) or the extent of supply for any given contract which is normally decided on the basis of the **purchaser's** project strategy. It does not cover*

- *any commercial, contractual or legal issues which are normally in separate parts of an **enquiry**,*
- *any allocation of responsibilities which are determined by the contract.*

*This Guide does not prescribe the arrangement of the documents in the **enquiry**.*

*NOTE: As a comprehensive European environmental policy is still under preparation, this Guide does not address the environmental implications of the **equipment**.*

2 Normative references

This Guide for Procurement incorporates by dated or undated reference, provisions from other publications. These normative references are cited in the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this Guide only when incorporated in it by amendment or revision. For undated references, the latest edition of the publication referred to applies.

European Standards

EN ISO 9001	Quality systems - Model for quality assurance in design, development, production, installation and servicing
EN ISO 9002	Quality systems - Model for quality assurance in production, installation and servicing
EN 60034-1	Rotating electrical machinery - Part 1 : Rating and performances
EN 60034-3	Rotating electrical machinery - Part 3: Specific requirements for turbine-type synchronous machines

International Standards

IEC 60050-191	<i>International electrotechnical vocabulary</i> Chapter 191: Dependability and Quality of Services
IEC 60842	Guide for application and operation of turbine-type synchronous machines using hydrogen as a coolant

3 Definitions

For the purposes of this Guide, the following definitions apply.

3.1 Organizational terms

3.1.1 **purchaser**: Recipient of a product and/or a service provided by a **supplier**.

3.1.2 **supplier**: Person or organization that provides a product and/or a service to the **purchaser**.

3.1.3 **specification**: Document stating technical requirements of the **purchaser**. It may form part of an **enquiry** issued by a **purchaser**.

3.1.4 **enquiry**: Invitation to **tender** issued by a **purchaser**. It will normally include a **specification** together with the necessary contractual and commercial conditions.

3.1.5 **tender**: Offer made by a **tenderer** in response to an **enquiry**.

3.1.6 **tenderer**: Person or organization submitting a **tender** for the **equipment** in response to the **enquiry**.

3.1.7 **site**: Place to which the **equipment** is to be delivered or where work is to be done by the **supplier**, together with so much of the area surrounding as the **supplier** may, with the consent of the **purchaser**, use for the purposes of the contract.

NOTE: Further definitions of useful organizational terms may be found in EN ISO 8402 (see Annex A).

3.2 Technical terms

3.2.1 **normal operation**: All operating conditions frequently encountered. These include rated operating conditions, maximum and minimum operating conditions, partial load, normal transients (start-up, shut-down, load changes), shut-down and stand-by situations.

3.2.2 **abnormal conditions** (of operation): Operating conditions of low occurrence (only for limited period of time) or low cumulative duration. These include situations in which limits of normal situations are exceeded, situations of tests, etc.

3.2.3 **accidental operating conditions**: Operating conditions of very low occurrence (typically only a few times during equipment lifetime). After such a condition has occurred, equipment inspection may be required. These include human errors, loss of power supply, overvoltages, earthquake, etc.

3.3 General terms

3.3.1 **equipment**: Plant, component, system and/or associated service to be provided in response to the **enquiry**.

3.3.2 **conformity**: Fulfilment of specified requirements by a product, process or service.

3.3.3 **performance**: Obligations verified by specified tests.

3.3.4 **operating period**: Time between planned outages or maintenance periods during which the **equipment** is in operation and/or does not restrict operational requirements of the power station.

3.3.5 life expectancy: Time period over which the **equipment** might be expected to operate with planned maintenance but without replacement of a significant component. For example, a stator, rotor or their windings are significant components.

3.3.6 design life: Operating hours of the **equipment** on which design calculations are based.

3.3.7 acceptability: Compliance with criteria defined by the **purchaser** for assessing the suitability of **equipment**.

3.3.8 equipment margins: Allowance for design, fabrication or operating contingency defined in the **specification**. These are separate to those normally included by the **supplier** for his own purposes.

3.3.9 proven equipment: **Equipment** which may be demonstrated to be similar to that offered and has operated for a sufficient time to have demonstrated performance and availability.

3.3.10 availability: As defined in IEC 60050-191.

3.3.11 reliability: As defined in IEC 60050-191.

3.3.12 maintainability: As defined in IEC 60050-191.

4 Brief overall project description

4.1 Role and organization of purchaser

The **enquiry** should define the **purchaser's** role in the project, including whether the **purchaser** will assume responsibility for the planning and technical coordination of the project, or whether other organizations will be appointed to carry out all or part of this function. The **enquiry** should define all organizational interfaces and the procedures to be employed for managing the contract and the **site**.

4.2 Site location

The **specification** should describe the geographical location of the **site** which may include surveying points, the previous use of the **site** and any local features such as the impact of industrial or military activities and planning restrictions.

Where applicable, the **specification** should indicate **site** datum on **specification** drawings and specify **site** and drawing orientation and define co-ordinate axes (x,y,z) and numbering order to ensure consistency between suppliers of connected equipment.

Where appropriate, the **specification** should define the permitted ground loading, dimensional and time restrictions on access routes up to but not including public roads or railways.

The **specification** should identify, where appropriate, the environment of the **site** in which the **equipment** will operate. The following factors may normally be included if appropriate:

- climatic e.g. atmospheric pressure, annual variation of air and cooling water temperature, relative humidity, rain fall, icing, snow, wind velocity (normal and maximum), lightning;
- geological e.g. seismic conditions and characteristics of subsoil (e.g. caverns, gliding stratifications, load bearing capability of subsoils);
- geographic e.g. elevation, influence of local topography and structures;
- hydrological e.g. flooding and tides.

4.3 Equipment task

The **specification** should describe in general terms the function, task or role of the **equipment** to be purchased. e.g. whether it is part of a new power generating plant, a modification to an existing power generating plant or replacement **equipment**.

Where appropriate, the **specification** should define the function and the known limitations, if any, in the **equipment** connected to that which is being supplied so that the **equipment** may avoid imposing adverse conditions or the **supplier** may suggest modifications to connected equipment which would ensure satisfactory operation.

4.4 Equipment to be purchased

The **specification** may define the **equipment** type or arrangement to be purchased.

For example

- power plant type (electrical power generation, combined heat and power generation, industrial power plant, nuclear or fossil fired plant),
- new construction or refurbishment or spare equipment,
- prototype or additional unit,
- mode of operation, eg. base load, average load, peak load, synchronous compensation.

The **specification** may also define preferences for **equipment** types (or give information) regarding compatibility with existing equipment, if required.

The **specification** should define the intended methods or local practice for maintenance, inspection and operation.

The **specification** should define requirements with regard to the general appearance of the **equipment** (e.g. dimensions, shape or colour) to meet local planning requirements or specific criteria, where such requirements exist.

NOTE: Attention is drawn to European, national and/or local legislation which may place restrictions in this area.

4.5 Control and instrumentation

The **specification** should define the general requirements for the control and instrumentation system, the level of operator intervention allowed or required, integration with other control systems, localized control loops, commonality and redundancy.

NOTE: Guidance on the procurement of control and instrumentation systems for power stations, including advice on interfaces, can be found in EN 45510-8-1.

4.6 Electrical supplies and other services

The **specification** should define the electrical supplies available for the operation of the **equipment**, their voltages and frequencies, with their range of variation, phases available and, where appropriate, the acceptable values of maximum load (kW) and short circuit level at each voltage level and the harmonic content. Requirements for terminals and terminal boxes should be stated; these should be to a recognized European or international standard.

The **specification** should define the type and capacity of other services for the operation of the **equipment** such as

- the gas requirements (purity, pressures, flowrates, etc.),
- cooling water requirements (flowrates, chemistry, filtration, etc.),
- lubricating oil and seal oil.

4.7 Other interfaces

The **specification** should define the interfaces with existing ancillary or new ancillary equipment, to be supplied under separate contracts, which interact directly with the **equipment**.

For example

- turbine (if not included in a common contract),
- foundations,
- busbars,
- protection system,
- hydrogen storage or production facility,
- purging gas storage,
- start-up equipment for gas turbine unit (if not included in a common contract),
- neutral earthing resistor,
- control and instrumentation system.

4.8 Project programme

The **specification** should describe the overall programme and timescale in which the project is to be carried out. This may include the principal dates associated with tendering, placement of orders, access to **site**, start and completion of installation, commissioning, take-over and final acceptance.

4.9 Equipment identification systems

The **specification** may specify the equipment identification system for use during the operating life of the plant. If applicable to the **project**, a recognized European or international system should be used.

5 Extent of supply

The **specification** should define the extent of supply of all the **equipment**.

This may include:-

the generator and the auxiliaries needed to operate the set (pumps, motors, pipes, valves, detection and measurement instruments), together with the associated instrumentation, protection and control devices.

The following items are normally included in the supply

- generator,
- exciter power supply system,
- excitation current rectifying system,
- voltage regulation system,
- coolers,
- auxiliary systems, eg. coolant, seal-oil, H₂ and CO₂, lubrication (if not included in turbine supply), etc.,
- instrumentation.

Additional equipment may include

- neutral connection,
- main connection to step-up generator transformer (if not included in generator switchgear supply),
- start-up device for gas turbine driven generator,
- measurement transformers, eg. for protections, etc.,
- equipment for supply and treatment of cooling and drainage fluids (where appropriate),
- electrical generator protection system.

These lists are not intended to be comprehensive.

For all the above **equipment**, items such as electrical motors, pipes, valves, covers, wiring boxes, facilities for remote-control, instrument taps, supports, etc., should be included in the **specification**.