

Power transformer and reactor fittings —

Part 2: Gas and oil actuated relay for liquid immersed transformers and reactors with conservator

The European Standard EN 50216-2:2002, with the incorporation of amendment A1:2002, has the status of a British Standard

ICS 29.120.70; 29.180

National foreword

This British Standard is the official English language version of EN 50216-2:2002, including amendment A1:2002.

The UK participation in its preparation was entrusted to Technical Committee PEL/14, Power transformers, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the *BSI Catalogue* under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

This British Standard, having been prepared under the direction of the Electrotechnical Sector Policy and Strategy Committee, was published under the authority of the Standards Policy and Strategy Committee on 12 April 2002

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 11 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments
14729	4 November 2003	Changes to Table 6

© BSI 4 November 2003

ISBN 0 580 39499 9

**Power transformer and reactor fittings
Part 2: Gas and oil actuated relay
for liquid immersed transformers and
reactors with conservator
(includes amendment A1:2002)**

Accessoires pour transformateurs
de puissance et bobines d'inductance
Partie 2: Relais de protection
(dégagement gazeux, niveau d'huile)
pour transformateurs et réactance
immergés dans un diélectrique liquide
équipés d'un conservateur
(inclut l'amendement A1:2002)

Zubehör für Transformatoren
und Drosselspulen
Teil 2: Buchholzrelais für
flüssigkeitsgefüllte Transformatoren
und Drosselspulen
mit Ausdehnungsgefäß
(enthält Änderung A1:2002)

This amendment A1 modifies the European Standard EN 50216-2:2002; it was approved by CENELEC on 2002-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 14, Power transformers.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50216-2 on 2001-09-25.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2002-10-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2004-10-01

EN 50216-2 is to be read in conjunction with EN 50216-1.

Foreword to amendment A1

This amendment was prepared by the Technical Committee CENELEC TC 14, Power transformers.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as amendment A1 to EN 50216-2:2002 on 2002-11-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2003-11-01
- latest date by which the national standards conflicting
with the amendment have to be withdrawn (dow) 2005-11-01

Contents

	Page
1 Scope	4
2 Normative references.....	4
3 Service conditions	4
3.1 Maximum inclination	4
3.2 Operating pressure	4
3.3 Sensitivity of the relay contacts to magnetic fields	5
3.4 Special mechanical conditions	5
4 Dimensions.....	5
5 Operational performance.....	7
5.1 Alarm and trip contacts	7
5.2 Oil loss from tank.....	8
5.3 Latching of trip element	8
6 Electrical characteristics of switch.....	8
6.1 Switch type	8
6.2 Rated currents	8
6.3 Breaking and making capacity	8
7 Mechanical requirements	9
7.1 Terminal box.....	9
7.2 Testing facility.....	9
7.3 Gas sampling.....	9
7.4 Draining device.....	9
7.5 Presence of gas in the relay	9
7.6 Mounting arrangement.....	9
7.7 Pressure and vacuum.....	9
8 Nameplate.....	10
9 Tests.....	10
9.1 Routine tests.....	10
9.2 Type tests	10