



BSI Standards Publication

Power transformer and reactor fittings

Part 4: Basic accessories (earthing terminal, drain and filling devices, thermometer pocket, wheel assembly)

National foreword

This British Standard is the UK implementation of EN 50216-4:2015. It supersedes BS EN 50216-4:2002, which will be withdrawn on 15 December 2017.

The UK participation in its preparation was entrusted to Technical Committee PEL/14, Power transformers.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015.
Published by BSI Standards Limited 2015

ISBN 978 0 580 90927 6

ICS 29.180

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2015.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

English Version

Power transformer and reactor fittings - Part 4: Basic accessories (earthing terminal, drain and filling devices, thermometer pocket, wheel assembly)

Accessoires pour transformateurs de puissance et bobines d'inductance - Partie 4: Accessoires de base (borne de terre, orifice de remplissage, vanne de vidange, doigt de gant, galets de roulement)

Zubehör für Transformatoren und Drosselspulen - Teil 4: Grundzubehör (Erdungsklemme, Ablass- und Füllleinrichtungen, Thermometertasche, Radbaugruppe)

This European Standard was approved by CENELEC on 2014-12-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
Foreword.....	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
4 Thermometer pockets to be used for liquid immersed transformers	5
4.1 General	5
4.2 Dimensions of thermometer pockets	5
5 Earth terminals to be used for liquid immersed and dry-type transformers.....	6
5.1 General	6
5.2 Dimensions of different earth terminals	6
6 Draining plug with sampler (preferred solution for distribution transformers).....	8
6.1 General	8
6.2 Dimensions of different devices.....	8
7 Filling openings for liquid immersed distribution transformers	9
7.1 General	9
7.2 Dimensions	9
8 Rollers, choice, dimensions and distance	10
8.1 General	10
8.2 Requirements	10
8.2.1 Choice of the roller.....	10
8.2.2 Distance between centres	12
Bibliography	15

Foreword

This document (EN 50216-4:2015) has been prepared by CLC/TC 14, "Power transformers".

The following dates are fixed:

- latest date by which this document has (dop) 2015-12-15
to be implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2017-12-15
standards conflicting with this
document have to be withdrawn

This document supersedes EN 50216-4:2002.

The main technical changes compared to the first edition are the following:

- Earth terminal Type B3 added;
- Figure 7 updated;
- Clause 8 completely new.

EN 50216-4 is to be read in conjunction with EN 50216-1.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

1 Scope

EN 50216-4 specifies basic accessories of transformers / reactors, such as

- Thermometer pockets, to be used for liquid immersed transformers,
- Earth terminals; to be used for liquid immersed and dry-type transformers,
- Draining plugs, to be used for liquid immersed distribution transformers,
- Filling openings, to be used for liquid immersed distribution transformers,
- Rollers, choice and distance to be used for liquid immersed and dry-type transformers.

After agreement between purchaser and manufacturer, this part of EN 50216 Series may still be applicable either as a whole or in part to large power transformers or special transformers.

2 Normative references

Addition to EN 50216-1:

EN 50464	Series	<i>Three-phase oil-immersed distribution transformers 50 Hz, from 50 kVA to 2 500 kVA with highest voltage for equipment not exceeding 36 kV</i>
EN 50522		<i>Earthing of power installations exceeding 1 kV a.c.</i>
EN 50541	Series	<i>Three-phase dry-type distribution transformers 50 Hz, from 100 kVA to 3 150 kVA, with highest voltage for equipment not exceeding 36 kV</i>
EN 60076	Series	<i>Power transformers (IEC 60076 Series)</i>

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply:

3.1

thermometer pocket

a device, generally mounted (may be welded) on the transformer or reactor cover, intended to house a thermometer to measure the insulating liquid temperature (marking A)

3.2

earth terminal

a terminal placed on the dry-type transformer structure or on the liquid immersed transformer/reactor tank, for connection to an earthing system (marking B)

3.3

draining plug

a device intended to sample or remove the insulating liquid from a transformer tank (marking C)