

Oil-immersed cable connection assemblies for transformers and reactors having highest voltage for equipment U_m from 72,5 kV to 550 kV

The European Standard EN 50299:2002 has the status of a
British Standard

ICS 29.180

National foreword

This British Standard is the official English language version of EN 50299:2002, including Corrigendum April 2004.

The UK participation in its preparation was entrusted to Technical Committee PEL/14, Power transformers, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Catalogue under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

This British Standard, having been prepared under the direction of the Electrotechnical Sector Policy and Strategy Committee, was published under the authority of the Standards Policy and Strategy Committee on 19 November 2002

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 11 and a back cover.

The BSI copyright date displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments
15517 Corrigendum No. 1	25 January 2005	Figure 2 replacement of column U_{max} with $\varnothing U$

© BSI 25 January 2005

ISBN 0 580 40795 0

EUROPEAN STANDARD

EN 50299

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2002

ICS 29.180

Incorporating Corrigendum April 2004

English version

Oil-immersed cable connection assemblies for transformers and reactors having highest voltage for equipment U_m from 72,5 kV to 550 kV

Boîte de raccordement de câble
pour transformateurs immergés
et bobine d'inductance de tensions
comprises entre 72,5 kV et 550 kV

Ölgefüllte Kabelanschlusseinheiten für
Transformatoren und Drosselspulen mit
einer höchsten Spannung für
Betriebsmittel U_m von 72,5 kV bis 550 kV

This European Standard was approved by CENELEC on 2002-10-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

© 2002 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Foreword

This European Standard was prepared by the CENELEC Technical Committee TC 14, Power transformers.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50299 on 2002-10-01.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2003-10-01
 - latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2005-10-01
-

Contents

1	Scope	4
2	Normative references	4
3	Definitions	5
4	Limits of supply	6
5	Rated values	6
6	Preferred values	6
6.1	Highest voltage for equipment.....	6
6.2	Rated current	6
7	Requirements.....	6
7.1	Temperature of connection interface	6
7.2	Mechanical requirements	7
7.3	Standard dimensions	7
7.4	Disconnecting link.....	7
7.5	Protection against corrosion.....	7
7.6	Mechanical forces on cable terminations	8
8	Tests	8
8.1	Factory tests	8
8.2	Tests after installation.....	8
Figure 1 – Limits of supply for transformer end terminal and cable termination.....		10
Figure 2 – Standard dimensions for cable connection assembly.....		11