

Luminaires —

Part 2.25: Particular requirements — Luminaires for use in clinical areas of hospitals and health care buildings

The European Standard EN 60598-2-25:1994, with the incorporation of amendment A1:2004, has the status of a British Standard

ICS 29.140.40

Committees responsible for this British Standard

The preparation of this British Standard was entrusted to Technical Committee CPL/34/4, Luminaires, upon which the following bodies were represented:

- Association of Consulting Scientists
- Association of Manufacturers Allied to the Electrical and Electronic Industry (BEAMA Ltd.)
- British Broadcasting Corporation
- British Lighting Association for the Preparation of Standards (Britlaps)
- British Retail Consortium
- British Telecommunications plc
- Chartered Institution of Building Services Engineers
- Consumer Policy Committee of BSI
- Department of Trade and Industry (Consumer Safety Unit, C A Division)
- Electrical Installation Equipment Manufacturers' Association (BEAMA Ltd.)
- Electricity Association
- Institute of Trading Standard Administration
- Institution of Lighting Engineers
- Lighting Association
- Lighting Industry Federation Ltd.
- National Illumination Committee of Great Britain
- Small Electrical Appliances Marketing Association

This British Standard, having been prepared under the direction of the Electrotechnical Sector Board, was published under the authority of the Standards Board and comes into effect on 15 June 1995

© BSI 19 January 2006

Amendments issued since publication

Amd. No.	Date	Comments
15542	21 March 2005	See national foreword
15799 Corrigendum No. 1	19 January 2006	See national foreword

The following BSI references relate to the work on this British standard:
Committee reference CPL/34/4
Draft for comment 84/26983 DC

ISBN 0 580 24175 0

Contents

	Page
Committees responsible	Inside front cover
National Foreword	ii
Foreword	2
Text of EN 60598-2-25	3

National foreword

This Part of BS EN 60598 has been prepared by Technical Committee CPL/34/4 and is the English language version of EN 60598-2-25 *Luminaires — Part 2.25: Particular requirements — Luminaires for use in clinical areas of hospitals and health care buildings*, including amendment A1:2004, published by the European Committee for Electrotechnical Standardization (CENELEC). It is identical with IEC 60598-2-25:1994 (including corrigendum dated September 1994) and including amendment 1:2004, published by the International Electrotechnical Commission (IEC).

The start and finish of text introduced or altered by amendment is indicated in the text by tags **A1** **A1**. Tags indicating changes to text carry the number of the amendment. For example, text altered by CENELEC amendment A1 is indicated by **A1** **A1**.

This British Standard is to be read in conjunction with BS EN 60598-1:2004 *Luminaires Part 1. General requirements and tests* which it supplements or modifies. The many references to Part 1 should be read as references to BS EN 60598-1 which is the English language version of EN 60598-1 which was derived from IEC 60598-1:2003.

The foreword of the EN makes reference to the date of withdrawal, dow, of the relevant national standard. In this case the relevant national standard is BS 4533-102.55:1986 which is withdrawn.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the *BSI Catalogue* under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, the EN title page, pages 2 to 13 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

ICS 29.140.40

Descriptors: Lighting equipment, luminaire, hospital, health care building, tungsten filament lamp, tubular lamp, fluorescent lamp, definition, marking, construction, characteristics, mechanical strength, wiring, protection against electric shocks, heating test

English version

Luminaires — Part 2-25: Particular requirements — Luminaires for use in clinical areas of hospitals and health care buildings

(IEC 60598-2-25:1994 + Corrigendum 1994 + A1)
(includes amendment A1:2004)

Luminaires —
Partie 2-25: Règles particulières —
Luminaires pour les unités de soins
des hôpitaux et les maisons de santé
(inclut l'amendement A1:2004)
(CEI 60598-2-25:1994 + Corrigendum 1994
+ A1:2004)

Leuchten —
Teil 2-25: Besondere Anforderungen —
Leuchten zur Verwendung in klinischen
Bereichen von Krankenhäusern und
Gebäuden zur Gesundheitsfürsorge
(enthält Änderung A1:2004)
(IEC 60598-2-25:1994 + Corrigendum 1994
+ A1:2004)

This European Standard was approved by CENELEC on 1994-10-04; amendment A1 was approved by CENELEC on 2004-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B-1050 Brussels

Foreword

The text of document 34D(CO)254, future edition 1 of IEC 60598-2-25, prepared by SC 34D, Luminares, of IEC TC 60034, Lamps and related equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC with its corrigendum September 1994 as EN 60598-2-25 on 1994-10-04.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 1995-10-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 1995-10-01

For products which have to be complied with the relevant national standard before 1995-10-01, as shown by the manufacturer or by a certification body, this previous standard may continue to apply for production until 2000-10-01.

Annexes designated “normative” are part of the body of the standard.

Annexes designated “informative” are given for information only.

In this standard, Annex ZA is normative.

Annex ZA has been added by CENELEC.

Foreword to amendment A1

The text of document 34D/822/FDIS, future amendment 1 to IEC 60598-2-25:1994, prepared by SC 34D, Luminares, of IEC TC 60034, Lamps and related equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as amendment A1 to EN 60598-2-25:1994 on 2004-11-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2005-08-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2011-11-01

Annex ZA has been added by CENELEC.

Contents

	Page
Foreword	2
25.1 General	3
25.1.1 Scope	3
25.1.2 Normative references	3
25.2 General test requirements	3
25.3 Definitions	3
25.4 Classification	4
25.5 Marking	4
25.6 Construction	5
25.7 Creepage distances and clearances	6
25.8 Provision for earthing	7
25.9 Terminals	7
25.10 External and internal wiring	7
25.11 Protection against electric shock	8
25.12 Endurance test and thermal tests	8
25.13 Resistance to dust, solid objects and moisture	9
25.14 Insulation resistance and electric strength	9
25.15 Resistance to heat, fire and tracking	9
Annex A <i>Deleted</i>	13
Annex ZA (normative) Other publications quoted in this standard with references to the relevant European publications	13
Figure 1 — Arrangement for impact test for hand-held inspection luminaires	10
Figure 2 — Apparatus for flexing test for hand-held inspection luminaires	11
Figure 3 — Crush test apparatus for hand-held inspection luminaires	12