BS EN 60670-24:2013

BSI Standards Publication

Boxes and enclosures for electrical accessories for household and similar fixed electrical installations

Part 24: Particular requirements for enclosures for housing protective devices and other power dissipating electrical equipment

bsi.

...making excellence a habit.™

Document Sharing Hub

Full document details: BS EN 60670-24:2013

National foreword

This British Standard is the UK implementation of EN 60670-24:2013. It is derived from IEC 60670-24:2011.

The CENELEC common modifications have been implemented at the appropriate places in the text. The start and finish of each common modification is indicated in the text by 〖C〗 〈C〗.

Attention is drawn to the UK A-deviation in Annex ZC detailing that:

– this standard cannot be used in installations with a 230 V single-phase supply rated up to 100 A that is under the control of ordinary persons;

– integration of mechanical and electrical devices into an enclosure are to be verified by compliance with BS EN 60439-3 or BS EN 61439-3.

The UK participation in its preparation was entrusted to Technical Committee PEL/23, Electrical accessories.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013

Published by BSI Standards Limited 2013

ISBN 978 0 580 80517 2

ICS 29.120.10

Compliance with a British Standard cannot confer immunity fromlegal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 August 2013.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS EN 60670-24:2013

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN 60670-24

April 2013

ICS 29.120.10

English version

Boxes and enclosures for electrical accessories for household and similar fixed electrical installations - Part 24: Particular requirements for enclosures for housing protective devices and other power dissipating electrical equipment

(IEC 60670-24:2011, modified)

Boîtes et enveloppes pour appareillage électrique pour installations électriques fixes pour usages domestiques et analogues -
Partie 24: Exigences particulières pour enveloppes pour appareillages de protection et autres appareillages électriques ayant une puissance dissipée
(CEI 60670-24:2011, modifiée)

Dosen und Gehäuse für Installationsgeräte für Haushalt und ähnliche ortsfeste elektrische Installationen -
Teil 24: Besondere Anforderungen für Gehäuse zur Aufnahme von Schutzgeräten und ähnlichen energieverbrauchenden Geräten
(IEC 60670-24:2011, modifiziert)

This European Standard was approved by CENELEC on 2013-03-04. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

© 2013 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Ref. No. EN 60670-24:2013 E

AVA Documents
Document Sharing Hub

Full document details: BS EN 60670-24:2013

Contents

Page

Foreword 3
1 Scope 4
2 Normative references 4
3 Definitions 4
7 Classification 4
8 Marking 4
12 Construction 4
13 Resistance to ageing, protection against ingress of solid foreign objects and against harmful ingress of water 4
17 Creepage distances, clearances and distances through sealing compound 5
101 Verification of the maximum capability to dissipate power (P_{de}) 5
Annex ZA (normative) Normative references to international publications with their corresponding European publications 6
Annex ZB (normative) Special national conditions 7
Annex ZC (informative) A-deviations 8

Documents
Document Sharing Hub
Full document details: BS EN 60670-24:2013

Foreword

This document (EN 60670-24:2013) consists of the text of IEC 60670-24:2011 prepared by IEC/SC 23B "Plugs, socket-outlets and switches" of IEC/TC 23 "Electrical accessories", together with the common modifications prepared by CLC/TC 23BX "Switches, boxes and enclosures for household and similar purposes, plugs and socket outlets for d.c. and for the charging of electrical vehicles including their connectors".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-03-04
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2018-03-04

This Part 24 is to be used in conjunction with EN 60670-1:2005. It lists the changes necessary to convert that standard into a specific standard for housing protective devices and other power dissipating electrical equipment.

Where this Part 24 states "addition“, "modification“ or "replacement“, the relevant requirement, test specifications or explanatory matter in Part 1 shall be adapted accordingly.

Clauses and subclauses, notes, figures or tables which are additional to those in Part 1 are numbered starting from 101.

Additional annexes to Part 1 are numbered AA, BB, etc.

In this publication the following print types are used:
- requirements proper: in roman type.
- *test specifications: in italic type.*
- notes: in smaller roman type.

Clauses, subclauses, notes, tables and figures which are additional to those in IEC 60670-24:2011 are prefixed “Z”.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC).

Documents
Document Sharing Hub
Full document details: BS EN 60670-24:2013

Endorsement notice

The text of the International Standard IEC 60670-24:2011 was approved by CENELEC as a European Standard with agreed common modifications.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 60439-3:1991 NOTE Harmonised as EN 60439-3:1991 (modified).

Documents
Document Sharing Hub

Full document details: BS EN 60670-24:2013

Documents
Document Sharing Hub

Full document details: BS EN 60670-24:2013

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

***Addition** to the Annex ZA of EN 60670-1:2005:*

Publication	Year	Title	EN/HD	Year
IEC 60417	-	Graphical symbols for use on equipment	-	-
IEC 60898-1	-	Electrical accessories - Circuit breakers for overcurrent protection for household and similar installations Part 1: Circuit-breakers for a.c. operation	EN 60898-1	-
IEC 61008-2-1	-	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) Part 2-1: Applicability of the general rules to RCCB's functionally independent of line voltage	EN 61008-2-1	-
IEC 61009-2-1	-	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's) Part 2-1: Applicability of the general rules to RCBO's functionally independent of line voltage	EN 61009-2-1	-
IEC 62262	-	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)	EN 62262	-

Documents
Document Sharing Hub
Full document details: BS EN 60670-24:2013

Annex ZB
(normative)

Special national conditions

Special national condition: National characteristic or practice that cannot be changed even over a long period, e.g. climatic conditions, electrical earthing conditions.

NOTE If it affects harmonization, it forms part of the European Standard.

For the countries in which the relevant special national conditions apply these provisions are normative, for other countries they are informative.

Clause	Special national condition
1	**Denmark** This standard can only be used for GP enclosures with the instructions according to Annex A. For the other types of enclosures the integration of mechanical and electrical devices into an enclosures are verified by compliance with DS EN 60439-3.
7	**Denmark, Italy** Only enclosures according to 7.101.1 and 7.102.1 can be used. **Belgium, Germany, France, Greece** Only enclosures classified according to 7.101.2 and 7.102.2 can be used.
12.101	**United Kingdom** The text of this clause does not apply. Cables are retained using fixing means applied during installation by the installer.
13.2	**Denmark** In the case of an enclosure with a door or a lid which can be opened without the use of a tool during normal use, a minimum degree of IP30 shall be maintained after opening the door or the lid.

Documents
Document Sharing Hub
Full document details: BS EN 60670-24:2013

Annex ZC
(informative)

A-deviations

A-deviation: National deviation due to regulations, the alteration of which is for the time being outside the competence of the CENELEC national member.

This European Standard falls under Directive 2006/95/EC.

NOTE (from CEN/CENELEC IR Part 2:2011, 2.17) Where standards fall under EU Directives, it is the view of the Commission of the European Communities (OJ No C 59, 1982-03-09) that the effect of the decision of the Court of Justice in case 815/79 Cremonini/Vrankovich (European Court Reports 1980, p. 3583) is that compliance with A-deviations is no longer mandatory and that the free movement of products complying with such a standard should not be restricted except under the safeguard procedure provided for in the relevant Directive.

A-deviations in an EFTA-country are valid instead of the relevant provisions of the European Standard in that country until they have been removed.

Clause	Deviation
1	**United Kingdom**
	{Electricity, Safety, Quality and Continuity Regulations; SI '2002 2665'}
	Add *after the second paragraph:*
	This standard cannot be used in installations with a 230 V single-phase supply rated up to 100 A that is under the control of ordinary persons. Integration of mechanical and electrical devices into an enclosure must be verified by compliance with BS EN 60439-3.

Documents
Document Sharing Hub
Full document details: BS EN 60670-24:2013

CONTENTS

1 Scope 6
2 Normative references 6
3 Definitions 7
4 General requirements 8
5 General notes on tests 8
6 Ratings 8
7 Classification 8
8 Marking 8
9 Dimensions 10
10 Protection against electric shock 10
11 Provisions for earthing 11
12 Construction 11
13 Resistance to ageing, protection against ingress of solid foreign objects and against harmful ingress of water 12
14 Insulation resistance and electric strength 12
15 Mechanical strength 12
16 Resistance to heat 12
17 Creepage distances, clearances and distances through sealing compound 12
18 Resistance of insulating material to abnormal heat and to fire 13
19 Resistance to tracking 13
20 Resistance to corrosion 14
21 Electromagnetic compatibility 14
101 Verification of the maximum capability to dissipate power (P_{de}) 14
102 Verification of temperature rise 15
Annex AA (normative) Instructions to be given by the manufacturer of the GP enclosure to the installer how to integrate accessories, and example of calculation 22
Annex BB (normative) Instructions to be given by the manufacturer of the PD enclosure to the installer how to integrate accessories 30
Bibliography 32

Figure 101 – Arrangement for the verification of the maximum capability to dissipate power (P_{de}) and for verification of temperature rise of surface type enclosures 17
Figure 102 – Heating resistor for the verification of the maximum capability to dissipate power (P_{de}) 18
Figure 103 – Position of the resistor for enclosures designed or intended to be fitted with rail mounting modular accessories and electrical equipment 19
Figure 104 – Position of the resistor(s) for enclosures other than those designed or intended to be fitted with rail mounting accessories and electrical equipment 20
Figure 105 – Position of the resistor(s) for enclosures other than those designed or intended to be fitted with rail mounting accessories and electrical equipment and allowing the mounting of several accessories and electrical equipment in different positions 21

Documents
Document Sharing Hub
Full document details: BS EN 60670-24:2013

Table 1 – Classification of boxes and enclosures 8
Table 101 – Creepage distances, clearances and distances through sealing compound 13
Table 102 – Diversity factor 16
Table 103 – Temperatures of accessible surfaces 17
Table AA.1 – Diversity factor 24
Table AA.2 – Tests and verifications 25
Table AA.3 – Calculation of P_{dp} 28
Table AA.4 – Calculation of P_{au} 29

Documents
Document Sharing Hub
Full document details: BS EN 60670-24:2013

BOXES AND ENCLOSURES FOR ELECTRICAL ACCESSORIES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 24: Particular requirements for enclosures for housing protective devices and other power dissipating electrical equipment

1 Scope

Replacement:

This part of IEC 60670 applies to enclosures and parts of them for housing protective devices and other power dissipating electrical equipment intended to be used with a rated voltage not exceeding 400 V and a total incoming load current not exceeding 125 A for household and similar fixed electrical installations.

These enclosures are intended to be installed where unskilled persons have access. They are intended to be integrated with electrical equipment on site by skilled persons (installers).

They are intended to be installed where the prospective short circuit current does not exceed 10 kA unless they are protected by current limiting protective devices with a cut-off current not exceeding 17 kA.

Enclosures complying with this standard are suitable for use, after installation, at ambient temperature not normally exceeding 25 °C, but occasionally reaching 35 °C over 24 h, max. 40 °C and min. –5 °C.

An enclosure which is an integral part of an electrical accessory and provides protection against external influences (e.g. mechanical impacts, ingress of solid objects or of water), is covered by the relevant standard for such an accessory.

This standard does not apply to a low-voltage switchgear and controlgear assembly (ASSEMBLY) as defined in the IEC 60439 or IEC 61439 series of standards nor to a main entrance panel which may or may not be part of the distribution board.

[C〉 NOTE 〈C] A main entrance panel is a set composed by a panel or an enclosure equipped with a meter and/or the main incoming device. Main entrance panels comply with their appropriate standards or the requirements of the local supplier if any.

2 Normative references

[C〉 See Annex ZA. 〈C]

Documents
Document Sharing Hub
Full document details: BS EN 60670-24:2013