

Flickermeter —

Part 0: Evaluation of flicker severity

The European Standard EN 60868-0:1993 has the status of a British Standard

UDC 621.317.7

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW



Document Sharing Hub

Cooperating organizations

The European Committee for Electrotechnical Standardization (CENELEC), under whose supervision this European Standard was prepared, comprises the national committees of the following countries:

Austria	Italy
Belgium	Luxembourg
Denmark	Netherlands
Finland	Norway
France	Portugal
Germany	Spain
Greece	Sweden
Iceland	Switzerland
Ireland	United Kingdom

This British Standard, having been prepared under the direction of the General Electrotechnical Standards Policy Committee, was published under the authority of the Standards Board and comes into effect on
15 May 1993

© BSI 08-1999

The following BSI references relate to the work on this standard:
Committee reference GEL/110
Announced in *BSI News*,
January 1992

ISBN 0 580 22132 6

Amendments issued since publication

Amd. No.	Date	Comments

Contents

	Page
Cooperating organizations	Inside front cover
National foreword	ii
Foreword	2
Text of EN 60868-0	3
National annex NA (informative) Committees responsible	26
National annex NB (informative) Cross-references	Inside back cover

National foreword

This British Standard has been prepared under the direction of the General Electrotechnical Standards Policy Committee and is the English language version of EN 60868-0:1993 *Flickermeter — Part 0: Evaluation of flicker severity*, published by the European Committee for Electrotechnical Standardization (CENELEC). It is identical with IEC 868-0:1991 published by the International Electrotechnical Commission (IEC).

This standard is complementary to IEC 868:1986 with Amendment No. 1:1990, which has been adopted by CENELEC as HD 498.S2 and published as BS 6796:1986.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, the EN title page, pages 2 to 26, an inside back cover and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.

UDC 621.317.7

Descriptors: Metrology, measuring instruments, flickermeter, evaluation, statistics, fidelity, verification, tests

English version

Flickermeter
Part 0: Evaluation of flicker severity
(IEC 868-0:1991)

Flickermètre
Partie 0: Evaluation de la sévérité du flicker
(CEI 868-0:1991)

Flickermeter
Teil 0: Beurteilung der Flickerschärfe
(IEC 868-0:1991)

This European Standard was approved by CENELEC on 1992-12-09. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B-1050 Brussels

Foreword

The CENELEC questionnaire procedure, performed for finding out whether or not the Technical Report IEC 868-0:1991 could be accepted without textual changes, has shown that no common modifications were necessary for the acceptance as European Standard.

The reference document was submitted to the CENELEC members for formal vote and was approved by CENELEC as EN 60868-0 on 9 December 1992.

The following dates were fixed:

- latest date of publication of an identical national standard (dop) 1993-12-01
- latest date of withdrawal of conflicting national standards (dow) 1993-12-01

Annexes designated “normative” are part of the body of the standard. In this standard, Annex ZA is normative.

Contents

	Page		Page
Foreword	2	Figure 1 — Basic illustration of the “time at level” method showing flicker level as a time-varying function. Signal permanence in class No. 7 is indicated as an example $T_7 = \sum_{i=1,5} t_i$	14
1 Statistical evaluation	3	Figure 2 — Cumulative probability function (CPF) of signal premanence in classes 1 to ten	15
2 Short-term flicker severity assessment	4	Figure 3 — CPF curves of sinusoidale and rectangular voltage fluctuations	16
2.1 Choosing the multipoint algorithm	4	Figure 4 — CPF curves for two pulse waveforms: waveform B is representative of repetitive motor starting	17
2.2 Practical checking of the P_{st} evaluation	5	Figure 5 — CPF curve for a 10 min observation period for an arc furnace and for infrequent step voltage changes	18
2.3 Agreement between simplified assessment methods and evaluation	5	Figure 6a — IEC limit curve and points of equal severity, $P_{st} = 1$	19
3 Accuracy of the P_{st} evaluation	5	Figure 6b — Curve of equal severity, $P_{st} = 1$	20
4 Interpolation	8	Figure 7 — Maximum relative error as a function of the ratio $\alpha = P_{st \text{ true}}/P_{st \text{ max}}$ for 64, 128 and 256 classes	21
4.1 Linear interpolation	8	Figure 8a — Linear interpolation	22
4.2 Non-linear interpolation	8	Figure 8b — Non-linear interpolation	22
4.3 Pseudo zero interpolation	8	Figure 9 — Pseudo zero interpolation	22
5 Smoothing percentile points	9	Figure 10 — Example of application of the four long-term assessment methods to an actual arc furnace operation	23
6 Non-linear classification	9	Table 1 — Voltage changes just permitted by IEC 555-3 compared with those giving one unit flicker severity ($P_{st} = 1$) for various changes of voltage per minute using unsmoothed and smoothed 5 point algorithm	6
7 Performance tests including the classifier	10	Table 2 — Minimum measurable P_{st} values with an error of 5 % for each range and three classifier sizes	7
8 Evaluation of long-term flicker severity	10	Table 3 — Test specifications for flickermeter classifier	10
9 Reference	11	Table 4 — Comparison of methods of long-term flicker evaluation	12
Annex ZA (normative) Other international publications quoted in this standard with the references of the relevant European publications	24	Table 5 — Application of the “cube law” method of P_{lt} evaluation	13

1 Statistical evaluation

The UIE/IEC flickermeter simulates the process of physiological visual perception and gives a reliable indication of the reaction of an observer to any type of flicker, which is independent of the source of the disturbance.

The flickermeter monitors individual and sequential flicker occurrences in units of perceptibility; it is necessary to evaluate its output by a method that indicates severity level for regular and irregular type of flicker. The output of the instrument is one unit, at the threshold of perceptibility.

The concern of UIE is to achieve a unique method for flicker evaluation using an evaluation procedure that is equally applicable to any kind of fluctuating load. The specification of limits for the disturbances generated by the various categories of equipment is the task of the appropriate standardization bodies.

To take account of the mechanisms of vision and the building up of annoyance, the flicker shall be evaluated over a sufficiently representative period of time. Moreover because of the random nature of flicker caused by some loads it must be assumed that during this time its instantaneous level can be widely and unpredictably variable. It is important to check not only the maximum attained levels but also for what percentage of a significant observation period any given flicker level has been exceeded. To cover all cases, a statistical approach is essential and this requires a function to be established relating flicker sensation levels and the corresponding percentages of duration, over the observation period.

The steps to establish this function are the following:

- first the measured instantaneous flicker sensation levels at the output of Block 4 of the flickermeter are classified according to their value, thus obtaining their frequency distribution;
- when the observation period expires, the cumulative probability function (CPF) is established.

This method has been called “time at level classification” and is illustrated in Figure 1.

Figure 2 shows the graphical representation of a CPF curve where, for clarity, only a small number of classes has been used.

Figure 3 to Figure 5 give examples of CPF curves obtained for different disturbing loads. It can be seen that the shapes of the curves are dissimilar, yet a common criterion is required to describe them in a concise and meaningful way and so assess flicker severity quantitatively and objectively.

If all CPF curves followed a standard type of distribution, such as Gaussian, they might be characterised by a few parameters such as mean, standard deviation and so on. This not being the case, a multipoint method which could be used to characterise any CPF curve was developed.

A suitable algorithm for use with various shapes of CPF curves can be expressed as follows:

$$P_{st} = \sqrt{K_1 P_1 + K_2 P_2 + \dots + K_n P_n}$$

where:

P_{st} is the value of short-term flicker severity;

K_1 to K_n are weighting coefficients and

P_1, P_2 to P_n are CPF curve levels with an assigned probability of being exceeded.

The weighting coefficients were determined in such a way as to indicate the flicker severity correctly for a wide range of frequencies of rectangular modulation of the input voltage but the response to other waveshapes was also taken into account.

A stable solution can be obtained using five gauge points or percentiles, namely:

$P_{0,1}$	the level exceeded by only	0,1 %	of the observation period
P_1	” ” ”	1 %	” ” ”
P_3	” ” ”	3 %	” ” ”
P_{10}	” ” ”	10 %	” ” ”
P_{50}	” ” ”	50 %	” ” ”

The 50 % reference point is the median level of flicker, giving a general indication of the order of magnitude of the disturbance. The other points are taken toward the low end of the probability scale to weight the higher sensation levels appropriately, because these are more significant in assessing the severity of the disturbance.

It should be noted that the maximum flicker level observed during the selected time interval is not included because a single peak level of very short duration cannot be representative of a flicker occurrence. The foundation of the CPF concept is that time at a given level gives the more useful indication; the choice of 0,1 % as a minimum percentile provides a suitable response for large, infrequent flicker amplitudes.

A suitable observation period should be chosen. This could be selected to match the duty cycle of a specific disturbing equipment but it is desirable to adopt a common time, independent of the specific type of disturbing source being considered.

In fulfilling this objective it has been necessary to consider again the physiology of flicker perception and the results of tests on human subjects and to try to determine what time interval would be appropriate to represent the reaction of the average observer to a wide range of flicker characteristics.

An interval of 10 min has been selected as a good compromise. It is long enough to avoid giving too much importance to isolated voltage changes. It is also long enough to allow an unaware subject to notice the disturbance and its persistence, but at the same time it is short enough to allow a detailed characterization of a disturbing equipment with a long lasting duty cycle. It is an important advantage that the same interval is the observation time specified in IEC 555-3.

2 Short-term flicker severity assessment

2.1 Choosing the multipoint algorithm

In choosing a suitable multipoint algorithm, another problem had to be resolved, that of relating the multipoint evaluation to flicker severity.

A limited number of human subjective response test results was available, which could be used to relate flicker severity with non-linear CPF curves. However, from investigations made into earlier work concerning human subjective response measurements, it appeared that the higher frequency part of the limit curve given in IEC 555-3 (Figure 6a) corresponds fairly well to the experimental results which relate flicker severity to consumer complaints for rectangular disturbance waveforms.

On the other hand it appeared that the part of the limit curve over the range 1 to 0,1 changes per minute was not a true measure of flicker severity but the 3 % limit of voltage change had to be introduced for reasons other than that of limiting flicker annoyance. A realistic relationship for flicker evaluation requires that the severity curve be extended to the 7,5 % voltage change level at 0,1 changes per minute (Figure 6b). It was therefore decided to determine a multipoint algorithm from this modified rectangular response curve and then to test its validity from results of subsequent human subjective response measurements.

The following values were obtained for the K coefficients:

K	for	0,1 %	level	=	0,0314
K	for	1 %	"	=	0,0525
K	for	3 %	"	=	0,0657
K	for	10 %	"	=	0,28
K	for	50 %	"	=	0,08

All chosen coefficients are positive, which ensures that the resulting values for flicker severity remain stable i.e. they do not appear to be oscillatory in relation to variations on the voltage changes per minute scale.

For the agreed short-term assessment period of 10 min, the flicker severity was therefore expressed by the equation

$$P_{st} = \sqrt{0,0314 P_{0,1} + 0,0525 P_1 + 0,0657 P_3 + 0,28 P_{10} + 0,08 P_{50}}$$

To check the accuracy of this flicker severity assessment and to ensure that the results were stable for regularly repeated fluctuations, the multipoint algorithm was used to evaluate every limit level given in the IEC table for the specified period of 10 min. The results are shown in Table 1 under the sub-columns “unsmoothed” and in Figure 6a.

It can be seen in Figure 6a that the greatest difference between the severity curve and the right-hand part of the IEC limit curve is about 10 %, which is a satisfactory result. A still better fit is however not possible the reason for that is probably the empirical origin of the IEC curve. The precision of such a curve is evidently limited and it is not suitable for exact mathematical representation.

2.2 Practical checking of the P_{st} evaluation

The next requirement was to demonstrate that the multipoint algorithm gave correct responses for different types of supply disturbance. The first test was related to arc furnace disturbances and the results were checked against gauge point voltages obtained from the ERA flickermeter. Good correlation was obtained with test results obtained at different installations.

Next, it was decided to demonstrate correlation with disturbances associated with motor starting. This demonstration was carried out in the United Kingdom by arranging for human subjective response tests to be made with simulated shapes of disturbance and was performed for test conditions representing six changes per minute. The measurements also included rectangular disturbances. The results obtained from the flickermeter concurred with the test subject opinions and, incidentally, the rectangular disturbance had a voltage variation which agreed closely with the IEC curve.

Further experience in flicker severity evaluation showed that if there were a need to modify the curve of equal severity as a function of voltage fluctuation frequencies, then the P_{st} coefficients could easily be adapted to fit a new curve.

Therefore the UIE proposes that this multipoint evaluation of flicker severity should be used, not only for household and similar appliances under the test conditions of IEC 555-3, but that the same evaluation should be used for voltage fluctuations caused by industrial loads, including arc furnaces.

The quantity P_{st} is proposed only as a means to gauge the level of flicker severity, its main purpose being to provide an international method of flicker severity assessment. The UIE does not propose a limiting value for P_{st} , this is recognized to be the responsibility of the various International and National Standards Committees.

The UIE, however, is mindful of the need to give some guidance on how to use the flickermeter for evaluating limit values for flicker severity.

A limit value for P_{st} could be set as greater or less than unity according to the application, taking into account the fact that in laboratory tests a substantial proportion of observers report flicker as annoying when $P_{st} = 1$.

2.3 Agreement between simplified assessment methods and evaluation

The above-mentioned difference between the $P_{st} = 1$ curve and the right-hand part of the IEC 555 curve will cause a small discrepancy (maximum 10 %) between simplified assessment methods and measurements.

The present practice is to use a simplified assessment method as a first step and to perform measurements in case of doubt (when the results are within 10 % of the limit). It may, however, cause problems if measurements are difficult or even impossible to carry out.

As a better solution, the UIE recommends to the IEC to revise the right-hand part of the IEC 555 limit curve slightly, so as to be identical to the $P_{st} = 1$ curve. Measuring P_{st} (with the additional requirement that the voltage changes shall not in any case exceed 3 %) will then give results identical to those obtained using the analytical method.

3 Accuracy of the P_{st} evaluation

The classification method used to obtain the CPF may introduce errors due to the fact that in a practical implementation of the statistical evaluation block the number of classes shall be limited, as shall the resolution of the analogue-to-digital converter that is used for both digital and analogue designs of flickermeter.

This usually means that the true values of the level associated with any of the selected percentiles, P_k ($k = 0, 1; 1; 3; 10; 50$), is not given directly but lies between two known values in the classified distribution.

Table 1 — Voltage changes just permitted by IEC 555-3 compared with those giving one unit flicker severity ($P_{st} = 1$) for various changes of voltage per minute using unsmoothed and smoothed 5 point algorithm

Column 1 Changes per minute	Column 2 Relative voltage changes $\Delta U/U$ %	Column 3 Voltage change for unit flicker ($P_{st} = 1$) $\Delta U/U$ %		Column 4 Percentage difference Column 3 — Column 2 Column 2 x 100 %	
		Unsmoothed	Smoothed	Unsmoothed	Smoothed
0,1	3,00	7,46	7,391	—	—
0,2	3,00	4,52	4,584	—	—
0,3	3,00	3,88	3,842	—	—
0,4	3,00	3,52	3,540	—	—
0,5	3,00	3,34	3,350	—	—
0,6	3,00	3,14	3,196	—	—
0,76	3,00	2,97	2,979	− 1,0	− 0,7
0,84	2,90	2,90	2,867	0,0	− 1,1
0,95	2,80	2,79	2,765	− 0,3	− 0,4
1,06	2,70	2,70	2,679	0,0	− 0,8
1,20	2,60	2,60	2,579	0,0	− 0,8
1,36	2,50	2,49	2,484	− 0,4	− 0,6
1,55	2,40	2,38	2,394	− 0,8	− 0,3
1,78	2,30	2,26	2,294	− 1,7	− 0,3
2,05	2,20	2,16	2,193	− 1,8	− 0,3
2,39	2,10	2,07	2,091	− 1,4	− 0,4
2,79	2,00	1,97	1,989	− 1,5	− 0,6
3,29	1,90	1,88	1,893	− 1,0	− 0,4
3,92	1,80	1,78	1,789	− 1,1	− 0,6
4,71	1,70	1,70	1,679	0,0	− 1,2
5,72	1,60	1,57	1,571	− 1,9	− 1,8
7,04	1,50	1,47	1,456	− 2,0	− 2,9
8,79	1,40	1,37	1,348	− 2,1	− 3,7
11,16	1,30	1,24	1,244	− 4,6	− 4,3
14,44	1,20	1,14	1,150	− 5,0	− 4,2
19,10	1,10	1,04	1,062	− 5,5	− 3,5
26,60	1,00	0,97	0,975	− 3,0	− 2,5
32,00	0,95	0,93	0,942	− 2,1	− 0,8
39,00	0,90	0,89	0,906	− 1,1	− 0,7
48,70	0,85	0,86	0,866	+ 1,2	+ 1,9
61,80	0,80	0,83	0,824	+ 3,8	+ 3,0
80,50	0,75	0,78	0,782	+ 4,0	+ 4,3
110,00	0,70	0,72	0,725	+ 2,9	+ 3,6
175,00	0,65	0,63	0,635	− 3,1	− 2,3
275,00	0,60	0,55	0,551	− 8,3	− 8,2
380,00	0,55	0,50	0,500	− 9,1	− 9,1
475,00	0,50	0,48	0,476	− 4,0	− 4,8
580,00	0,45	0,43	0,423	− 4,4	− 6,0
690,00	0,40	0,37	0,367	− 7,5	− 8,25
795,00	0,35	0,32	0,321	− 8,6	− 8,3
1 052,00	0,29	0,28	0,276	− 1,1	− 4,8
1 180,00	0,30	0,29	0,283	− 3,3	− 5,7
1 400,00	0,35	0,33	0,331	− 5,7	− 5,4
1 620,00	0,40	0,40	0,402	0,0	+ 0,5
1 800,00	0,45	0,47	0,480	+ 4,4	+ 6,7