

Auxiliaries for lamps — Ballasts for discharge lamps (excluding tubular fluorescent lamps) — General and safety requirements

This European Standard EN 60922:1997 has the status of a
British Standard

ICS 29.140.30

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

BSI
Documents

AVA

Document Sharing Hub

National foreword

This British Standard is the English language version of EN 60922:1997. It is identical with IEC 60922:1997. It supersedes BS EN 60922:1991 which will be withdrawn on 1997-10-01.

The UK participation in its preparation was entrusted to Technical Committee CPL/34/3, Auxiliaries for lamps, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

From 1 January 1997, all IEC publications have the number 60000 added to the old number. For instance, IEC 27-1 has been renumbered as IEC 60027-1. For a period of time during the change over from one numbering system to the other, publications may contain identifiers from both systems.

Cross-references

Attention is drawn to the fact that CEN and CENELEC Standards normally include an annex which lists normative references to international publication with their corresponding European publications. The British Standards which implement these international or European publications may be found in the BSI Standards Catalogue under the section entitled “International Standards Correspondence Index”, or using the “Find” facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, page i and ii, the EN title page, pages 2 to 34 and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.

This British Standard, having been prepared under the direction of the Electrotechnical Sector Board, was published under the authority of the Standards Board and comes into effect on 15 September 1997

© BSI 11-1999

ISBN 0 580 27792 5

Amendments issued since publication

Amd. No.	Date	Comments

Contents

	Page
National foreword	Inside front cover
Foreword	ii
Text of EN 60922	5

English version

Auxiliaries for lamps — Ballasts for discharge lamps (excluding tubular fluorescent lamps) General and safety requirements

(IEC 60922:1997)

Appareils auxiliaires pour lampes Ballasts pour
lampes à décharge (à l'exclusion des lampes
tubulaires à fluorescence) — Prescriptions
générales et prescriptions de sécurité
(CEI 60922:1997)

Geräte für Lampen Vorschaltgeräte für
Entladungslampen (ausgenommen
röhrenförmige Leuchtstofflampen) —
Allgemeine und Sicherheitsanforderungen
(IEC 60922:1997)

This European Standard was approved by CENELEC on 1996-12-09. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B-1050 Brussels

Foreword

The text of document 34C/375/FDIS, future edition 2 of IEC 60922, prepared by SC 34C, Auxiliaries for lamps, of IEC TC 34, Lamps and related equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60922 on 1996-12-09.

This European Standard supersedes EN 60922:1991 and its amendment A2:1993.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 1997-10-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 1997-10-01

For products which have complied with EN 60922:1991 and its amendment A2:1993 before 1997-10-01, as shown by the manufacturer or by a certification body, this previous standard may continue to apply for production until 2002-10-01.

Annexes designated “normative” are part of the body of the standard.

Annexes designated “informative” are given for information only.

In this standard, Annex A, Annex B, Annex D, Annex E, Annex F and Annex ZA are normative and Annex C is informative.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60922:1997 was approved by CENELEC as a European Standard without any modification.

Contents

	Page	Page		Page
Foreword	2	Figure 1 — Test circuit for ballasts for lamps with internal starting devices	19	
Introduction	5	Figure 2 — Test arrangement for thermal test	20	
Section 1. General requirements	5	Figure 3 — Determination of pulse width	20	
1 General	5	Figure 4 — Relation between winding temperature and test duration	21	
1.1 Scope and object	5	Figure 5 — Assessment of claimed value of S	22	
1.2 Normative references	6	Figure 6 — Test corner for ballast heating test	23	
2 Definitions	6	Figure 7 — Test hood for ballast heating test	23	
3 General requirements	8	Table 1 — Dielectric strength test voltages	12	
4 General notes on tests	8	Table 2 — Maximum temperatures	14	
5 Classification	9	Table 3 — Limiting temperatures of windings under abnormal operating conditions and at 110 % of rated voltage for ballasts subjected to an endurance test duration of 30 days	15	
6 Marking	9	Table 4 — Limiting temperatures of windings under abnormal conditions and at 110 % of rated voltage for ballasts marked “D6” which are subjected to an endurance test duration of 60 days	15	
6.1 Mandatory markings	9	Table 5A — Minimum distances for a.c. (50 Hz/60 Hz) sinusoidal voltages	17	
6.2 Information to be provided, if applicable	10	Table 5B — Minimum distances for non-sinusoidal pulse voltages	17	
6.3 Other information	10	Table 6 — Theoretical test temperature for ballasts subjected to an endurance test duration of 30 days	24	
6.4 Marking shall be durable and legible	10	Table F.1	32	
Section 2. Safety requirements	10			
7 Protection against accidental contact with live parts	10			
8 Terminals	11			
9 Provisions for earthing	11			
10 Moisture resistance and insulation	11			
11 High-voltage impulse test	12			
12 Thermal endurance of windings	13			
13 Ballast heating	13			
14 Screws, current-carrying parts and connections	16			
15 Creepage distances and clearances	16			
16 Resistance to heat, fire and tracking	17			
17 Resistance to corrosion	18			
Annex A (normative) Thermal endurance test for windings	24			
Annex B (normative) The use of constants S other than 4 500 in T_w tests	25			
Annex C (informative) Draught-proof enclosure	27			
Annex D (normative) Method of selection of varistors	27			
Annex E (normative) Explanation to ballast temperatures	28			
Annex F (normative) Particular requirements for thermally protected ballasts	29			
Annex ZA (normative) Normative references to international publications with their corresponding European publications	33			

Introduction

This standard covers general and safety requirements for ballasts for discharge lamps, excluding tubular fluorescent lamps. Performance requirements for these ballasts are the subject of IEC 923.

NOTE Safety requirements ensure that electrical equipment constructed in accordance with these requirements does not endanger the safety of persons, domestic animals or property when the equipment is properly installed and maintained, and used in applications for which it was intended.

Relevant sections of this specification, e.g. thermal endurance tests for windings, apply also to ballasts which form an integral part of a luminaire and which cannot be tested separately.

The thermal characteristics of ballasts are specified by the rated maximum operating temperature of the winding (symbol t_w), which shall not be exceeded in order to ensure a sufficient length of life for the ballast when it is built into a luminaire. In addition, for ballasts which are subjected to abnormal conditions, the limiting temperature is given, which shall not be exceeded when the ballast is built into a luminaire. Moreover, an indication of the rated temperature rise of a winding (symbol Δt) may be added as an optional requirements.

For checking the rated maximum operating temperature t_w , this standard specifies an endurance test period for 30 days as the standard method. At the manufacturer's choice, optional endurance test periods of 60, 90 or 120 days may be used.

This standard permits the use of constants S other than 4 500 in t_w tests. If a claim is not made to the contrary, the endurance testing of ballasts is based on the constant S , given in Annex A, having a value of 4 500. A manufacturer may claim the use of other values if this can be justified by either of the tests specified.

For the present, this specification refers only to inductive ballasts for use with those types of lamp which are internationally the most popular in demand.

Many high-pressure sodium lamps and metal halide lamps are started by the superimposition of short repetitive voltage pulses on the normal ballast circuit voltage. These high-voltage pulses are often generated by electronic ignitors and, in some circuit arrangements, the pulses are applied to both lamp and ballast terminals.

It is therefore necessary to ensure that ballasts used in these types of circuit are capable of withstanding a suitable high voltage impulse test.

This standard specifies particular tests for ballasts designed for operating in a circuit with a starting device external to the lamp and for ballasts designed for operating lamps with an internal starting device.

Some ballasts incorporate internal or external surge voltage suppression devices, and therefore this specification includes test procedures, for this type of ballast, as it is necessary to ensure the safety of these devices, if fitted.

These requirements acknowledge that ballasts may be subjected to voltage pulses when lamp and ballasts are both in hot or cold conditions.

These requirements apply only to those circuits incorporating lamps the standardization of which is already completed, or is at present under discussion.

Section 1. General requirements

1 General

1.1 Scope and object

This standard specifies safety requirements for ballasts for discharge lamps such as high-pressure mercury vapour, low-pressure sodium vapour, high-pressure sodium vapour and metal halide lamps. Section 1 specifies general requirements and section 2 specifies thermal and mechanical requirements. The standard covers inductive ballasts for use on a.c. supplies up to 1 000 V at 50 Hz or 60 Hz associated with discharge lamps, having rated wattages, dimensions and characteristics as specified in the relevant IEC lamp standards according to IEC 188, IEC 192 and IEC 662.

Tests in this standard are type tests. Requirements for testing individual ballasts during production are not included.

NOTE 1 For certain types of discharge lamp an ignitor is required.

NOTE 2 Ballasts for tubular fluorescent discharge lamps are covered by IEC 920.

Particular requirements for thermally protected ballasts are given in Annex F.

1.2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 112:1979, *Method for determining the comparative and the proof tracking indices of solid insulating materials under moist conditions*.

IEC 188:1974, *High-pressure mercury vapour lamps*.

IEC 192:1973, *Low-pressure sodium vapour lamps*.

IEC 216, *Guide for the determination of thermal endurance properties of electrical insulating materials*.

IEC 249-1:1982, *Base materials for printed circuits — Part 1: Test methods*.

IEC 317, *Specifications for particular types of winding wires*.

IEC 417C: 1977, *Graphical symbols for use on equipment — Index, survey and compilation of the single sheets — Third supplement*.

IEC 529:1989, *Degrees of protection provided by enclosures (IP code)*.

IEC 598-1:1992, *Luminaires — Part 1: General requirements and tests*.

IEC 662:1980, *High pressure sodium vapour lamps*.

IEC 691:1993, *Thermal links — Requirements and application guide*.

IEC 695-2-1:1991, *Fire hazard testing — Part 2: Test methods — Section 1: Glow-wire test and guidance*.

IEC 695-2-2:1991, *Fire hazard testing — Part 2: Test methods — Section 2: Needle-flame test*.

IEC 730-2-3:1990, *Automatic electrical controls for household and similar use — Part 2: Particular requirements for thermal protections for ballasts for tubular fluorescent lamps*.

IEC 920:1990, *Ballasts for tubular fluorescent lamps — General and safety requirements*.

IEC 921:1988, *Ballasts for tubular fluorescent lamps — Performance requirements*.

IEC 922:1989, *Ballasts for discharge lamps (excluding tubular fluorescent lamps) — General and safety requirements*.

IEC 923:1988, *Ballasts for discharge lamps (excluding tubular fluorescent lamps) — Performance requirements*.

IEC 926:1995, *Auxiliaries for lamps — Starting devices (other than glow starters) — General and safety requirements*.

ISO 4046:1978, *Paper, board, pulp and related terms — Vocabulary*.

2 Definitions

For the purpose of this standard, the following definitions apply:

2.1 ballast

Unit inserted between the supply and one or more discharge lamps which, by means of inductance, capacitance, or a combination of inductance and capacitance serves mainly to limit the current of the lamp(s) to the required value. The ballast may consist of one or more separate components.

It may also include means for transforming the supply voltage and arrangements which help provide starting voltage, prevent cold starting, reduce stroboscopic effects, correct the power factor and/or suppress radio interference.

2.1.1

independent ballast

ballast which can be mounted separately outside a luminaire without any additional enclosure. This may consist of a built-in ballast housed in a suitable enclosure which provides all the necessary protection according to its markings

2.1.2**built-in ballast**

ballast exclusively designed to be built into a luminaire, a box, an enclosure or the like. The control gear compartment in the base of a road lighting column is considered to be an enclosure

2.1.3**integral ballast**

ballast which forms a non-replaceable part of a luminaire and which cannot be tested separately from the luminaire

2.2**reference ballast**

special inductive ballast designed for the purpose of providing comparison standards for use in testing ballasts and for the selection of reference lamps. It is essentially characterized by a stable voltage-to-current ratio, which is relatively uninfluenced by variations in current, temperature and magnetic surroundings, as outlined in Annex A of IEC 923

2.3**reference lamp**

lamp selected for testing ballasts which, when associated with a reference ballast, has electrical characteristics which are close the nominal values as stated in the relevant lamp standard

2.4**calibration current of a reference ballast**

value of the current on which are based the calibration and control of the reference ballast

NOTE Such a current should preferably be approximately equal to the running current of the lamps for which the reference ballast is suitable.

2.5**supply voltage**

voltage applied to the complete circuit of the lamp or lamps and ballast

2.6**supply current**

current supplied to the complete circuit of the lamp or lamps and ballast

2.7**working voltage**

highest r.m.s. voltage which may occur across any insulation, transients being neglected, in open-circuit conditions or during lamp operation, when the ballast is operated at its rated voltage

2.8**circuit power factor (symbol λ)**

power factor of the combination of a ballast and the lamp or lamps for which the ballast is designed

2.9**high power factor ballast**

ballast having a circuit power factor of at least 0,85 (leading or lagging)

NOTE The value 0,85 takes into account the distortion of the current waveform. For North America, a high power factor is defined as a power factor of at least 0,9.

2.10**rated maximum operating temperature of a capacitor case (symbol t_c)**

highest permissible temperature which may occur at any place on the outer surface under normal operating conditions

2.11**rated maximum operating temperature of a ballast winding (symbol t_w)**

temperature assigned by the manufacturer as the highest at which the ballast may be expected to have a service life of at least 10 years' continuous operation

2.12**rated temperature rise of a ballast winding (symbol Δt)**

temperature rise assigned by the manufacturer under the conditions specified in this standard

NOTE The specifications for the supply and mounting conditions of the ballasts are given in 13.2.

2.13**test duration of endurance test (symbol D)**

optional duration of the endurance test on which the temperature conditions are to be based

2.14**degradation of insulation of a ballast winding (symbol S)**

constant which determines the degradation of ballast insulation

2.15**type test**

test or series of tests made on a type-test sample for the purpose of checking compliance of the design of a given product with the requirements of the relevant standard

2.16**type-test sample**

sample consisting of one or more similar units submitted by the manufacturer or responsible vendor for the purpose of a type test

2.17**high voltage impulse**

intentionally applied aperiodic transient voltage which rises rapidly to a peak value and then falls, usually less rapidly, to zero. Such an impulse is, in general, well represented by the sum of two exponentials

NOTE The term "impulse" is to be distinguished from the term "surge" which refers to transients occurring in electrical equipment or networks in service.

2.18**ignitor**

starting device intended to generate voltage pulses to start discharge lamps and which does not provide for the preheating of electrodes (IEC 926 and IEC 927)

3 General requirements

Ballasts shall be so designed and constructed that in normal use they operate without danger to the user or surroundings. Capacitors and other components incorporated in ballasts shall comply with the requirements of the appropriate IEC standard.

Thermally protected ballasts shall comply with the requirements of Annex F.

In general, compliance of ballasts and other elements is checked by carrying out all the tests specified.

The enclosure of independent ballasts shall, in addition, comply with the requirements of IEC 598-1, including the classification and marking requirements of that standard.

4 General notes on tests

4.1 Tests according to this standard are type tests.

NOTE The requirements and tolerances permitted by the standard are related to testing of a type test sample submitted for that purpose. The compliance of the type test sample does not ensure compliance of the whole production of a manufacture with this safety standard. Conformity of production is the responsibility of the manufacturer, and should include routine tests and quality assurance in addition to type testing.

4.2 The tests are carried out in the order of the clauses, unless otherwise specified.

4.3 The type test is carried out on one sample consisting of eight ballasts submitted for the purpose of the type test (see definition 2.15). Seven ballasts are for the endurance test and one for all other tests. For conditions of compliance for the endurance test, see clause 12.