

Low-voltage switchgear and controlgear —

Part 7-3: Ancillary equipment — Safety requirements for fuse terminal blocks

The European Standard EN 60947-7-3:2002 has the status of a
British Standard

ICS 29.120.99; 29.130.20

National foreword

This British Standard is the official English language version of EN 60947-7-3:2002. It is identical with IEC 60947-7-3:2002, including Corrigendum March 2003.

The UK participation in its preparation was entrusted by Technical Committee PEL/17, Switchgear, controlgear and HV-LV co-ordination, to Subcommittee PEL/17/2, Low-voltage switchgear and controlgear, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the *BSI Catalogue* under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

This British Standard, having been prepared under the direction of the Electrotechnical Sector Policy and Strategy Committee, was published under the authority of the Standards Policy and Strategy Committee on 27 November 2002

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 38, an inside back cover and a back cover.

The BSI copyright date displayed in this document indicates when the document was last issued.

Sidelining in this document indicates the most recent changes by amendment.

Amendments issued since publication

Amd. No.	Date	Comments
14469 Corrigendum No. 1	16 July 2003	Indicated by a sideline

© BSI 16 July 2003

ISBN 0 580 40818 3

EUROPEAN STANDARD

EN 60947-7-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2002

ICS 29.120.99; 29.130.20

English version

**Low-voltage switchgear and controlgear
Part 7-3: Ancillary equipment -
Safety requirements for fuse terminal blocks
(IEC 60947-7-3:2002)**

Appareillage à basse tension
Partie 7-3: Matériels accessoires -
Prescriptions de sécurité
pour les blocs de jonction à fusible
(CEI 60947-7-3:2002)

Niederspannungsschaltgeräte
Teil 7-3: Hilfseinrichtungen -
Sicherheitsanforderungen
für Sicherungs-Reihenklemmen
(IEC 60947-7-3:2002)

This European Standard was approved by CENELEC on 2002-10-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

© 2002 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Ref. No. EN 60947-7-3:2002 E

AVA Documents
Document Sharing Hub

Foreword

The text of document 17B/1193/FDIS, future edition 1 of IEC 60947-7-3, prepared by SC 17B, Low-voltage switchgear and controlgear, of IEC TC 17, Switchgear and controlgear, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60947-7-3 on 2002-10-01.

This Part 7-3 shall be read in conjunction with EN 60947-1 and EN 60947-7-1. The provisions of the general rules dealt with in EN 60947-1 and the requirements for terminal blocks of EN 60947-7-1 are applicable to this standard, where specifically called for. Clauses and subclauses, tables, figures and annexes thus applicable are identified by reference to "IEC 60947-1" or "IEC 60947-7-1", e.g. 1.2 of IEC 60947-1, table 4 of IEC 60947-7-1 or annex A of IEC 60947-1.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2003-07-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2005-10-01

Annexes designated "normative" are part of the body of the standard.

Annexes designated "informative" are given for information only.

In this standard, annexes A, C and ZA are normative and annex B is informative.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60947-7-3:2002 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60127-6	NOTE	Harmonized as EN 60127-6:1994 (not modified).
IEC 60715	NOTE	Harmonized as EN 60715:2001 (not modified).
IEC 61180-1	NOTE	Harmonized as EN 61180-1:1994 (not modified).
IEC 61180-2	NOTE	Harmonized as EN 61180-2:1994 (not modified).

CONTENTS

INTRODUCTION.....	4
1 General	5
1.1 Scope.....	5
1.2 Normative references	6
2 Definitions	6
3 Classification.....	7
4 Characteristics	7
4.1 Fuse-links	7
4.2 Rated power dissipation value.....	8
4.3 Rated and limiting values	8
5 Product information	8
5.1 Marking	8
5.2 Additional information.....	9
5.3 Marking on the packing unit.....	9
6 Normal service, mounting and transport conditions.....	9
7 Constructional and performance requirements.....	10
7.1 Constructional requirements.....	10
7.2 Performance requirements	11
7.3 Electromagnetic compatibility (EMC)	12
8 Tests	12
8.1 Kinds of test	12
8.2 General	12
8.3 Verification of mechanical characteristics	12
8.4 Verification of electrical characteristics.....	15
8.5 Verification of thermal characteristics	19
8.6 Verification of EMC characteristics	26
Annex A (normative) Gauges	27
Annex B (informative) Power dissipation values P_V and P_{VK}	28
Annex C (normative) Order of tests and number of specimens	36
Annex ZA (normative) Normative references to international publications with their corresponding European publications	37
Bibliography.....	38

INTRODUCTION

The standard for fuse terminal blocks covers not only the terminal block requirements but also takes into account the specifications of the cartridge fuse-links according to IEC 60127-1 and IEC 60127-2. A connection between these two standards is made by adding (adapting) the fundamental specifications of cartridge fuse-links (rated current, rated voltage, maximum voltage drop and maximum sustained power dissipation for cartridge fuse-links with the dimension of 5 mm × 20 mm or 6,3 mm × 32 mm with their different response characteristics) to the IEC 60947-7-1 requirements for terminal blocks. By this means, it is possible to judge the quality of the product "fuse terminal blocks".

An important fact when using such cartridge fuse-links with fuse terminal blocks is that fuses heat up much less under rated load than they would do under overload conditions. The rated load is the result of rated current and maximum voltage drop. But there is a considerably increased power dissipation under overload conditions, equalling the maximum sustained power dissipation loss according to IEC 60127-2.

In industrial applications, single fuse terminal blocks are used within an arrangement of terminal blocks or many of them forming an arrangement on their own. This means that the same current and fuse-link will result in different heat emissions. Furthermore, it should be taken into account that apart from the general full range fuse (for overload and short-circuit protection), some fuse terminal blocks are exclusively used for short-circuit protection according to IEC 60364-4-43, e.g. in control circuits, where no overloads occur (i.e. safety coils, indicator lights or similar equipment).

Consequently there are four different types of application that need to be described in the catalogue or indicated on the terminal block. For more information, see annex B.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 7-3: Ancillary equipment – Safety requirements for fuse terminal blocks

1 General

1.1 Scope

This part of IEC 60947 applies to fuse terminal blocks with screw-type or screwless-type clamping units for the connection of rigid (solid or stranded) or flexible copper conductors for the reception of cartridge fuse-links in accordance with IEC 60127-2, intended primarily for industrial or similar use in circuits not exceeding 1 000 V a.c., up to 1 000 Hz or 1 500 V d.c., and having a maximum short-circuit breaking capacity of 1 500 A.

They are intended for installation in electrical equipment with enclosures which surround the fuse terminal blocks to such an extent that they are accessible only with the aid of a tool.

For certain applications, for example in control circuits, the fuse terminal blocks may be designed exclusively for short-circuit protection.

NOTE This standard may be used as a guide for fuse terminal blocks for the reception of special cartridge fuse-links which do not meet the requirements of IEC 60127-2.

The object of this standard is to specify safety requirements and test methods for the mechanical, electrical and thermal characteristics of fuse terminal blocks, to ensure the compatibility between terminal blocks and standardized fuse-links.

This standard may be used as a guide for

- fuse terminal blocks requiring the fixing of special devices to the conductors, for example quick connect terminations or wrapped connections, etc.;
- fuse terminal blocks providing direct contact to the conductors by means of edges or points penetrating the insulation, for example insulation displacement connections, etc.

Where applicable in this standard, the term “clamping unit” has been used instead of the term “terminal”. This is taken into account in case of reference to IEC 60947-1.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60127-1:1988, *Miniature fuses – Part 1: Definitions for miniature fuses and general requirements for miniature fuse-links*
Amendment 1 (1999)

IEC 60127-2:1989, *Miniature fuses – Part 2: Cartridge fuse-links*

IEC 60216-1:2001, *Guide for the determination of thermal endurance properties of electrical insulating materials – Part 1: General guidelines for ageing procedures and evaluation of test results*

IEC 60695-2-2:1991, *Fire hazard testing – Part 2: Test methods – Section 2: Needle-flame test*
Amendment 1 (1994)

IEC 60947-1:1999, *Low-voltage switchgear and controlgear – Part 1: General rules*
Amendment 1 (2000)
Amendment 2 (2001)

IEC 60947-7-1:2002, *Low-voltage switchgear and controlgear – Part 7-1: Ancillary equipment – Terminal blocks for copper conductors*

ISO 3:1973, *Preferred numbers – Series of preferred numbers*

ISO 4046:1978, *Paper, board, pulp and related terms – Vocabulary*

2 Definitions

For the purpose of this part of IEC 60947, definitions given in IEC 60947-7-1, together with the following definitions, apply.

2.1

fuse terminal block

terminal block base with a fuse-carrier

2.2

terminal block base

insulating part of a fuse terminal block carrying the clamping units and contacts, intended to be fixed to a support

2.3

fuse-carrier

movable part of a fuse terminal block designed to carry the cartridge fuse-link and enable its exchange

NOTE The fuse-carrier can be mechanically coupled with the terminal block base.

2.4

maximum power dissipation of the cartridge fuse-link

2.4.1 in the case of an overload of P_{V1} , equal to the maximum sustained power dissipation as given in IEC 60127-2

2.4.2 in the case of a nominal load of P_{V2} , equal to the power dissipation value calculated from the nominal values, i.e. the maximum voltage drop and the rated current in accordance with IEC 60127-2

2.5

separate arrangement of a fuse terminal block

arrangement of a single fuse terminal block between adjacent terminal blocks (without additional function) (see figure 2)

NOTE Mounting of fuse terminal blocks side by side with a spacing that securely prevents any mutual thermal influence is also considered as a separate arrangement.

2.6

compound arrangement of fuse terminal blocks

arrangement of two or several fuse terminal blocks side by side or the arrangement of a single fuse terminal block between adjacent terminal blocks with additional function (see figure 3)

NOTE Additional functions within the meaning of this standard include all components which may thermally influence the function of the fuse terminal block due to their own power dissipation.

2.7

rated power dissipation value of a fuse terminal block

maximum permissible value with which the fuse terminal block can be continuously loaded by the cartridge fuse-link under specified conditions

2.8

rated cross-section

value, stated by the manufacturer, of a rigid (solid or stranded) or flexible conductor to which certain thermal, mechanical and electrical requirements are referred

2.9

rated connecting capacity

range of cross-sections and/or the number of conductor cross-sections for which the fuse terminal block is designed

3 Classification

Fuse terminal blocks are classified as follows:

- a) fuse terminal block with separate fuse-carrier, e.g. screw type or plug-in type;
- b) fuse terminal block with mechanically coupled fuse-carrier, e.g. hinged type.

4 Characteristics

4.1 Fuse-links

The fuse links shall be in accordance with IEC 60127-2.

4.2 Rated power dissipation value

4.2.1 Overload and short-circuit protection (P_V)

The rated value (P_V) is the maximum permissible power dissipation value of a fuse terminal block under overload and short-circuit conditions related to an ambient temperature of 23 °C.

4.2.2 Exclusive short-circuit protection (P_{VK})

The rated value (P_{VK}) is the maximum permissible power dissipation value of a fuse terminal block, which can accept a fuse-link with an equal or lower sustained power dissipation used under exclusive short-circuit conditions and related to an ambient temperature of 23 °C (see annex B).

4.3 Rated and limiting values

4.3.1 Rated voltages

Subclause 4.3.1 of IEC 60947-7-1 applies.

4.3.2 Void

4.3.3 Standard cross-sections

Subclause 4.3.3 of IEC 60947-7-1 applies.

4.3.4 Rated cross-section

Subclause 4.3.4 of IEC 60947-7-1 applies.

4.3.5 Rated connecting capacity

Subclause 4.3.5 of IEC 60947-7-1 applies with the following addition.

The conductor cross-section specified for the temperature-rise test according to 8.4.5 shall be included in the range of the rated connecting capacity.

4.3.6 Working voltage

See 2.5.52 of IEC 60947-1.

5 Product information

5.1 Marking

A fuse terminal block shall be marked in a durable and legible manner with the following:

- a) the name of the manufacturer or a trade mark, by which the manufacturer can be readily identified;
- b) a type reference permitting its identification in order to obtain relevant information from the manufacturer or his catalogue;
- c) energy flow direction, if required to ensure protection against electric shock, according to 7.1.8, e.g. line-load marking or →.

5.2 Additional information

The following information shall be stated by the manufacturer, if applicable, e.g. in the manufacturer's data sheet or catalogue or on the packing unit:

- a) IEC 60947-7-3, if the manufacturer claims compliance with this standard;
- b) the rated cross-section;
- c) the rated connecting capacity, if different from table 2 of IEC 60947-7-1, including the number of conductors simultaneously connectable;
- d) the rated insulation voltage of the terminal block base and the fuse-carrier, if applicable;
- e) the working voltage or working voltage range, primarily determined by the fuse-link or by additional components, e.g. illuminated indicators;
- f) rated impulse voltage;

NOTE This value may be marked on the fuse terminal block only if the rated insulation voltage or the working voltage is also marked on the fuse terminal block, e.g. 250 V/4 kV or 250/4 kV.

- g) rated value of the power dissipation (P_V) and rated current of the fuse-link as declared by the manufacturer
 - in case of separate arrangement,
 - in case of compound arrangement;
- h) maximum power dissipation (P_{VK}) and rated current of the fuse-link
 - in case of separate arrangement,
 - in case of compound arrangement;
- i) operating conditions, if different from clause 6;
- j) size of the fuse-link.

5.3 Marking on the packing unit

- a) "No overload protection" in case of fuse terminal blocks which are designed exclusively for short-circuit protection.
- b) "No overload protection in compound arrangement" in case of fuse terminal blocks which are designed for overload only in separate arrangement and short-circuit protection in compound arrangement.

6 Normal service, mounting and transport conditions

Clause 6 of IEC 60947-1 applies with the following addition.

6.1.1 Ambient temperature

The rated value of the power dissipation refers to an ambient temperature of 23 °C.

In those cases where the ambient temperature differs from 23 °C, this fact shall be taken into account with respect to the function. See derating curves in annex B.

7 Constructional and performance requirements

7.1 Constructional requirements

7.1.1 Clamping units

Subclause 7.1.1 of IEC 60947-7-1 applies.

7.1.2 Mounting

Fuse terminal blocks shall be provided with means that allow them to be securely attached to a rail or a mounting surface.

Tests shall be made in accordance with 8.3.2.

NOTE Information on mounting rails can be found in IEC 60715.

7.1.3 Clearances and creepage distances

Clearances and creepage distances shall be designed for overvoltage category III and pollution degree 3.

The requirements in accordance with IEC 60947-7-1 apply with the following additions.

Clearances and creepage distances shall be checked where the fuse terminal block is assembled for normal use, e.g. fuse-carrier and gauge no. 3 or no. 6 is inserted in the terminal block base in accordance with table A.1.

The following aspects shall be considered:

a) functional insulation:

- insulation between live parts with different potential;
- insulation between live parts to adjacent fuse terminal blocks of same type of construction and size;

b) basic insulation:

- insulation between live parts and the fixing support.

Compliance is checked by measurement. Subclause 8.3.3.4 of IEC 60947-1 applies.

7.1.4 Terminal identification and marking

Subclause 7.1.4 of IEC 60947-7-1 applies.

7.1.5 Void

7.1.6 Rated cross-section and rated connecting capacity

Subclause 7.1.6 of IEC 60947-7-1 applies.

7.1.7 Void

7.1.8 Actuating conditions

The fuse terminal block shall be so designed that live parts are not accessible when it is assembled, installed and operated under normal use.

The safety from finger touch of live parts of the fuse-carrier shall be ensured during replacement of the fuse-link, unless otherwise specified by the manufacturer. The safety from finger touch shall be maintained until the fuse-carrier and the fuse-link are de-energized.

7.2 Performance requirements

7.2.1 Mechanical requirements during actuation

Fuse terminal blocks shall have an adequate mechanical strength so as to withstand the stresses which occur during operation.

Compliance shall be checked in accordance with 8.3.4 and 8.3.5.

7.2.2 Electrical requirements

7.2.2.1 Dielectric strength

The dielectric strength shall be adequate.

Verification shall be made by an impulse voltage test and a power-frequency withstand test on the fuse terminal block assembled by means of gauges as in normal use, in accordance with 8.4.3.

7.2.2.2 Contact resistance

The test shall be carried out in accordance with 8.4.4. If not otherwise specified, the mean value of the contact resistance shall not exceed 10 mΩ. The value of an individual measurement shall not exceed 15 mΩ.

7.2.2.3 Temperature rise of clamping units

The temperature rise of the clamping units shall not exceed 45 K.

Compliance shall be checked in accordance with 8.4.5.

7.2.2.4 Electrical performance after ageing (for screwless-type fuse terminal blocks only)

Fuse terminal blocks shall be capable of withstanding the ageing test comprising 192 temperature cycles in accordance with 8.4.7.

7.2.3 Thermal requirements

7.2.3.1 Rated value of power dissipation

A fuse terminal block shall be so designed that it can use a fuse-link with rated current and maximum sustained power dissipation, according to IEC 60127-1, lower or equal to the rated power dissipation value of the fuse terminal block and at an ambient air temperature of 23 °C (see annex B).

In this way, the temperature of 85 °C on the surface of the actuating elements of the fuse-carrier and the relative temperature index (RTI) of the insulating material as stated by the manufacturer in accordance with IEC 60216-1 shall not be exceeded.

Compliance shall be checked in accordance with 8.5.2.