

BS EN 61158-5-19:2014



BSI Standards Publication

Industrial communication networks — Fieldbus specifications

Part 5-19: Application layer service definition — Type 19 elements

bsi.

...making excellence a habit.
AVA Documents™
Document Sharing Hub

National foreword

This British Standard is the UK implementation of EN 61158-5-19:2014. It is identical to IEC 61158-5-19:2014. It supersedes BS EN 61158-5-19:2012 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee AMT/7, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014.
Published by BSI Standards Limited 2014

ISBN 978 0 580 79461 2
ICS 25.040.40; 35.100.70; 35.110

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 October 2014.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 61158-5-19

October 2014

ICS 25.040.40; 35.100.70; 35.110

Supersedes EN 61158-5-19:2012

English Version

**Industrial communication networks - Fieldbus specifications -
Part 5-19: Application layer service definition - Type 19 elements
(IEC 61158-5-19:2014)**

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 5-19: Définition des services de la
couche application - Eléments de type 19
(CEI 61158-5-19:2014)

Industrielle Kommunikationsnetze - Feldbusse -
Teil 5-19: Dienstfestlegungen des Application Layer
(Anwendungsschicht) - Typ 19-Elemente
(IEC 61158-5-19:2014)

This European Standard was approved by CENELEC on 2014-09-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2014 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Foreword

The text of document 65C/763/FDIS, future edition 3 of IEC 61158-5-19, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-5-19:2014.

The following dates are fixed:

- latest date by which the document has to be (dop) 2015-06-22
implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2017-09-22
standards conflicting with the
document have to be withdrawn

This document supersedes EN 61158-5-19:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-5-19:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61131-1	NOTE	Harmonized as EN 61131-1.
IEC 61784-1	NOTE	Harmonized as EN 61784-1.
IEC 61784-2	NOTE	Harmonized as EN 61784-2.
IEC 61800-1	NOTE	Harmonized as EN 61800-1.
IEC 61800-7 Series	NOTE	Harmonized as EN 61800-7 Series (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61131-3	-	Programmable controllers - Part 3: Programming languages	EN 61131-3	-
IEC 61158-1	2014	Industrial communication networks - Fieldbus specifications - Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series	EN 61158-1	2014
IEC 61158-3-16	2007	Industrial communication networks - Fieldbus specifications - Part 3-16: Data-link layer service definition - Type 16 elements	EN 61158-3-16	2008
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic reference model: The basic model	-	-
ISO/IEC 8822	-	Information technology - Open Systems Interconnection - Presentation service definition	-	-
ISO/IEC 8824-1	-	Information technology - Abstract Syntax Notation One (ASN.1): Specification of basic notation	-	-
ISO/IEC 9545	-	Information technology - Open Systems Interconnection - Application layer structure	-	-
ISO/IEC 10646	-	Information technology - Universal Coded Character Set (UCS)	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
ISO/IEC/IEEE 60559	-	Information technology - Microprocessor Systems - Floating-Point arithmetic	-	-

CONTENTS

INTRODUCTION.....	6
1 Scope.....	7
1.1 General.....	7
1.2 Specifications.....	8
1.3 Conformance.....	8
2 Normative references	8
3 Terms, definitions, abbreviations, symbols and conventions	9
3.1 ISO/IEC 7498-1 terms	9
3.2 ISO/IEC 8822 terms	9
3.3 ISO/IEC 9545 terms	9
3.4 ISO/IEC 8824-1 terms	9
3.5 Fieldbus application-layer specific definitions	10
3.6 Abbreviations and symbols.....	11
3.7 Conventions	12
4 Concepts.....	14
5 Data type ASE.....	14
5.1 Bitstring types	15
5.2 Unsigned types	16
5.3 Integer types	16
5.4 Floating Point types.....	17
5.5 Structure types.....	17
6 Communication model specification.....	18
6.1 Concepts.....	18
6.2 ASEs.....	18
6.3 ARs.....	30
6.4 Summary of AR classes	32
6.5 Permitted FAL services by AREP role.....	32
Bibliography.....	34
Table 1 – Read service parameters.....	20
Table 2 – Write service parameters.....	21
Table 3 – Read service parameters.....	22
Table 4 – Write service parameters.....	23
Table 5 – Notify service parameters.....	23
Table 6 – Get network status service parameters.....	25
Table 7 – Get device status service parameters.....	25
Table 8 – Network status change report service parameters	26
Table 9 – Station status change report service parameters	26
Table 10 – Set device status service parameters	27
Table 11 – Enable RTC service parameters	28
Table 12 – Enable hotplug service parameters.....	29
Table 13 – Notify RTC service parameters.....	29
Table 14 – Disable RTC service parameters	30

Table 15 – AREP (SVC) class summary.....	32
Table 16 – AREP (RTC-MS) class summary	32
Table 17 – AREP (RTC-CC) class summary.....	32
Table 18 – FAL services by AR type	33

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This standard defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-19: Application layer service definition – Type 19 elements

1 Scope

1.1 General

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 19 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the fieldbus application layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- a) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- b) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This standard specifies the structure and services of the fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal application programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill the application layer services as defined in this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61131-3, *Programmable controllers – Part 3: Programming languages*

IEC 61158-1:2014, *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

IEC 61158-3-16:2007, *Industrial communication networks – Fieldbus specifications – Part 3-16: Data-link layer service definition – Type 16 elements*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10646, *Information technology – Universal Coded Character Set (UCS)*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC/IEEE 60559, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

3 Terms, definitions, abbreviations, symbols and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions as defined in these publications apply:

3.1 ISO/IEC 7498-1 terms

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation
- g) application transaction
- h) real open system
- i) transfer syntax

3.2 ISO/IEC 8822 terms

- a) abstract syntax
- b) presentation context

3.3 ISO/IEC 9545 terms

- a) application-association
- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type
- h) application-service-element
- i) application control service element

3.4 ISO/IEC 8824-1 terms

- a) object identifier
- b) type

3.5 Fieldbus application-layer specific definitions

3.5.1

coded character set

code

set of unambiguous rules that establish a character set and one-to-one relationship between the characters of the set and their representation by one or more bit combinations

3.5.2

cross communication

direct data transfer between slave devices (without active involvement of master)

3.5.3

cycle time

duration of a communication cycle

3.5.4

cyclic data

part of a telegram, which does not change its meaning during cyclic operation of the network

3.5.5

device

slave in the communication network

Note 1 to entry: Examples are a power drive system as defined in the IEC 61800 standard family, I/O stations as defined in the IEC 61131 standard family, etc.

3.5.6

device status

four adjacent octets inside the acknowledge telegram containing status information for each device

3.5.7

element

part of IDNs

Note 1 to entry: Each IDN has 7 elements, whereas each one has a specific meaning (e.g., number, name, data).

3.5.8

hot plug

possibility to open the communication network and insert or remove slaves while the network is still in real-time operation

3.5.9

identification number

designation of operating data under which a data block is preserved with its attribute, name, unit, minimum and maximum input values, and the data

3.5.10

loopback

mode by which a device passes on a received telegram to the same port and to the other port, either changed or unchanged

3.5.11

master

node, which assigns the other nodes (i.e., slaves) the right to transmit