

Industrial-process control — Safety of analyser houses

The European Standard EN 61285:2004 has the status of a
British Standard

ICS 25.040.40; 13.110

National foreword

This British Standard is the official English language version of EN 61285:2004. It is identical with IEC 61285:2004. It supersedes BS EN 61285:1995 which is withdrawn.

The UK participation in its preparation was entrusted by Technical Committee GEL/65, Measurement and control, to Subcommittee GEL/65/4, Process instruments for gas and liquid analysis, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the *BSI Catalogue* under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 27 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 6 January 2005

© BSI 6 January 2005

ISBN 0 580 45194 1

EUROPEAN STANDARD

EN 61285

NORME EUROPÉENNE

EUROPÄISCHE NORM

December 2004

ICS 25.040.40; 13.110

Supersedes EN 61285:1994

English version

**Industrial-process control -
Safety of analyser houses
(IEC 61285:2004)**

Commande des processus industriels -
Sécurité des bâtiments pour analyseurs
(CEI 61285:2004)

Prozessautomatisierung -
Sicherheit von Analysengeräteräumen
(IEC 61285:2004)

This European Standard was approved by CENELEC on 2004-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

© 2004 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Foreword

The text of document 65D/107/FDIS, future edition 2 of IEC 61285, prepared by SC 65D, Analyzing equipment, of IEC TC 65, Industrial-process measurement and control, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61285 on 2004-11-01.

This European Standard replaces EN 61285:1994.

This new edition includes minor updates to several sections and references.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2005-08-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2007-11-01 |

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 61285:2004 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60079-10	NOTE	Harmonized as EN 60079-10:2003 (not modified).
IEC 61115	NOTE	Harmonized as EN 61115:1993 (not modified).

CONTENTS

FOREWORD.....	2
INTRODUCTION.....	4
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 Location of AHs and connection within the process plant areas	8
4.1 Response time	8
4.2 Utilities	8
4.3 Safety	8
4.4 Access	9
5 Design, construction and layout of AHs	9
5.1 General	9
5.2 General requirements	9
5.3 Dimensions and layout	10
5.4 Structural requirements	10
5.5 Equipment	10
5.6 Labelling/instructions/documentation	12
6 Explosion protection of AHs.....	13
6.1 General	13
6.2 General requirements	13
6.3 Protection of AHs against explosion hazards by means of artificial ventilation	13
6.4 Protection of AHs against explosion hazards by means of natural ventilation	16
7 Measures to prevent health hazards to personnel in AHs.....	17
7.1 General	17
7.2 Guidelines	17
7.3 General requirements	17
7.4 Safety measures	18
7.5 External hazards	19
7.6 Additional measures for abnormal working conditions.....	19
7.7 Labelling/instructions/documentation	19
Annex A (normative) Leakage risk of modules in AHs	21
Annex B (informative) Ventilation calculation (assumes STP conditions).....	23
Annex ZA (normative) Normative references to international publications with their corresponding European publications	26
Bibliography.....	27
Table A.1 – Module evaluation	22

INTRODUCTION

Process analysers measure the characteristics of a process stream continuously and automatically. The process sample is introduced automatically and the system is designed for unattended operation and minimal maintenance.

This document is designed to set forth minimum safety requirements for typical analyser houses (AHs). It shall be superseded in all cases by national, local, or corporate requirements, which may be more stringent.

The measured output is transmitted continuously for process control, operator action or documentation. Process analysers are used for

- environmental analysis;
- personnel protection;
- equipment protection;
- quality measurement/control;
- process control (plant optimization);
- energy conservation.

In the simplest case, the analyser sensor is mounted directly in the material to be measured, and there is no need to extract a sample. In other cases, a sample is extracted from the main stream and transported to the analyser. The system may include many functional elements such as

- sample extraction;
- sample transport;
- sample conditioning;
- sample stream disposal and/or return to process;
- utilities and auxiliary materials supply;
- stream switching;
- automatic or manual calibration and validation system;
- signal processing;
- performance monitoring and control.

(See IEC 61115.)

Analyser elements can be arranged modularly and located separately. There are advantages in grouping analysers and systems and further advantages in enclosing them. Advantages include

- lower cost of installation of utilities and signals;
- protection of personnel and complex modules and equipment from adverse ambient conditions;
- ease of maintenance;
- safety.

Analysers are constructed to various standards: some are ex-proof, some intrinsically safe, some suitable for Zone 2 and some suitable only for a non-hazardous area. Not all analysers are available in all variants.

Process plants usually include all zones – 0, 1, 2 and non-hazardous.

The selection of the AH location, the source of ventilation air, and the classification of the house interior and its analysers is an economic exercise.

Factors include the distance from the sample point to the AH , classification of the area around the AH, distance from the AH to the source of non-hazardous air, and the cost of analysers of classification appropriate to the house interior.

INDUSTRIAL-PROCESS CONTROL – SAFETY OF ANALYSER HOUSES

1 Scope

This International Standard describes the physical requirements for the safe operation of the process analyser measuring system installed in an AH in order to ensure its protection against fire, explosion and health hazards. This standard extends beyond IEC 60079-16 to include houses with Zone 2 interiors and to apply to toxic hazards. (Appropriate national guidelines on toxic hazards are to be followed.)

This standard does not address facilities where dust is the hazard.

Clause 4 addresses the location of the AH and connection within the process plant areas.

Clause 5 addresses the design, construction and layout of the AH. It does not address parts of the analyser measuring system installed in other locations such as sample conditioning rooms (SCR) or switchgear rooms.

Clause 6 addresses measures for reducing the danger of explosion for AHs while permitting maintenance of equipment with the power on and the case open.

NOTE For most fluids, the major constraint is that the concentration of vapours, which are hazardous for personnel, is lower than the lower explosive (flammable) limit (LEL) (see Clause 7).

Using n-Pentane as an example, the LEL is 1,4 % or $14\,000 \times 10^{-6}$. The level immediately dangerous to life or health (which is the maximum level from which a worker could escape within 30 min without any escape-impairing symptoms or any irreversible health effects) is only 0,5 % or $5\,000 \times 10^{-6}$.

Classification of a house interior as Zone 1 may imply that no technician can enter without protective equipment such as breathing gear. Placing an AH in a Zone 1 area would usually imply that no technician could approach the house without wearing protective equipment.

Clause 7 addresses those measures for protecting personnel from materials in the atmosphere of AHs that are hazardous to health.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-16:1990, *Electrical apparatus for explosive gas atmospheres – Part 16: Artificial ventilation for the protection of analyser(s) houses*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

analyser cabinet

small housing in which analysers are installed individually or grouped together. Maintenance is performed from outside the cabinet with the door(s) open

3.2

analyser shelter

structure with one or more sides open and free from obstruction to the natural passage of air, in which one or more analysers are installed. The maintenance of the analysers is normally performed in the protection of the shelter

3.3

analyser house (AH)

enclosed building or part of a building containing process analysers and associated equipment where streams for analysis are brought in and which is regularly entered by authorized personnel

NOTE Within the scope of this standard, the term AH is used regardless of the structure configuration as either a room, cabinet or building and whether or not it is an integral part of, or attached to, another structure.

3.4

sample conditioning room SCR

room that is separated from the AH and has modules for sample conditioning, auxiliary material, or sample disposal equipment.

3.5

toxic material

material that is a health hazard by inhalation from the surrounding atmosphere. Atmospheric routes such as skin absorption or ingestion are not addressed

3.6

safety back-up

additional personnel, in constant contact with a person or persons in dangerous working conditions, who could assist or get additional help

3.7

external and internal hazards

distinction is made between "external" and "internal" explosion hazards. An external explosion hazard exists when the AH is erected at a location where flammable material can be introduced from the outside resulting in dangerous concentrations of flammable gases and vapours inside the AH. An internal explosion hazard exists when a flammable mixture can result from the leakage of samples or auxiliary supplies inside the AH

3.8

lower explosive limit LEL lower flammable limit LFL

volume ratio of the flammable gas or vapour in air below which an explosive gas atmosphere will not be formed

3.9

explosive gas atmosphere

mixture with air, under atmospheric conditions, of a flammable material in the form of gas or vapour in which, after ignition, combustion spreads through the unconsumed mixture