

Conduit systems for cable management —

Part 1: General requirements

The European Standard EN 61386-1:2004 has the status of a
British Standard

ICS 29.120.10

National foreword

This British Standard is the official English language version of EN 61386-1:2004, including Corrigendum April 2004. It is identical with IEC 61386-1:1996, including amendment 1:2000. It supersedes BS EN 50086-1:1994 which will be withdrawn on 30 June 2008.

The UK participation in its preparation was entrusted to Technical Committee PEL/213, Cable management, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the *BSI Catalogue* under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 37 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 22 June 2004

© BSI 22 June 2004

ISBN 0 580 43798 1

EUROPEAN STANDARD

EN 61386-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2004

ICS 29.120.10

Supersedes EN 50086-1:1993
Incorporates Corrigendum April 2004

English version

Conduit systems for cable management
Part 1: General requirements
(IEC 61386-1:1996 + A1:2000)

Systèmes de conduits pour la gestion
du câblage
Partie 1: Règles générales
(CEI 61386-1:1996 + A1:2000)

Elektroinstallationsrohrsysteme für
elektrische Energie und für Informationen
Teil 1: Allgemeine Anforderungen
(IEC 61386-1:1996 + A1:2000)

This European Standard was approved by CENELEC on 2003-09-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

© 2004 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Ref. No. EN 61386-1:2004 E



Documents
Document Sharing Hub

Foreword

The text of the International Standard IEC 61386-1:1996 + A1:2000, prepared by SC 23A, Cable management systems, of IEC TC 23, Electrical accessories, was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 61386-1 on 2003-09-23.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2004-10-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) –

This European Standard supersedes EN 50086-1:1993 + corrigendum February 2001. However, EN 50086-1:1993 remains valid until all the parts 2 that are used in conjunction with it have been withdrawn.

NOTE The date of withdrawal (dow) is left open until the situation for EN 50086-2-4 is clarified by the CEN/CLC JWG on "Conduits buried underground" (BT Decision D118/051).

This part 1 of EN 61386 is to be used in conjunction with the appropriate part 2, which contains clauses to supplement or modify the corresponding clauses in part 1, to provide the relevant particular requirements for each type of product. A conduit system which conforms to this standard is deemed safe for use.

In this standard, the following print types are used:

- requirements: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type.

Annexes ZA and ZB have been added by CENELEC.

The contents of the corrigendum of April 2004 have been included in this copy.

Endorsement notice

The text of the International Standard IEC 61386-1:1996 + A1:2000 was approved by CENELEC as a European Standard without any modification.

CONTENTS

Clause		Page
1	Scope	4
2	Normative references.....	4
3	Definitions	4
4	General requirements	6
5	General conditions for tests	6
6	Classification	7
7	Marking and documentation	10
8	Dimensions.....	10
9	Construction	11
10	Mechanical properties.....	12
11	Electrical properties.....	16
12	Thermal properties.....	18
13	Fire hazard	19
14	External influences	21
15	Electromagnetic compatibility	23
Figures		
1	Arrangement for compression test	24
2	Impact test apparatus	25
3	Assembly of conduit and conduit fittings for bonding test	26
4	Arrangement for insulation resistance and electric strength test – Rigid conduit	27
5	Arrangement for insulation resistance and electric strength test – Pliable and flexible conduit.....	28
6	Enclosure for flame propagation resistance test.....	29
7	Arrangement for flame propagation resistance test	30
8	Test apparatus for burning resistance to heat	31
Annex A (normative) – Classification coding for conduit systems		32
Annex B (normative) Determination of material thickness.....		35
Annex ZA (normative) Normative references to international publications with their corresponding European publications		36
Annex ZB (informative) Tests to be carried out for conduit systems complying with EN 50086-1:1993.....		37

CONDUIT SYSTEMS FOR ELECTRICAL INSTALLATIONS –

Part 1: General requirements

1 Scope

This part of IEC 1386 specifies requirements and tests for conduit systems, including conduits and conduit fittings, for the protection and management of insulated conductors and/or cables in electrical installations or in communication systems up to 1000 V a.c. and/or 1500 V d.c. This standard applies to metallic, non-metallic and composite conduit systems, including threaded and non-threaded entries which terminate the system. This standard does not apply to enclosures and connecting boxes which come within the scope of IEC 670.

NOTES

- 1 Certain conduit systems may also be suitable for use in hazardous atmospheres. Regard should then be taken of the extra requirements necessary for equipment to be installed in such conditions.
- 2 Earthing conductors may or may not be insulated.

2 Normative references

The following normative documents contain provisions which through reference in this text, constitute provisions of this part of IEC 1386. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this part of IEC 1386 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 417: 1973, *Graphical symbols for use on equipment. Index, survey and compilation of the single sheets, as well as all of the supplements A to L*

IEC 423: 1993, *Conduits for electrical purposes – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 529: 1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 670: 1989, *General requirements for enclosures for accessories for household and similar fixed electrical installations*

IEC 695-2-1/1:1994, *Fire hazard testing – Part 2: Test methods – Section 1/Sheet 1: Glow-wire end-product test and guidance*

IEC 695-2-4/1: 1991, *Fire hazard testing – Part 2: Test methods – Section 4/Sheet 1: 1 kW nominal pre-mixed test flame and guidance*

3 Definitions

For the purposes of this International Standard, the following definitions apply:

3.1 **conduit system:** Closed wiring system consisting of conduits and conduit fittings for the protection and management of insulated conductors and/or cables in electrical or communication installations, allowing them to be drawn in and/or replaced, but not to be inserted laterally.

3.2 **conduit:** Part of a closed wiring system of general circular cross-section for insulated conductors and/or cables in electrical or communication installations, allowing them to be drawn in and/or replaced.

3.3 **conduit fitting:** Device designed to join one or more components of a conduit system, or for them to change direction.

3.4 **metallic conduit and/or conduit fitting:** Conduit or conduit fitting which consists of metal only.

3.5 **non-metallic conduit and/or conduit fitting:** Conduit or conduit fitting which consists uniquely of non-metallic material and which has no metallic components whatsoever.

3.6 **composite conduit and/or conduit fitting:** Conduit or conduit fitting comprising both metallic and non-metallic materials.

3.7 **non-flame propagating conduit and/or conduit fitting:** Conduit or conduit fitting which is liable to catch fire as a result of an applied flame, but in which the flame does not propagate, and which extinguishes itself within a limited time after the flame is removed.

3.8 **plain conduit:** Conduit in which the profile is even in the longitudinal section. (see note to 3.9).

3.9 **corrugated conduit:** Conduit in which the profile is corrugated in the longitudinal section.

NOTE – Both annular and helical corrugated conduits are permissible, and a combination of both corrugated and plain conduit is possible.

3.10 **rigid conduit:** Conduit which cannot be bent, or which can only be bent with the help of a mechanical aid, with or without special treatment.

3.11 **pliable conduit:** Conduit which can be bent by hand with reasonable force, and which is not intended for frequent flexing.

3.12 **flexible conduit:** Conduit which can be bent by hand with reasonable small force, and which is intended to flex frequently throughout its life.

3.13 **self-recovering conduit:** Pliable conduit which deforms when a transverse force is applied for a short time and which, after removal of this force, returns close to its original shape within a further short time.

3.14 **threadable conduit and conduit fitting:** Conduit and conduit fittings which carry a thread for connection; or in or on which a thread can be formed.

3.15 **non-threadable conduit and conduit fitting:** Conduit and conduit fittings which are suitable for connection only by means other than threads.

3.16 **terminating conduit fitting:** conduit fitting that terminates a conduit system

3.17 **external influence:** Factors which may affect the conduit system.

NOTE – Examples of such factors are a presence of water, oil or building materials, low and high temperatures, and corrosive or polluting substances.

3.18 **hot dip galvanising:** Coating of zinc, and zinc-iron alloy layers, obtained by dipping prepared iron or steel articles in molten zinc.

Note – Under some circumstances, the whole coating may consist of zinc-alloy layers.

3.19 **sherardizing:** Diffusion process in which articles are heated in close contact with zinc dust and inert operating media.

NOTE – The process is normally carried out in a slowly rotating closed container at a temperature in the region of 385 °C. The corrosion resistance is proportional to the coating thickness, which can be controlled.

4 General requirements

4.1 Conduit and conduit fittings within the scope of this standard shall be so designed and constructed that in normal use their performance is reliable and they provide protection to the user or surroundings.

When assembled in accordance with manufacturer's instructions as part of a conduit system, conduits and conduit fittings shall provide mechanical and, where required, electrical protection of the insulated conductors and cables contained therein.

4.2 The protective properties of the joint between the conduit and conduit fitting shall not be less than that declared for the conduit system.

4.3 Conduit and conduit fittings shall withstand the stresses likely to occur during transport, storage, recommended installation practice and application.

4.4 Compliance is checked by carrying out all specified relevant tests.

5 General conditions for tests

5.1 Tests in accordance with this standard are type tests.

5.2 Unless otherwise specified, the tests shall be carried out at an ambient temperature of $(20 \pm 5) ^\circ\text{C}$.

5.3 Unless otherwise specified, each test shall be made on three new samples.

NOTE – Certain tests, for instance the checking of dimensions, do not affect a change in the property of the samples; therefore these samples are considered as new samples and can be used for further tests.

5.4 Samples of non-metallic and composite conduits and conduit fittings shall be conditioned for at least 240 h, at a temperature of $(23 \pm 2) ^\circ\text{C}$ and a relative humidity between 40 % and 60 %. All tests shall be carried out immediately after general conditioning.

5.5 Unless otherwise specified, the samples for each test shall be in a clean and new condition, with all parts in place and mounted as in normal use. After checking dimensions in accordance with clause 8, and unless otherwise specified in the relevant test, the conduit fittings shall be assembled with adequate lengths of conduit of the type for which they are intended. Due regard shall be taken of the manufacturer's instructions, especially where force is required in the assembly of the joint.

NOTE – Where similarities are claimed, the selection of representative fittings for test purposes can be agreed between the manufacturer, or responsible vendor, and the testing station.

5.6 Where the conduit entries are part of the detachable or loose type conduit fitting, the detachable conduit fitting shall be capable of being assembled again, after the test, according to the manufacturer's instructions without loss of the declared properties according to clause 6.

5.7 Unless otherwise specified, three samples are subjected to the tests, and the requirements are satisfied if the tests are met.

If only one of the samples does not satisfy a test, due to an assembly or a manufacturing defect, that test and any preceding one which may have influenced the result of the test shall be repeated, and also the tests which follow shall be carried out in the required sequence on another full set of samples, all of which shall comply with the requirements.

NOTE – If the additional set of samples is not submitted at the same time, a failure of one sample will entail a rejection. The applicant, when submitting the first set of samples, may also submit an additional set of samples which may be used, should one sample fail. The testing station will then, without further request, test the additional set of samples and will reject them only if a further failure occurs.

5.8 When toxic or hazardous processes are used, due regard shall be taken of the safety of the persons within the test area.

5.9 Conduit systems which are used as an integral part of other equipment shall also be tested in accordance with the relevant standard for that equipment.

6 Classification

NOTE – Annex A shows the classification coding format for declared properties of the conduit system, which may be incorporated in the manufacturer's literature.

6.1 *According to mechanical properties*

6.1.1 Resistance to compression

- 1 Very light
- 2 Light
- 3 Medium
- 4 Heavy
- 5 Very heavy

6.1.2 Resistance to impact

- 1 Very light
- 2 Light
- 3 Medium
- 4 Heavy
- 5 Very heavy

6.1.3 Resistance to bending

- 1 Rigid
- 2 Pliable
- 3 Pliable/Self-recovering
- 4 Flexible

6.1.4 Tensile strength

- 1 Very light
- 2 Light
- 3 Medium
- 4 Heavy
- 5 Very heavy

6.1.5 Suspended load capacity

- 1 Very light
- 2 Light
- 3 Medium
- 4 Heavy
- 5 Very heavy

6.2 According to temperature

6.2.1 Lower temperature range

Table 1 – Lower temperature range

Classification (1st numeral)	Transport, application and installation – Temperature not less than: °C
1X	+ 5
2X	– 5
3X	– 15
4X	– 25
5X	– 45

6.2.2 Upper temperature range

Table 2 – Upper temperature range

Classification (2nd numeral)	Application and installation – Temperature not more than: °C
X1	60
X2	90
X3	105
X4	120
X5	150
X6	250
X7	400

6.3 According to electrical characteristics

6.3.1 With electrical continuity characteristics

6.3.2 With electrical insulating characteristics

6.3.3 With electrical continuity and insulating characteristics

6.4 According to resistance to external influences

6.4.1 Protection against ingress of solid objects: protection in accordance with IEC 529 to a minimum of IP3X

6.4.2 Protection against ingress of water: protection in accordance with IEC 529 to a minimum of IPX0

6.4.3 Resistance against corrosion

6.4.3.1 Without protection

6.4.3.2 With protection as detailed in table 10

6.5 According to resistance to flame propagation

6.5.1 Non-flame propagating

6.5.2 Flame propagating

7 Marking and documentation

7.1 The conduit shall be marked on the product with a trade mark or a name identifying the manufacturer or responsible vendor.

The conduit shall in addition be marked in such a way that it can be identified in the manufacturer's, or responsible vendor's, literature.

7.1.1 The conduit may also be marked with the classification code, which shall be in accordance with annex A, and which shall include at least the first four digits.

7.1.2 The manufacturer shall be responsible for indicating the compatibility of parts within a conduit system.

7.2 The conduit fitting shall be marked in accordance with 7.1, on the product wherever possible, but where this is impractical, then the mark may be on a label attached to the product, or on the box or carton containing the fittings.

7.3 Flame propagating material shall be orange in colour. It shall not be coloured orange by painting or other superficial means.

Non-flame propagating material may be of any colour except yellow, orange or red, unless clearly marked on the product to be of non-flame propagating material.

7.4 Earthing facilities shall be indicated by the symbol for protective earth in accordance with IEC 417, symbol 417-IEC-5019-a. This marking shall not be placed on easily removable parts, for example screws.

7.5 Compliance with 7.1 to 7.4 is checked by inspection.

7.6 *The marking shall be durable and clearly legible*

Compliance is checked by inspection and by rubbing the marking by hand for 15 s with a piece of cloth soaked with water, and again for 15 s with a piece of cloth soaked with petroleum spirit.

NOTES

1 Petroleum spirit is defined as the aliphatic solvent hexane with a content of aromatics of maximum 0,1% volume, a kauri-butanol value of 29, initial boiling point 65 °C, a dry point 69 °C, and density of approximately 0,68 g/cm³.

2 Marking may be applied, for example, by moulding, pressing, engraving, printing, adhesive labels, or water slide transfers.

3 Marking made by moulding, pressing or engraving is not subjected to this test.

After the test, the marking shall be legible.

8 Dimensions

8.1 Threads and outside diameters, where appropriate, shall comply with IEC 423.

Compliance is checked by means of the gauges specified in IEC 423.