

WC pans with integral trap

The European Standard EN 997:1999 has the status of a British Standard

ICS 91.140.70

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

BSI
Documents



Document Sharing Hub

National foreword

This British Standard is the English language version of EN 997:1999. It supersedes BS 5503-2:1977 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee B/503, Sanitary appliances, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled “International Standards Correspondence Index”, or by using the “Find” facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 25 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

This British Standard, having been prepared under the direction of the Sector Committee for Building and Civil Engineering, was published under the authority of the Standards Committee and comes into effect on 15 November 1999

© BSI 11-1999

ISBN 0 580 30808 1

EUROPEAN STANDARD

EN 997

NORME EUROPÉENNE

EUROPÄISCHE NORM

July 1999

ICS 91.040.70

English version

WC pans with integral trap

Cuvettes de WC à siphon intégré

Klosettbecken mit angeformtem Geruchverschluß

This European Standard was approved by CEN on 24 February 1999.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CEN

European Committee for Standardization
Comité Européen de Normalisation
Europäisches Komitee für Normung

Central Secretariat: rue de Stassart 36, B-1050 Brussels

© 1999 Copyright reserved to CEN members.

Ref. No. EN 997 : 1999 E

Contents

	Page
Foreword	3
1 Scope	4
2 Definitions	4
3 Functional requirements	5
3.1 Depth of water seal	5
3.2 Flushing requirements	5
3.2.1 General	5
3.2.2 Wash of bowl.....	6
3.2.3 Flushing of toilet paper.....	6
3.2.4 Flushing of single plastic ball	6
3.2.5 Flushing of fifty small plastic balls.....	6
3.2.6 Over-splashing.....	6
3.2.7 After-flush volume	7
3.3 Water absorption.....	7
3.4 Static load	7
4 Test methods	7
4.1 Depth of water seal	7
4.2 Flushing tests	7
4.2.1 Apparatus.....	7
4.2.2 Preparation to test.....	7
4.2.3 Sawdust test.....	7
4.2.4 Toilet paper test	8
4.2.5 Single plastic ball test	8
4.2.6 Fifty plastic balls test.....	8
4.2.7 Over-splashing test	8
4.2.8 After-flush volume test	8
4.3 Determination of water absorption.....	9
4.4 Load test	10
5 Classification	10
5.1 Nominal flushing volumes	10
5.2 Flushing devices	11
5.3 Nominal flushing volumes and flushing devices	11
6 Marking	11
6.1 Permanent marking.....	11
6.2 Marking by label.....	12
7 Quality control	12
Annex A (normative) Valve-type test flushing cistern	13
Annex B (normative) Valveless-type test flushing cistern	15
Annex C (normative) Test rig for pressure flush valve	17
Annex D (normative) Test rig for after-flush volume test	19
Annex E (normative) Basket method	21
Annex F (normative) Preparation of test specimens	22
Annex G (informative) Quality control	24
Annex H (informative) Classification, flushing volume and regulations of countries on interchangeability of flushing devices	25

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 163 "Sanitary appliances", the Secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2000, and conflicting national standards shall be withdrawn at the latest by January 2000.

This standard is one of a series of standards for sanitary appliances. Supporting standards are those for flushing devices and connecting dimensions.

This standard includes annexes, seven normative and one informative, covering the current interchangeability of independent WC pans by flushing volume class and flushing device acceptable in the different Member States of the European Union and European Free Trade Association.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This standard specifies constructional and performance requirements together with test methods for WC pans with integral trap used for domestic purposes made from vitreous china or stainless steel which are flushed by a nominal volume of 6 l, 7 l or 9 l.

This standard is not applicable to WC pans flushed with other volumes, squatting WC's and WC pans without integral trap.

2 Definitions

For the purpose of this standard, the following definitions apply:

2.1 pedestal WC pan: Floor mounted WC pan that has an integral base.



2.2 wall-hung WC pan: WC pan cantilevered clear of the floor.



2.3 wash-out WC pan: WC pan in which excrement falls first into a shallow water filled bowl, before being removed by the flushing water.



2.4 wash-down WC pan: WC pan in which excrement falls directly into the trap before being removed by the flushing water.



2.5 siphonic WC pan WC pan in which excrement is removed by siphonage induced by the flushing water.



2.6 close-coupled suite: Combination of a WC pan and flushing cistern directly coupled into a functional unit.



2.7 one-piece WC pan: WC pan manufactured with an integral flushing cistern.



2.8 independent WC pan: WC pan suitable for the connection with a flushing cistern or a pressure flush valve.



2.9 valve-type flushing cistern: Cistern with integral valve outlet device for storage and discharge of a defined volume of flushing water for removal of excrement from a WC pan.



2.10 valveless-type flushing cistern:

Cistern with integral siphonic outlet device for storage and discharge of a defined volume of flushing water for removal of excrement from a WC pan.



2.11 pressure flush valve:

Valve directly connected to the water supply which delivers a pre-determined volume of flushing water for removal of excrement from a WC pan.



NOTE: Drawings are diagrammatic only

3 Functional requirements

Table 1 correlates the functional requirements of this standard to the Essential Requirements of the Council Directive of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (89/106/EEC).

Table 1

Functional requirements	Essential Requirements		
	Hygiene Health Environment	Safety in use	Energy economy
Depth of water seal	X		
Flushing tests	X		
Flushing volume	X		X
Water absorption	X		
Static load		X	

3.1 Depth of water seal

When tested in accordance with 4.1 the depth of the water seal shall be not less than 50 mm.

3.2 Flushing requirements

3.2.1 General

Table 2 correlates the flushing requirements to the WC pan type, flushing volume and flushing device type.

Table 2

WC pan	Nominal flushing volume (litres)	Flushing device	Wash of bowl (3.2.2)	Flushing of toilet paper (3.2.3)	Flushing of single ball (3.2.4)	Flushing of 50 balls (3.2.5)	Over-splashing (3.2.6)	After-flush volume (3.2.7)
Close-coupled suites and one-piece WC pans	9	Valve-type flushing cistern	X	X		X	X	
	7	Valve-type flushing cistern	X	X		X	X	
		Valveless-type flushing	X	X	X		X	
	6	Valve-type flushing cistern	X	X			X	X
		Valveless-type flushing cistern	X	X	X		X	X
Independent WC pans	9	Valve-type flushing cistern	X	X		X	X	
		Pressure flush valve	X	X		X	X	
	7	Valve-type flushing cistern	X	X		X	X	
		Valveless-type flushing cistern	X	X	X		X	
		Pressure flush valve	X	X		X	X	
	6	Valve-type flushing cistern	X	X			X	X
		Valveless-type flushing cistern	X	X	X		X	X
		Pressure flush valve	X	X			X	X

The efficiency of flushing excrement is simulated by the following requirements.

3.2.2 Wash of bowl

When tested in accordance with **4.2.3**, the arithmetic average of any unflushed area below the rim and above the surface of the water in the trap shall not be more than 50 cm² after 5 flushing operations.

3.2.3 Flushing of toilet paper

When tested in accordance with **4.2.4**, 12 sheets of toilet paper shall be flushed out of the WC pan a minimum of 4 times out of 5 tests.

3.2.4 Flushing of single plastic ball

When tested in accordance with **4.2.5**, the plastic ball shall be flushed out of the WC pan a minimum of 4 times out of 5 tests.

3.2.5 Flushing of fifty small plastic balls

When tested in accordance with **4.2.6**, after 5 tests, each with 50 balls, a minimum of 85% of the balls shall be flushed out of the WC pan.

3.2.6 Over-splashing

When tested in accordance with **4.2.7**, flushing water shall not splash beyond the rim of the bowl and wet the floor. Only a few small drops are permissible.

3.2.7 After-flush volume

When tested in accordance with 4.2.8, an after-flush volume of 2.5 l or 2.8 l as appropriate is required.

3.3 Water absorption

When tested in accordance with 4.3, the arithmetic average for water absorption of glazed ceramic WC pans shall not exceed 0,5 % by mass.

3.4 Static load

When tested in accordance with 4.4, wall-hung and non-ceramic pedestal WC pans shall withstand a loading of (400 ± 5) kg without showing any evidence of cracking or permanent deformation.

4 Test methods

4.1 Depth of water seal

Install the WC pan in accordance with 4.2.2. Flush the WC pan and measure the height from the invert of the trappage back plate to the surface of the water.

4.2 Flushing tests

4.2.1 Apparatus

Independent WC pans are to be tested with one or any combination of the following separate flushing devices as indicated by the manufacturer:

Valve-type flushing cistern	Type A (see annex A)
Valveless-type flushing cistern	Type B (see annex B)
Pressure flush valve	Type C (see annex C)

For interchangeability of independent WC pans and flushing devices the test requirements shall be fulfilled for any combination (see Tables 3 and 5 and annex H).

For close-coupled suites and one-piece WC pans see Table 4 and annex D.

4.2.2 Preparation to test

Independent WC pans: Install the pedestal or wall-hung WC pan to be tested on a firm flat horizontal or vertical surface as appropriate. Connect a flushing device in accordance with annex A, B or C.

Close-coupled suites and one-piece WC pans: Install the suite or the one-piece WC pan on a firm flat horizontal or vertical surface as appropriate using the flushing device provided and specified by the manufacturer. The flushing volume shall be verified for the class of the WC pan (see Table 4 and annex D).

4.2.3 Sawdust test

4.2.3.1 Test material

20 g of fine dry wooden sawdust.

4.2.3.2 Test method

Moisten the complete inner surface of the WC pan below the flushing rim and above the surface of the water in the trap. Immediately afterwards, sprinkle the sawdust as completely and evenly as possible over the moistened surface. Flush the WC pan and measure any unwashed area. Repeat this procedure 5 times.

© BSI 11-1999