BS EN IEC 60730-2-14:2019+A2:2021



BSI Standards Publication

Automatic electrical controls

Part 2-14: Particular requirements for electric actuators

Documents
Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

National foreword

This British Standard is the UK implementation of EN IEC 60730-2-14:2019+A2:2021. It is derived from IEC 60730-2-14:2017 incorporating amendment A1:2019 and A2:2021. It supersedes BS EN IEC 60730-2-14:2019, which will be withdrawn on 26 November 2024.

The texts of IEC amendment 1:2019, CENELEC amendment 2:2021, and IEC amendment 2:2021 have been provided in their entirety at the end of this document. BSI's policy of providing consolidated content remains unchanged; however, in the interest of expediency, in this instance BSI have chosen to collate the relevant content at the beginning of this document.

The UK participation in its preparation was entrusted to Technical Committee CPL/72, Electrical control devices for household equipment and appliances.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2022
Published by BSI Standards Limited 2022

ISBN 978 0 539 15421 4

ICS 29.120.01; 97.120

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 28 February 2019.

Amendments/corrigenda issued since publication

Date	Text affected
31 March 2022	Implementation of IEC amendment A1:2019: collated at end of document
31 March 2022	Implementation of CENELEC amendment A2:2021 incorporating IEC amendment A2:2021 collated at end of document

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN IEC 60730-2-14

February 2019

ICS 29.120.01; 97.120

Supersedes EN 60730-2-14:1997

English Version

Automatic electrical controls - Part 2-14: Particular requirements for electric actuators (IEC 60730-2-14:2017)

Dispositifs de commande électrique automatiques - Partie 2-14: Exigences particulières pour les actionneurs électriques (IEC 60730-2-14:2017)

Automatische elektrische Regel- und Steuergeräte für den Hausgebrauch und ähnliche Anwendungen - Teil 2-14: Besondere Anforderungen an elektrische Stellantriebe (IEC 60730-2-14:2017)

This European Standard was approved by CENELEC on 2019-01-16. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2019 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 60730-2-14:2019 E

Documents
Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

European foreword

The text of document 72/1079/FDIS, future edition 2 of IEC 60730-2-14, prepared by IEC/TC 72 "Automatic electrical controls" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60730-2-14:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2019-10-16
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-01-16

This document supersedes EN 60730-2-14:1997.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60730-2-14:2017 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated :

IEC 60034 (series)	NOTE	Harmonized in EN 60034 series.
IEC 60730-2-8:2000 + A1:2002	NOTE	Harmonized in EN 60730-2-8:2002 (modified) + A1:2003 (modified).

Documents
Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

CONTENTS

FOREWORD ... 3
1 Scope and normative references ... 5
2 Terms and definitions ... 6
3 General requirements ... 7
4 General notes on tests ... 7
5 Rating ... 7
6 Classification ... 7
7 Information ... 8
8 Protection against electric shock ... 9
9 Provision for protective earthing ... 9
10 Terminals and terminations ... 9
11 Constructional requirements ... 9
12 Moisture and dust resistance ... 9
13 Electric strength and insulation resistance ... 9
14 Heating ... 9
15 Manufacturing deviation and drift ... 10
16 Environmental stress ... 11
17 Endurance ... 11
18 Mechanical strength ... 11
19 Threaded parts and connections ... 11
20 Creepage distances, clearances and distances through solid insulation ... 11
21 Resistance to heat, fire and tracking ... 11
22 Resistance to corrosion ... 11
23 Electromagnetic compatibility (EMC) requirements – Emission ... 11
24 Components ... 12
25 Normal operation ... 12
26 Electromagnetic compatibility (EMC) requirements – Immunity ... 12
27 Abnormal operation ... 12
28 Guidance on the use of electronic disconnection ... 14
Annex H (normative) Requirements for electronic controls ... 15
Annex AA (normative) Regional differences ... 20
Annex BB (informative) Specific regional requirements in Japan ... 21
Bibliography ... 22

Table 1 – (7.2 of edition 3) – Required information and methods of providing information ... 8

Documents
Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

AUTOMATIC ELECTRICAL CONTROLS –

Part 2-14: Particular requirements for electric actuators

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60730-2-14 has been prepared by IEC technical committee 72: Automatic electrical controls.

This second edition cancels and replaces the first edition, published in 1995, its Amendment 1 (2001) and its Amendment 2 (2007). This edition constitutes a technical revision. This edition includes the following significant technical changes with respect to the previous edition:

- adapting it to the 5th Ed of IEC 60730-1,
- addition of checking electric actuators with action 1.AB or 2AB, and
- modification of tests under abnormal condition.

This Part 2-14 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the 5th edition of that standard (2013). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

AVA Documents Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

This part 2-14 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for electric actuators.

Where this part 2-14 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

Where no change is necessary part 2-14 indicates that the relevant clause or subclause applies.

In the development of a fully international standard it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" notes regarding differing national practice are contained in the following subclauses:

- Table 1,
- 27.2.3.1.

In this publication:

1) The following print types are used:
   - requirements proper: in roman type;
   - *test specifications: in italic type;*
   - explanatory matter: in smaller roman type.
   - Defined terms: **bold type**.
2) Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
72/1079/FDIS	72/1100/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

AUTOMATIC ELECTRICAL CONTROLS –

Part 2-14: Particular requirements for electric actuators

1 Scope and normative references

This clause of Part 1 is applicable except as follows:

1.1 *Replacement:*

This part 2-14 applies to **electric actuators** for use in, on, or in association with equipment for household and similar use. The equipment may use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof.

NOTE Throughout this standard the word "equipment" means "appliance and equipment."

EXAMPLE 1 **Electric actuators** for appliances within the scope of IEC 60335.

This International Standard is applicable to **controls** for building automation within the scope of ISO 16484.

This part 2-14 also applies to automatic **electrical controls** for equipment that may be used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications.

EXAMPLE 2 **Controls** for commercial catering, heating and air-conditioning equipment.

This part 2-14 is also applicable to individual **electric actuators** utilized as part of a **control system** or **controls**, which are mechanically integral with **multifunctional controls** having non-electrical outputs.

EXAMPLE 3 Independently mounted water valves, **controls** in smart grid **systems** and **controls** for building automation systems within the scope of ISO 16484-2.

This part 2-14 does not apply to automatic **electric actuators** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard.

1.1.1 This part 2-14 applies to the inherent safety, to the **operating values**, **operating times** and **operating sequences** where such are associated with equipment safety and to the testing of **electric actuators** used in or in association with equipment.

NOTE Requirements for specific **operating values**, **operating times** and **operating sequences** may be given in the standards for appliances and equipment.

This standard is also applicable to the **functional safety** of **low complexity safety related systems** and **controls**.

This part 2-14 does not apply to **electric actuators** which are mechanically integrated with valves covered by a separate part 2, e.g. IEC 60730-2-8.

This part 2-14 does not apply to electric motors, requirements for which are contained in IEC 60034.

1.1.2 Requirements for manual switches not integral with an **electric actuator** are contained in IEC 61058-1.

AVA Documents Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

1.1.3 *Replacement*

This part 2-14 applies to a.c. or d.c. powered **electric actuators** with a rated voltage not exceeding 690 V a.c. or 600 V d.c.

1.1.4 *Replacement*

This part 2-14 does not take into account the **response value** of an **automatic action** of an **electric actuator**, if such a **response value** is dependent upon the method of mounting the **electric actuator** in the equipment. Where a **response value** is of significant purpose for the protection of the **user**, or surroundings, the value defined in the appropriate household equipment or as determined by the manufacturer shall apply.

2 Terms and definitions

This clause of part 1 is applicable, except as follows:

2.2 Definitions of types of control according to purpose

Additional definition:

2.2.101
electric actuator
device in which a **prime mover** is mechanically linked to a valve, damper or similar device and which responds to **initiation** from a **control** or switch

Note 1 to entry: The **electric actuator** moves the valve, damper or similar device to defined positions and may also incorporate other functions, such as electric interlock switches and/or feedback.

2.3 Definitions relating to the function of controls

Additional definitions:

2.3.101
multi-position action
action denoting that the **electric actuator** operates in such a manner that only two or more defined positions can be reached

2.3.102
modulating action
action denoting that the **electric actuator** operates in such a manner that every position between two defined limits can be reached

2.3.103
travel time
time taken by an **electric actuator** to move from one defined position to another

2.3.104
stroke
distance travelled by a linear actuator

2.3.105
angular rotation
operating movement of a rotary actuator given in radians or degrees

Documents
Document Sharing Hub
Full document details: BS EN IEC 60730-2-14:2019+A2:2021

3 General requirements

This clause of Part 1 is applicable.

4 General notes on tests

This clause of Part 1 is applicable.

5 Rating

This clause of Part 1 is applicable.

6 Classification

This clause of Part 1 is applicable, except as follows:

6.1 According to nature of supply

6.1.1 Control for a.c. only

Replacement:

Electric actuators which are designed for a.c. supply only shall not be used on d.c. supply.

6.3 According to their purpose

Additional subclauses:

6.3.101 – electric actuator;

6.3.102 – electric actuator as a component of a multi-purpose control or **system**.

NOTE See also H.6.18 according to classes of **control** functions.

6.4 According to features of automatic action

Additional subclauses:

6.4.101 Type of action

6.4.101.1 Multi-position action

6.4.101.2 Modulating action

6.4.102 Type of movement

6.4.102.1 Rotary movement

6.4.102.2 Linear movement

6.4.3 *Additional subclauses:*

6.4.3.101 –an action in which the **electric actuator** assumes a predefined position upon loss of the electrical supply and/or upon loss of the **control** signal (type 1.AA or type 2.AA);

AVA Documents Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021

6.4.3.102 – an action in which the **electric actuator** operates normally between 1,1 V_R and 0,85 V_R inclusive and in which it either operates normally or assumes a predefined position between 0,85 V_R and a declared lower percentage of rated voltage (type 1.AB or type 2.AB).

6.11 According to number of automatic cycles (A) of each automatic action

Modification:

Subclauses 6.11.8 to 6.11.12 inclusive are not applicable.

7 Information

This clause of part 1 is applicable except as follows:

Table 1 – (7.2 of edition 3) – Required information and methods of providing information

Information		Clause or subclause	Method
Modifications:			
7	The type of load controlled by each external circuit	6.2, 14	D
22	Temperature limits of the actuator, if T_{min} lower than 0 °C or T_{max} other than 60 °C	6.7, 14,5, 14.7, 17.3	D
23	Temperature limits of mounting surfaces (T_s)	6.12.2, 14.1, 17,3	D
27	Number of automatic cycles (A) for each **automatic action** [102]	6.11	X
28	Not applicable		
34	Detail of any limitation of **operating time** [101, 103]	14, 17	C
37	Not applicable		
38	Not applicable		
43	Not applicable		
44	Not applicable		
47	Not applicable		
Additional requirements:			
101	Impedance protected motor	14.4.101	D
102	Thermally protected motor	14.4.102	D
103	Type of movement	2.3.104, 2.3.105, 6.4.102	D
104	Type of action	2.3.101, 2.3.102, 6.4.101	D
105	Maximum rated mechanical load	14.4, 15.5.102	D
106	**Travel time**	2.3.103, 15.5.101, 15.5.102	D
107	**Stroke**	2.3.104	D
108	**Angular rotation**	2.3.105	D
109	Response time and method of measurement (for types 1.AA or 2.AA)	6.4.3.101 15.5.102	D
110	Lower percentage of rated voltage (for types 1.AB or 2.AB)	6.4.3.102	D
Additional notes:			
101	This may be given as a maximum percentage of ON time of the power supply to avoid over-heating of the windings in a declared period of time.		
102	**Electric actuators** are subjected to a minimum of 6 000 cycles.		
103	For integrated and incorporated **electric actuators**, the method is D.		

Documents
Document Sharing Hub
Full document details: BS EN IEC 60730-2-14:2019+A2:2021

7.3.1 *Addition:*

NOTE Actuators of class II construction provided with a cord for connection to the **fixed wiring** which does not have a plug fitted may carry the symbol for class II construction.

8 Protection against electric shock

This clause of part 1 is applicable.

9 Provision for protective earthing

This clause of Part 1 is applicable.

10 Terminals and terminations

This clause of Part 1 is applicable.

11 Constructional requirements

This clause of Part 1 is applicable except as follows:

11.4 Actions

Additional subclauses:

11.4.101 A type 1.AA or 2.AA action shall operate such that for any duration of voltage interruption which is greater than the response time declared in Table 1, requirement 109, the actuator assumes the predefined position and resumes normal **operation** upon restoration of the supply.

Compliance is checked by test.

11.4.102 A type 1.AB or 2.AB action shall operate normally between 1,1 V_R and 0,85 V_R inclusive and shall respond as declared by the manufacturer at voltages below 0,85 V_R and the voltage declared in Table 1, requirement 110.

Compliance is checked by test.

12 Moisture and dust resistance

This clause of Part 1 is applicable.

13 Electric strength and insulation resistance

This clause of Part 1 is applicable.

14 Heating

This clause of Part 1 is applicable except as follows:

14.3 Not applicable.

Documents
Document Sharing Hub
Full document details: BS EN IEC 60730-2-14:2019+A2:2021

14.4 *Replacement of the first paragraph by the following:*

The tests based on an action type 1.AB or 2.AB shall be checked by the lowest (0,85 V_R) and the highest (1,1 V_R) rated voltage as declared by the manufacturer. During this test, the temperature shall not exceed the values specified in Table 13 (14.1 of edition 3.)

*The actuator shall be loaded with the maximum rated mechanical load. Each **duty cycle** shall be operated at the declared maximum **stroke** or **angular rotation**.*

14.4.3.1 to **14.4.3.3** Not applicable.

14.4.4 Not applicable.

Additional subclauses:

14.4.101 If stalling of the **electric actuator** drive shaft is part of normal **operation**, then the drive shaft of motorized actuators shall be stalled and temperatures measured after steady-state conditions are reached. The temperatures shall comply with the limits of Table 13. In addition, if any protective device provided does not cycle under stalled conditions, then the **electric actuator** is also considered to comply with the requirements of the burnout test of 27.2.

14.4.102 If stalling of the **electric actuator** drive shaft is not part of normal **operation**, then Table 13 limits do not apply during stalling. The **electric actuator** shall comply with the requirements of the burnout test of 27.2.

14.5.1 *Replacement:*

Change "switch head" to "**electric actuator**".

14.5.2 Not applicable.

14.6 *Replacement:*

The temperatures specified for the **electric actuator** shall be attained in approximately 1 h.

14.7 *Replacement:*

The temperature of the medium in which the **electric actuator** is located shall be measured as near as possible to the centre of the space occupied by the samples and at a distance of approximately 50 mm from the actuator.

15 Manufacturing deviation and drift

This clause of Part 1 is applicable except as follows:

15.5 *Additional subclauses:*

15.5.101 The **travel time** shall be measured at 0,85 V_R.

15.5.102 The **travel time** and the response time shall be measured with the maximum rated mechanical load declared by the manufacturer and in the most unfavourable mounting position declared by the manufacturer.

15.6 Not applicable.

AVA Documents Document Sharing Hub

Full document details: BS EN IEC 60730-2-14:2019+A2:2021