



BSI Standards Publication

Industrial communication networks - Fieldbus specifications

Part 4-4: Data-link layer protocol specification - Type 4 elements

National foreword

This British Standard is the UK implementation of EN IEC 61158-4-4:2019. It is identical to IEC 61158-4-4:2019. It supersedes BS EN 61158-4-4:2014, which will be withdrawn on 23 May 2022.

The UK participation in its preparation was entrusted to Technical Committee GEL/65/3, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 539 04856 8

ICS 35.100.20; 25.040.40; 35.110

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2019.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

English Version

Industrial communication networks - Fieldbus specifications -
Part 4-4: Data-link layer protocol specification - Type 4 elements
(IEC 61158-4-4:2019)

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 4-4: Spécification du protocole de la
couche liaison de données - Eléments de type 4
(IEC 61158-4-4:2019)

Industrielle Kommunikationsnetze - Feldbusse - Teil 4-4:
Protokollspezifikation des Data Link Layer
(Sicherheitsschicht) - Typ 4-Elemente
(IEC 61158-4-4:2019)

This European Standard was approved by CENELEC on 2019-05-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 65C/946/FDIS, future edition 3 of IEC 61158-4-4, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61158-4-4:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-02-23
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-05-23

This document supersedes EN 61158-4-4:2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61158-4-4:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- IEC 61158-1:2019 NOTE Harmonized as EN IEC 61158-1:2019 (not modified)
- IEC 61158-2:2014 NOTE Harmonized as EN 61158-2:2014 (not modified)
- IEC 61158-3-4:2019 NOTE Harmonized as EN IEC 61158-3-4:2019 (not modified)
- IEC 61158-5-4:2019 NOTE Harmonized as EN IEC 61158-5-4:2019 (not modified)
- IEC 61784-1:2019 NOTE Harmonized as EN IEC 61784-1:2019 (not modified)
- IEC 61784-2:2019 NOTE Harmonized as EN IEC 61784-2:2019 (not modified)

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 7498-1	-	Information technology - Open Systems-Interconnection - Basic reference model: The basic model		-
ISO/IEC 7498-3	-	Information technology - Open Systems-Interconnection - Basic reference model: Naming and addressing		-
ISO/IEC 10731	-	Information technology - Open Systems-Interconnection - Basic Reference Model - Conventions for the definition of OSI services		-

This page deliberately left blank

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
1.1 General.....	7
1.2 Specifications	7
1.3 Procedures	7
1.4 Applicability	7
1.5 Conformance	7
2 Normative references	8
3 Terms, definitions, symbols and abbreviations.....	8
3.1 Reference model terms and definitions	8
3.2 Service convention terms and definitions	10
3.3 Terms and definitions.....	11
3.4 Symbols and abbreviations	14
4 Data Link Protocol Definition	14
4.1 Overview of the DL-protocol.....	14
4.2 General structure and encoding of PhIDUs and DLPDUs, and related elements of procedure	26
4.3 DLPDU-specific structure, encoding and elements of procedure	33
4.4 DL-service elements of procedure.....	37
4.5 Route mechanism	40
4.6 Link-access system.....	43
4.7 Local variables, counters and queues	44
Bibliography.....	46
Figure 1 – Relationship of PhE, DLE and DLS-user	15
Figure 2 – DLE state diagram for confirmed and unconfirmed, unacknowledged DLPDUs.....	17
Figure 3 – DLE state diagram for confirmed acknowledged DLPDUs.....	18
Figure 4 – DLE state diagram for unconfirmed acknowledged DLPDUs.....	19
Figure 5 – Full duplex DLE receive state diagram	20
Figure 6 – Full duplex DLE transmit state diagram	20
Figure 7 – Link access example	23
Figure 8 – Simple Type 4-route format	29
Figure 9 – Extended Type 4-route format	29
Figure 10 – Complex Type 4-route format	30
Figure 11 – Immediate Type 4-route format	30
Figure 12 – IP Type 4-route format	31
Figure 13 – Control-status format.....	32
Figure 14 – Data-field-format	32
Figure 15 – Source / destination designator	41
Figure 16 – Simple Type 4-route generation	41
Figure 17 – Extended Type 4-route generation	41
Figure 18 – Complex and IP Type 4-route generation	42
Figure 19 – Simple DL-route generation.....	42

Figure 20 – Extended DL-route generation.....	43
Figure 21 – Complex and IP DL-route generation.....	43
Table 1 – Summary structure of DLPDUs.....	33
Table 2 – Structure of confirmed DLPDUs.....	34
Table 3 – Structure of unconfirmed DLPDUs.....	35
Table 4 – Structure of acknowledge DLPDU	36
Table 5 – Structure of immediate-reply DLPDU.....	36

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 4-4: Data-link layer protocol specification –
Type 4 elements****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-4-4 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This third edition cancels and replaces the second edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) additional user parameters to services;
- b) additional services to support distributed objects;
- c) additional secure services;

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/946/FDIS	65C/955/RVD

Full information on the voting for the approval of this International standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all the parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementors and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This document is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-4: Data-link layer protocol specification – Type 4 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides a means of connecting devices through a partial mesh network, such that most failures of an interconnection between two devices can be circumvented. In common practice the devices are interconnected in a non-redundant hierarchical manner reflecting application needs

1.2 Specifications

This document specifies

- a) procedures for the timely transfer of data and control information from one data-link user entity to a peer user entity, and among the data-link entities forming the distributed data-link service provider;
- b) the structure of the fieldbus DLPDUs used for the transfer of data and control information by the protocol of this document, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

- a) the interactions between peer DL-entities (DLEs) through the exchange of fieldbus DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and a Ph-service provider in the same system through the exchange of Ph-service primitives.

1.4 Applicability

These procedures are applicable to instances of communication between systems which support time-critical communications services within the data-link layer of the OSI or fieldbus reference models, and which require the ability to interconnect in an open systems interconnection environment.

Profiles provide a simple multi-attribute means of summarizing an implementation's capabilities, and thus its applicability to various time-critical communications needs.

1.5 Conformance

This document also specifies conformance requirements for systems implementing these procedures. This document does not contain tests to demonstrate compliance with such requirements.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

3 Terms, definitions, symbols and abbreviations

For the purposes of this document, the following terms, definitions, symbols and abbreviations apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 Reference model terms and definitions

This document is based in part on the concepts developed in ISO/IEC 7498-1 and ISO/IEC 7498-3, and makes use of the following terms defined therein.

3.1.1	called-DL-address	[7498-3]
3.1.2	calling-DL-address	[7498-3]
3.1.3	centralized multi-end-point-connection	[7498-1]
3.1.4	correspondent (N)-entities correspondent DL-entities (N=2) correspondent Ph-entities (N=1)	[7498-1]
3.1.5	demultiplexing	[7498-1]
3.1.6	DL-address	[7498-3]
3.1.7	DL-address-mapping	[7498-1]
3.1.8	DL-connection	[7498-1]
3.1.9	DL-connection-end-point	[7498-1]
3.1.10	DL-connection-end-point-identifier	[7498-1]
3.1.11	DL-connection-mode transmission	[7498-1]

3.1.12	DL-connectionless-mode transmission	[7498-1]
3.1.13	DL-data-sink	[7498-1]
3.1.14	DL-data-source	[7498-1]
3.1.15	DL-duplex-transmission	[7498-1]
3.1.16	DL-facility	[7498-1]
3.1.17	DL-local-view	[7498-3]
3.1.18	DL-name	[7498-3]
3.1.19	DL-protocol	[7498-1]
3.1.20	DL-protocol-connection-identifier	[7498-1]
3.1.21	DL-protocol-control-information	[7498-1]
3.1.22	DL-protocol-data-unit	[7498-1]
3.1.23	DL-protocol-version-identifier	[7498-1]
3.1.24	DL-relay	[7498-1]
3.1.25	DL-service-connection-identifier	[7498-1]
3.1.26	DL-service-data-unit	[7498-1]
3.1.27	DL-simplex-transmission	[7498-1]
3.1.28	DL-subsystem	[7498-1]
3.1.29	DL-user-data	[7498-1]
3.1.30	flow control	[7498-1]
3.1.31	layer-management	[7498-1]
3.1.32	multiplexing	[7498-3]
3.1.33	naming-(addressing)-authority	[7498-3]
3.1.34	naming-(addressing)-domain	[7498-3]
3.1.35	naming-(addressing)-subdomain	[7498-3]
3.1.36	(N)-entity DL-entity Ph-entity	[7498-1]
3.1.37	(N)-interface-data-unit DL-service-data-unit (N=2) Ph-interface-data-unit (N=1)	[7498-1]
3.1.38	(N)-layer DL-layer (N=2) Ph-layer (N=1)	[7498-1]
3.1.39	(N)-service DL-service (N=2) Ph-service (N=1)	[7498-1]

3.1.40	(N)-service-access-point DL-service-access-point (N=2) Ph-service-access-point (N=1)	[7498-1]
3.1.41	(N)-service-access-point-address DL-service-access-point-address (N=2) Ph-service-access-point-address (N=1)	[7498-1]
3.1.42	peer-entities	[7498-1]
3.1.43	Ph-interface-control-information	[7498-1]
3.1.44	Ph-interface-data	[7498-1]
3.1.45	primitive name	[7498-3]
3.1.46	reassembling	[7498-1]
3.1.47	recombining	[7498-1]
3.1.48	reset	[7498-1]
3.1.49	responding-DL-address	[7498-3]
3.1.50	routing	[7498-1]
3.1.51	segmenting	[7498-1]
3.1.52	sequencing	[7498-1]
3.1.53	splitting	[7498-1]
3.1.54	synonymous name	[7498-3]
3.1.55	systems-management	[7498-1]

3.2 Service convention terms and definitions

This document also makes use of the following terms defined in ISO/IEC 10731 as they apply to the data-link layer:

3.2.1	acceptor
3.2.2	asymmetrical service
3.2.3	confirm (primitive); requestor.deliver (primitive)
3.2.4	deliver (primitive)
3.2.5	DL-confirmed-facility
3.2.6	DL-facility
3.2.7	DL-local-view
3.2.8	DL-mandatory-facility
3.2.9	DL-non-confirmed-facility
3.2.10	DL-provider-initiated-facility
3.2.11	DL-provider-optional-facility
3.2.12	DL-service-primitive; primitive

3.2.13 DL-service-provider**3.2.14 DL-service-user****3.2.15 DL-user-optional-facility****3.2.16 indication (primitive)
acceptor.deliver (primitive)****3.2.17 multi-peer****3.2.18 request (primitive);
requestor.submit (primitive)****3.2.19 requestor****3.2.20 response (primitive);
acceptor.submit (primitive)****3.2.21 submit (primitive)****3.2.22 symmetrical service****3.3 Terms and definitions**

For the purposes of this document, the following terms and definitions apply.

3.3.1**broadcast-Node-address**

address used to send broadcasts to all DLEs on a Link

Note 1 to entry: All DLEs on a Link receive all DLPDUs where the first Node-address is equal to the Broadcast-Node-Address. Such DLPDUs are always Unconfirmed, and their receipt is never acknowledged. The value of a Broadcast-Node-address is 126.

3.3.2**destination-DL-route**

holds a sequence of DL-route-elements, describing the complete route to the destination

Note 1 to entry: This includes both the destination DLSAP and a local component meaningful to the destination DLS-user.

3.3.3**DL-route**

combination of a Destination-DL-route and a Source-DL-route

3.3.4**DL-route-element**

octet holding a Node-address or an address used by the DLS-user

3.3.5**DLSAP**

distinctive point at which DL-services are provided by a single DL-entity to a single higher-layer entity.

Note 1 to entry: This definition, derived from ISO/IEC 7498-1, is repeated here to facilitate understanding of the critical distinction between DLSAPs and their DL-addresses.

3.3.6**DL(SAP)-address**

an individual DLSAP-address, designating a single DLSAP of a single DLS-user