



BSI Standards Publication

Industrial communication networks - Fieldbus specifications

Part 5-10: Application layer service definition - Type 10 elements

National foreword

This British Standard is the UK implementation of EN IEC 61158-5-10:2019. It is identical to IEC 61158-5-10:2019. It supersedes BS EN 61158-5-10:2014, which will be withdrawn on 15 May 2022.

The UK participation in its preparation was entrusted to Technical Committee GEL/65/3, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 539 04838 4

ICS 25.040.40; 35.110; 35.100.70

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2019.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

English Version

Industrial communication networks - Fieldbus specifications -
Part 5-10: Application layer service definition - Type 10 elements
(IEC 61158-5-10:2019)

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 5-10 : Définition des services de la
couche application - Éléments de type 10
(IEC 61158-5-10:2019)

Industrielle Kommunikationsnetze - Feldbusse - Teil 5-10:
Dienstfestlegungen des Application Layer
(Anwendungsschicht) - Typ 10-Elemente
(IEC 61158-5-10:2019)

This European Standard was approved by CENELEC on 2019-05-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 65C/947/FDIS, future edition 4 of IEC 61158-5-10, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61158-5-10:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-02-15
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-05-15

This document supersedes EN 61158-5-10:2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61158-5-10:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60870-5-4	NOTE	Harmonized as EN 60870-5-4
IEC 61131-1	NOTE	Harmonized as EN 61131-1
IEC 61131-3	NOTE	Harmonized as EN 61131-3
IEC 61375-2-1	NOTE	Harmonized as EN 61375-2-1
IEC 61784-1	NOTE	Harmonized as EN 61784-1
IEC 61784-2	NOTE	Harmonized as EN 61784-2

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-1	2019	Industrial communication networks - Fieldbus specifications - Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series	- EN IEC 61158-1	2019
IEC 61158-5-3	-	Industrial communication networks - Fieldbus specifications - Part 5-3: Application layer service definition - Type 3 elements	- EN 61158-5-3	-
IEC 61158-6-3	-	Industrial communication networks - Fieldbus specifications - Part 6-3: Application layer protocol specification - Type 3 elements	- EN 61158-6-3	-
IEC 61158-6-10	2019	Industrial communication networks - Fieldbus specifications - Part 6-10: Application layer protocol specification - Type 10 elements	- EN 61158-6-10	2019
IEC 61800-7-203	2015	Adjustable speed electrical power drive systems - Part 7-203: Generic interface and use of profiles for power drive systems - Profile type 3 specification	EN 61800-7-203	2016
IEC 62439-2	-	Industrial communication networks – High availability automation networks – Part 2: Media Redundancy Protocol (MRP)	EN 62439-2	-
ISO/IEC 646	-	Information technology; ISO 7-bit coded character set for information interchange	-	-
ISO/IEC 7498-1	-	Information technology - Open Systems - Interconnection - Basic reference model: The basic model	-	-
ISO/IEC 8822	-	Information technology - Open Systems - Interconnection - Presentation service definition	-	-

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 8824-1	-	Information technology - Abstract Syntax - Notation One (ASN.1): Specification of basic notation	-	-
ISO/IEC 9545	-	Information technology - Open Systems - Interconnection - Application layer structure	-	-
ISO/IEC 9834-8	-	Information technology - Procedures for the operation of object identifier registration authorities - Part 8: Generation of universally unique identifiers (UUIDs) and their use in object identifiers	-	-
ISO/IEC 10646	-	Information technology - Universal Coded - Character Set (UCS)	-	-
ISO/IEC 10731	-	Information technology - Open Systems - Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
ISO/IEC 15802-1	-	Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Common specifications - Part 1: Medium Access Control (MAC) service definition	-	-
ISO/IEC/IEEE 60559	2011	Information technology - Microprocessor - Systems - Floating-Point arithmetic	-	-
ISO 8601	-	Data elements and interchange formats - Information interchange - Representation of dates and times	-	-
IEEE Std 802	-	IEEE Standard for Local and metropolitan area networks: Overview and Architecture	-	-
IEEE Std 802.1	-	IEEE Standard for Local and metropolitan area networks: Station and Media Access Control Connectivity Discovery	-	-
IEEE Std 802.1AB	-	IEEE Standard for Local and metropolitan area networks: Station and Media Access Control Connectivity Discovery	-	-
IEEE Std 802.1AS	-	IEEE Standard for Information technology - Telecommunications and information exchange between systems - IEEE standard for Local and metropolitan area networks - Timing and Synchronization for Time-Sensitive Applications in Bridged Local Area Networks	-	-
IEEE Std 802.1Q	-	IEEE Standard for Local and metropolitan area networks - Media Access Control (MAC) Bridges and Virtual Bridged Local Area Networks	-	-
IEEE Std 802.3	-	IEEE Standard for Ethernet	-	-
IETF RFC 768	-	User Datagram Protocol	-	-

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IETF RFC 791	-	Internet Protocol	-	-
IETF RFC 792	-	Internet Control Message Protocol	-	-
IETF RFC 826	-	Ethernet Address Resolution Protocol: Or - Converting Network Protocol Addresses to 48.bit Ethernet Address for Transmission on Ethernet Hardware	-	-
IETF RFC 894	-	Standard for the Transmission of IP - Datagrams over Ethernet Networks	-	-
IETF RFC 1034	-	Domain names - concepts and facilities	-	-
IETF RFC 1112	-	Host Extensions for IP Multicasting	-	-
IETF RFC 1157	-	Simple Network Management Protocol - (SNMP)	-	-
IETF RFC 1213	-	Management Information Base for Network - Management of TCP/IP-based Internets: MIB-II	-	-
IETF RFC 2131	-	Dynamic Host Configuration Protocol	-	-
IETF RFC 2132	-	DHCP Options and BOOTP Vendor - Extensions	-	-
IETF RFC 2365	-	Administratively Scoped IP Multicast	-	-
IETF RFC 2674	-	Definitions of Managed Objects for Bridges - with Traffic Classes, Multicast Filtering and Virtual LAN Extensions	-	-
IETF RFC 2737	-	Entity MIB (Version 2)	-	-
IETF RFC 2863	-	The Interfaces Group MIB	-	-
IETF RFC 3418	-	Management Information Base (MIB) for - the Simple Network Management Protocol (SNMP)	-	-
IETF RFC 3490	-	Internationalizing Domain Names in - Applications (IDNA)	-	-
IETF RFC 3621	-	Power Ethernet MIB	-	-
IETF RFC 4836	-	Definitions of Managed Objects for IEEE - 802.3 Medium Attachment Units (MAUs)	-	-
IETF RFC 5905	-	Network Time Protocol Version 4: Protocol - and Algorithms Specification	-	-
IETF RFC 6890	-	Special-Purpose IP Address Registries	-	-
The Open Group -- Publication C706	-	Technical standard DCE1.1: Remote - Procedure Call	-	-

This page deliberately left blank

CONTENTS

FOREWORD.....	15
INTRODUCTION.....	17
1 Scope.....	18
1.1 General.....	18
1.2 Specifications	19
1.3 Conformance	19
2 Normative references	19
3 Terms, definitions, abbreviations, symbols and conventions	22
3.1 Referenced terms and definitions.....	22
3.1.1 ISO/IEC 7498-1 terms.....	22
3.1.2 ISO/IEC 8822 terms.....	22
3.1.3 ISO/IEC 9545 terms.....	22
3.1.4 ISO/IEC 8824-1 terms.....	23
3.2 Additional Type 10 terms and definitions.....	23
3.3 Additional Type 10 terms and definitions for media redundancy	30
3.4 Abbreviations and symbols	32
3.4.1 General	32
3.4.2 Additional Type 10 abbreviations and symbols.....	33
3.4.3 Abbreviations and symbols for services	34
3.5 Conventions.....	34
3.5.1 Overview	34
3.5.2 General conventions.....	34
3.5.3 Conventions for class definitions	34
3.5.4 Conventions for service definitions	36
3.5.5 Conventions used in state machines.....	37
4 Concepts	40
5 Data type ASE.....	40
5.1 General.....	40
5.1.1 Overview	40
5.1.2 Date and time type specifics	41
5.1.3 Transfer of user data	41
5.1.4 Data type overview	41
5.2 Formal definition of data type objects.....	44
5.2.1 Data type class.....	44
5.3 FAL defined data types	45
5.3.1 Fixed length types	45
5.3.2 Variable Length types	66
5.4 Data type ASE service specification.....	69
6 Communication model for common services	69
6.1 Concepts	69
6.1.1 Overview	69
6.1.2 Middle Layer ASEs	69
6.2 ASE data types	69
6.3 Application Service Elements.....	69
6.3.1 Remote procedure call ASE.....	69
6.3.2 Domain name system ASE	78

6.3.3	Simple network management ASE	79
6.3.4	IP suite ASE	80
6.3.5	Real time cyclic ASE	84
6.3.6	Real time acyclic ASE	100
6.3.7	Discovery and basic configuration ASE	110
6.3.8	Dynamic host configuration ASE	138
6.3.9	IEEE 802.1AB ASE	138
6.3.10	Media redundancy ASE	151
6.3.11	Precision time control ASE	158
6.3.12	IEEE 802.1AS ASE	172
6.3.13	Virtual Bridges ASE	175
6.3.14	MAC Bridges ASE	178
6.3.15	Fragmentation ASE	191
6.3.16	IEEE 802.3 ASE	192
6.3.17	Common DL mapping ASE	195
7	Communication model for decentralized periphery	200
7.1	Concepts	200
7.1.1	User requirements	200
7.1.2	Features	200
7.1.3	Associations	201
7.1.4	Device types	202
7.1.5	Instance model and device addresses	210
7.1.6	Application process	210
7.1.7	Application service element	217
7.1.8	Application relationship	219
7.2	ASE data types	220
7.3	ASEs	220
7.3.1	AR ASE	220
7.3.2	Real Identification ASE	355
7.3.3	Communication Interface Management ASE	445
7.3.4	Diagnosis ASE	516
7.3.5	PE ASE	561
7.3.6	LogBook ASE	571
7.3.7	RS ASE	574
7.3.8	Time ASE	599
7.4	Application characteristics	604
7.4.1	Device ident number	604
7.4.2	Network topology	604
7.5	Summary of FAL services	606
7.5.1	IO device	606
7.5.2	IO controller	607
7.5.3	IO Supervisor	607
Annex A (informative)	Device instances	608
Annex B (informative)	Components of an Ethernet interface	610
Annex C (informative)	Scheme of MAC address assignment	614
Annex D (informative)	Measurement of the fast startup time	615
Annex E (informative)	Dynamic Frame Packing	616
Annex F (informative)	Precondition for Diagnosis	624

Bibliography.....	629
Figure 1 – Middle Layer ASEs communication architecture	69
Figure 2 – Sequence Chart for reading the EndPointMapper.....	71
Figure 3 – Media redundancy diagnosis dependencies	157
Figure 4 – PTCP applications.....	158
Figure 5 – Example of periods at a local port	177
Figure 6 – Example of communication between controlling devices and field devices.....	201
Figure 7 – Example of communication between an engineering station and several controlling and field devices.....	202
Figure 8 – Example of communication between field devices and a server station	202
Figure 9 – Example of communication between field devices	202
Figure 10 – Data Objects and Diagnosis Data Model	206
Figure 11 – Example for channel modelling.....	207
Figure 12 – Mapping to PROFINET device model	208
Figure 13 – Identification hierarchy	208
Figure 14 – Application Process with application process objects (APOs)	211
Figure 15 – Access to a remote APO	212
Figure 16 – Access to a remote APO for provider/consumer association.....	213
Figure 17 – Overview of application processes	214
Figure 18 – IO device with APs, slots and subslots	214
Figure 19 – Example 1 structural units for interfaces and ports within API 0.....	216
Figure 20 – Example 2 structural units for interfaces and ports within API 0.....	217
Figure 21 – FAL ASEs communication architecture	218
Figure 22 – Example of one AR with two AREPs.....	220
Figure 23 – Example IO application relationship (one-to-one)	223
Figure 24 – Example IO application relationship one-to-many	224
Figure 25 – Implicit application relationship	225
Figure 26 – State transition diagram DEVSM	257
Figure 27 – State transition diagram CTLSM.....	265
Figure 28 – Assignment of Communication Relationship to Application Relationship.....	270
Figure 29 – Overview Communication Relationship Class service interactions	273
Figure 30 – Example for an intersection of IO device, slot, and AR	336
Figure 31 – Substitute Value.....	364
Figure 32 – State transition diagram RSMSM.....	372
Figure 33 – Ownership handling.....	376
Figure 34 – State transition diagram OWNSM.....	379
Figure 35 – State transition diagram ASSSM	380
Figure 36 – State transition diagram PLUGSM	392
Figure 37 – State transition diagram PULLSM.....	395
Figure 38 – Basic model for isochronous applications	424
Figure 39 – General isochronous application model (example CACF == 1)	425
Figure 40 – General isochronous application model (example CACF == 2)	426

Figure 41 – ASE relations in an IO device operating in isochronous mode for a submodule	432
Figure 42 – State transition diagram of ISOM_SYNC	434
Figure 43 – State transition diagram ISOM_OUT	437
Figure 44 – State transition diagram ISOM_IN	442
Figure 45 – State transition diagram SYNC_DIAG	484
Figure 46 – MRP interconnection	506
Figure 47 – Diagnosis Base Model	516
Figure 48 – Severity classification of fault, maintenance and qualified	517
Figure 49 – Data Base Model	518
Figure 50 – State transition diagram DIAG_DIAG	547
Figure 51 – State transition diagram DIAG_MR	551
Figure 52 – State transition diagram DIAG_MD	554
Figure 53 – State transition diagram DIAG_QUALIFIED	558
Figure 54 – Architecture	562
Figure 55 – State transition diagram PESM	570
Figure 56 – Reporting System components	575
Figure 57 – AR / ARSet and Reporting System	576
Figure 58 – Max Scan Delay	584
Figure 59 – RS Incident window	587
Figure 60 – State transition diagram RSOBS	592
Figure 61 – State transition diagram RSBUF	596
Figure 62 – State transition diagram TimeSM	602
Figure 63 – Example of network topology including slower wireless segments	605
Figure 64 – Example of media redundancy including wireless segments	605
Figure A.1 – Instance model	608
Figure B.1 – Scheme of an Ethernet interface	610
Figure B.2 – Scheme of an Ethernet interface with bridging ability	611
Figure B.3 – Scheme of an Ethernet interface with optical ports	612
Figure B.4 – Scheme of an Ethernet interface with bridging ability using radio communication	613
Figure B.5 – Scheme of an Ethernet interface with radio communication	613
Figure C.1 – Scheme of MAC address assignment	614
Figure D.1 – Measurement of the fast startup time	615
Figure E.1 – Frame Layout	616
Figure E.2 – Subframe Layout	617
Figure E.3 – End to End	618
Figure E.4 – Dynamic frame packing	618
Figure E.5 – Dynamic frame packing – Truncation of outputs	619
Figure E.6 – Dynamic frame packing – Outbound Pack	619
Figure E.7 – Dynamic frame packing – Concatenation of inputs	620
Figure E.8 – Dynamic frame packing – Inbound Pack	621
Figure E.9 – Dynamic frame packing – Distributed watchdog	623
Figure E.10 – Interrelation between IO CR and dynamically packed frame	623

Table 1 – State machine description elements	37
Table 2 – Description of state machine elements	38
Table 3 – Conventions used in state machines	38
Table 4 – Conventions for services used in state machines	39
Table 5 – Data type overview.....	41
Table 6 – V2 octets.....	46
Table 7 – L2 octets	46
Table 8 – E2 octets.....	47
Table 9 – E2 value range.....	47
Table 10 – Unipolar2.16 octets	48
Table 11 – Unipolar2.16 value range	48
Table 12 – N2 value range.....	49
Table 13 – N4 value range.....	50
Table 14 – X2 value range.....	51
Table 15 – X4 value range.....	52
Table 16 – C4 value range.....	53
Table 17 – T2 value range	54
Table 18 – T4 value range	55
Table 19 – D2 value range.....	56
Table 20 – R2 value range.....	56
Table 21 – Status value range	57
Table 22 – Status value range	58
Table 23 – F message trailer with 4 octets.....	62
Table 24 – Unsigned16_S octets	64
Table 25 – Unsigned16_S meaning.....	64
Table 26 – Integer16_S octets	65
Table 27 – Integer16_S meaning	65
Table 28 – Unsigned8_S octets	65
Table 29 – Unsigned8_S meaning	65
Table 30 – OctetString_S octets	66
Table 31 – OctetString_S status bits.....	67
Table 32 – Connect.....	72
Table 33 – Release.....	73
Table 34 – Read	74
Table 35 – Write	75
Table 36 – Control	76
Table 37 – ReadImplicit	77
Table 38 – Add Static ARP Cache Entry	83
Table 39 – Remove Static ARP Cache Entry.....	83
Table 40 – PPM Set Prov Data	89
Table 41 – PPM Set Prov Status.....	90
Table 42 – PPM Activate.....	91

Table 43 – PPM Close	93
Table 44 – PPM Start.....	94
Table 45 – PPM Error	94
Table 46 – Get Cons Data	94
Table 47 – CPM Get cons status.....	95
Table 48 – CPM Set RedRole	96
Table 49 – CPM Activate	97
Table 50 – CPM NoData	99
Table 51 – CPM Stop.....	99
Table 52 – CPM New Data Indication.....	100
Table 53 – APMS Activate	103
Table 54 – APMR Activate	104
Table 55 – APMS A Data	106
Table 56 – APMR A Data	107
Table 57 – APMR Ack.....	107
Table 58 – APMS Error	108
Table 59 – APMS Error ERRCLS/ERRCODE	108
Table 60 – APMR Error	109
Table 61 – APMR Error ERRCLS/ERRCODE	109
Table 62 – APMS_Close	109
Table 63 – APMR_Close.....	110
Table 64 – Get.....	118
Table 65 – Set	123
Table 66 – Local Set Command	128
Table 67 – Identify	130
Table 68 – Hello	136
Table 69 – System capabilities	144
Table 70 – Auto negotiation support and status	145
Table 71 – MDI Power Support	146
Table 72 – Link aggregation status	146
Table 73 – Remote systems data change.....	150
Table 74 – Start bridge	165
Table 75 – Start slave.....	166
Table 76 – Start master	167
Table 77 – Stop bridge.....	168
Table 78 – Stop slave	169
Table 79 – Stop master.....	170
Table 80 – Sync state change.....	170
Table 81 – Line Delay change.....	171
Table 82 – Local Get Time.....	174
Table 83 – Local time state info	174
Table 84 – Allowed values of Forwarding Mode	181
Table 85 – Allowed values of Fast Forwarding Multicast MAC Add.....	184

Table 86 – Tx Port Entry	184
Table 87 – Dependencies of RedPeriodBegin and GreenPeriodBegin	187
Table 88 – Port state change	190
Table 89 – Set port state	190
Table 90 – Flush filtering data base	191
Table 91 – MAU Type change	194
Table 92 – Set MAU Type	194
Table 93 – P Data	195
Table 94 – N Data	197
Table 95 – A Data	198
Table 96 – C Data	199
Table 97 – Requirements and features	200
Table 98 – Binding application relationship services	226
Table 99 – Device Access	229
Table 100 – Companion AR	229
Table 101 – Acknowledge Companion AR	230
Table 102 – Startup Mode	230
Table 103 – Pull Module Alarm Allowed	230
Table 104 – Input Valid on Backup AR	233
Table 105 – Mode	234
Table 106 – APStructureIdentifier with API := 0	234
Table 107 – APStructureIdentifier with API != 0	235
Table 108 – RS Alarm Transport Mode	235
Table 109 – Connect	237
Table 110 – Connect Device Access	243
Table 111 – Release	244
Table 112 – Prm Begin	246
Table 113 – Prm End	248
Table 114 – Application Ready	249
Table 115 – Abort	250
Table 116 – Local AR Abort	251
Table 117 – Local Set AR State	251
Table 118 – Local AR In Data	251
Table 119 – Data elements of Read AR Data	252
Table 120 – Data elements of Expected Fast Startup Data	254
Table 121 – Remote primitives issued or received by DEVSM	255
Table 122 – Local primitives issued or received by DEVSM	256
Table 123 – State table DEVSM	258
Table 124 – Functions, Macros, Timers and Variables by DEVSM	263
Table 125 – Remote primitives issued or received by CTLSM	264
Table 126 – Local primitives issued or received by CTLSM	264
Table 127 – State table CTLSM	266
Table 128 – Functions, Macros, Timers and Variables used by CTLSM	268

Table 129 – Binding communication relationship services	274
Table 130 – Traffic Classes versus RT Class	276
Table 131 – Local Set Input	284
Table 132 – Local Set Input IOCS	285
Table 133 – Local Get Input	286
Table 134 – Local Get Input IOCS	287
Table 135 – Local New Input	288
Table 136 – Local Set Output	289
Table 137 – Local Set Output IOCS	290
Table 138 – Local Get Output	291
Table 139 – Local Get Output IOCS	292
Table 140 – Local New Output	293
Table 141 – Local Set Provider State	294
Table 142 – Local Set Redundancy	295
Table 143 – Local Set State	295
Table 144 – Local Data State Changed	296
Table 145 – Binding expected identification services	303
Table 146 – Module State	305
Table 147 – AR Info	308
Table 148 – Ident Info	309
Table 149 – General Data definition for identification services	309
Table 150 – Data elements of Read Module Diff Block	311
Table 151 – Alarm type	315
Table 152 – Alarm types attached to diagnosis ASE	317
Table 153 – Alarm types attached to ownership	317
Table 154 – Alarm types attached to common profiles, profiles, and application	318
Table 155 – Binding Alarm services	318
Table 156 – Alarm Notification	322
Table 157 – Channel Diagnosis	324
Table 158 – Manufacturer Specific Diagnosis	324
Table 159 – Submodule Diagnosis State	325
Table 160 – AR Diagnosis State	325
Table 161 – User Structure Identifier	326
Table 162 – Semantics of Specifier	328
Table 163 – Binding Record Data services	336
Table 164 – Read	338
Table 165 – Read Services	340
Table 166 – Read Implicit	342
Table 167 – Read Query	343
Table 168 – Write	344
Table 169 – Write Services	345
Table 170 – Data elements of Write Combined Object Container	346
Table 171 – Local Write Multiple	347

Table 172 – Local New Write Multiple	350
Table 173 – Binding real identification services.....	356
Table 174 – Local Add Submodule.....	359
Table 175 – Local Remove Submodule	360
Table 176 – Local Update Submodule.....	360
Table 177 – Data elements of Read API Data	362
Table 178 – Data elements of Read Record Input Data Object Element	363
Table 179 – Data elements of Read Record Output Data Object Element	366
Table 180 – Data elements of Read Substitute Value.....	367
Table 181 – Selector for Read GSD Data.....	369
Table 182 – Data elements of Read GSD Data	369
Table 183 – Remote primitives issued or received by RSMSM	371
Table 184 – Local primitives issued or received by RSMSM.....	371
Table 185 – State table RSMSM	372
Table 186 – Functions, Macros, Timers and Variables used by RSMSM	374
Table 187 – Rules for Submodule State.Ident Info	374
Table 188 – Remote primitives issued or received by OWNSM and ASSSM.....	378
Table 189 – Local primitives issued or received by OWNSM	379
Table 190 – State table OWNSM	380
Table 191 – State table ASSSM.....	387
Table 192 – Functions, Macros, Timers and Variables used by OWNSM.....	388
Table 193 – Functions, Macros, Timers and Variables used by ASSSM	389
Table 194 – Rules for Submodule State.AR Info	389
Table 195 – Remote primitives issued or received by PLUGSM	390
Table 196 – Local primitives issued or received by PLUGSM	391
Table 197 – State table PLUGSM	393
Table 198 – Functions, Macros, Timers and Variables used by PLUGSM.....	394
Table 199 – Remote primitives issued or received by PULLSM	395
Table 200 – Local primitives issued or received by PULLSM.....	395
Table 201 – State table PULLSM	396
Table 202 – Functions, Macros, Timers and Variables used by PULLSM	397
Table 203 – Binding I&M data services	399
Table 204 – Data elements of Read I&M0 Filter Data.....	412
Table 205 – Data elements of Read I&M0 Data.....	415
Table 206 – Data elements of Write I&M1 Data.....	416
Table 207 – Data elements of Write I&M2 Data.....	417
Table 208 – Data elements of Write I&M3 Data.....	418
Table 209 – Data elements of Write I&M4 Data.....	418
Table 210 – Data elements of Read I&M5 Data.....	419
Table 211 – Data elements of Read Asset Management Data	422
Table 212 – Binding Isochronous Mode Application services.....	426
Table 213 – Data elements of Write Isochronous Mode Data	431
Table 214 – Remote primitives issued or received by ISOM_SYNC.....	433

Table 215 – Local primitives issued or received by ISOM_SYNC	433
Table 216 – State table ISOM_SYNC	434
Table 217 – Functions, Macros, Timers and Variables used by the ISOM_SYNC	435
Table 218 – Remote primitives issued or received for ISOM_OUT	435
Table 219 – Local primitives issued or received for ISOM_OUT	436
Table 220 – State table ISOM_OUT	438
Table 221 – Functions, Macros, Timers and Variables used by the ISOM_OUT	440
Table 222 – Remote primitives issued or received for ISOM_IN	441
Table 223 – Local primitives issued or received for ISOM_IN	441
Table 224 – State table ISOM_IN	443
Table 225 – Functions, Macros, Timers and Variables used by the ISOM_IN	444
Table 226 – Binding Communication Interface Management services	446
Table 227 – Subslot number for interface submodules	449
Table 228 – Subslot number for port submodules	453
Table 229 – Data elements of Read PDev Data	458
Table 230 – Data elements of Read PD Real Data	458
Table 231 – Data elements of Read PD Expected Data	460
Table 232 – Data elements of Read PD Interface Data Real	461
Table 233 – Data elements of Write PD Interface Adjust	462
Table 234 – Data elements of Write PD Interface FSU Data Adjust	463
Table 235 – Data elements of Write PD NC Data Check	464
Table 236 – Data elements of Read PD Port Data Real	465
Table 237 – Data elements of Read PD Port Data Real Extended	466
Table 238 – Data elements of Write PD Port Data Check	467
Table 239 – Data elements of Write PD Port Data Adjust	469
Table 240 – Data elements of Read Port FO Data Real	470
Table 241 – Data elements of Write PD Port FO Data Check	471
Table 242 – Data elements of Write PD Port FO Data Adjust	471
Table 243 – Data elements of Read PD Port Statistic	472
Table 244 – Binding PTCP services	475
Table 245 – Sync Properties Role	478
Table 246 – Sync Class	478
Table 247 – Data elements of Write PD Sync Data	479
Table 248 – Local Sync State Info	481
Table 249 – Local SYNCH Event	482
Table 250 – Remote primitives issued or received by SYNC_DIAG	483
Table 251 – Local primitives issued or received by SYNC_DIAG	483
Table 252 – State table SYNC_DIAG	485
Table 253 – Functions, Macros, Timers and Variables used by SYNC_DIAG	486
Table 254 – Binding MAC Bridge services	487
Table 255 – Distributed Watchdog Factor	489
Table 256 – Restart Factor For Distributed Watchdog	489
Table 257 – DFP Mode	490

Table 258 – SFIOCRProperties.DFPRedundantPathLayout.....	490
Table 259 – SFCRC16	490
Table 260 – Data elements of Write PD IR Data	491
Table 261 – Data elements of Write PD IR Subframe Data.....	493
Table 262 – Binding Media Redundancy services	494
Table 263 – Data elements of Read PD Interface MRP Data Real.....	496
Table 264 – Data elements of Write PD Interface MRP Data Check	498
Table 265 – Data elements of Write PD Interface MRP Data Adjust	499
Table 266 – Data elements of Read PD Port MRP Data Real	501
Table 267 – Data elements of Write PD Port MRP Data Adjust	501
Table 268 – Data elements of Read PD Port MRPIC Data Real	502
Table 269 – Data elements of Write PD Port MRPIC Data Check	503
Table 270 – Data elements of Write PD Port MRPIC Data Adjust.....	503
Table 271 – Binding IEEE 802.1AS services	507
Table 272 – Data elements of Write PD Time Data	509
Table 273 – List of supported MIBs.....	509
Table 274 – Cross-referencing of MIB-II objects	510
Table 275 – Cross-referencing of LLDP-MIB objects	510
Table 276 – Cross-referencing of LLDP-EXT-PNIO MIB objects.....	510
Table 277 – Cross-referencing of LLDP-EXT-DOT3 MIB objects	511
Table 278 – Binding Autoconfiguration Data services.....	511
Table 279 – Data elements of Read Autoconfiguration Data	514
Table 280 – Binding Diagnosis services.....	521
Table 281 – General Data definition for Diagnosis services.....	527
Table 282 – Local Add Diagnosis Entry.....	530
Table 283 – Local Remove Diagnosis Entry	531
Table 284 – Local Update Diagnosis Entry.....	532
Table 285 – Remote primitives issued or received by DIAG_DIAG	547
Table 286 – Local primitives issued or received by DIAG_DIAG	547
Table 287 – State table DIAG_DIAG	548
Table 288 – Functions, Macros, Timers and Variables used by DIAG_DIAG	549
Table 289 – Remote primitives issued or received by DIAG_MR	550
Table 290 – Local primitives issued or received by DIAG_MR.....	551
Table 291 – State table DIAG_MR	552
Table 292 – Functions, Macros, Timers and Variables used by DIAG_MR.....	552
Table 293 – Remote primitives issued or received by DIAG_MD	554
Table 294 – Local primitives issued or received by DIAG_MD	554
Table 295 – State table DIAG_MD	555
Table 296 – Functions, Macros, Timers and Variables used by the maintenance demanded entry.....	556
Table 297 – Remote primitives issued or received by DIAG_QUALIFIED	557
Table 298 – Local primitives issued or received by DIAG_QUALIFIED	557
Table 299 – State table DIAG_QUALIFIED	559

Table 300 – Functions, Macros, Timers and Variables used by DIAG_QUALIFIED	559
Table 301 – Binding PE services	563
Table 302 – Local Add PE Entity	564
Table 303 – Local Remove PE Entity	565
Table 304 – Local Update PE_OperationalMode	566
Table 305 – PE Entity Filter Data definition	567
Table 306 – PE Entity Filter Data definition	568
Table 307 – Remote primitives issued or received by PESM	570
Table 308 – Local primitives issued or received by PESM	570
Table 309 – State table PESM	571
Table 310 – Functions, Macros, Timers and Variables used by PESM	571
Table 311 – Binding LogBook services	572
Table 312 – Data elements of Read LogBook Data	573
Table 313 – Local Create LogBook Entry	574
Table 314 – Binding RS services	581
Table 315 – Immanent observers	583
Table 316 – Configured observers	583
Table 317 – Data elements of Local Add RS Event	589
Table 318 – Data elements of RS Get Event	590
Table 319 – Data elements of RS Ack Event	590
Table 320 – Data elements of RS Adjust Observer	591
Table 321 – Local primitives issued or received by RSOBS	592
Table 322 – State table RSOBS	594
Table 323 – Functions, Macros, Timers and Variables used by RSOBS	595
Table 324 – Local primitives issued or received by RSBUF	596
Table 325 – State table RSBUF	597
Table 326 – Functions, Macros, Timers and Variables used by RSBUF	599
Table 327 – Binding Time services	600
Table 328 – Local Get Time	601
Table 329 – Local primitives issued or received by TimeSM	602
Table 330 – State table TimeSM	603
Table 331 – Functions, Macros, Timers and Variables used by TimeSM	604
Table 332 – FAL services of the IO device	606
Table 333 – FAL services of the IO controller	607
Table F.1 – ChannelErrorType	624
Table F.2 – Preconditions ChannelErrorType 0 – 0xFF	625
Table F.3 – Preconditions for ChannelErrorType 0x0100 – 0x7FFF, 0x9000 – 0x9FFF	625
Table F.4 – Preconditions for ChannelErrorType “Data transmission impossible”	625
Table F.5 – Preconditions for ChannelErrorType “Remote mismatch”	626
Table F.6 – Preconditions for ChannelErrorType “Media redundancy mismatch – ring”	626
Table F.7 – Preconditions for ChannelErrorType “Media redundancy mismatch - interconnection”	627
Table F.8 – Preconditions for ChannelErrorType “Sync mismatch”	627

Table F.9 – Preconditions for ChannelErrorType “Isochronous mode mismatch”	627
Table F.10 – Preconditions for ChannelErrorType “Multicast CR mismatch”	627
Table F.11 – Preconditions for ChannelErrorType “Fiber optic mismatch”	628
Table F.12 – Preconditions for ChannelErrorType “Network component function mismatch”	628
Table F.13 – Preconditions for ChannelErrorType “Dynamic Frame Packing function mismatch”	628
Table F.14 – Preconditions for ChannelErrorType “Media redundancy with planned duplication mismatch”	628
Table F.15 – Preconditions for ChannelErrorType “Multiple interface mismatch”	628

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 5-10: Application layer service definition –
Type 10 elements****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This International Standard IEC 61158-5-10 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- integration of system redundancy basic functionality;
- integration of dynamic reconfiguration basic functionality;
- integration of reporting system basic functionality;

- integration of asset management basic functionality;
- integration of media redundancy ring interconnection basic functionality.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/947/FDIS	65C/950/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This document defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-10: Application layer service definition – Type 10 elements

1 Scope

1.1 General

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 10 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the Type 10 fieldbus application layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to

- a) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- b) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This document specifies the structure and services of the Type 10 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this document to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this document is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal application programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This document does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill the Type 10 application layer services as defined in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross -references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61158-1:2019, *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

IEC 61158-5-3, *Industrial communication networks – Fieldbus specifications – Part 5-3: Application layer service definition – Type 3 elements*

IEC 61158-6-3, *Industrial communication networks – Fieldbus specifications – Part 6-3: Application layer protocol specification – Type 3 elements*

IEC 61158-6-10:2019, *Industrial communication networks – Fieldbus specifications – Part 6-10: Application layer protocol specification – Type 10 elements*

IEC 61800-7-203:2015, *Adjustable speed electrical power drive systems – Part 7-203: Generic interface and use of profiles for power drive systems – Profile type 3 specification*

IEC 62439-2, *Industrial communication networks – High availability automation networks – Part 2: Media Redundancy Protocol (MRP)*

ISO/IEC 646, *Information technology – ISO 7-bit coded character set for information interchange*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 9834-8, *Information technology – Procedures for the operation of object identifier registration authorities – Part 8: Generation of universally unique identifiers (UUIDs) and their use in object identifiers*

ISO/IEC 10646, *Information technology – Universal Coded Character Set (UCS)*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 15802-1, *Information technology -- Telecommunications and information exchange between systems – Local and metropolitan area networks – Common specifications – Part 1: Medium Access Control (MAC) service definition*

ISO/IEC/IEEE 60559:2011, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

ISO 8601, *Data elements and interchange formats – Information interchange – Representation of dates and times*

IEEE Std 802, *IEEE Standard for Local and metropolitan area networks: Overview and Architecture*, available at <<http://www.ieee.org>>[viewed 2018-09-21]

IEEE Std 802.1, *IEEE Standard for Local and metropolitan area networks: Station and Media Access Control Connectivity Discovery*, available at <<http://www.ieee.org>>[viewed 2018-09-21]

IEEE Std 802.1AB, *IEEE Standard for Local and metropolitan area networks: Station and Media Access Control Connectivity Discovery*, available at <<http://www.ieee.org>>[viewed 2018-09-21]

IEEE Std 802.1AS, *IEEE Standard for Information technology – Telecommunications and information exchange between systems – IEEE standard for Local and metropolitan area networks – Timing and Synchronization for Time-Sensitive Applications in Bridged Local Area Networks*, available at <<http://www.ieee.org>>[viewed 2018-09-21]

IEEE Std 802.1Q, *IEEE Standard for Local and metropolitan area networks – Media Access Control (MAC) Bridges and Virtual Bridged Local Area Networks*, available at <<http://www.ieee.org>>[viewed 2018-09-21]

IEEE Std 802.3, *IEEE Standard for Ethernet*, available at <<http://www.ieee.org>>[viewed 2018-09-21]

IETF RFC 768, *User Datagram Protocol*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 791, *Internet Protocol*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 792, *Internet Control Message Protocol*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 826, *An Ethernet Address Resolution Protocol or Converting Network Protocol Addresses to 48.bit Ethernet Address for Transmission on Ethernet Hardware*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 894, *A Standard for the Transmission of IP Datagrams over Ethernet Networks*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 1034, *Domain names – concepts and facilities*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 1112, *Host Extensions for IP Multicasting*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 1157, *A Simple Network Management Protocol (SNMP)*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 1213, *Management Information Base for Network Management of TCP/IP-based internets: MIB-II*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 2131, *Dynamic Host Configuration Protocol*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 2132, *DHCP Options and BOOTP Vendor Extensions*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 2365, *Administratively Scoped IP Multicast*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 2674, *Definitions of Managed Objects for Bridges with Traffic Classes, Multicast Filtering and Virtual LAN Extensions*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 2737, *Entity MIB (Version 2)*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 2863, *The Interfaces Group MIB*; available at <<http://www.ietf.org>>[2018-09-21]

IETF RFC 3418, *Management Information Base (MIB) for the Simple Network Management Protocol (SNMP)*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 3490, *Internationalizing Domain Names in Applications (IDNA)*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 3621, *Power Ethernet MIB*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 4836, *Definitions of Managed Objects for IEEE 802.3 Medium Attachment Units (MAUs)*, available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 5905, *Network Time Protocol Version 4: Protocol and Algorithms Specification*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

IETF RFC 6890, *Special-Purpose IP Address Registries*; available at <<http://www.ietf.org>>[viewed 2018-09-21]

The Open Group — Publication C706, *Technical standard DCE1.1: Remote Procedure Call*, available at <<http://www.opengroup.org/onlinepubs/9629399/toc.htm>>[viewed 2018-09-21]

3 Terms, definitions, abbreviations, symbols and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviated terms and conventions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 Referenced terms and definitions

3.1.1 ISO/IEC 7498-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 7498-1 apply:

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation
- g) application transaction
- h) real open system
- i) transfer syntax

3.1.2 ISO/IEC 8822 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8822 apply:

- a) abstract syntax
- b) presentation context

3.1.3 ISO/IEC 9545 terms

For the purposes of this document, the following terms as defined in ISO/IEC 9545 apply:

- a) application-association
- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type

- h) application-service-element
- i) application control service element

3.1.4 ISO/IEC 8824-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8824-1 apply:

- a) object identifier
- b) type

3.2 Additional Type 10 terms and definitions

3.2.1

alarm

activation of an event that shows a critical state

3.2.2

alarm ack

acknowledgment of an event that shows a critical state

3.2.3

alarm data object

object(s) which represent critical states referenced by device/slot/subslot/alarm type

3.2.4

allocate

take a resource from a common area and assign that resource for the exclusive use of a specific entity

3.2.5

application

function or data structure for which data is consumed or produced

3.2.6

application layer interoperability

capability of application entities to perform coordinated and cooperative operations using the services of the FAL

3.2.7

application objects

multiple object classes that manage and provide a run time exchange of PDUs across the network and within the network device

3.2.8

application process

part of a distributed application on a network, which is located on one device and unambiguously addressed

3.2.9

application process identifier

attribute that identifies an application process used in a device

3.2.10

application process object

component of an application process that is identifiable and accessible through an FAL application relationship

Note 1 to entry: Application process object definitions are composed of a set of values for the attributes of their class (see the definition for Application Process Object Class Definition). Application process object definitions may be accessed remotely using the services of the FAL Object Management ASE. FAL Object Management services can be used to load or update object definitions, to read object definitions, and to dynamically create and delete application process objects and their corresponding definitions.

3.2.11

application process object class

class of application process objects defined in terms of the set of their network-accessible attributes and services

3.2.12

application relationship

cooperative association between two or more application-entity-invocations for the purpose of exchange of information and coordination of their joint operation. This relationship is activated either by the exchange of application-protocol-data-units or as a result of preconfiguration activities

3.2.13

application relationship application service element

application-service-element that provides the exclusive means for establishing and terminating all application relationships

3.2.14

application relationship endpoint

context and behavior of an application relationship as seen and maintained by one of the application processes involved in the application relationship

Note 1 to entry: Each application process involved in the application relationship maintains its own application relationship endpoint.

3.2.15

attribute

description of an externally visible characteristic or feature of an object

Note 1 to entry: The attributes of an object contain information about variable portions of an object. Typically, they provide status information or govern the operation of an object. Attributes may also affect the behavior of an object. Attributes are divided into class attributes and instance attributes.

3.2.16

backup

status of the IO AR, which indicates that it, is in the standby state

3.2.17

behavior

indication of how an object responds to particular events

3.2.18

channel

representation of a single physical or logical link of an input or output application process object of a server to the process in order to support addressing of diagnosis information

Note 1 to entry: The channel typically represents a single connector or clamp as a real interface of a module or sub-module. This reference is used to identify points of failure within diagnosis PDUs.

3.2.19

channel related diagnosis

information concerning a specific element of an input or output application process object, provided for maintenance purposes

EXAMPLE open loop

3.2.20**class**

set of objects, all of which represent the same kind of system component

Note 1 to entry: A class is a generalization of an object; a template for defining variables and methods. All objects in a class are identical in form and behavior, but usually contain different data in their attributes.

3.2.21**class attributes**

attribute that is shared by all objects within the same class

3.2.22**class code**

unique identifier assigned to each object class

3.2.23**class specific service**

service defined by a particular object class to perform a required function which is not performed by a common service

Note 1 to entry: A class specific object is unique to the object class which defines it.

3.2.24**clear**

status of the IO controller, which indicates that the control algorithm is currently not running

3.2.25**client**

- a) object which uses the services of another (server) object to perform a task
- b) initiator of a PDU to which a server reacts

3.2.26**common profile**

collection of device independent information and functionality providing consistency between all devices

3.2.27**communication data object**

object(s) which are parameter of communication relationships and referenced by device/ slot/ subslot/ index

3.2.28**configuration check**

comparison of the expected IO-Data object structuring of the client with the real IO-Data object structuring to the server in the start-up phase

3.2.29**configuration fault**

unacceptable difference between the expected IO-Data object structuring and the real IO-Data object structuring, as detected by the server

3.2.30**configuration identifier**

representation of a portion of IO Data of a single input- and/or output-module of a server

3.2.31**consume**

act of receiving data from a provider

3.2.32

consumer

node or sink receiving data from a provider

3.2.33

context management

network-accessible information (communication objects) that supports managing the operation of the fieldbus system, including the application layer

Note 1 to entry: Managing includes functions such as controlling, monitoring, and diagnosing.

3.2.34

conveyance path

unidirectional flow of APDUs across an application relationship

3.2.35

cyclic

repetitive in a regular manner

3.2.36

data consistency

means for coherent transmission and access of the input- or output-data object between and within client and server

3.2.37

device

physical hardware connected to the link

Note 1 to entry: A device may contain more than one node.

3.2.38

device ID

vendor assigned device type identification

3.2.39

device profile

collection of device dependent information and functionality providing consistency between similar devices of the same device type

3.2.40

diagnosis data object

object(s) which contain diagnosis information referenced by device/slot/subslot/index

3.2.41

diagnosis information

all data available at the server for maintenance purposes

3.2.42

dynamic reconfiguration

change of IO data objects without interruption of an established application relationship and continuous updating of non-changed IO data objects

3.2.43

endpoint

one of the communicating entities involved in a connection

3.2.44**engineering**

abstract term that characterizes the client application or device responsible for configuring an automation system

3.2.45**error**

discrepancy between a computed, observed or measured value or condition and the specified or theoretically correct value or condition

3.2.46**error class**

general grouping for related error definitions and corresponding error codes

3.2.47**error code**

identification of a specific type of error within an error class

3.2.48**event**

instance of a change of conditions

3.2.49**extended channel related diagnosis**

information concerning a specific element of a specific application process object, provided for maintenance purposes

EXAMPLE Link Fail

3.2.50**fast startup**

accelerated procedure to setup an IO device after a power cycle

3.2.51**frame**

unit of data transfer on a link

3.2.52**identification data object**

object(s) that contain information about device, module and submodule manufacturer and type referenced by device/slot/subslot/index

3.2.53**implicit AR endpoint**

AR endpoint that is defined locally within a device without use of the create service

3.2.54**index**

address of a record data object within an application process

3.2.55**instance**

the actual physical occurrence of an object within a class that identifies one of many objects within the same object class

3.2.56**instance attributes**

attribute that is unique to an object instance and not shared by the object class

3.2.57

instantiated

object that has been created in a device

3.2.58

invocation

act of using a service or other resource of an application process

Note 1 to entry: Each invocation represents a separate thread of control that may be described by its context. Once the service completes, or use of the resource is released, the invocation ceases to exist. For service invocations, a service that has been initiated but not yet completed is referred to as an outstanding service invocation. Also for service invocations, an Invoke ID may be used to unambiguously identify the service invocation and differentiate it from other outstanding service invocations.

3.2.59

IO controller

controlling device, which acts as client for several IO devices (field devices)

Note 1 to entry: This is usually a programmable controller or a distributed control system.

3.2.60

IO data object

object designated to be transferred cyclically for the purpose of processing and referenced by device/slot/subslot

3.2.61

IO device

field device which acts as server for IO operation

3.2.62

IO parameter server

server for application parameter of IO devices (client)

Note 1 to entry: This is usually a device to backup parameter data and to log online changes of device parameter.

3.2.63

IO subsystem

subsystem composed of one IO controller and all its associated IO devices

3.2.64

IO supervisor

engineering device which manages commissioning and/or diagnosis of an IO system

3.2.65

IO system

system composed of all its IO subsystems

Note 1 to entry: As an example a PLC with more than one IO controller (network interface) controls one IO system composed of an IO subsystem for each IO controller.

3.2.66

Isochronous mode

IO system operating tightly synchronized with a jitter of less than 1 µs

3.2.67

member

piece of an attribute that is structured as an element of an array

**3.2.68
method**

synonym for an operational service which is provided by the server ASE and invoked by a client

**3.2.69
module**

hardware or logical component of a physical device

**3.2.70
network**

set of nodes connected by some type of communication medium, including any intervening repeaters, bridges, routers and lower-layer gateways

**3.2.71
object**

abstract representation of a particular component within a device, usually a collection of related data (in the form of variables) and methods (procedures) for operating on that data that have a clearly defined interface and behavior

**3.2.72
object specific service**

service unique to the object class which defines it

**3.2.73
operate**

status of the IO controller that indicates that the control algorithm is currently running

**3.2.74
peer**

role of an AR endpoint in which it is capable of acting as both client and server

**3.2.75
physical device**

automation or other network device

**3.2.76
point-to-point connection**

connection that exists between exactly two application process objects

**3.2.77
primary**

status of the IO AR that indicates that it is in the operating state

Note 1 to entry: Besides a primary IO AR a backup IO AR may exist. In example used for system redundancy and dynamic reconfiguration of IO data.

**3.2.78
provider**

node or source sending data to one or many consumer

**3.2.79
PTCP domain**

certain number of PTCP subdomains in one IP subnet

**3.2.80
PTCP subdomain**

certain amount of DTEs with synchronized clocks

3.2.81

record data object

object(s) which are already pre-processed and transferred acyclically for the purpose of information or further processing and referenced by device/slot/subslot/index

3.2.82

resource

processing or information capability

3.2.83

run

status of the IO controller which indicates that the control algorithm is currently operating

3.2.84

server

- a) role of an AREP in which it returns a confirmed service response APDU to the client that initiated the request
- b) object which provides services to another (client) object

3.2.85

service

operation or function that an object and/or object class performs upon a request from another object and/or object class

3.2.86

slot

address of a structural unit within an IO device

Note 1 to entry: Within a modular device, a slot typically addresses a physical module. Within compact devices, a slot typically addresses a logical function or virtual module.

3.2.87

stop

status of the IO controller which indicates that the control algorithm is currently not running

3.2.88

submodule

hardware or logical component of a module

3.2.89

subslot

address of a structural unit within a slot

Note 1 to entry: A subslot may address a physical interface for submodules within a module. Generally, a subslot is a second level to structure data within a device.

3.2.90

vendor ID

central administrative number used as manufacturer identification

3.3 Additional Type 10 terms and definitions for media redundancy

3.3.1

failure

termination of the ability of an item to perform a required function

Note 1 to entry: After failure the item has a fault.

Note 2 to entry: "Failure" is an event, as distinguished from "fault", which is a state.

Note 3 to entry: This concept as defined does not apply to items considering of software only.

3.3.2

fault

state of an item characterized by its inability to perform a required function, excluding the inability during preventive maintenance or other planned actions, or due to lack of external resources

Note 1 to entry: A fault is often the result of a failure of the item itself, but may exist without prior failure.

3.3.3

recovery

event when the item regains the ability to perform a required function, after a fault

3.3.4

recovery time

time period required for recovery

3.3.5

redundancy

existence in an item of two or more means of performing a required function

Note 1 to entry: In this context, the existence of more than one path (consisting of links and switches) between end nodes.

3.3.6

ring

network where each node is connected in series to two other nodes

Note 1 to entry: Nodes are connected to one another in the logical shape of a circle.

Note 2 to entry: Frames are passed sequentially between active nodes, each able to examine or modify the frame before forwarding it.

3.3.7

ringport

port of a switch to which a ring link is attached

3.3.8

ring link

link that connects two switches of a ring

3.3.9

switch node

MAC bridge as defined in IEEE 802.1Q

Note 1 to entry: It is called "switch" in this context.

3.4 Abbreviations and symbols

3.4.1 General

AE	Application Entity
AL	Application Layer
ALME	Application Layer Management Entity
ALP	Application Layer Protocol
AP	Application Process
APDU	Application Protocol Data Unit
API	Application Process Identifier
APMR	Acyclic Protocol Machine Receiver
APMS	Acyclic Protocol Machine Sender
APO	Application Process Object
AR	Application Relationship
AREP	Application Relationship End Point
ARL	Application Relationship List
ASCII	American Standard Code for Information Interchange
ASE	Application Service Element
BMA	Best Master Algorithm
CID	Connection ID
CIM	Computer Integrated Manufacturing
CIP	Control and Information Protocol
CR	Communication Relationship
CREP	Communication Relationship End Point
CTLSM	Controller state machine
DEVSM	Device state machine
DIAG_DIAG	Diagnosis entry state machine
DIAG_MD	Maintenance demanded entry state machine
DIAG_MR	Maintenance required entry state machine
DIAG_QUALIFIED	Qualified entry state machine
DL-	(as a prefix) Data Link-
DLC	Data Link Connection
DLL	Data Link Layer
DLSAP	Data Link Service Access Point
DNS	Domain Name Service
DP	Decentralized Peripherals
FAL	Fieldbus Application Layer
FIFO	First In First Out
FODIAG	Fiber Optic Diagnosis
FOMD	Fiber Optic Maintenance Demanded
FOMR	Fiber Optic Maintenance Required
HMI	Human Machine Interface
ID	Identifier
IEC	International Electrotechnical Commission
IP	Internet Protocol
ISO	International Organization for Standardization
LME	Layer Management Entity
LOC_LNK	Local Link
MAU	Medium Attachment Unit
MIB	Management Information Base
MRA	Media Redundancy Manager (auto negotiation)
MRC	Media Redundancy Client
MRM	Media Redundancy Manager
MRP	Media Redundancy Protocol
MRPD	Media Redundancy with Planned Duplication of frames
OSI	Open Systems Interconnect
OWNSM	Ownership Submodule
PDev	Physical Device
PDU	Protocol Data Unit
PL	Physical Layer
PLUGSM	Plug State Machine

PULLSM	Pull State Machine
REM_CHK	Remote check (neighborhood check)
REP	Route Endpoint
RSMSM	Real Submodule State Machine
SAP	Service Access Point
SCL	Security Level
SDU	Service Data Unit
SEM	State Event Matrix
SMIB	System Management Information Base
SMK	System Management Kernel
SNMP	Simple Network Management Protocol
STD	State Transition Diagram, used to describe object behavior
S-VFD	Simple Virtual Field Device
SYNC_DIAG	Synchronization Diagnosis
UTC	Universal Time Coordinated

3.4.2 Additional Type 10 abbreviations and symbols

ACK	Acknowledged
ALPMI	Alarm Protocol Machine Initiator
ALPMR	Alarm Protocol Machine Responder
ARP	Address Resolution Protocol
BBUU	Buffer Buffer Unconfirmed Unidirectional
BBUU-OM	Buffer Buffer Unconfirmed Unidirectional - One to Many
BMC	Best Master Clock
CL-RPC	Connectionless Remote Procedure Call
CM	Context Management
CPM	Cyclic Consumer Protocol Machine
DCE	OSF Distributed Computing Environment
DCP	Discovery and basic Configuration Protocol
DHCP	Dynamic Host Configuration Protocol
DIM	Device Interface Module
DLPDU	Data Link-Protocol Data Unit
DTE	Data Terminal Equipment
GSDML	General Station Description Markup Language
I&M	Identification and Maintenance Profile
IANA	Internet Assigned Numbers Authority
ICMP	Internet Control Message Protocol
IDNA	Internationalizing Domain Names in Applications
IOCR	Input Output Communication Relation
IOCS	Input Output Object Consumer Status
IOPS	Input Output Object Provider Status
IR	Isochronous Relay
IRT	Isochronous Real Time Protocol
ISO	International Organization for Standardization
IsoM	Isochronous Mode
ISOM_IN	Isochronous Mode Input Data state machine
ISOM_OUT	Isochronous Mode Output Data state machine
ISOM_SYNC	Isochronous Mode Sync state machine
LED	Light Emitting Diode
LLDP	Link Layer Discovery Protocol
LME	Layer Management Entity
lsb	Least Significant Bit
LT	Length/Type
MAC	Medium Access Control
MCR	Multicast Communication Relation
msb	Most Significant Bit
NCA	Network Computing Architecture
PL	Physical Layer
PPM	Cyclic Provider Protocol Machine

PTCP	Precision Transparent Clock Protocol
QQCB-CL	Queue Queue Confirmed Bi-directional - Connectionless
QQCB-CO	Queue Queue Confirmed Bi-directional - Connection-Oriented
RPC	Remote Procedure Call
RT	Real Time
RTA	Real Time Protocol Acyclic
RTC	Real Time Protocol Cyclic
RTC3PSM	Realtime Class 3 Port State Machine
TLV	Type Length Value (coding rule)
UDP	User Datagram Protocol
UUID	Universally Unique Identifier
VLAN	Virtual Local Area Network

3.4.3 Abbreviations and symbols for services

cnf	Confirmation
ind	Indication
req	Request
rsp	Response

3.5 Conventions

3.5.1 Overview

The FAL is defined as a set of object-oriented ASEs. Each ASE is specified in a separate subclause. Each ASE specification is composed of two parts, its class specification, and its service specification.

The class specification defines the attributes of the class. The attributes are accessible from instances of the class using the Object Management ASE services specified in Clause 5 of this document. The service specification defines the services that are provided by the ASE.

3.5.2 General conventions

This document uses the descriptive conventions given in ISO/IEC 10731.

3.5.3 Conventions for class definitions

Class definitions are described using templates. Each template consists of a list of attributes for the class. The general form of the template is shown below:

FAL ASE:	ASE Name
CLASS:	Class Name
CLASS ID:	#
PARENT CLASS:	Parent Class Name
ATTRIBUTES:	
1	(o) Key Attribute: numeric identifier
2	(o) Key Attribute: name
3	(m) Attribute: attribute name(values)
4	(m) Attribute: attribute name(values)
4.1	(s) Attribute: attribute name(values)
4.2	(s) Attribute: attribute name(values)
4.3	(s) Attribute: attribute name(values)
5	(c) Constraint: constraint expression
5.1	(m) Attribute: attribute name(values)
5.2	(o) Attribute: attribute name(values)
6	(m) Attribute: attribute name(values)

6.1 (s) Attribute: attribute name(values)

6.2 (s) Attribute: attribute name(values)

SERVICES:

1 (o) OpsService: service name

2 (c) Constraint: constraint expression

2.1 (o) OpsService: service name

3 (m) MgtService: service name

(1) The "FAL ASE:" entry is the name of the FAL ASE that provides the services for the class being specified.

(2) The "CLASS:" entry is the name of the class being specified. All objects defined using this template will be an instance of this class. The class may be specified by this document, or by a user of this document.

(3) The "CLASS ID:" entry is a number that identifies the class being specified. This number is unique within the FAL ASE that will provide the services for this class. When qualified by the identity of its FAL ASE, it unambiguously identifies the class within the scope of the FAL. The value "NULL" indicates that the class cannot be instantiated. Class IDs between 1 and 255 are reserved by this document to identify standardized classes. They have been assigned to maintain compatibility with existing national standards. CLASS IDs between 256 and 2 048 are allocated for identifying user defined classes.

(4) The "PARENT CLASS:" entry is the name of the parent class for the class being specified. All attributes defined for the parent class and inherited by it are inherited for the class being defined, and therefore do not have to be redefined in the template for this class.

NOTE The parent-class "TOP" indicates that the class being defined is an initial class definition. The parent class TOP is used as a starting point from which all other classes are defined. The use of TOP is reserved for classes defined by this document.

(5) The "ATTRIBUTES" label indicate that the following entries are attributes defined for the class.

- a) Each of the attribute entries contains a line number in column 1, a mandatory (m) / optional (o) / conditional (c) / selector (s) indicator in column 2, an attribute type label in column 3, a name or a conditional expression in column 4, and optionally a list of enumerated values in column 5. In the column following the list of values, the default value for the attribute may be specified.
- b) Objects are normally identified by a numeric identifier or by an object name, or by both. In the class templates, these key attributes are defined under the key attribute.
- c) The line number defines the sequence and the level of nesting of the line. Each nesting level is identified by period. Nesting is used to specify
 - i) fields of a structured attribute (4.1, 4.2, 4.3),
 - ii) attributes conditional on a constraint statement (5). Attributes may be mandatory (5.1) or optional (5.2) if the constraint is true. Not all optional attributes require constraint statements as does the attribute defined in (5.2),
 - iii) the selection fields of a choice type attribute (6.1 and 6.2).

(6) The "SERVICES" label indicates that the following entries are services defined for the class.

- a) An (m) in column 2 indicates that the service is mandatory for the class, while an (o) indicates that it is optional. A (c) in this column indicates that the service is conditional. When all services defined for a class are defined as optional, at least one has to be selected when an instance of the class is defined.
- b) The label "OpsService" designates an operational service (1).
- c) The label "MgtService" designates a management service (2).

- d) The line number defines the sequence and the level of nesting of the line. Each nesting level is identified by period. Nesting within the list of services is used to specify services conditional on a constraint statement.

Attributes and services are addressed with the following syntax:

- ASE:class:attribute
- ASE::attribute (if ASE contains only one class with same name)
- ASE:class:service():parameter
- ASE::service():parameter (if ASE contains only one class with same name)

Among other things, this is used for relation definitions.

3.5.4 Conventions for service definitions

3.5.4.1 General

The service model, service primitives, and time-sequence diagrams used are entirely abstract descriptions; they do not represent a specification for implementation.

3.5.4.2 Service parameters

Service primitives are used to represent service user/service provider interactions (see ISO/IEC 10731). They convey parameters which indicate information available in the user/provider interaction. In any particular interface, not all parameters need be explicitly stated.

The service specifications of this document use a tabular format to describe the component parameters of the ASE service primitives. The parameters which apply to each group of service primitives are set out in tables. Each table consists of up to five columns for the

- 1) Parameter name,
- 2) request primitive,
- 3) indication primitive,
- 4) response primitive, and
- 5) confirm primitive.

One parameter (or component of it) is listed in each row of each table. Under the appropriate service primitive columns, a code is used to specify the type of usage of the parameter on the primitive specified in the column:

- M parameter is mandatory for the primitive.
- U parameter is a User option, and may or may not be provided depending on dynamic usage of the service user. This does not imply that the support of the parameter is optional. When not provided, a default value for the parameter is assumed.
- C parameter is conditional upon other parameters or upon the environment of the service user.
- (blank) parameter is never present.
- S parameter is a selected item.

Some entries are further qualified by items in brackets. These may be

- a) a parameter-specific constraint:
 - “(=)” indicates that the parameter is semantically equivalent to the parameter in the service primitive to its immediate left in the table.
- b) an indication that some note applies to the entry:
 - “(n)” indicates that the following note "n" contains additional information pertaining to the parameter and its use.

3.5.4.3 Service procedures

The procedures are defined in terms of

- the interactions between application entities through the exchange of fieldbus Application Protocol Data Units, and
- the interactions between an application layer service provider and an application layer service user in the same system through the invocation of application layer service primitives. These services get a “local” prefix in this document.

These procedures are applicable to instances of communication between systems which support time-constrained communications services within the Fieldbus Application Layer.

Interactions between the ASEs in the same layer are not shown here.

3.5.5 Conventions used in state machines

The protocol sequences are described by means of State Machines.

In state transition diagrams, states are represented as boxes; state transitions are shown as arrows. Names of states and transitions of the state transition diagram correspond to the names in the textual listing of the state transitions.

The initialization of all parameters (e.g. default values) of a state machine will be realized automatically during the instantiation of the machine (new instance). Implicit transition from POWER-ON to first state calling the INIT service. If it is necessary to have different instances of one machine type, different parameters are set by the INIT service.

The textual listing of the state transitions is structured as follows, see also Table 1.

- The first row contains the name of the transition.
- The second row defines the current state.
- The third row contains an optional event followed by Conditions starting with a “/” as first line character and finally followed by the Actions starting with a “=>” as first line character.
- The last row contains the next state.

If the event occurs and the conditions are fulfilled the transition fires, e.g. the actions are executed and the next state is entered.

The layout of a machine description is shown in Table 1. The meaning of the elements of a State Machine Description is shown in Table 2.

Table 1 – State machine description elements

#	Current state	Event or condition => action	Next state

Table 2 – Description of state machine elements

Description element	Meaning
Current state	Name of the given states.
Next state	
#	Name or number of the state transition.
Event	Name or description of the event.
/Condition	Boolean expression. The preceding “/” is not part of the condition.
=> Action	List of assignments and service or function invocations. The preceding “=>” is not part of the action.

The conventions used in the state machines are shown in Table 3.

Table 3 – Conventions used in state machines

Convention	Meaning
:=	Value of an item on the left is replaced by value of an item on the right. If an item on the right is a parameter, it comes from the primitive shown as an input event.
xxx	A parameter name. Example: Identifier := reason means value of a ‘reason’ parameter is assigned to a parameter called ‘Identifier.’
“xxx”	Indicates fixed value. Example: Identifier := “abc” means value “abc” is assigned to a parameter named ‘Identifier.’
= or ==	A logical condition to indicate an item on the left is equal to an item on the right.
<	A logical condition to indicate an item on the left is less than the item on the right.
>	A logical condition to indicate an item on the left is greater than the item on the right.
<> or !=	A logical condition to indicate an item on the left is not equal to an item on the right.
>>	A semantic condition with the meaning “newer”
<<	A semantic condition with the meaning “older”
&&	Logical “AND”
	Logical “OR”
<=	A logical condition to indicate an item on the left is equal or less than the item on the right.
>=	A logical condition to indicate an item on the left is equal or greater than the item on the right.
for (Identifier := start_value to end_value) actions endfor	This construct allows the execution of a sequence of actions in a loop within one transition. The loop is executed for all values from start_value to end_value.
If (condition) actions else actions	This construct allows the execution of alternative actions depending on some condition (which might be the value of some identifier or the outcome of a previous action) within one transition. The parts beginning with “else” can be omitted if there is no action if the condition is not fulfilled.

The conventions used for service in the state machines are shown in Table 3.

Table 4 – Conventions for services used in state machines

Convention	Meaning
xxx.req ()	request according to ISO/IEC 7498-1 invokes the service and passes any required parameter parameters are omitted and listed within the state machine description
xxx.ind ()	indication according to ISO/IEC 7498-1 advices the activation of a requested service
xxx.rsp (+), xxx.cnf (+)	response according to ISO/IEC 7498-1 may positively acknowledge or complete an action previously invoked by a request primitive confirmation according to ISO/IEC 7498-1 primitive returned to the requestor to positively acknowledge or complete an action previously invoked by a request primitive parameters are omitted and listed within the state machine description
xxx.rsp (-), xxx.cnf (-)	response according to ISO/IEC 7498-1 may negatively acknowledge or complete an action previously invoked by a request primitive confirmation according to ISO/IEC 7498-1 primitive returned to the requestor to negatively acknowledge or complete an action previously invoked by a request primitive parameters are omitted and listed within the state machine description
xxx_req (), xxx_cnf (+), xxx_cnf (-)	this construct is used for the description of local and confirmed services, which are transferred between state machines parameters are listed within the state machine description and can be delivered inside the brackets optionally
xxx_ind ()	this construct is used for the description of local services and indicates the reception of this service parameters are listed within the state machine description and can be delivered inside the brackets optionally
xxx ()	this construct is used for the description of state machine internal functions (local) parameters are listed within the state machine description and can be delivered inside the brackets optionally
(), (+), (-)	replacement of the associated parameter list, described in the primitives definition except local services and functions can deliver parameters inside the brackets if the result is not necessary for further executions, the sign + and – can be omitted

Readers are strongly recommended to refer to the clauses for the AREP and CREP attribute definitions, the local functions and the FAL-PDU definitions to understand protocol machines. It is assumed that readers have sufficient knowledge of these definitions and they are used without further explanations.

In addition the following description elements are used:

Wildcard in names

name_XXX: “XXX” is used as wildcard string for all names beginning with “name”.

The typical use of a wildcard is an Event. In this context there are as many state transitions as possible events for this wildcard exists.

Conditional Macro

<CONDITIONAL -MACRO-NAME>

<

CONDITION1: macrobody1

CONDITION2: macrobody2

...

>

CONDITION1, CONDITION2, etc. define all possible cases for the conditional macro. The “CONDITIONAL-MACRO-NAME” acts as place holder for the “macrocode” depending on the result of the condition.

Replacement Macro

<REPLACEMENT-MACRO-NAME>

<

XXX= Name1 : macrobody1

XXX= Name2 : macrobody2

...

>

Name1, Name2, etc. define all possible cases for the replacement macro. The “REPLACEMENT-MACRO-NAME” acts as place holder for the “macrocode” depending on the value of the current use of the wildcard XXX.

EXAMPLE

<SERVICE_REQ_PARA>

<

XXX=Read: Para1, Para2

XXX=Write: Para1, Para2, Para3

>

when called in

MSAB_XXX.req(<SERVICE_REQ_PARA>)

will result in

MSAB_Read.req(Para1, Para2) or MSAB_Write.req(Para1, Para2, Para3)

4 Concepts

NOTE Clause 9 of IEC 61158-1 describes the concepts of the application layer service descriptions and the templates used in this document.

5 Data type ASE

5.1 General

5.1.1 Overview

Fieldbus data types specify the machine independent syntax for application data conveyed by FAL services. The fieldbus application layer supports the definition and transfer of both basic and constructed data types. Encoding rules for the data types specified in Clause 5 are provided in IEC 61158-6-10.

Basic types are atomic types that cannot be decomposed into more elemental types. Constructed types are types composed of basic types and other constructed types. Their complexity and depth of nesting is not constrained by this document.

The basic data classes are used to define fixed length and bitstring data types. Standard types are taken from ISO/IEC 8824-1, other standard basic data types are defined specifically for fieldbus applications.

5.1.2 Date and time type specifics

Any date and time related data type, i.e. BinaryDate, TimeOfDay with and without date indication, TimeDifference with and without date indication, NetworkTime, NetworkTimeDifference, and TimeStamp is always related to a specific timescale.

Possible timescales are:

- Local time / local counter; used e.g. for working duration, ...
- WORKING_CLOCK; used e.g. for SendClock, Tinput, Toutput, SampleTime, ...
- Global time / Wall clock; Used e.g. for a comparable point in time, a start time, a stop time, ...

Usable timescales need to be strict monotonously rising, like TAI (temps atomique international), to allow any TimeDifference to be calculated.

Any usage of these data types is only meaningful when having the information, to which timescale the value is related.

Only the data type TimeStamp offers the timescale related to and whether the time is synchronized. All other data types have no indication to which timescale they belong to, or whether the time is synchronized to other devices.

NOTE IEEE 802.1AS provides a mechanism to synchronize devices to the TAI timescale. Thus, no Universal Time Coordinated (UTC) information is available.

5.1.3 Transfer of user data

User data is transferred between applications by the FAL protocol. All encoding and decoding are performed by the FAL user.

The rules for encoding user data in FAL protocol data units is data type dependent. These rules are defined in IEC 61158-6-10. User-defined data types for which there are no encoding rules are transferred as a variable-length sequence of octets. The format of the data within the OctetString is defined by the user.

5.1.4 Data type overview

Table 5 gives an overview over all data types defined within here.

Table 5 – Data type overview

Data type numeric identifier	Data type name	Usage	Alias name	Definition
1	Boolean	Type 10, Type 3	—	see 5.3.1.1
2	Integer8	Type 10, Type 3	char, int8_t	see 5.3.1.3.3.1
3	Integer16	Type 10, Type 3	short, int16_t	see 5.3.1.3.3.2
4	Integer32	Type 10, Type 3	long, int32_t	see 5.3.1.3.3.3
5	Unsigned8	Type 10, Type 3	unsigned char, uint8_t	see 5.3.1.3.4.1
6	Unsigned16	Type 10, Type 3	unsigned short, uint16_t	see 5.3.1.3.4.2
7	Unsigned32	Type 10, Type 3	unsigned long, uint32_t	see 5.3.1.3.4.3

Data type numeric identifier	Data type name	Usage	Alias name	Definition
8	Float32	Type 10, Type 3	float, float32_t	see 5.3.1.3.1.1
9	VisibleString	Type 10, Type 3	—	see 5.3.2.2
10	OctetString	Type 10, Type 3	—	see 5.3.2.1
12	TimeOfDay with date indication	Type 10, Type 3 should not use it	—	see 5.3.1.5.3
13	TimeDifference	obsolete	—	see 5.3.1.5.5
15	Float64	Type 10, Type 3	double, float64_t	see 5.3.1.3.1.2
39	UNICODEString	Type 10, Type 3 should not use it	—	see 5.3.2.4
40	UnicodeString8	Type 10, Type 3	—	see 5.3.2.5
41	61131_STRING	Type 10	—	see 5.3.2.6
42	61131_WSTRING	Type 10	—	see 5.3.2.7
50	BinaryDate	Type 10, Type 3 should not use it	—	see 5.3.1.5.2
52	TimeOfDay without date indication	Type 10, Type 3 should not use it	Unsigned32	see 5.3.1.5.4
53	TimeDifference with date indication	Type 10, Type 3 should not use it	—	see 5.3.1.5.6
54	TimeDifference without date indication	Type 10, Type 3 should not use it	Unsigned32	see 5.3.1.5.7
55	Integer64	Type 10, Type 3	int64_t	see 5.3.1.3.3.4
56	Unsigned64	Type 10, Type 3	uint64_t	see 5.3.1.3.4.4
58	NetworkTime	Type 10, Type 3 should not use it	Unsigned64	see 5.3.1.5.8
59	NetworkTimeDifference	Type 10, Type 3 should not use it	Integer64	see 5.3.1.5.9
60	TimeStamp	Type 10, Type 3	—	see 5.3.1.4.1
61	TimeStampDifference	Type 10, Type 3	—	see 5.3.1.4.2
62	TimeStampDifferenceShort	Type 10, Type 3	Integer64	see 5.3.1.4.3
100	Float64+Unsigned8	Type 10, Type 3	—	see 5.3.1.6.5
101	Float32+Unsigned8	Type 10, Type 3	—	see 5.3.1.6.6
102	Unsigned8+Unsigned8	Type 10, Type 3	—	see 5.3.1.6.7
103	OctetString2+Unsigned8	Type 10, Type 3	—	see 5.3.1.6.4

Data type numeric identifier	Data type name	Usage	Alias name	Definition
104	Unsigned16_S	Type 10, Type 3	—	see 5.3.1.6.8
105	Integer16_S	Type 10, Type 3	—	see 5.3.1.6.9
106	Unsigned8_S	Type 10, Type 3	—	see 5.3.1.6.10
107	OctetString_S	Type 10, Type 3	—	see 5.3.2.2
110	F message trailer with 4 octets	Type 10, Type 3	—	see 5.3.1.6.2
111	F message trailer with 5 octets	Type 10, Type 3	—	see 5.3.1.6.2
113	N2	Type 10, Type 3	Integer16	see 5.3.1.3.3.5
114	N4	Type 10, Type 3	Integer32	see 5.3.1.3.3.6
115	V2	Type 10, Type 3	—	see 5.3.1.2.1
116	L2	Type 10, Type 3	—	see 5.3.1.2.2
117	R2	Type 10, Type 3	Unsigned16	see 5.3.1.3.8
118	T2	Type 10, Type 3	Unsigned16	see 5.3.1.3.5
119	T4	Type 10, Type 3	Unsigned32	see 5.3.1.3.6
120	D2	Type 10, Type 3	Unsigned16	see 5.3.1.3.7
121	E2	Type 10, Type 3	—	see 5.3.1.3.2.1
122	C4	Type 10, Type 3	Integer32	see 5.3.1.3.3.9
123	X2	Type 10, Type 3	Integer16	see 5.3.1.3.3.7
124	X4	Type 10, Type 3	Integer32	see 5.3.1.3.3.8
125	Unipolar2.16	Type 10, Type 3	—	see 5.3.1.3.2.2
128 – 255	for this document: reserved for Type 3: user specific data types	Type 3	—	—
256 – 1 024	Reserved	Type 10	—	—
1 025	UUID	Type 10	—	see 5.3.1.6.1
1 026 – 65 535	Reserved	Type 10	—	—
other	Reserved	Type 10, Type 3	—	—