BS EN IEC 61158-6-10:2019

BSI Standards Publication

Industrial communication networks — Fieldbus specifications

Part 6-10: Application layer protocol specification — Type 10 elements

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

National foreword

This British Standard is the UK implementation of EN IEC 61158-6-10:2019. It is identical to IEC 61158-6-10:2019. It supersedes BS EN 61158-6-10:2014, which will be withdrawn on 25 July 2022.

The UK participation in its preparation was entrusted to Technical Committee GEL/65, Measurement and control.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 580 99211 7

ICS 35.110; 25.040.40; 35.100.70

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 September 2019.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN IEC 61158-6-10

August 2019

ICS 25.040.40; 35.100.70; 35.110

Supersedes EN 61158-6-10:2014 and all of its amendments and corrigenda (if any)

English Version

Industrial communication networks - Fieldbus specifications - Part 6-10: Application layer protocol specification - Type 10 elements (IEC 61158-6-10:2019)

Réseaux de communication industriels - Spécifications des bus de terrain - Partie 6-10: Spécification du protocole de la couche application - Eléments de type 10 (IEC 61158-6-10:2019)

Industrielle Kommunikationsnetze - Feldbusse - Teil 6-10: Protokollspezifikation des Application Layer (Anwendungsschicht) - Typ 10-Elemente (IEC 61158-6-10:2019)

This European Standard was approved by CENELEC on 2019-07-25. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2019 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 61158-6-10:2019 E

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

European foreword

The text of document 65C/948/FDIS, future edition 4 of IEC 61158-6-10, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61158-6-10:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-04-25
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-07-25

This document supersedes EN 61158-6-10:2014 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61158-6-10:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60793-2-30 NOTE Harmonized as EN 60793-2-30
IEC 60793-2-40 NOTE Harmonized as EN 60793-2-40
IEC 61784-3-3 NOTE Harmonized as EN 61784-3-3

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

Publication	Year	Title	EN/HD	Year
IEC 61131-9	-	Programmable controllers - Part 9: Single-drop digital communication interface for small sensors and actuators (SDCI)	EN 61131-9	-
IEC 61158-1	2019	Industrial communication networks - Fieldbus specifications - Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series	EN IEC 61158-1	2019
IEC 61158-2	-	Industrial communication networks - Fieldbus specifications - Part 2: Physical layer specification and service definition	EN 61158-2	-
IEC 61158-5-10	2019	Industrial communication networks - Fieldbus specifications - Part 5-10: Application layer service definition - Type 10 elements	EN IEC 61158-5-10	2019
IEC 61158-6-3	2019	Industrial communication networks - Fieldbus specifications - Part 6-3: Application layer protocol specification - Type 3 elements	--	-
IEC 62439-2	-	Industrial communication networks – High availability automation networks – Part 2: Media Redundancy Protocol (MRP)	EN 62439-2	-
ISO 8601	-	Data elements and interchange formats - Information interchange - Representation of dates and times	--	-
ISO/IEC 646	1991	Information technology - ISO 7-bit coded-character set for information interchange		-
ISO/IEC 7498-1	-	Information technology - Open Systems-Interconnection - Basic Reference Model: The Basic Model		-
ISO/IEC 8822	-	Information technology - Open Systems-Interconnection - Presentation service definition		-
ISO/IEC 8824-1	-	Information technology - Abstract Syntax-Notation One (ASN.1): Specification of basic notation		-
ISO/IEC 9545	-	Information technology - Open Systems-Interconnection - Application Layer structure		-

Documents
Document Sharing Hub
Full document details: BS EN IEC 61158-6-10:2019

ISO/IEC 9834-8	-	Information technology - Procedures for the operation of object identifier registration authorities - Part 8: Generation of universally unique identifiers (UUIDs) and their use in object identifiers	-
ISO/IEC 10646	-	Information technology - Universal Coded Character Set (UCS)	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-
IEEE Std 802	-	IEEE Standard for Local and metropolitan area networks: Overview and Architecture	-
IEEE Std 802.15.1	-	IEEE Standard for Information technology -- Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements. - Part 15.1: Wireless medium access control (MAC) and physical layer (PHY) specifications for wireless personal area networks (WPANs)	-
IEEE Std 802.1AB	2016	IEEE Standard for Local and metropolitan area networks: Station and Media Access Control Connectivity Discovery	-
IEEE Std 802.1AC	-	IEEE Standard for Local and metropolitan area networks: Media Access Control (MAC) Service definition	
IEEE Std 802.1AS	-	IEEE Standard for Local and metropolitan area networks - Timing and Synchronization for Time-Sensitive Applications in Bridged Local Area Networks	-
IEEE Std 802.1Q	2018	IEEE Standard for Local and metropolitan area networks - Bridges and Bridged Networks	-
IEEE Std 802.3	-	IEEE Standard for Ethernet	-
IEEE Std 802.11	-	IEEE Standard for Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 11: Wireless LAN Medium Access Control (MAC) and Physical Layer (PHY) Specifications	
IETF RFC 1034	-	Domain names - concepts and facilities	-
IETF RFC 1213	-	Management Information Base for Network Management of TCP/IP-based Internets: MIB-II	-
IETF RFC 2131	-	Dynamic Host Configuration Protocol	-
IETF RFC 2132	-	DHCP Options and BOOTP Vendor Extensions	-
IETF RFC 2236	-	Internet Group Management Protocol, Version 2	-
IETF RFC 2365	-	Administratively Scoped IP Multicast	-
IETF RFC 2474	-	Definition of the Differentiated Services Field (DS Field) in the IPv4 and IPv6 Headers	-
IETF RFC 2674	-	Definitions of Managed Objects for Bridges with Traffic Classes, Multicast Filtering and Virtual LAN Extensions	-
IETF RFC 2863	-	The Interfaces Group MIB	-

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

IETF RFC 3418	-	Management Information Base (MIB) for the Simple Network Management Protocol (SNMP)	-
IETF RFC 3621	-	Power Ethernet MIB	-
IETF RFC 4361	-	Node-specific Client Identifiers for Dynamic Host Configuration Protocol Version Four (DHCPv4)	-
IETF RFC 4363	-	Definitions of Managed Objects for Bridges with Traffic Classes, Multicast Filtering, and Virtual LAN Extensions	-
IETF RFC 4604	-	Using Internet Group Management Protocol Version 3 (IGMPv3) and Multicast Listener Discovery Protocol Version 2 (MLDv2) for Source-Specific Multicast	-
IETF RFC 4632	-	Classless Inter-domain Routing (CIDR): The Internet Address Assignment and Aggregation Plan	
IETF RFC 4836	-	Definitions of Managed Objects for IEEE 802.3 Medium Attachment Units (MAUs)	-
IETF RFC 5227	-	IPv4 Address Conflict Detection	-
IETF RFC 5890	-	Internationalized Domain Names for Applications (IDNA): Definitions and Document Framework	-
IETF RFC 5905	-	Network Time Protocol Version 4: Protocol and Algorithms Specification	
IETF RFC 6151	-	Updated Security Considerations for the MD5 Message-Digest and the HMAC-MD5 Algorithms	
IETF RFC 6890	-	Special-Purpose IP Address Registries	-
IETF RFC 768	-	User Datagram Protocol	-
IETF RFC 791	-	Internet protocol darpa internet program protocol specification	-
IETF RFC 792	-	Internet Control Message Protocol	-
IETF RFC 826	-	Ethernet Address Resolution Protocol: Or Converting Network Protocol Addresses to 48.bit Ethernet Address for Transmission on Ethernet Hardware	-
IETF RFC 950	-	Internet Standard Subnetting Procedure	-
ISO/IEC/IEEE 60559	2011	Information technology - Microprocessor Systems - Floating-Point arithmetic	-
The Open Group, Publication C706	-	Technical standard DCE1.1: Remote Procedure Call	

Documents
Document Sharing Hub
Full document details: BS EN IEC 61158-6-10:2019

This page deliberately left blank

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

CONTENTS

FOREWORD 37
INTRODUCTION 39
1 Scope 41
1.1 General 41
1.2 Specifications 41
1.3 Conformance 41
2 Normative references 42
3 Terms, definitions, abbreviated terms, symbols and conventions 45
3.1 Referenced terms and definitions 45
3.1.1 ISO/IEC 7498-1 terms 45
3.1.2 ISO/IEC 8822 terms 45
3.1.3 ISO/IEC 8824-1 terms 45
3.1.4 ISO/IEC 9545 terms 45
3.2 Terms and definitions for decentralized periphery 46
3.3 Abbreviated terms and symbols 54
3.3.1 Abbreviated terms and symbols for media redundancy 54
3.3.2 Abbreviated terms and symbols for decentralized periphery 54
3.3.3 Abbreviated terms and symbols for services 58
3.3.4 Abbreviated terms and symbols for IEEE 802.1Q 58
3.3.5 Abbreviated terms and symbols for IETF RFC 2474 58
3.3.6 Abbreviated terms and symbols for IETF RFC 4291 58
3.4 Conventions 58
3.4.1 General concept 58
3.4.2 Conventions for decentralized periphery 58
3.4.3 Conventions used in state machines 67
4 Application layer protocol specification for common protocols 72
4.1 FAL syntax description 72
4.1.1 DLPDU abstract syntax reference 72
4.1.2 Data types 74
4.2 Transfer syntax 75
4.2.1 Coding of basic data types 75
4.2.2 Coding section related to common basic fields 83
4.3 Discovery and basic configuration 94
4.3.1 DCP syntax description 94
4.3.2 DCP protocol state machines 122
4.3.3 DLL Mapping Protocol Machines 139
4.4 Precision working time control 140
4.4.1 FAL syntax description 140
4.4.2 AP-Context state machine 151
4.4.3 FAL Service Protocol Machines 151
4.4.4 Application Relationship Protocol Machines 152
4.4.5 DLL Mapping Protocol Machines 215
4.5 Time synchronization 215
4.5.1 General 215
4.5.2 GlobalTime 216
4.5.3 WorkingClock 216
4.6 Media redundancy 217

AVA Documents Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

4.6.1 Media redundancy and loop prevention 217
4.6.2 Seamless media redundancy 220
4.7 Real time cyclic 220
4.7.1 FAL syntax description 220
4.7.2 FAL transfer syntax 221
4.7.3 FAL Service Protocol Machines 231
4.7.4 Application Relationship Protocol Machines 231
4.7.5 DLL Mapping Protocol Machines 249
4.8 Real time acyclic 249
4.8.1 RTA syntax description 249
4.8.2 RTA transfer syntax 250
4.8.3 FAL Service Protocol Machines 254
4.8.4 Application Relationship Protocol Machines 254
4.8.5 DLL Mapping Protocol Machines 269
4.9 Fragmentation 269
4.9.1 General 269
4.9.2 FRAG syntax description 272
4.9.3 FRAG transfer syntax 273
4.9.4 FAL Service Protocol Machines 275
4.9.5 Application Relationship Protocol Machines 275
4.9.6 DLL Mapping Protocol Machines 275
4.10 Remote procedure call 286
4.10.1 General 286
4.10.2 RPC syntax description 286
4.10.3 RPC Transfer syntax 288
4.10.4 FAL Service Protocol Machines 304
4.10.5 Application Relationship Protocol Machines 304
4.10.6 DLL Mapping Protocol Machines 305
4.11 Link layer discovery 305
4.11.1 General 305
4.11.2 FAL common syntax description 305
4.11.3 LLDP transfer syntax 307
4.11.4 FAL Service Protocol Machines 317
4.11.5 Application Relation Protocol Machines 317
4.11.6 DLL Mapping Protocol Machines 317
4.12 Bridges and End Stations 317
4.12.1 General 317
4.12.2 Model 318
4.12.3 Traffic Shaping 333
4.12.4 Bridge extensions 334
4.12.5 QueueHandler 335
4.12.6 FAL Service Protocol Machines 335
4.12.7 Application Relation Protocol Machines 335
4.12.8 DLL Mapping Protocol Machines 335
4.13 IP suite 374
4.13.1 Overview 374
4.13.2 IP/UDP syntax description 374
4.13.3 IP/UDP transfer syntax 375
4.13.4 ARP 378

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

4.14 Domain name system 380
4.14.1 General 380
4.14.2 Primitive definitions 380
4.14.3 DNS state transition diagram 381
4.14.4 State machine description 381
4.14.5 DNS state table 381
4.14.6 Functions, Macros, Timers and Variables 381
4.15 Dynamic host configuration 381
4.15.1 General 381
4.15.2 Primitive definitions 382
4.15.3 DHCP state transition diagram 382
4.15.4 State machine description 382
4.15.5 DHCP state table 382
4.15.6 Functions, Macros, Timers and Variables 382
4.16 Simple network management 383
4.16.1 Overview 383
4.16.2 IETF RFC 1213-MIB 383
4.16.3 Enterprise number for PNIO MIB 383
4.16.4 MIB cross reference 384
4.16.5 Behavior in case of modular built bridges 384
4.16.6 LLDP EXT MIB 384
4.17 Common DLL Mapping Protocol Machines 384
4.17.1 Overview 384
4.17.2 Data Link Layer Mapping Protocol Machine 385
4.18 Additional definitions 390
5 Application layer protocol specification for decentralized periphery 390
5.1 FAL syntax description 390
5.1.1 DLPDU abstract syntax reference 390
5.1.2 APDU abstract syntax 390
5.2 Transfer syntax 409
5.2.1 Coding section related to BlockHeader specific fields 409
5.2.2 Coding section related to RTA-SDU specific fields 424
5.2.3 Coding section related to common address fields 429
5.2.4 Coding section related to AL services 445
5.2.5 Coding section related to ARVendorBlock 479
5.2.6 Coding section related to PNIOStatus 481
5.2.7 Coding section related to I&M Records 498
5.2.8 Coding section related to Alarm and Diagnosis PDUs 505
5.2.9 Coding section related to upload and retrieval 527
5.2.10 Coding section related to iParameter 527
5.2.11 Coding section related to Physical Device Interface Data 528
5.2.12 Coding section related to Physical Device Port Data 528
5.2.13 Coding section related to Physical Device IR Data 531
5.2.14 Coding section related to Physical Sync Data 554
5.2.15 Coding section related to Isochrone Mode Data 559
5.2.16 Coding section related to Physical Time Data 561
5.2.17 Coding section related to Media Redundancy 564
5.2.18 Coding section related to fiber optics 575
5.2.19 Coding section related to network components 577

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

5.2.20 Coding section related port statistic 578
5.2.21 Coding section related to fast startup 581
5.2.22 Coding section related to DFP 583
5.2.23 Coding section related to MRPD 587
5.2.24 Coding section related to auto configuration 588
5.2.25 Coding section related to controller to controller communication 591
5.2.26 Coding section related to system redundancy 592
5.2.27 Coding section related to energy saving 595
5.2.28 Coding section related to asset management 595
5.2.29 Coding section related to reporting system 600
5.2.30 Coding section related to Logbook 606
5.2.31 Coding section related to Time 607
5.2.32 Coding section related to Channel Related Process Alarm Reason 607
5.2.33 PDU checking rules 610
5.3 FAL protocol state machines 643
5.3.1 Overall structure 643
5.4 AP-Context state machine 645
5.5 FAL Service Protocol Machines 645
5.5.1 Overview 645
5.5.2 FAL Service Protocol Machine Device 645
5.5.3 FAL Service Protocol Machine Controller 654
5.6 Application Relationship Protocol Machines 665
5.6.1 Alarm Protocol Machine Initiator 665
5.6.2 Alarm Protocol Machine Responder 669
5.6.3 Device 673
5.6.4 Controller 756
5.7 DLL Mapping Protocol Machines 818
Annex A (normative) Unified establishing of an AR for all RT classes 819
A.1 General 819
A.2 AR establishing 820
A.3 Startup of Alarm transmitter and receiver 825
Annex B (normative) Compatible establishing of an AR 828
Annex C (informative) Establishing of a device access AR 831
Annex D (informative) Establishing of an AR (accelerated procedure) 832
Annex E (informative) Establishing of an AR (fast startup procedure) 835
Annex F (informative) Example of the upload, storage and retrieval procedure 837
Annex G (informative) OSI reference model layers 839
Annex H (informative) Overview of the IO controller and the IO device state machines 840
Annex I (informative) Priority regeneration 842
Annex J (informative) Overview of the PTCP synchronization master hierarchy 843
Annex K (informative) Optimization of bandwidth usage 845
Annex L (informative) Time constraints for bandwidth allocation 847
Annex M (informative) Time constraints for the forwarding of a frame 849
M.1 Principle 849
M.2 Forwarding 849
Annex N (informative) Principle of dynamic frame packing 851
Annex O (informative) Principle of Fragmentation 854

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Annex P (informative) MRPD – Principle of seamless media redundancy 858
Annex Q (normative) Principle of a RED_RELAY without forwarding information in PDIRFrameData 860
Annex R (informative) Optimization for fast startup without autonegotiation 863
Annex S (informative) Example of a PrmBegin, PrmEnd and ApplRdy sequence 866
Annex T (informative) List of supported MIBs 867
Annex U (informative) Structure and content of BLOB 868
Annex V (normative) LLDP EXT MIB 869
Annex W (normative) Cross reference to the IEC 62439-2 887
W.1 Cross reference to the IEC 62439-2 887
W.1.1 General 887
W.1.2 Ring 887
W.1.3 Interconnection 888
Annex X (normative) Maintaining statistic counters for Ethernet 890
X.1 General 890
X.2 Counting model 890
X.3 Explanation of the IETF RFC defined statistic counters 892
X.4 Value range of the IETF RFC defined statistic counters 893
Bibliography 894

Figure 1 – Common structure of specific fields for octet 1 (high) 60
Figure 2 – Common structure of specific fields for octet 2 60
Figure 3 – Common structure of specific fields for octet 3 60
Figure 4 – Common structure of specific fields for octet 4 61
Figure 5 – Common structure of specific fields for octet 5 61
Figure 6 – Common structure of specific fields for octet 6 61
Figure 7 – Common structure of specific fields for octet 7 62
Figure 8 – Common structure of specific fields for octet 8 62
Figure 9 – Common structure of specific fields for octet 9 62
Figure 10 – Common structure of specific fields for octet 10 63
Figure 11 – Common structure of specific fields for octet 11 63
Figure 12 – Common structure of specific fields for octet 12 63
Figure 13 – Common structure of specific fields for octet 13 64
Figure 14 – Common structure of specific fields for octet 14 64
Figure 15 – Common structure of specific fields for octet 15 64
Figure 16 – Common structure of specific fields for octet 16 (low) 65
Figure 17 – Coding of the data type BinaryDate 77
Figure 18 – Encoding of TimeOfDay with date indication value 77
Figure 19 – Encoding of TimeOfDay without date indication value 78
Figure 20 – Encoding of TimeDifference with date indication value 78
Figure 21 – Encoding of TimeDifference without date indication value 78
Figure 22 – Encoding of a NetworkTime value 79
Figure 23 – Encoding of NetworkTimeDifference value 79
Figure 24 – Encoding of TimeStamp value 80

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Figure 25 – Encoding of TimeStampDifference value 81
Figure 26 – Encoding of TimeStampDifferenceShort value 82
Figure 27 – FastForwardingMulticastMACAdd 88
Figure 28 – State transition diagram of DCPUCS 123
Figure 29 – State transition diagram of DCPUCR 127
Figure 30 – State transition diagram of DCPMCS 131
Figure 31 – State transition diagram of DCPMCR 134
Figure 32 – State transition diagram of DCPHMCS 137
Figure 33 – State transition diagram of DCPHMCR 139
Figure 34 – PTCP_SequenceID value range 144
Figure 35 – Timescale correspondence between PTCP_Time and CycleCounter 147
Figure 36 – Message timestamp point 152
Figure 37 – Timer model 152
Figure 38 – Four message timestamps 153
Figure 39 – Line delay protocol with follow up 154
Figure 40 – Line delay protocol without follow up 154
Figure 41 – Line delay measurement 156
Figure 42 – Model parameter for GSDML usage 158
Figure 43 – Bridge delay measurement 159
Figure 44 – Delay accumulation 160
Figure 45 – Worst case accumulated time deviation of synchronization 161
Figure 46 – Signal generation for measurement of deviation 161
Figure 47 – Measurement of deviation 162
Figure 48 – PTCP master sending Sync-Frame without Follow Up-Frame 163
Figure 49 – PTCP master sending Sync-Frame with FollowUp-Frame 163
Figure 50 – !FU Sync Slave Forwarding Sync-Frame 164
Figure 51 – FU Sync Slave Forwarding Sync- and FollowUp-Frame 165
Figure 52 – FU Sync Slave Forwarding Sync- and Generating FollowUp-Frame 166
Figure 53 – Principle of the monitoring of the line delay measurement 167
Figure 54 – State transition diagram of DELAY_REQ 169
Figure 55 – State transition diagram of DELAY_RSP 177
Figure 56 – Overview of PTCP 181
Figure 57 – State transition diagram of SYN_BMA 184
Figure 58 – State transition diagram of SYN_MPSM 193
Figure 59 – State transition diagram of SYN_SPSM 199
Figure 60 – State transition diagram of SYNC_RELAY 206
Figure 61 – State transition diagram of SCHEDULER 212
Figure 62 – GlobalTime timer model 216
Figure 63 – WorkingClock timer model 217
Figure 64 – Media redundancy – Ring 217
Figure 65 – Media redundancy – Interconnection 219
Figure 66 – CycleCounter value range 222
Figure 67 – Structure of the CycleCounter 223

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Figure 68 – Optimized CycleCounter setting 224
Figure 69 – SFCRC16 generation rule 228
Figure 70 – SFCycleCounter value range 229
Figure 71 – Basic structure of a PPM with frame structure 232
Figure 72 – Basic structure of a PPM with subframe structure 233
Figure 73 – State transition diagram of PPM 235
Figure 74 – Basic structure of a CPM 239
Figure 75 – State transition diagram of CPM 241
Figure 76 – Addressing scheme of RTA 251
Figure 77 – Structure of the APM 255
Figure 78 – Structure of the APMS 256
Figure 79 – State transition diagram of APMS 258
Figure 80 – Structure of the APMR 263
Figure 81 – State transition diagram of APMR 265
Figure 82 – State transition diagram of FRAG_D 276
Figure 83 – State transition diagram of FRAG_S 280
Figure 84 – State transition diagram of DEFRAG 283
Figure 85 – DLL Maping Protocol Machines (DMPM) 317
Figure 86 – Principle traffic flow model of a bridge 322
Figure 87 – Principle resource model of a bridge 323
Figure 88 – End station – on port bridge – transmit 328
Figure 89 – End station – on port bridge – receive 329
Figure 90 – Bridge with End Station 330
Figure 91 – Transmit – one port of a bridge 330
Figure 92 – Forwarding process – bridge 331
Figure 93 – Receive – on port of a bridge 331
Figure 94 – Transmit – Management port 332
Figure 95 – Receive – Management port 333
Figure 96 – State transition diagram of RTC3PSM 339
Figure 97 – State transition diagram for generating events 343
Figure 98 – State transition diagram of RED_RELAY 345
Figure 99 – Scheme of the DFP_RELAY 349
Figure 100 – Scheme of the DFP_RELAY_INBOUND and DFP_RELAY_IN_STORAGE 349
Figure 101 – Scheme of the DFP_RELAY_OUTBOUND 350
Figure 102 – State transition diagram of DFP_RELAY 351
Figure 103 – State transition diagram of DFP_RELAY_INBOUND 354
Figure 104 – State transition diagram of DFP_RELAY_IN_STORAGE 358
Figure 105 – State transition diagram of DFP_RELAY_OUTBOUND 362
Figure 106 – State transition diagram of MUX 366
Figure 107 – State transition diagram of DEMUX 371
Figure 108 – State transition diagram of ACCM 379
Figure 109 – Structuring of the protocol machines within the DMPM (bridge) 385
Figure 110 – State transition diagram of LMPM 388

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Figure 111 – AlarmSpecifier.SequenceNumber value range 427
Figure 112 – FrameSendOffset vs. duration of a cycle 472
Figure 113 – Severity classification of fault, maintenance and normal 526
Figure 114 – Calculation principle for a cycle 548
Figure 115 – Calculation principle for the minimum YellowTime 549
Figure 116 – Definition of the reserved interval 556
Figure 117 – Toplevel view to the PLL window 559
Figure 118 – Definition of PLL window 559
Figure 119 – Toplevel view to the time PLL window 562
Figure 120 – Definition of time PLL window 563
Figure 121 – Detection of dropped frames – appear 578
Figure 122 – Detection of dropped frames – disappear 578
Figure 123 – Detection of DFP late error – appear and disappear 586
Figure 124 – MediaRedundancyWatchDog expired – appear and disappear 588
Figure 125 – EndPoint1 and Endpoint2 scheme – above and below 593
Figure 126 – EndPoint1 and Endpoint2 scheme – left and right 593
Figure 127 – Relationship among Protocol Machines 643
Figure 128 – State transition diagram of ALPMI 666
Figure 129 – State transition diagram of ALPMR 670
Figure 130 – Scheme of the IO device CM 674
Figure 131 – State transition diagram of the IO device CM 676
Figure 132 – State transition diagram of CMDEV 680
Figure 133 – Scheme of the IO device CM – device access 685
Figure 134 – State transition diagram of CMDEV_DA 687
Figure 135 – State transition diagram of CMSU 691
Figure 136 – State transition diagram of CMIO 696
Figure 137 – State transition diagram of CMRS 699
Figure 138 – State transition diagram of CMWRR 702
Figure 139 – State transition diagram of CMRDR 707
Figure 140 – State transition diagram of CMSM 709
Figure 141 – State transition diagram of CMPBE 713
Figure 142 – State transition diagram of CMDMC 718
Figure 143 – State transition diagram of CMINA 723
Figure 144 – State transition diagram of CMRPC 734
Figure 145 – Intersection and residual amount using different ARUUID.ConfigIDs 740
Figure 146 – Intersection and removed amount using different ARUUID.ConfigIDs 741
Figure 147 – State transition diagram of CMSRL 742
Figure 148 – Single Input and single Output buffer of CMSRL 748
Figure 149 – Dynamic reconfiguration with CMSRL 749
Figure 150 – Alarm queue management of CMSRL 750
Figure 151 – Reporting System management of CMSRL 751
Figure 152 – Primary: Switchover time between two ARs of an ARset 751
Figure 153 – Backup: Switchover time between two ARs of an ARset 752

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Figure 154 – State transition diagram of CMSRL_AL 754
Figure 155 – Scheme of the IO controller CM 757
Figure 156 – State transition diagram of the IO controller CM 758
Figure 157 – State transition diagram of CMCTL 762
Figure 158 – State transition diagram of CTLSM 769
Figure 159 – State transition diagram of CTLIO 771
Figure 160 – State transition diagram of CTLRDI 775
Figure 161 – State transition diagram of CTLRDR 778
Figure 162 – State transition diagram of CTLRPC 782
Figure 163 – State transition diagram of CTLSU 787
Figure 164 – State transition diagram of CTLWRI 792
Figure 165 – State transition diagram of CTLWRR 796
Figure 166 – State transition diagram of CTLPBE 799
Figure 167 – State transition diagram of CTLDINA 805
Figure 168 – Automatic NameOfStation assignment 810
Figure 169 – State transition diagram of CTLSRL 812
Figure 170 – Input and Output buffer of CTLSRL 816
Figure 171 – Input and Output buffer with dynamic reconfiguration 816
Figure 172 – Alarm queue management of CTLSRL 817
Figure 173 – Alarm queue management with dynamic reconfiguration 818
Figure A.1 – Establishing of an AR using RT_CLASS_1, RT_CLASS_2 or RT_CLASS_3 (Initial connection monitoring w/o RT) 820
Figure A.2 – Establishing of an AR using RT_CLASS_1, RT_CLASS_2 or RT_CLASS_3 (Connection monitoring with RT) 821
Figure A.3 – Principle of the data evaluation during startup (delayed RED channel establishment) 822
Figure A.4 – Principle of the data evaluation during startup (immediate RED channel establishment) 823
Figure A.5 – Principle of the data evaluation during startup (Special case: Isochronous mode application) 824
Figure A.6 – Startup of Alarm transmitter and receiver without System Redundancy 825
Figure A.7 – Startup of Alarm transmitter and receiver with System Redundancy 826
Figure A.8 – Startup of Alarm transmitter and receiver during a PrmBegin / PrmEnd / ApplRdy sequence 827
Figure B.1 – Establishing of an AR using RT_CLASS_3 AR with startup mode “Legacy” 829
Figure B.2 – Establishing of an AR using RT_CLASS_1, 2 or UDP AR with startup mode “Legacy” 830
Figure C.1 – Establishing of a device access AR 831
Figure D.1 – Accelerated establishing of an IOAR without error 833
Figure D.2 – Accelerated establishing of an IOAR with “late” error 834
Figure E.1 – Establishing of an IOAR using fast startup 836
Figure F.1 – Example of upload with storage 837
Figure F.2 – Example of retrieval with storage 838
Figure G.1 – Assignment of the OSI reference model layers 839
Figure H.1 – Overview of the IO controller state machines 840

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Figure H.2 – Overview of the IO device state machines 840
Figure J.1 – Level model for synchronization master hierarchy 843
Figure J.2 – Two level variant of the synchronization master hierarchy 844
Figure K.1 – Devices build up in a linear structure 845
Figure K.2 – Propagation of frames in linear transmit direction 845
Figure K.3 – Propagation of a frames in receive direction 846
Figure L.1 – Overview of time constraints for bandwidth allocation 847
Figure L.2 – Calculation of the length of a RED period 847
Figure L.3 – Calculation of the length of a GREEN period 848
Figure M.1 – IEEE 802.3 definition 849
Figure M.2 – Minimization of bridge delay 849
Figure N.1 – Dynamic frame packing 851
Figure N.2 – Dynamic frame packing – truncation of outputs 852
Figure N.3 – Dynamic frame packing – concatenation of inputs 852
Figure N.4 – End node mode 853
Figure N.5 – DFPFeed definition 853
Figure O.1 – Principle of fragmentation 855
Figure O.2 – Protocol elements of fragments 855
Figure O.3 – Bandwidth allocation using fragmentation 856
Figure O.4 – Guardian for a fragmentation domain 856
Figure P.1 – Principle of seamless media redundancy – I/OCR 858
Figure P.2 – Principle of seamless media redundancy – MCR 859
Figure P.3 – Principle of seamless media redundancy – Line 859
Figure Q.1 – Generating the FrameSendOffset for a RED_RELAY without forwarding information in PDIRFrameData 860
Figure R.1 – Scheme of a 2-port switch 863
Figure R.2 – Scheme of 2-ports 863
Figure S.1 – PrmBegin, PrmEnd and AppIRdy procedure 866
Figure X.1 – IEEE 802 structure used for statistic counters 891
Figure X.2 – IEEE 802 summary for statistic counters 892

Table 1 – One octet 65
Table 2 – Two subsequent octets 66
Table 3 – Four subsequent octets 66
Table 4 – Eight subsequent octets 67
Table 5 – Sixteen subsequent octets 67
Table 6 – State machine description elements 68
Table 7 – Description of state machine elements 68
Table 8 – Conventions used in state machines 69
Table 9 – Conventions for services used in state machines 70
Table 10 – IEEE 802.3 DLPDU syntax 72
Table 11 – IEEE 802.11 DLPDU syntax 73
Table 12 – IEEE 802.15.1 DLPDU syntax 74

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 13 – Status 79
Table 14 – Time source 81
Table 15 – SourceAddress 83
Table 16 – Single port device 83
Table 17 – DCP_MulticastMACAdd for Identify 84
Table 18 – DCP_MulticastMACAdd for Hello 84
Table 19 – DCP_MulticastMACAdd 84
Table 20 – MulticastMACAdd range 1 84
Table 21 – MulticastMACAdd range 2 84
Table 22 – MulticastMACAdd range 3 85
Table 23 – PTCP_MulticastMACAdd range 2 85
Table 24 – PTCP_MulticastMACAdd range 3 85
Table 25 – PTCP_MulticastMACAdd range 4 85
Table 26 – PTCP_MulticastMACAdd range 5 86
Table 27 – PTCP_MulticastMACAdd range 6 86
Table 28 – PTCP_MulticastMACAdd range 7 86
Table 29 – MulticastMACAdd range 8 86
Table 30 – MulticastMACAdd range 9 86
Table 31 – MulticastMACAdd range 10 87
Table 32 – MulticastMACAdd range 11 87
Table 33 – RT_CLASS_3 destination multicast address 88
Table 34 – RT_CLASS_3 invalid frame multicast address 89
Table 35 – LT (Length/Type) 89
Table 36 – TagControlInformation.VID 89
Table 37 – TagControlInformation.DEI 90
Table 38 – TagControlInformation.PCP 90
Table 39 – FrameID range 1 90
Table 40 – FrameID range 2 91
Table 41 – FrameID range 3 91
Table 42 – FrameID range 4 91
Table 43 – FrameID range 5 91
Table 44 – FrameID range 6 92
Table 45 – FrameID range 7 92
Table 46 – FrameID range 8 92
Table 47 – FrameID range 9 93
Table 48 – FrameID range 10 93
Table 49 – FrameID range 11 93
Table 50 – FrameID range 12 93
Table 51 – FrameID range 13 93
Table 52 – FragmentationFrameID.FragSequence 94
Table 53 – FragmentationFrameID.Constant 94
Table 54 – DCP APDU syntax 94
Table 55 – DCP substitutions 95

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 56 – ServiceID 98
Table 57 – ServiceType.Selection 98
Table 58 – ServiceType.Reserved 98
Table 59 – ServiceType.Selection 99
Table 60 – ServiceType.Reserved_1 99
Table 61 – ServiceType.Response 99
Table 62 – ServiceType.Reserved_2 99
Table 63 – ResponseDelayFactor 100
Table 64 – List of options 101
Table 65 – List of suboptions for option IPOption 102
Table 66 – List of suboptions for option DevicePropertiesOption 102
Table 67 – List of suboptions for option DHCPOption 102
Table 68 – List of suboptions for option ControlOption 103
Table 69 – List of suboptions for option DeviceInitiativeOption 103
Table 70 – List of suboptions for option AllSelectorOption 103
Table 71 – List of suboptions for option ManufacturerSpecificOption 103
Table 72 – SuboptionDHCP 105
Table 73 – Coding of DCPBlockLength in conjunction with SuboptionStart 106
Table 74 – Coding of DCPBlockLength in conjunction with SuboptionStop 106
Table 75 – Coding of DCPBlockLength in conjunction with SuboptionSignal 106
Table 76 – Coding of DCPBlockLength in conjunction with SuboptionFactoryReset 107
Table 77 – Alignment between FactoryReset and ResetToFactory 107
Table 78 – Coding of DCPBlockLength in conjunction with SuboptionResetToFactory 107
Table 79 – Meaning of the different ResetToFactory modes 108
Table 80 – Coding of DCPBlockLength in conjunction with SuboptionDeviceInitiative 108
Table 81 – Coding of DCPBlockLength 109
Table 82 – BlockQualifier with options IPOption, DevicePropertiesOption, DHCPOption and ManufacturerSpecificOption 109
Table 83 – BlockQualifier with option ControlOption and suboption SuboptionResetToFactory 110
Table 84 – BlockQualifier with option ControlOption and NOT suboption SuboptionResetToFactory 111
Table 85 – BlockError 111
Table 86 – BlockInfo for SuboptionIPParameter 111
Table 87 – Bit 1 and Bit 0 of BlockInfo for SuboptionIPParameter 112
Table 88 – Bit 7 of BlockInfo for SuboptionIPParameter 112
Table 89 – BlockInfo for all other suboptions 112
Table 90 – DeviceInitiativeValue 112
Table 91 – SignalValue 113
Table 92 – DeviceRoleDetails 115
Table 93 – IPAddress 115
Table 94 – Subnetmask 117
Table 95 – StandardGateway 118
Table 96 – Correlation between the subfields of IPsuite 119

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 97 – MACAddress as client identifier 120
Table 98 – NameOfStation as client identifier 120
Table 99 – Arbitrary client identifier 120
Table 100 – DHCPParameterValue using DHCP Option 255 121
Table 101 – StandardGatewayValue.StandardGateway 122
Table 102 – Remote primitives issued or received by DCPUCS 122
Table 103 – Local primitives issued or received by DCPUCS 123
Table 104 – DCPUCS state table 124
Table 105 – Functions, Macros, Timers and Variables used by the DCPUCS 126
Table 106 – Remote primitives issued or received by DCPUCR 127
Table 107 – Local primitives issued or received by DCPUCR 127
Table 108 – DCPUCR state table 128
Table 109 – Functions, Macros, Timers and Variables used by the DCPUCR 130
Table 110 – Remote primitives issued or received by DCPMCS 130
Table 111 – Local primitives issued or received by DCPMCS 131
Table 112 – DCPMCS state table 132
Table 113 – Functions used by the DCPMCS 133
Table 114 – Remote primitives issued or received by DCPMCR 134
Table 115 – Local primitives issued or received by DCPMCR 134
Table 116 – DCPMCR state table 135
Table 117 – Functions, Macros, Timers and Variables used by the DCPMCR 136
Table 118 – Remote primitives issued or received by DCPHMCS 136
Table 119 – Local primitives issued or received by DCPHMCS 137
Table 120 – DCPHMCS state table 137
Table 121 – Functions, Macros, Timers and Variables used by the DCPHMCS 138
Table 122 – Remote primitives issued or received by DCPHMCR 138
Table 123 – Local primitives issued or received by DCPHMCR 138
Table 124 – DCPHMCR state table 139
Table 125 – Functions, Macros, Timers and Variables used by the DCPHMCR 139
Table 126 – PTCP APDU syntax 140
Table 127 – PTCP substitutions 140
Table 128 – PTCP_TLVHeader.Type 141
Table 129 – PTCP_Delay10ns 142
Table 130 – PTCP_Delay1ns_Byte.Value 142
Table 131 – PTCP_Delay1ns 143
Table 132 – PTCP_Delay1ns_FUP 143
Table 133 – PTCP_SequenceID 143
Table 134 – PTCP_SubType for OUI (=00-0E-CF) 144
Table 135 – PTCP_Seconds 145
Table 136 – PTCP_NanoSeconds 145
Table 137 – PTCP_Flags.LeapSecond 145
Table 138 – Timescale correspondence between PTCP_EpochNumber, PTCP_Second, PTCP_Nanosecond, CycleCounter and SendClockFactor 146

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 139 – PTCP_CurrentUTCOffset 148
Table 140 – PTCP_MasterPriority1.Priority for SyncID == 0 and SyncProperties.Role == 2 148
Table 141 – PTCP_MasterPriority1.Priority for SyncID == 0 and SyncProperties.Role == 1 148
Table 142 – PTCP_MasterPriority1.Level 149
Table 143 – PTCP_MasterPriority2 149
Table 144 – PTCP_ClockClass for SyncID == 0 (working clock synchronization) 149
Table 145 – PTCP_ClockAccuracy 150
Table 146 – PTCP_ClockVariance 151
Table 147 – PTCP_T2PortRxDelay 151
Table 148 – PTCP_T3PortTxDelay 151
Table 149 – PTCP_T2TimeStamp 151
Table 150 – Remote primitives issued or received by DELAY_REQ 168
Table 151 – Local primitives issued or received by DELAY_REQ 168
Table 152 – DELAY_REQ state table 170
Table 153 – Functions, macros, timers and variables used by the DELAY_REQ 174
Table 154 – Remote primitives issued or received by DELAY_RSP 176
Table 155 – Local primitives issued or received by DELAY_RSP 176
Table 156 – DELAY_RSP state table 178
Table 157 – Functions, Macros, Timers and Variables used by the DELAY_RSP 180
Table 158 – Remote primitives issued or received by SYN_BMA 182
Table 159 – Local primitives issued or received by SYN_BMA 182
Table 160 – SYN_BMA state table 185
Table 161 – Functions, Macros, Timers and Variables used by the SYN_BMA 189
Table 162 – Remote primitives issued or received by SYN_MPSM 192
Table 163 – Local primitives issued or received by SYN_MPSM 192
Table 164 – SYN_MPSM state table 194
Table 165 – Functions, Macros, Timers and Variables used by the SYN_MPSM 197
Table 166 – Remote primitives issued or received by SYN_SPSM 198
Table 167 – Local primitives issued or received by SYN_SPSM 198
Table 168 – SYN_SPSM state table 200
Table 169 – Functions, Macros, Timers and Variables used by the SYN_SPSM 203
Table 170 – Truth table for one SyncID for receiving sync and follow up frames 204
Table 171 – Remote primitives issued or received by SYNC_RELAY 205
Table 172 – Local primitives issued or received by SYNC_RELAY 205
Table 173 – SYNC_RELAY state table 207
Table 174 – Functions, Macros, Timers and Variables used by the SYNC_RELAY 208
Table 175 – Truth table for one SyncID for receiving 210
Table 176 – Truth table for one SyncID for transmitting 211
Table 177 – Remote primitives issued or received by SCHEDULER 211
Table 178 – Local primitives issued or received by SCHEDULER 212
Table 179 – SCHEDULER state table 213
Table 180 – Functions, Macros, Timers and Variables used by the SCHEDULER 214
Table 181 – Truth table for RxPeriodChecker of one port 215

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 182 – Truth table for TxPeriodChecker of one port 215
Table 183 – Timescales 215
Table 184 – Timescale correspondence between GlobalTime, TAI and UTC 216
Table 185 – Conjunction between supported MRP_Role and default MRP_Prio 218
Table 186 – Extended forwarding rule 218
Table 187 – Managed Multicast MAC address 219
Table 188 – RTC APDU syntax 220
Table 189 – RTC substitutions 221
Table 190 – CycleCounter Difference 222
Table 191 – DataStatus.State 224
Table 192 – DataStatus.Redundancy in conjunction with DataStatus.State==Backup 225
Table 193 – DataStatus.Redundancy in conjunction with DataStatus.State==Primary 225
Table 194 – DataStatus.DataValid 225
Table 195 – DataStatus.ProviderState 225
Table 196 – DataStatus.StationProblemIndicator 226
Table 197 – DataStatus.Ignore of a frame 226
Table 198 – DataStatus.Ignore of a sub frame 226
Table 199 – TransferStatus for RT_CLASS_3 227
Table 200 – SFPosition.Position 228
Table 201 – SFPosition.Reserved 228
Table 202 – SFDataLength 228
Table 203 – SFCycleCounter Difference 230
Table 204 – IOxS.Extension 230
Table 205 – IOxS.Instance 230
Table 206 – IOxS.DataState 231
Table 207 – APDU_Status of a PPM with subframe structure 233
Table 208 – Remote primitives issued or received by PPM 234
Table 209 – Local primitives issued or received by PPM 234
Table 210 – PPM state table 236
Table 211 – Functions, Macros, Timers and Variables used by the PPM 237
Table 212 – Truth table used by the PPM for TxOption 238
Table 213 – Remote primitives issued or received by CPM 240
Table 214 – Local primitives issued or received by CPM 240
Table 215 – CPM state table 242
Table 216 – Functions, Macros, Timers and Variables used by the CPM 245
Table 217 – Truth table used by the CPM for RxOption 246
Table 218 – Truth table for one frame using RT_CLASS_x 247
Table 219 – Truth table for one frame using RT_CLASS_UDP 247
Table 220 – Truth table for the C_SDU 247
Table 221 – Truth table for arranging DHt and data 248
Table 222 – Truth table for the subframe – frame check 248
Table 223 – Truth table for the subframe – sub frame check 248
Table 224 – Truth table for the subframe – sub frame data check 249

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 225 – Truth table for the subframe – DHt and data 249
Table 226 – RTA APDU syntax 249
Table 227 – RTA substitutions 250
Table 228 – PDUType.Type 252
Table 229 – PDUType.Version 252
Table 230 – AddFlags.WindowSize 252
Table 231 – AddFlags.TACK 252
Table 232 – SendSeqNum 253
Table 233 – SendSeqNum and AckSeqNum start sequence 253
Table 234 – AckSeqNum 254
Table 235 – VarPartLen 254
Table 236 – Remote primitives issued or received by APMS 256
Table 237 – Local primitives issued or received by APMS 257
Table 238 – APMS state table 259
Table 239 – Functions, Macros, Timers and Variables used by the APMS 261
Table 240 – Remote primitives issued or received by APMR 264
Table 241 – Local primitives issued or received by APMR 265
Table 242 – APMR state table 266
Table 243 – Functions, Macros, Timers and Variables used by the APMR 268
Table 244 – TagControlInformation.PCP vs. streams 269
Table 245 – Lower limit of fragments 272
Table 246 – FRAG APDU syntax 272
Table 247 – FRAG substitutions 273
Table 248 – FragDataLength 274
Table 249 – FragStatus.FragmentNumber 274
Table 250 – FragStatus.Reserved 274
Table 251 – FragStatus.MoreFollows 275
Table 252 – Remote primitives issued or received by FRAG_D 275
Table 253 – Local primitives issued or received by FRAG_D 275
Table 254 – FRAG_D state table (dynamic) 277
Table 255 – Functions, Macros, Timers and Variables used by the FRAG_D (dynamic) 278
Table 256 – Remote primitives issued or received by FRAG_S 279
Table 257 – Local primitives issued or received by FRAG_S 279
Table 258 – FRAG_S state table (static) 281
Table 259 – Functions, Macros, Timers and Variables used by the FRAG_S (static) 282
Table 260 – Remote primitives issued or received by DEFRAG 283
Table 261 – Local primitives issued or received by DEFRAG 283
Table 262 – DEFRAG state table 284
Table 263 – Functions, Macros, Timers and Variables used by the DEFRAG 285
Table 264 – Truth table for the DefragGuard – first fragment 285
Table 265 – Truth table for the DefragGuard – next fragment 285
Table 266 – Truth table for the DefragGuard – last fragment 286
Table 267 – RPC APDU syntax 286

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 268 – RPC substitutions 287
Table 269 – RPCVersion 288
Table 270 – RPCPacketType 288
Table 271 – RPCFlags 289
Table 272 – RPCFlags2 289
Table 273 – RPCDRep.Character- and IntegerEncoding 290
Table 274 – RPCDRep Octet 2 – Floating Point Representation 290
Table 275 – RPCObjectUUID.Data4 291
Table 276 – RPCObjectUUID for devices 291
Table 277 – Instance or node number 291
Table 278 – RPCInterfaceUUID for PNIO 292
Table 279 – RPCInterfaceUUID for the RPC end point mapper 292
Table 280 – RPCInterfaceVersion.Major 293
Table 281 – RPCInterfaceVersion.Minor 293
Table 282 – RPCOperationNmb (IO device, controller and supervisor) 294
Table 283 – RPCOperationNmb for endpoint mapper 294
Table 284 – RPCVersionFack 295
Table 285 – RPCDataRepresentationUUID – defined values 296
Table 286 – RPCInquiryType 298
Table 287 – RPCEPMapStatus 300
Table 288 – Values of NCAFaultStatus 302
Table 289 – Values of NCARejectStatus 303
Table 290 – Remote primitives issued or received by RPC 304
Table 291 – Local primitives issued or received by RPC 304
Table 292 – LLDP APDU syntax 306
Table 293 – LLDP substitutions 306
Table 294 – LLDP_ChassisID in conjunction with MultipleInterfaceMode.NameOfDevice == 0 and NameOfStation 307
Table 295 – LLDP_ChassisID in conjunction with MultipleInterfaceMode.NameOfDevice == 1 307
Table 296 – LLDP_PortID in conjunction with MultipleInterfaceMode.NameOfDevice 308
Table 297 – LLDP_PNIO_SubType 308
Table 298 – PTCP_PortRxDelayLocal 309
Table 299 – PTCP_PortRxDelayRemote 309
Table 300 – PTCP_PortTxDelayLocal 309
Table 301 – PTCP_PortTxDelayRemote 309
Table 302 – CableDelayLocal 310
Table 303 – RTClass2_PortStatus.State with ARProperties.StartupMode == Legacy 310
Table 304 – RTClass2_PortStatus.State with ARProperties.StartupMode == Advanced 310
Table 305 – RTClass3_PortStatus.State 311
Table 306 – RTClass3_PortStatus.Fragmentation 311
Table 307 – RTClass3_PortStatus.PreambleLength 311
Table 308 – Truth table for shortening of the preamble 312
Table 309 – RTClass3_PortStatus.Optimized 312

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 310 – MRRT_PortStatus.State 313
Table 311 – IRDataUUID 313
Table 312 – LLDP_RedOrangePeriodBegin.Offset 313
Table 313 – LLDP_RedOrangePeriodBegin.Valid 313
Table 314 – LLDP_OrangePeriodBegin.Offset 314
Table 315 – LLDP_OrangePeriodBegin.Valid with ARProperties.StartupMode == Legacy 314
Table 316 – LLDP_OrangePeriodBegin.Valid with ARProperties.StartupMode == Advanced 314
Table 317 – LLDP_GreenPeriodBegin.Offset 315
Table 318 – LLDP_GreenPeriodBegin.Valid 315
Table 319 – LLDP_LengthOfPeriod.Length 315
Table 320 – LLDP_LengthOfPeriod.Valid 315
Table 321 – Priority remapping at an ingress boundary port 319
Table 322 – Trees and FDBs 320
Table 323 – Available queue 322
Table 324 – Queue related memory management 323
Table 325 – Queue usage 324
Table 326 – Queue usage 324
Table 327 – QBTSA usage 325
Table 328 – QBTSA usage 326
Table 329 – Traffic Classes[0..7] for eight queues 334
Table 330 – Traffic Classes[0..3] for four queues 334
Table 331 – Unicast FDB entries 335
Table 332 – Multicast FDB entries 336
Table 333 – Broadcast FDB entry 337
Table 334 – Remote primitives issued or received by MAC_RELAY 337
Table 335 – Local primitives issued or received by MAC_RELAY 338
Table 336 – Functions, Macros, Timers and Variables used by the MAC_RELAY 338
Table 337 – Remote primitives issued or received by RTC3PSM 339
Table 338 – Local primitives issued or received by RTC3PSM 339
Table 339 – RTC3PSM state table 340
Table 340 – Functions, Macros, Timers and Variables used by the RTC3PSM 341
Table 341 – Truth table for the RTC3PSM 342
Table 342 – RXBeginEndAssignment and TXBeginEndAssignment 342
Table 343 – Event function table 343
Table 344 – Remote primitives issued or received by RED_RELAY 344
Table 345 – Local primitives issued or received by RED_RELAY 344
Table 346 – RED_RELAY state table 346
Table 347 – Functions, Macros, Timers and Variables used by the RED_RELAY 347
Table 348 – Truth table for the RedGuard with full check 347
Table 349 – Truth table for the RedGuard with reduced check 348
Table 350 – Truth table for the RedGuard with minimal check 348
Table 351 – Remote primitives issued or received by DFP_RELAY 350

Documents
Document Sharing Hub
Full document details: BS EN IEC 61158-6-10:2019

Table 352 – Local primitives issued or received by DFP_RELAY 351
Table 353 – DFP_RELAY state table 352
Table 354 – Functions, Macros, Timers and Variables used by the DFP_RELAY 352
Table 355 – Truth table for the DFPGuard 353
Table 356 – Remote primitives issued or received by DFP_RELAY_INBOUND 353
Table 357 – Local primitives issued or received by DFP_RELAY_INBOUND 354
Table 358 – DFP_RELAY_INBOUND state table 355
Table 359 – Functions, Macros, Timers and Variables used by the DFP_RELAY_INBOUND 355
Table 360 – Truth table for the InboundGuard – frame check 356
Table 361 – Truth table for the InboundGuard – sub frame check 356
Table 362 – Truth table for the InboundGuard – sub frame data check 356
Table 363 – Truth table for the InboundGuard – full check 357
Table 364 – Remote primitives issued or received by DFP_RELAY_IN_STORAGE 357
Table 365 – Local primitives issued or received by DFP_RELAY_IN_STORAGE 358
Table 366 – DFP_RELAY_IN_STORAGE state table 359
Table 367 – Functions, Macros, Timers and Variables used by the DFP_RELAY_IN_STORAGE 360
Table 368 – Remote primitives issued or received by DFP_RELAY_OUTBOUND 361
Table 369 – Local primitives issued or received by DFP_RELAY_OUTBOUND 361
Table 370 – APDU_Status used if frame is shortened 362
Table 371 – DFP_RELAY_OUTBOUND state table 363
Table 372 – Functions, Macros, Timers and Variables used by the DFP_RELAY_OUTBOUND 364
Table 373 – Truth table for the OutboundGuard – frame check 364
Table 374 – Truth table for the OutboundGuard – sub frame check 365
Table 375 – Remote primitives issued or received by MUX 365
Table 376 – Local primitives issued or received by MUX 365
Table 377 – MUX state table 367
Table 378 – Functions, Macros, Timers and Variables used by MUX 368
Table 379 – Truth table for FrameSizeFits 369
Table 380 – Truth table for StateChecker 369
Table 381 – Remote primitives issued or received by DEMUX 370
Table 382 – Local primitives issued or received by DEMUX 370
Table 383 – DEMUX state table 372
Table 384 – Functions, Macros, Timers and Variables used by the DEMUX 373
Table 385 – IP/UDP APDU syntax 374
Table 386 – IP/UDP substitutions 375
Table 387 – UDP_SrcPort 376
Table 388 – UDP_DstPort 376
Table 389 – IP_DstIPAddress 376
Table 390 – IP Multicast DstIPAddress according to IETF RFC 2365 376
Table 391 – IP_DifferentiatedServices.DSCP 377
Table 392 – IP_DifferentiatedServices.ECN 377

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 393 – Remote primitives issued or received by ACCM 378
Table 394 – Local primitives issued or received by ACCM 379
Table 395 – ACCM state table 380
Table 396 – Functions, Macros, Timers and Variables used by the ACCM 380
Table 397 – Remote primitives issued or received by DNS 381
Table 398 – Local primitives issued or received by DNS 381
Table 399 – Functions, Macros, Timers and Variables used by the DNS 381
Table 400 – Remote primitives issued or received by DHCP 382
Table 401 – Local primitives issued or received by machines 382
Table 402 – Functions, Macros, Timers and Variables used by the DHCP 383
Table 403 – List of supported IETF RFC 1213-MIB objects 383
Table 404 – Enterprise number 384
Table 405 – Cross reference – MIBs 384
Table 406 – Cross reference – PDPortDataAdjust 384
Table 407 – Remote primitives issued or received by LMPM 386
Table 408 – Local primitives issued or received by LMPM 387
Table 409 – LMPM state table 388
Table 410 – Functions, Macros, Timers and Variables used by the LMPM 389
Table 411 – IO APDU substitutions 391
Table 412 – BlockType 409
Table 413 – BlockLength 422
Table 414 – BlockVersionHigh 423
Table 415 – BlockVersionLow 423
Table 416 – AlarmType 424
Table 417 – AlarmSpecifier.SequenceNumber 427
Table 418 – AlarmSpecifier.SequenceNumber Difference 428
Table 419 – AlarmSpecifier.ChannelDiagnosis 428
Table 420 – AlarmSpecifier.ManufacturerSpecificDiagnosis 428
Table 421 – AlarmSpecifier.SubmoduleDiagnosisState 429
Table 422 – AlarmSpecifier.ARDiagnosisState 429
Table 423 – API 430
Table 424 – SlotNumber 430
Table 425 – SubslotNumber 430
Table 426 – Index range 431
Table 427 – Expression 1 (subslot specific) 432
Table 428 – Expression 2 (slot specific) 432
Table 429 – Expression 3 (AR specific) 432
Table 430 – Expression 4 (API specific) 432
Table 431 – Expression 5 (device specific) 432
Table 432 – Grouping of DiagnosisData 433
Table 433 – Index (user specific) 434
Table 434 – Index (subslot specific) 434
Table 435 – Index (slot specific) 434

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 436 – Index (AR specific) 439
Table 437 – Index (API specific) 441
Table 438 – Index (device specific) 442
Table 439 – RecordDataLength 445
Table 440 – ARType 445
Table 441 – IOCRMulticastMACAdd using RT_CLASS_UDP 446
Table 442 – IOCRMulticastMACAdd using RT_CLASS_x 446
Table 443 – Type 10 OUI 447
Table 444 – ARProperties.State 447
Table 445 – ARProperties.SupervisorTakeoverAllowed 447
Table 446 – ARProperties.ParameterizationServer 448
Table 447 – ARProperties.DeviceAccess 448
Table 448 – ARProperties.CompanionAR 448
Table 449 – ARProperties.AcknowledgeCompanionAR 448
Table 450 – ARProperties.CombinedObjectContainer with ARProperties.StartupMode == Legacy 449
Table 451 – ARProperties.CombinedObjectContainer with ARProperties.StartupMode == Advanced 449
Table 452 – ARProperties.StartupMode 449
Table 453 – ARProperties.PullModuleAlarmAllowed 449
Table 454 – IOCRProperties.RTClass 450
Table 455 – IOCRTagHeader.IOCRVLANID 451
Table 456 – IOCRTagHeader.IOUserPriority 451
Table 457 – IOCRType 451
Table 458 – CMInitiatorActivityTimeoutFactor with ARProperties.DeviceAccess==0 451
Table 459 – CMInitiatorActivityTimeoutFactor with ARProperties.DeviceAccess==1 or ARProperties.StartupMode==1 452
Table 460 – CMInitiatorTriggerTimeoutFactor 452
Table 461 – IODataObjectFrameOffset 453
Table 462 – IOCSFrameOffset 453
Table 463 – LengthIOCS 454
Table 464 – LengthIOPS 454
Table 465 – LengthData 454
Table 466 – AlarmCRProperties.Priority 455
Table 467 – AlarmCRProperties.Transport 455
Table 468 – AlarmCRTagHeaderHigh.AlarmCRVLANID 455
Table 469 – AlarmCRTagHeaderHigh.AlarmUserPriority 456
Table 470 – AlarmCRTagHeaderLow.AlarmCRVLANID 456
Table 471 – AlarmCRTagHeaderLow.AlarmUserPriority 456
Table 472 – AlarmSequenceNumber 456
Table 473 – AlarmCRType 457
Table 474 – RTATimeoutFactor 457
Table 475 – RTARetries 457
Table 476 – AddressResolutionProperties.Protocol 458

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 477 – AddressResolutionProperties.Factor 458
Table 478 – MCITimeoutFactor 459
Table 479 – DeviceIDLow and DeviceIDHigh 459
Table 480 – VendorIDLow 460
Table 481 – VendorIDHigh 460
Table 482 – ModuleIdentNumber 460
Table 483 – SubmoduleIdentNumber 461
Table 484 – ARUUID 462
Table 485 – ARUUID in conjunction with ARType==IOCARSR 462
Table 486 – Conjunction between ARUUID.ARnumber and Endpoint1 or Endpoint2 462
Table 487 – ARUUID.ConfigID generation rule 463
Table 488 – TargetARUUID 463
Table 489 – AdditionalValue1 and AdditionalValue2 463
Table 490 – ControlBlockProperties in conjunction with ControlCommand.ApplicationReady with ARProperties.StartupMode==1 463
Table 491 – ControlBlockProperties in conjunction with ControlCommand.ApplicationReady with ARProperties.StartupMode==0 464
Table 492 – ControlBlockProperties in conjunction with the other values of the field ControlCommand 464
Table 493 – ControlCommand.PrmEnd 464
Table 494 – ControlCommand.ApplicationReady 464
Table 495 – ControlCommand.Release 465
Table 496 – ControlCommand.Done 465
Table 497 – ControlCommand.ReadyForCompanion 465
Table 498 – ControlCommand.ReadyForRT_CLASS_3 465
Table 499 – ControlCommand.PrmBegin 465
Table 500 – DataDescription.Type 466
Table 501 – Values of DataLength 466
Table 502 – Values of SendClockFactor 467
Table 503 – Values of ReductionRatio for RT_CLASS_1 and RT_CLASS_2 468
Table 504 – Values of ReductionRatio for RT_CLASS_3 and SendClockFactor ≥ 8 468
Table 505 – Values of ReductionRatio for RT_CLASS_3 and SendClockFactor < 8 468
Table 506 – Values of ReductionRatio in conjunction with a non power of 2 SendClockFactor 468
Table 507 – Values of ReductionRatio for RT_CLASS_UDP 469
Table 508 – Values of Phase 469
Table 509 – Values of Sequence 469
Table 510 – DataHoldFactor of a frame 470
Table 511 – DataHoldFactor of a Subframe 470
Table 512 – Values of FrameSendOffset 471
Table 513 – ModuleState 472
Table 514 – SubmoduleState.AddInfo 473
Table 515 – SubmoduleState.Advice 473
Table 516 – SubmoduleState.MaintenanceRequired 473

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 517 – SubmoduleState.MaintenanceDemanded 473
Table 518 – SubmoduleState.Fault 474
Table 519 – SubmoduleState.ARInfo 474
Table 520 – SubmoduleState.IdentInfo 474
Table 521 – SubmoduleState.FormatIndicator 475
Table 522 – SubmoduleProperties.Type 475
Table 523 – SubmoduleProperties.SharedInput 475
Table 524 – SubmoduleProperties.ReduceInputSubmoduleDataLength 476
Table 525 – SubmoduleProperties.ReduceOutputSubmoduleDataLength 476
Table 526 – SubmoduleProperties.DiscardIOXS 476
Table 527 – SubstitutionMode 477
Table 528 – SubstituteActiveFlag 477
Table 529 – InitiatorUDPRTPort 478
Table 530 – ResponderUDPRTPort 478
Table 531 – InitiatorRPCServerPort 478
Table 532 – ResponderRPCServerPort 479
Table 533 – MaxAlarmDataLength 479
Table 534 – APStructureIdentifier with API==0 480
Table 535 – APStructureIdentifier with API ≠ 0 480
Table 536 – ExtendedIdentificationVersionHigh 480
Table 537 – ExtendedIdentificationVersionLow 480
Table 538 – Values of ErrorCode for negative responses 481
Table 539 – Values of ErrorDecode 482
Table 540 – Coding of ErrorCode1 with ErrorDecode PNIORW 482
Table 541 – Coding of ErrorCode2 with ErrorDecode PNIORW 483
Table 542 – Coding of ErrorCode1 with ErrorDecode:= PNIO 484
Table 543 – Values of ErrorCode2 for ErrorDecode:= PNIO and ErrorCode1 (part 1) 487
Table 544 – Values of ErrorCode2 for ErrorDecode:= PNIO and ErrorCode1 (part 2 – alarm acknowledge) 490
Table 545 – Values of ErrorCode2 for ErrorDecode:= PNIO and ErrorCode1 (part 3 – machines) 491
Table 546 – Values of ErrorCode2 for ErrorDecode:= PNIO and ErrorCode1 (part 4 – IO controller) 492
Table 547 – Values of ErrorCode2 for ErrorDecode:= PNIO and ErrorCode1 (part 5 – IO device) 494
Table 548 – Values of ErrorCode2 for ErrorDecode:= PNIO and ErrorCode1 (part 6 – abort reasons) 495
Table 549 – Values of ErrorCode2 for ErrorDecode:= PNIO and ErrorCode1 (part 7 – Reserved) 498
Table 550 – Coding of ErrorCode1 for ErrorDecode with the value ManufacturerSpecific 498
Table 551 – Coding of ErrorCode2 for ErrorDecode with the value ManufacturerSpecific 498
Table 552 – Visible characters 498
Table 553 – FactoryReset / ResetToFactory behavior (legacy from IEC 61158-x-3) 499

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 554 – FactoryReset / ResetToFactory behavior (default without IEC 61158-x-3 history) 499
Table 555 – FactoryReset / ResetToFactory behavior if used in conjuction with functional safety submodules 499
Table 556 – IM_Hardware_Revision 499
Table 557 – IM_SWRevision_Functional_Enhancement 500
Table 558 – IM_SWRevision_Bug_Fix 500
Table 559 – IM_SWRevision_Internal_Change 500
Table 560 – IM_Revision_Counter 500
Table 561 – IM_Profile_ID 501
Table 562 – IM_Profile_Specific_Type in conjunction with IM_Profile_ID == 0x0000 501
Table 563 – IM_Profile_Specific_Type in conjunction with IM_Profile_ID range 0x0001 – 0xF6FF 501
Table 564 – IM_Version_Major 502
Table 565 – IM_Version_Minor 502
Table 566 – IM_Supported.I&M1 502
Table 567 – IM_Date with time 504
Table 568 – IM_Date without time 504
Table 569 – IM_Annotation 504
Table 570 – IM_OrderID 505
Table 571 – IM_UniqueIdentifier 505
Table 572 – UserStructureIdentifier 506
Table 573 – ChannelErrorType – range 1 508
Table 574 – ChannelErrorType – range 2 509
Table 575 – ChannelErrorType – range 3 509
Table 576 – ChannelErrorType – range 4 510
Table 577 – ChannelNumber 510
Table 578 – ChannelProperties.Type 511
Table 579 – ChannelProperties.Accumulative 511
Table 580 – ChannelProperties.Maintenance 512
Table 581 – Valid combinations within ChannelProperties 512
Table 582 – Valid combinations for Alarmnotification and RecordDataRead(DiagnosisData) 513
Table 583 – ChannelProperties.Specifier 514
Table 584 – ChannelProperties.Direction 514
Table 585 – ExtChannelErrorType 514
Table 586 – Allowed combinations of ChannelErrorType, ExtChannelErrorType, and ExtChannelAddValue 515
Table 587 – ExtChannelErrorType for ChannelErrorType 0 – 0xFF 515
Table 588 – Additional ExtChannelErrorType for ChannelErrorType 0x0F and 0x10 515
Table 589 – ExtChannelErrorType for ChannelErrorType 0x0100 – 0x7FFF 515
Table 590 – ExtChannelErrorType for ChannelErrorType “Data transmission impossible” 516
Table 591 – ExtChannelErrorType for ChannelErrorType “Remote mismatch” 516

Documents
Document Sharing Hub
Full document details: BS EN IEC 61158-6-10:2019

Table 592 – ExtChannelErrorType for ChannelErrorType “Media redundancy mismatch – Ring” 517
Table 593 – ExtChannelErrorType for ChannelErrorType “Media redundancy mismatch – Interconnection” 517
Table 594 – ExtChannelErrorType for ChannelErrorType “Sync mismatch” and for ChannelErrorType “Time mismatch” 518
Table 595 – ExtChannelErrorType for ChannelErrorType “Isochronous mode mismatch” 518
Table 596 – ExtChannelErrorType for ChannelErrorType “Multicast CR mismatch” 518
Table 597 – ExtChannelErrorType for ChannelErrorType “Fiber optic mismatch” 519
Table 598 – ExtChannelErrorType for ChannelErrorType “Network component function mismatch” 519
Table 599 – ExtChannelErrorType for ChannelErrorType “Dynamic Frame Packing function mismatch” 519
Table 600 – ExtChannelErrorType for ChannelErrorType “Media redundancy with planned duplication mismatch” 520
Table 601 – ExtChannelErrorType for ChannelErrorType “Multiple interface mismatch” 520
Table 602 – Values for ExtChannelAddValue 521
Table 603 – Values for “Accumulative Info” 521
Table 604 – Values for ExtChannelErrorType “Parameter fault detail” 522
Table 605 – Values for ExtChannelAddValue.Index 522
Table 606 – Values for ExtChannelAddValue.Offset 522
Table 607 – Values for ExtChannelErrorType “Consistency fault detail” 522
Table 608 – Values for ExtChannelAddValue.Index 523
Table 609 – Values for “Fiber optic mismatch” – “Power Budget” 523
Table 610 – Values for “Network component function mismatch” – “Frame dropped” 523
Table 611 – Values for “Remote mismatch” – ”Peer CableDelay mismatch” 524
Table 612 – Values for “Multiple interface mismatch” – ”Conflicting MultipleInterfaceMode.NameOfDevice mode” 524
Table 613 – Values for “Multiple interface mismatch” – ”Inactive StandardGateway” 524
Table 614 – Values for QualifiedChannelQualifier 525
Table 615 – Values for MaintenanceStatus 525
Table 616 – URRecordIndex 527
Table 617 – URRecordLength 527
Table 618 – iPar_Req_Header 527
Table 619 – Max_Segm_Size 527
Table 620 – Transfer_Index 528
Table 621 – Total_iPar_Size 528
Table 622 – MultipleInterfaceMode.NameOfDevice 528
Table 623 – NumberOfPeers in conjunction with PDPortDataCheck 529
Table 624 – NumberOfPeers in conjunction with PDPortDataReal or PDPortDataRealExtended 529
Table 625 – LineDelay.Value with LineDelay.FormatIndicator == 0 530
Table 626 – LineDelay.Value with LineDelay.FormatIndicator == 1 530
Table 627 – LineDelay.FormatIndicator 531
Table 628 – RxPort 531
Table 629 – NumberOfTxPortGroups 531

AVA Documents Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 630 – TxPortEntry 532
Table 631 – FrameDetails.SyncFrame in conjunction with FrameDataProperties.ForwardingMode==“Absolute mode” 533
Table 632 – FrameDetails.SyncFrame in conjunction with FrameDataProperties.ForwardingMode==“Relative mode” 533
Table 633 – FrameDetails.MeaningFrameSendOffset 534
Table 634 – FrameDetails.MediaRedundancyWatchDog 534
Table 635 – FrameDataProperties.ForwardingMode 534
Table 636 – FrameDataProperties.FastForwardingMulticastMACAdd 534
Table 637 – FrameDataProperties.FragmentationMode 535
Table 638 – MAUType 535
Table 639 – MAUType with MAUTypeExtension 539
Table 640 – Valid combinations between MAUType and LinkState 539
Table 641 – MAUTypeExtensions and its corresponding MAUTypes 540
Table 642 – CheckSyncMode.CableDelay 540
Table 643 – CheckSyncMode.SyncMaster 540
Table 644 – MAUTypeMode.Check 541
Table 645 – DomainBoundaryIngress 541
Table 646 – DomainBoundaryEgress 541
Table 647 – DomainBoundaryAnnounce 542
Table 648 – MulticastBoundary 542
Table 649 – PeerToPeerBoundary 543
Table 650 – DCPBoundary 543
Table 651 – PreambleLength.Length 544
Table 652 – LinkState.Link 544
Table 653 – LinkState.Port 545
Table 654 – MediaType 545
Table 655 – MaxBridgeDelay 545
Table 656 – NumberOfPorts 546
Table 657 – MaxPortTxDelay 546
Table 658 – MaxPortRxDelay 546
Table 659 – MaxLineRxDelay 546
Table 660 – YellowTime 547
Table 661 – StartOfRedFrameID in conjunction with ARProperties.StartupMode:= Legacy 549
Table 662 – StartOfRedFrameID in conjunction with ARProperties.StartupMode:= Advanced 550
Table 663 – EndOfRedFrameID 550
Table 664 – Dependencies of StartOfRedFrameID and EndOfRedFrameID 550
Table 665 – NumberOfAssignments 550
Table 666 – NumberOfPhases 551
Table 667 – AssignedValueForReservedBegin 551
Table 668 – AssignedValueForOrangeBegin 552
Table 669 – AssignedValueForReservedEnd 552

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 670 – Values of RedOrangePeriodBegin 552
Table 671 – Dependencies of RedOrangePeriodBegin, OrangePeriodBegin and GreenPeriodBegin 553
Table 672 – Values of OrangePeriodBegin with ARProperties.StartupMode == Legacy 553
Table 673 – Values of OrangePeriodBegin with ARProperties.StartupMode == Advanced 553
Table 674 – Values of GreenPeriodBegin 553
Table 675 – EtherType 554
Table 676 – SyncProperties.Role 554
Table 677 – SyncProperties.SyncID 554
Table 678 – ReservedIntervalBegin with ARProperties.StartupMode == Legacy 555
Table 679 – ReservedIntervalBegin with ARProperties.StartupMode == Advanced 555
Table 680 – ReservedIntervalEnd with ARProperties.StartupMode == Legacy 555
Table 681 – ReservedIntervalEnd with ARProperties.StartupMode == Advanced 555
Table 682 – Dependencies of ReservedIntervalBegin and ReservedIntervalEnd 555
Table 683 – SyncSendFactor 556
Table 684 – PTCPTimeoutFactor 557
Table 685 – PTCPTakeoverTimeoutFactor 557
Table 686 – PTCPMasterStartupTime 558
Table 687 – PLLWindow 558
Table 688 – TimeIObase 560
Table 689 – TimeDataCycle 560
Table 690 – TimeIOInput 560
Table 691 – TimeIOOutput 561
Table 692 – TimeIOInputValid 561
Table 693 – TimeIOOutputValid 561
Table 694 – ControllerApplicationCycleFactor 561
Table 695 – TimePLLWindow 562
Table 696 – TimeMasterPriority1 563
Table 697 – TimeMasterPriority2 563
Table 698 – MRP_Version 564
Table 699 – MRP_RingState 564
Table 700 – MRP_DomainUUID 564
Table 701 – MRP_LengthDomainName 565
Table 702 – MRP_DomainName 565
Table 703 – MRP_Role 565
Table 704 – MRP_Version 565
Table 705 – MRP_Prio 566
Table 706 – MRP_TOPchgT 566
Table 707 – MRP_TOPNRmax 567
Table 708 – MRP_TSTshortT 567
Table 709 – MRP_TSTdefaultT 567
Table 710 – MRP_TSTNRmax 568
Table 711 – MRP_LNKdownT 568

Documents
Document Sharing Hub
Full document details: BS EN IEC 61158-6-10:2019

Table 712 – MRP_LNKupT 568
Table 713 – MRP_LNKNRmax 569
Table 714 – MRP_Check.MediaRedundancyManager 569
Table 715 – MRP_Check.MRP_DomainUUID 569
Table 716 – MRP_NumberOfEntries 570
Table 717 – MRP_Instance 570
Table 718 – MRPIC_LengthDomainName 570
Table 719 – MRPIC_DomainName 570
Table 720 – MRPIC_State 571
Table 721 – MRPIC_Role 571
Table 722 – MRPIC_DomainID 571
Table 723 – MRPIC_TOPchgT 572
Table 724 – MRPIC_TOPNRmax 572
Table 725 – MRPIC_LinkStatusChangeT 573
Table 726 – MRPIC_LinkStatusNRmax 573
Table 727 – MRPIC_LNKdownT 573
Table 728 – MRPIC_LNKupT 574
Table 729 – MRPIC_LNKNRmax 574
Table 730 – MRPIC_StartDelay 575
Table 731 – MRPIC_Check.MIM 575
Table 732 – MRPIC_Check.MRPIC_DomainID 575
Table 733 – VendorBlockType 576
Table 734 – FiberOpticType 576
Table 735 – FiberOpticCableType 576
Table 736 – FiberOpticPowerBudgetType.Value 577
Table 737 – FiberOpticPowerBudgetType.CheckEnable 577
Table 738 – NCDropBudgetType.Value 577
Table 739 – NCDropBudgetType.CheckEnable 578
Table 740 – CounterStatus.ifInOctets 579
Table 741 – CounterStatus.ifOutOctets 579
Table 742 – CounterStatus.ifInDiscards 579
Table 743 – CounterStatus.ifOutDiscards 579
Table 744 – CounterStatus.ifInErrors 579
Table 745 – CounterStatus.ifOutErrors 580
Table 746 – CounterStatus.Reserved 580
Table 747 – FSHelloMode.Mode 581
Table 748 – FSHelloInterval 581
Table 749 – FSHelloRetry 582
Table 750 – FSHelloDelay 582
Table 751 – FSParameterMode.Mode 582
Table 752 – FSParameterUUID 583
Table 753 – NumberOfSubframeBlocks 583
Table 754 – SFIOCRProperties.DistributedWatchDogFactor 583

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 755 – SFIOCRProperties.RestartFactorForDistributedWD 584
Table 756 – SFIOCRProperties.DFPMode 584
Table 757 – SFIOCRProperties.DFPDirection 585
Table 758 – SFIOCRProperties.DFPRedundantPathLayout 585
Table 759 – SFIOCRProperties.SFCRC16 585
Table 760 – SubframeData.Position 586
Table 761 – SubframeData.DataLength 586
Table 762 – Event function table 587
Table 763 – SubframeOffset 587
Table 764 – Event function table 588
Table 765 – SCFEntry 589
Table 766 – ACCommunicationProperties.DFP 590
Table 767 – ACCommunicationProperties.RTC3 590
Table 768 – ACCommunicationProperties.RTCUDP 590
Table 769 – ACMinDeviceInterval 591
Table 770 – FromOffsetData 591
Table 771 – NextOffsetData 591
Table 772 – TotalSize 591
Table 773 – RedundancyInfo.EndPoint1 592
Table 774 – RedundancyInfo.EndPoint2 592
Table 775 – Valid combination of RedundancyInfo.EndPoint1 and RedundancyInfo.EndPoint2 592
Table 776 – SRProperties.InputValidOnBackupAR with SRProperties.Mode == 0 593
Table 777 – SRProperties.InputValidOnBackupAR with SRProperties.Mode == 1 594
Table 778 – SRProperties.Reserved_1 594
Table 779 – SRProperties.Mode 594
Table 780 – RedundancyDataHoldFactor 594
Table 781 – NumberOfEntries 595
Table 782 – PE_OperationalMode 595
Table 783 – AM_Location.Structure 596
Table 784 – AM_Location.Levelx 596
Table 785 – AM_Location.Reserved1 597
Table 786 – AM_Location.BeginSubslotNumber 597
Table 787 – AM_Location.EndSubslotNumber 597
Table 788 – AM_Location.Reserved2 597
Table 789 – AM_Location.Reserved3 598
Table 790 – AM_Location.Reserved4 598
Table 791 – AM_DeviceIdentification.DeviceSubID 598
Table 792 – AM_DeviceIdentification.DeviceSubID for AM_DeviceIdentification.Organization:= 0x0000 599
Table 793 – AM_DeviceIdentification.DeviceID 599
Table 794 – AM_DeviceIdentification.VendorID 599
Table 795 – AM_DeviceIdentification.Organization 599
Table 796 – RS_Properties.AlarmTransport 600

Documents
Document Sharing Hub
Full document details: BS EN IEC 61158-6-10:2019

Table 797 – RS_BlockType used for events 600
Table 798 – RS_BlockType used for adjust 601
Table 799 – RS_BlockLength in conjunction with RS_EventBlock 601
Table 800 – RS_BlockLength in conjunction with other blocks 602
Table 801 – RS_Specifier.SequenceNumber 602
Table 802 – RS_Specifier.Specifier 602
Table 803 – RS_MinusError 603
Table 804 – RS_PlusError 603
Table 805 – RS_ExtensionBlockType 603
Table 806 – RS_ExtensionBlockLength 603
Table 807 – RS_MaxScanDelay 604
Table 808 – RS_AdjustSpecifier.Incident 604
Table 809 – RS_ReasonCode.Reason 604
Table 810 – RS_ReasonCode.Detail 605
Table 811 – RS_DigitalInputCurrentValue.Value 605
Table 812 – RS_DomainIdentification 605
Table 813 – RS_MasterIdentification 605
Table 814 – ActualLocalTimeStamp 606
Table 815 – LocalTimeStamp 606
Table 816 – NumberOfLogEntries 606
Table 817 – EntryDetail 606
Table 818 – Time_TimeStamp 607
Table 819 – Allowed combinations of PRAL_Reason, PRAL_ExtReason, and PRAL_ReasonAddValue 607
Table 820 – PRAL_ChannelProperties.Reserved_1 607
Table 821 – PRAL_ChannelProperties.Accumulative 608
Table 822 – PRAL_ChannelProperties.Reserved_2 608
Table 823 – PRAL_ChannelProperties.Direction 608
Table 824 – Values for PRAL_Reason 608
Table 825 – Values for PRAL_ExtReason 610
Table 826 – Usage of PRAL_ReasonAddValue 610
Table 827 – Values for PRAL_ReasonAddValue[0..3] 610
Table 828 – Values for PRAL_ReasonAddValue[0] to [127] 610
Table 829 – ArgsLength check 611
Table 830 – ARBlockReq – request check 612
Table 831 – IOCRBlockReq – request check 613
Table 832 – AlarmCRBlockReq – request check 617
Table 833 – ExpectedSubmoduleBlockReq – request check 617
Table 834 – PrmServerBlock – request check 619
Table 835 – MCRBlockReq – request check 619
Table 836 – ARRPCBlockReq – request check 620
Table 837 – IRInfoBlock – request check 620
Table 838 – SRInfoBlock – request check 621

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 839 – RSInfoBlock – request check 621
Table 840 – ArgsLength check 622
Table 841 – ARBlockRes – response check 622
Table 842 – IOCRBlockRes – response check 623
Table 843 – AlarmCRBlockRes – response check 624
Table 844 – ModuleDiffBlock – response check 624
Table 845 – ARServerBlockRes – response check 625
Table 846 – ArgsLength check 626
Table 847 – ControlBlockConnect(PrmEnd) – request check 626
Table 848 – ControlBlockPlug(PrmEnd) – request check 627
Table 849 – ControlBlockConnect(PrmBegin) – request check 627
Table 850 – SubmoduleListBlock – request check 628
Table 851 – ArgsLength check 628
Table 852 – ControlBlockConnect – response check 629
Table 853 – ControlBlockPlug – response check 629
Table 854 – ControlBlockConnect(PrmBegin) – response check 630
Table 855 – ArgsLength check 631
Table 856 – ControlBlockConnect(ApplRdy) – request check 631
Table 857 – ControlBlockPlug(ApplRdy) – request check 632
Table 858 – ArgsLength check 632
Table 859 – ControlBlockConnect – response check 633
Table 860 – ControlBlockPlug – response check 633
Table 861 – ArgsLength check 634
Table 862 – ReleaseBlock – request check 635
Table 863 – ArgsLength check 635
Table 864 – ReleaseBlock – response check 636
Table 865 – ArgsLength check 636
Table 866 – IODWriteReqHeader – request check 637
Table 867 – ArgsLength check 637
Table 868 – IODWriteResHeader – response check 638
Table 869 – ArgsLength check 639
Table 870 – ArgsLength check 640
Table 871 – ArgsLength check 640
Table 872 – IODReadReqHeader – request check 641
Table 873 – RecordDataReadQuery – request check 642
Table 874 – ArgsLength check 642
Table 875 – IODReadResHeader – response check 642
Table 876 – Primitives issued by AP-Context (FAL user) to FSPMDEV 645
Table 877 – Primitives issued by FSPMDEV to AP-Context (FAL user) 648
Table 878 – Functions, Macros, Timers and Variables used by the AP-Context (FAL user) to FSPMDEV 651
Table 879 – Functions, Macros, Timers and Variables used by the FSPMDEV to AP-Context (FAL user) 652
Table 880 – Primitives issued by AP-Context (FAL user) to FSPMCTL 653

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 881 – Primitives issued by FSPMCTL to AP-Context (FAL user) 657
Table 882 – Functions, Macros, Timers and Variables used by AP-Context (FAL user) to FSPMCTL 661
Table 883 – Functions, Macros, Timers and Variables used by FSPMCTL to AP-Context (FAL user) 662
Table 884 – Remote primitives issued or received by ALPMI 665
Table 885 – Local primitives issued or received by ALPMI 666
Table 886 – ALPMI state table 667
Table 887 – Functions, Macros, Timers and Variables used by ALPMI 668
Table 888 – Remote primitives issued or received by ALPMR 669
Table 889 – Local primitives issued or received by ALPMR 670
Table 890 – ALPMR state table 671
Table 891 – Functions, Macros, Timers and Variables used by ALPMR 673
Table 892 – Remote primitives issued or received by CMDEV 677
Table 893 – Local primitives issued or received by CMDEV 679
Table 894 – CMDEV state table 682
Table 895 – Functions, Macros, Timers and Variables used by CMDEV 684
Table 896 – Remote primitives issued or received by CMDEV_DA 686
Table 897 – Local primitives issued or received by CMDEV_DA 686
Table 898 – CMDEV_DA state table 688
Table 899 – Functions, Macros, Timers and Variables used by CMDEV(DA) 688
Table 900 – Remote primitives issued or received by CMSU 689
Table 901 – Local primitives issued or received by CMSU 689
Table 902 – CMSU state table 692
Table 903 – Functions, Macros, Timers and Variables used by the CMSU 695
Table 904 – Remote primitives issued or received by CMIO 695
Table 905 – Local primitives issued or received by CMIO 695
Table 906 – CMIO state table 697
Table 907 – Functions used by the CMIO 698
Table 908 – Remote primitives issued or received by CMRS 698
Table 909 – Local primitives issued or received by CMRS 699
Table 910 – CMRS state table 700
Table 911 – Functions, Macros, Timers and Variables used by the CMRS 700
Table 912 – Remote primitives issued or received by CMWRR 701
Table 913 – Local primitives issued or received by CMWRR 701
Table 914 – CMWRR state table 703
Table 915 – Functions, Macros, Timers and Variables used by CMWRR 705
Table 916 – Remote primitives issued or received by CMRDR 706
Table 917 – Local primitives issued or received by CMRDR 706
Table 918 – CMRDR state table 707
Table 919 – Functions, Macros, Timers and Variables used by CMRDR 708
Table 920 – Remote primitives issued or received by CMSM 708
Table 921 – Local primitives issued or received by CMSM 709
Table 922 – CMSM state table 710

Documents
Document Sharing Hub
Full document details: BS EN IEC 61158-6-10:2019

Table 923 – Functions, Macros, Timers and Variables used by the CMSM 711
Table 924 – Remote primitives received by CMPBE 712
Table 925 – Local primitives issued or received by CMPBE 712
Table 926 – CMPBE state table 714
Table 927 – Functions, Macros, Timers and Variables used by the CMPBE 716
Table 928 – Remote primitives issued or received by CMDMC 716
Table 929 – Local primitives issued or received by CMDMC 717
Table 930 – CMDMC state table 719
Table 931 – Functions, Macros, Timers and Variables used by the CMDMC 721
Table 932 – Remote primitives issued or received by CMINA 722
Table 933 – Local primitives issued or received by CMINA 722
Table 934 – CMINA state table 724
Table 935 – Functions, Macros, Timers and Variables used by the CMINA 730
Table 936 – Return values of CheckAPDU 731
Table 937 – Remote primitives issued or received by CMRPC 732
Table 938 – Local primitives issued or received by CMRPC 734
Table 939 – CMRPC state table 735
Table 940 – Functions, Macros, Timers and Variables used by the CMRPC 738
Table 941 – Return values of CheckRPC 740
Table 942 – Remote primitives issued or received by CMSRL 741
Table 943 – Local primitives issued or received by CMSRL 742
Table 944 – CMSRL state table 743
Table 945 – Functions, Macros, Timers and Variables used by the CMSRL 746
Table 946 – Combinations of DataStatus for Output buffers 747
Table 947 – Combinations of DataStatus for Input buffers 747
Table 948 – Remote primitives issued or received by CMSRL_AL 753
Table 949 – Local primitives issued or received by CMSRL_AL 753
Table 950 – CMSRL_AL state table 755
Table 951 – Functions, Macros, Timers and Variables used by the CMSRL_AL 756
Table 952 – Remote primitives issued or received by CMCTL 759
Table 953 – Local primitives issued or received by CMCTL 760
Table 954 – CMCTL state table 764
Table 955 – Functions, Macros, Timers and Variables used by the CMCTL 767
Table 956 – Remote primitives issued or received by CTLSM 767
Table 957 – Local primitives issued or received by CTLSM 768
Table 958 – CTLSM state table 769
Table 959 – Functions, Macros, Timers and Variables used by the CTLSM 770
Table 960 – Remote primitives issued or received by CTLIO 770
Table 961 – Local primitives issued or received by CTLIO 771
Table 962 – CTLIO state table 772
Table 963 – Functions, Macros, Timers and Variables used by the CTLIO 773
Table 964 – Remote primitives received by CTLRDI 774
Table 965 – Local primitives issued or received by CTLRDI 774

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table 966 – CTLRDI state table 776
Table 967 – Functions, Macros, Timers and Variables used by CTLRDI 776
Table 968 – Remote Primitives received by CTLRDR 777
Table 969 – Local primitives issued or received by CTLRDR 778
Table 970 – CTLRDR state table 778
Table 971 – Functions, Macros, Timers and Variables used by CTLRDR 779
Table 972 – Remote primitives received by CTLRPC 779
Table 973 – Local primitives issued or received by CTLRPC 782
Table 974 – CTLRPC state table 783
Table 975 – Functions, Macros, Timers and Variables used by the CTLRPC 785
Table 976 – Remote primitives issued or received by CTLSU 785
Table 977 – Local Primitives issued or received by CTLSU 786
Table 978 – CTLSU state table 788
Table 979 – Functions, Macros, Timers and Variables used by the CTLSU 790
Table 980 – Remote primitives issued or received by CTLWRI 791
Table 981 – Local primitives issued or received by CTLWRI 791
Table 982 – CTLWRI state table 793
Table 983 – Functions, Macros, Timers and Variables used by CTLWRI 794
Table 984 – Remote primitives issued or received by CTLWRR 795
Table 985 – Local primitives issued or received by CTLWRR 795
Table 986 – CTLWRR state table 797
Table 987 – Functions, Macros, Timers and Variables used by CTLWRR 797
Table 988 – Remote primitives issued or received by CTLPBE 798
Table 989 – Local primitives issued or received by CTLPBE 799
Table 990 – CTLPBE state table 800
Table 991 – Functions, Macros, Timers and Variables used by CTLPBE 802
Table 992 – Remote primitives issued or received by CTLDINA 803
Table 993 – Local primitives issued or received by CTLDINA 804
Table 994 – CTLDINA state table 806
Table 995 – Functions, Macros, Timers and Variables used by the CTLDINA 809
Table 996 – Remote primitives issued or received by CTLSRL 811
Table 997 – Local primitives issued or received by CTLSRL 811
Table 998 – CTLSRL state table 813
Table 999 – Functions, Macros, Timers and Variables used by the CTLSRL 815
Table A.1 – Examples for the AR establishing 819
Table A.2 – Startup of Alarm transmitter and receiver 819
Table B.1 – Examples for compatible AR establishing 828
Table I.1 – Priority regeneration and queue usage 842
Table M.1 – IEEE 802.3 cross reference 849
Table R.1 – Truth table 864
Table R.2 – “MAC/PHY configuration/status” with AutoNegotiation disabled 864
Table R.3 – “MAC/PHY configuration/status” with AutoNegotiation enabled 864
Table R.4 – Auto-negotiation support within “MAC/PHY configuration/status” 864

AVA Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Table R.5 – Auto-negotiation settings 865
Table T.1 – List of supported MIBs 867
Table U.1 – Content of archive 868
Table W.1 – Cross reference IEC 62439-2 “MRP MIB objects” 887
Table W.2 – Cross reference IEC 62439-2 “Events, created by state machines” 887
Table W.3 – Cross reference IEC 62439-2 “MRM parameter” 888
Table W.4 – Cross reference IEC 62439-2 “MRC parameter” 888
Table W.5 – Cross reference IEC 62439-2 “MRP MIB objects” 888
Table W.6 – Cross reference IEC 62439-2 “Events, created by state machines” 889
Table W.7 – Cross reference IEC 62439-2 “MIM parameter” 889
Table W.8 – Cross reference IEC 62439-2 “MIC parameter” 889
Table X.1 – Meaning of numbers 891
Table X.2 – Statistic counters – octets 892
Table X.3 – Statistic counters – packets or frames 893
Table X.4 – Statistic counters – errors 893

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-10: Application layer protocol specification – Type 10 elements

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-6-10 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2014. This edition constitutes a technical revision.

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

This edition includes the following significant technical changes with respect to the previous edition:

a) integration of system redundancy basic functionality;
b) integration of dynamic reconfiguration basic functionality;
c) integration of reporting system basic functionality;
d) integration of asset management basic functionality;e) integration of media redundancy ring interconnection basic functionality.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/948/FDIS	65C/956/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications,* can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'color inside' logo on the cover page of this publication indicates that it contains colors which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a color printer.

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

– as a guide for implementers and designers;
– for use in the testing and procurement of equipment;
– as part of an agreement for the admittance of systems into the open systems environment;
– as a refinement to the understanding of time-critical communications within OSI.

This document is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

NOTE Attention is drawn to the fact that use of the associated protocol type(s) is restricted by its (their) intellectual-property-right holder(s). In all cases, the commitment to limited release of intellectual-property-rights made by the holder(s) of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the IEC 61784 series. Use of the protocol type(s) in other combinations may require permission of their respective intellectual-property-right holder(s).

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent concerning Type 10 elements and possibly other types given in this document as follows:

The following patent rights for Type 10 have been announced by [SI]:

Publication	Title
WO 02/043336	System and method for parallel transfer of real-time critical and non-real-time critical data via switchable data networks, particularly Ethernet
WO 02/076033	Synchronous clocked communication system with decentralized input/output modules and methods for integrating decentralized input/output modules in such a system
WO 03/028258	Method for synchronizing nodes of a communication system
WO 03/028259	Communications system and method for synchronizing a communications cycle
WO 04/030284	Method for permanent redundant transmission of data telegrams in communication systems
EP 1558002	Method for assigning an IP address to a device
EP 1318630	Matrices for controlling the device specific data transfer rates on a field bus

IEC takes no position concerning the evidence, validity and scope of these patent rights.

The holder of these patent rights has assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of these patent rights is registered with IEC. Information may be obtained from:

AVA Documents Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

[SI]: Siemens AG
LC TE IP&IT

Otto-Hahn-Ring 6
D-81739 Munich
Germany

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (http://www.iec.ch/tctools/patent_decl.htm) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-10: Application layer protocol specification – Type 10 elements

1 Scope

1.1 General

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 10 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible behavior provided by the Type 10 fieldbus application layer in terms of:

a) the abstract syntax defining the application layer protocol data units conveyed between communicating application entities,
b) the transfer syntax defining the application layer protocol data units conveyed between communicating application entities,
c) the application context state machine defining the application service behavior visible between communicating application entities, and
d) the application relationship state machines defining the communication behavior visible between communicating application entities.

The purpose of this document is to define the protocol provided to:

a) define the wire-representation of the service primitives defined in IEC 61158-5-10 and
b) define the externally visible behavior associated with their transfer.

This document specifies the protocol of the Type 10 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI Application Layer Structure (ISO/IEC 9545).

1.2 Specifications

The principal objective of this document is to specify the syntax and behavior of the application layer protocol that conveys the application layer services defined in IEC 61158-5-10.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of protocols standardized in IEC 61158-6.

1.3 Conformance

This document does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

AVA Documents Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

Conformance is achieved through implementation of this application layer protocol specification.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61131-9, *Programmable controllers – Part 9: Single-drop digital communication interface for small sensors and actuators (SDCI)*

IEC 61158-1:2019, *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

IEC 61158-2, *Industrial communication networks – Fieldbus specifications – Part 2: Physical layer specification and service definition*

IEC 61158-5-10:2019, *Industrial communication networks – Fieldbus specifications – Application layer service definition – Type 10 elements*

IEC 61158-6-3:2019, *Industrial communication networks – Fieldbus specifications – Part 6-3: Application layer protocol specification – Type 3 elements*

IEC 62439-2, *Industrial communication networks – High availability automation networks – Part 2: Media Redundancy Protocol (MRP)*

ISO/IEC 646:1991, *Information technology – ISO 7-bit coded character set for information interchange*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 9834-8, *Information technology – Procedures for the operation of object identifier registration authorities – Part 8: Generation of universally unique identifiers (UUIDs) and their use in object identifiers*

ISO/IEC 10646, *Information technology – Universal Coded Character Set (UCS)*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC/IEEE 60559:2011, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019

ISO 8601, *Data elements and interchange formats – Information interchange – Representation of dates and times*

IEEE Std 802, *IEEE Standard for Local and metropolitan area networks: Overview and Architecture,* available at http://www.ieee.org [viewed 2018-09-27]

IEEE Std 802.1AB:2016, *IEEE Standard for Local and metropolitan area networks: Station and Media Access Control Connectivity Discovery*, available at http://www.ieee.org [viewed 2018-09-27]

IEEE Std 802.1AC, *IEEE Standard for Local and metropolitan area networks – Media Access Control (MAC) Service definition*, available at http://www.ieee.org [viewed 2018-09-27]

IEEE Std 802.1AS, *IEEE standard for Local and metropolitan area networks – Timing and Synchronization for Time-Sensitive Applications in Bridged Local Area Networks*, available at http://www.ieee.org [viewed 2018-09-27]

IEEE Std 802.1Q-2018, *IEEE Standard for Local and metropolitan area networks – Bridges and Bridged Networks*, available at http://www.ieee.org [viewed 2018-09-27]

IEEE Std 802.3, *IEEE Standard for Ethernet*, available at http://www.ieee.org [viewed 2018-09-27]

IEEE Std 802.11, *IEEE Standard for Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 11: Wireless LAN Medium Access Control (MAC) and Physical Layer (PHY) Specifications,* available at http://www.ieee.org [viewed 2018-09-27]

IEEE Std 802.15.1, *IEEE Standard for Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 15.1: Wireless medium access control (MAC) and physical layer (PHY) specifications for wireless personal area networks (WPANs),* available at http://www.ieee.org [viewed 2018-09-27]

IETF RFC 768, *User Datagram Protocol*; available at http://www.ietf.org [viewed 2018-09-27]

IETF RFC 791, *Internet Protocol*; available at http://www.ietf.org [viewed 2018-09-27]

IETF RFC 792*, Internet Control Message Protocol*; available at http://www.ietf.org [viewed 2018-09-27]

IETF RFC 826, *An Ethernet Address Resolution Protocol or Converting Network Protocol Addresses to 48.bit Ethernet Address for Transmission on Ethernet Hardware*; available at http://www.ietf.org [viewed 2018-09-27]

IETF RFC 950, *Internet Standard Subnetting Procedure*; available at http://www.ietf.org [viewed 2018-09-27]

IETF RFC 1034, *Domain names – Concepts and Facilities*; available at http://www.ietf.org [viewed 2018-09-27]

IETF RFC 1213, *Management Information Base for Network Management of TCP/IP-based internets: MIB-II;* available at http://www.ietf.org [viewed 2018-09-27]

IETF RFC 2131, *Dynamic Host Configuration Protocol*; available at http://www.ietf.org [viewed 2018-09-27]

Documents
Document Sharing Hub

Full document details: BS EN IEC 61158-6-10:2019