



BSI Standards Publication

Industrial networks — Profiles

Part 1-19: Fieldbus profiles — Communication Profile Family 19

National foreword

This British Standard is the UK implementation of EN IEC 61784-1-19:2023. It is identical to IEC 61784-1-19:2023. It partially supersedes BS EN IEC 61784-1:2019.

The UK participation in its preparation was entrusted to Technical Committee GEL/65, Measurement and control.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2024
Published by BSI Standards Limited 2024

ISBN 978 0 539 13662 3

ICS 35.100.20; 35.100.20; 35.240.50; 35.240.50

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 September 2024.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

English Version

Industrial networks - Profiles - Part 1-19: Fieldbus profiles -
Communication Profile Family 19
(IEC 61784-1-19:2023)

Réseaux industriels - Profils - Partie 1-19: Profils de bus de
terrain - Famille de profils de communication 19
(IEC 61784-1-19:2023)

Industrielle Kommunikationsnetze - Profile - Teil 1-19:
Feldbusprofile - Kommunikationsprofilfamilie (CPF) 19
(IEC 61784-1-19:2023)

This European Standard was approved by CENELEC on 2023-04-28. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 65C/1207/FDIS, future edition 1 of IEC 61784-1-19, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61784-1-19:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2024-01-28
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2026-04-28

This document, together with other parts of the same series, partially supersedes EN IEC 61784-1:2019 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61784-1-19:2023 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60793 (series) NOTE Approved as EN IEC 60793 (series)
IEC 61158-1 NOTE Approved as EN IEC 61158-1
IEC 61158-3 (series) NOTE Approved as EN 61158-3 (series)
IEC 61158-4 (series) NOTE Approved as EN 61158-4 (series)
IEC 61158-5 (series) NOTE Approved as EN 61158-5 (series)
IEC 61158-6 (series) NOTE Approved as EN 61158-6 (series)
IEC 61784-1 (series) NOTE Approved as EN IEC 61784-1 (series)
IEC 61784-2 (series) NOTE Approved as EN IEC 61784-2 (series)
IEC 61784-2-19 NOTE Approved as EN IEC 61784-2-19

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cencenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158	series	Industrial communication networks - Fieldbus specifications	EN IEC 61158	series
IEC 61158-2	2023	Industrial communication networks - Fieldbus specifications - Part 2: Physical layer specification and service definition	EN IEC 61158-2	2023
IEC 61158-3-24	2023	Industrial communication networks - Fieldbus specifications - Part 3-24: Data- link layer service definition - Type 24 elements	EN IEC 61158-3-24	2023
IEC 61158-4-24	2023	Industrial communication networks - Fieldbus specifications - Part 4-24: Data- link layer protocol specification - Type 24 elements	EN IEC 61158-4-24	2023
IEC 61158-5-24	2023	Industrial communication networks - Fieldbus specifications - Part 5-24: Application layer service definition - Type 24 elements	EN IEC 61158-5-24	2023
IEC 61158-5-27	2023	Industrial communication networks - Fieldbus specifications - Part 5-27: Application layer service definition - Type 27 elements	EN IEC 61158-5-27	2023
IEC 61158-6-24	2023	Industrial communication networks - Fieldbus specifications - Part 6-24: Application layer protocol specification - Type 24 elements	EN IEC 61158-6-24	2023
IEC 61158-6-27	2023	Industrial communication networks - Fieldbus Specifications Part 6-27: Application layer protocol specification - Type 27 elements	EN IEC 61158-6-27	2023
IEC 61784-1-0	2023	Industrial networks - Profiles - Part 1-0: Fieldbus profiles - General concepts and terminology	EN IEC 61784-1-0	2023

EN IEC 61784-1-19:2023 (E)

ISO/IEC/IEEE 8802-3 -		Telecommunications and exchange between information technology systems - Requirements for local and metropolitan area networks - Part 3: Standard for Ethernet	-	-
TIA-485-A	1998	Electrical Characteristics of Generators and Receivers for Use in Balanced Digital Multipoint Systems	-	-

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms, definitions, abbreviated terms, symbols, and conventions	9
3.1 Terms and definitions.....	9
3.2 Abbreviations and symbols	9
3.2.1 Common abbreviations and symbols.....	9
3.2.2 Other abbreviations and symbols.....	9
3.3 Conventions.....	9
4 CPF 19 (MECHATROLINK).....	9
4.1 General overview.....	9
4.2 CP 19/1 (MECHATROLINK-II).....	10
4.2.1 Physical layer selection	10
4.2.2 Data-link layer	12
4.2.3 Application layer.....	23
4.3 CP 19/2 (M-III).....	29
4.3.1 Physical layer	29
4.3.2 Data-link layer	30
4.3.3 Application layer.....	40
4.4 CP 19/3 (Σ-LINK II).....	44
4.4.1 Physical layer selection	44
4.4.2 Data-link layer	46
4.4.3 Application layer.....	57
Bibliography.....	63
Table 1 – CPF 19: overview of profile sets (CP19/1 and CP19/2).....	10
Table 2 – CPF 19: Overview of profile sets (CP19/3 and CP19/4)	10
Table 3 – CP 19/1 profile: PhL selection	11
Table 4 – CP 19/1: DLL service selection.....	12
Table 5 – DLL service selection for C1 master of CP 19/1.....	14
Table 6 – DLL service selection for C2 master of CP 19/1.....	15
Table 7 – DLL service selection for slave of CP 19/1	16
Table 8 – CP 19/1: DLL protocol selection	16
Table 9 – DLL protocol selection for C1 master of CP 19/1	19
Table 10 – DLL protocol selection for C2 master of CP 19/1	20
Table 11 – DLL protocol selection for slave of CP 19/1	21
Table 12 – CP 19/1: AL service selection.....	23
Table 13 – Class selection for C1 master of CP 19/1	24
Table 14 – Master class attribute selection for C1 master of CP 19/1.....	24
Table 15 – Master class service selection	24
Table 16 – FDCMaster-AR class attribute selection for C1 master of CP 19/1.....	24
Table 17 – FDCMaster-AR class service selection	25
Table 18 – Class selection for C2 master of CP 19/1	25

Table 19 – Monitor class attribute selection for C2 master of CP 19/1	25
Table 20 – Monitor class service selection	26
Table 21 – FDCMonitor-AR class attribute selection for C2 master of CP 19/1	26
Table 22 – FDCMonitor-AR class service selection	26
Table 23 – Class selection for slave AP of CP 19/1	27
Table 24 – Slave class attribute selection for slave AP of CP 19/1	27
Table 25 – Slave class service selection	27
Table 26 – FDCSlave-AR class attribute selection for slave AP of CP 19/1	28
Table 27 – FDCSlave-AR class service selection	28
Table 28 – CP 19/1: AL protocol selection	29
Table 29 – CP 19/2: DLL service selection	30
Table 30 – DLL service selection for C1 master of CP 19/2	31
Table 31 – DLL service selection for C2 master of CP 19/2	32
Table 32 – DLL service selection for slave of CP 19/2	33
Table 33 – CP 19/2: DLL protocol selection	33
Table 34 – DLL protocol selection for C1 master of CP 19/2	35
Table 35 – DLL protocol selection for C2 master of CP 19/2	37
Table 36 – DLL protocol selection for slave of CP 19/2	38
Table 37 – CP 19/2: AL service selection	40
Table 38 – Class selection for C1 master of CP 19/2	41
Table 39 – EventManager class attribute selection for C1 master of CP 19/2	41
Table 40 – EventManager class service selection	41
Table 41 – Class selection for C2 master of CP 19/2	42
Table 42 – EventManager class attribute selection for C2 master of CP 19/2	42
Table 43 – EventManager class service selection	42
Table 44 – Class selection for slave AP of CP 19/2	43
Table 45 – EventManager class attribute selection for slave AP of CP 19/2	43
Table 46 – EventManager class service selection	43
Table 47 – CP 19/2: AL protocol selection	44
Table 48 – CP 19/3 profile: PhL selection	44
Table 49 – CP 19/3: DLL service selection	46
Table 50 – DLL service selection for C1 master of CP 19/3	48
Table 51 – DLL service selection for C2 master of CP 19/3	49
Table 52 – DLL service selection for slave of CP 19/3	50
Table 53 – CP 19/3: DLL protocol selection	50
Table 54 – DLL protocol selection for C1 master of CP 19/3	52
Table 55 – DLL protocol selection for C2 master of CP 19/3	54
Table 56 – DLL protocol selection for slave of CP 19/3	55
Table 57 – CP 19/3: AL service selection	57
Table 58 – Class selection for C1 master of CP 19/3	58
Table 59 – Master class attribute selection for C1 master of CP 19/3	58
Table 60 – Master class service selection	58
Table 61 – FDCMaster-AR class attribute selection for C1 master of CP 19/3	59

Table 62 – FDCMaster-AR class service selection	59
Table 63 – Class selection for C2 master of CP 19/3	59
Table 64 – Monitor class attribute selection for C2 master of CP 19/3.....	59
Table 65 – Monitor class service selection	60
Table 66 – FDCMonitor-AR class attribute selection for C2 master of CP 19/3.....	60
Table 67 – FDCMonitor-AR class service selection	60
Table 68 – Class selection for slave AP of CP 19/3.....	60
Table 69 – Slave class attribute selection for slave AP of CP 19/3	61
Table 70 – Slave class service selection	61
Table 71 – FDCSlave-AR class attribute selection for slave AP of CP 19/3	61
Table 72 – FDCSlave-AR class service selection	61
Table 73 – CP 19/3: AL protocol selection	62

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL NETWORKS –
PROFILES –****Part 1-19: Fieldbus profiles –
Communication Profile Family 19****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by their respective intellectual property right holders.

NOTE Combinations of protocol types are specified in the IEC 61784-1 series and the IEC 61784-2 series.

IEC 61784-1-19 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This first edition, together with the other parts of the same series, cancels and replaces the fifth edition of IEC 61784-1 published in 2019. This first edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC 61784-1:2019:

- split of the original IEC 61784-1 into several subparts, one subpart for the material of a generic nature, and one subpart for each Communication Profile Family specified in the original document;
- addition of profile CP 19/3;
- update of selection tables for CPF 19.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1207/FDIS	65C/1236/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61784-1 series, published under the general title *Industrial networks – Profiles – Part 1: Fieldbus profiles*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

The IEC 61784-1 series provides a set of Communication Profiles (CP) in the sense of ISO/IEC TR 10000-1. These answer the need of identifying the protocol families co-existing within the IEC 61158 series, as a result of the international harmonization of fieldbus technologies available on the market. More specifically, these profiles help to correctly state the compliance with the IEC 61158 series, and to avoid the spreading of divergent implementations, which would limit its use, clearness and understanding. Additional profiles to address specific market concerns, such as functional safety or information security, can be addressed by future parts of the IEC 61784-1 series.

The IEC 61784-1 series contains several Communication Profile Families (CPF), which specify one or more communication profiles. Such profiles identify, in a strict sense, protocol subsets of the IEC 61158 series via protocol specific communication profiles. They do not define device profiles that specify communication profiles together with application functions needed to answer the need of a specific application ("application profiles").

It is agreed that these latter classes of profiles would facilitate the use of the IEC 61158 series of standards; the profiles defined in the IEC 61784-1 series are a necessary step to achieve that task.

It is also important to clarify that interoperability – defined as the ability of two or more network systems to exchange information and to make mutual use of the information that has been exchanged (see ISO/IEC TR 10000-1) – can be directly achieved on the same link only for those devices complying with the same communication profile.

Profiles contained in the IEC 61784-1 series are constructed of references to IEC 61158-2 and the IEC 61158-3, IEC 61158-4, IEC 61158-5 and IEC 61158-6 series, and other IS, TS or worldwide-accepted standards, as appropriate¹. Each profile is required to reference at least one part of the IEC 61158 series in addition to IEC 61158-1.

Two or more Profiles, which are related to a common family, are specified within a "Communication Profile Family" (CPF).

¹ International Standardised Profiles may contain normative references to specifications other than International Standards; see ISO/IEC JTC 1 N 4047: *The Normative Referencing of Specifications other than International Standards in JTC 1 International Standardized Profiles – Guidelines for ISP Submitters*.

INDUSTRIAL NETWORKS – PROFILES –

Part 1-19: Fieldbus profiles – Communication Profile Family 19

1 Scope

This part of IEC 61784-1 defines Communication Profile Family 19 (CPF 19). CPF 19 specifies a set of protocol specific communication profiles (CPs) based on the IEC 61158 series (Type 24 and Type 27) and other standards, to be used in the design of devices involved in communications in factory manufacturing and process control.

NOTE 1 All CPs are based on standards or draft standards or International Standards published by the IEC or on standards or International Standards established by other standards bodies or open standards processes.

NOTE 2 Some CPs of CPF 19 are specified in IEC 61784-2-19.

Each CP selects an appropriate consistent and compatible subset of services and protocols from the relevant set that is defined and modelled in the IEC 61158 series. For the selected subset of services and protocols, the profile also describes any possible or necessary constraints in parameter values.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as the IEC 61784-1 series and the IEC 61784-2 series are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61158 (all parts), *Industrial communication networks – Fieldbus specifications*

IEC 61158-2:2023, *Industrial communication networks – Fieldbus specifications – Part 2: Physical layer specification and service definition*

IEC 61158-3-24:2023, *Industrial communication networks – Fieldbus specifications – Part 3-24: Data-link layer service definition – Type 24 elements*

IEC 61158-4-24:2023, *Industrial communication networks – Fieldbus specifications – Part 4-24: Data-link layer protocol specification – Type 24 elements*

IEC 61158-5-24:2023, *Industrial communication networks – Fieldbus specifications – Part 5-24: Application layer service definition – Type 24 elements*

IEC 61158-5-27:2023, *Industrial communication networks – Fieldbus specifications – Part 5-27: Application layer service definition – Type 27 elements*

IEC 61158-6-24:2023, *Industrial communication networks – Fieldbus specifications – Part 6-24: Application layer protocol specification – Type 24 elements*

IEC 61158-6-27:2023, *Industrial communication networks – Fieldbus specifications – Part 6-27: Application layer protocol specification – Type 27 elements*

IEC 61784-1-0:2023, *Industrial networks – Profiles – Part 1-0: Fieldbus profiles – General concepts and terminology*

ISO/IEC/IEEE 8802-3, *Telecommunications and exchange between information technology systems – Requirements for local and metropolitan area networks – Part 3: Standard for Ethernet*

TIA-485-A:1998, *Electrical Characteristics of Generators and Receivers for Use in Balanced Digital Multipoint Systems*

3 Terms, definitions, abbreviated terms, symbols, and conventions

3.1 Terms and definitions

For the purposes of this document, all terms and definitions provided in the IEC 61158 series and IEC 61784-1-0 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.2 Abbreviations and symbols

3.2.1 Common abbreviations and symbols

For the purposes of this document, all abbreviations and symbols defined in the IEC 61158 series and IEC 61784-1-0 apply.

CP	communication profile
CPF	communication profile family
MAU	medium attachment unit

3.2.2 Other abbreviations and symbols

RS 485	MAU according to TIA-485-A
--------	----------------------------

3.3 Conventions

For the purposes of this document, the conventions defined in IEC 61784-1-0 apply.

4 CPF 19 (MECHATROLINK²)

4.1 General overview

Communication Profile Family 19 defines communication profiles (CPs) based on IEC 61158-2 type 24, IEC 61158-3-24, IEC 61158-4-24, IEC 61158-5-24 and IEC 61158-6-24, and on other standards. (See Table 1 and Table 2.)

² MECHATROLINK™ is a trade name of YASKAWA ELECTRIC CORPORATION. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the trade names holder or any of its products. Compliance with this profile does not require use of the trade names. Use of the trade name MECHATROLINK requires permission of the trade name holder.

The CPF 19 (MECHATROLINK) consists of four distinct protocol sets, known generically (for historical reasons) as MECHATROLINK- II (M-II) for CP 19/1, MECHATROLINK- III (M-III) for CP 19/2, Σ -LINK II for CP19/3, and MECHATROLINK-4 (M-4) for CP 19/4, which mainly differ by their physical layers.

- Profile 19/1 (M-II): based on TIA-485-A PhL, which operates at 10 Mbit/s,
- Profile 19/2 (M-III): based on ISO/IEC/IEEE 8802-3 (Ethernet) PhL, which operates at 100 Mbit/s,
- Profile 19/3 (Σ -LINK II): based on TIA-485-A PhL, which operates at up to 32 Mbit/s;
- Profile 19/4 (M-4): based on ISO/IEC/IEEE 8802-3 (Ethernet) PhL, which operates at 100 Mbit/s.

Each CP is classified into more detailed profiles, based on another aspect of application process (AP) type or a sort of device type. Each AP types in a same CP play different roles in a same network as C1 master, C2 master and slave. Such detailed profiles are described in each subclause if needed.

Table 1 – CPF 19: overview of profile sets (CP19/1 and CP19/2)

Layer	Profile 19/1 (M-II)			Profile 19/2 (M-III)		
	C1 master	C2 master	Slave	C1 master	C2 master	Slave
Application	IEC 61158-5-24, IEC 61158-6-24			IEC 61158-5-24, IEC 61158-6-24		
Data link	IEC 61158-3-24, IEC 61158-4-24			IEC 61158-3-24, IEC 61158-4-24		
Physical	IEC 61158-2			IEC 61158-2 ISO/IEC/IEEE 8802-3		

Table 2 – CPF 19: Overview of profile sets (CP19/3 and CP19/4)

Layer	Profile 19/3(Σ -LINK II)			Profile 19/4(M-4)-	
	C1 master	C2 master	Slave	C1 master	Slave
Application	IEC 61158-5-24, IEC 61158-6-24			IEC 61158-5-27, IEC 61158-6-27	
Data link	IEC 61158-3-24, IEC 61158-4-24			—	
Physical	IEC 61158-2			IEC 61158-2 ISO/IEC/IEEE 8802-3	

4.2 CP 19/1 (MECHATROLINK-II)

4.2.1 Physical layer selection

Table 3 specifies the PhL selection within IEC 61158-2 for this profile.

Table 3 – CP 19/1 profile: PhL selection

Clause	Header	Presence	Constraints
1	Scope	YES	—
2	Normative reference	Partial	Used if needed
3	Terms and definitions	—	—
3.1	Common terms and definitions	Partial	Used when applicable
3.2 – 3.10	—	NO	—
3.11	Type 24: terms and definitions	YES	—
Next subclauses	—	NO	—
4	Symbols and abbreviated terms	—	—
4.1	Symbols	—	—
4.1.1 – 4.1.9	—	NO	—
4.1.10	Type 24: symbols	YES	—
Next subclauses	—	NO	—
4.2	Abbreviated terms	—	—
4.2.1 – 4.2.9	—	NO	—
4.2.10	Type 24: abbreviations	YES	—
Next subclauses	—	NO	—
5	DLL-PhL interface	—	—
5.1	General	Partial	Used when applicable
5.2 – 5.10	—	NO	—
5.11	Type 24: Required Service	YES	—
Next subclauses	—	NO	—
6	Systems management – PhL interface	—	—
6.1	General	Partial	Used when applicable
6.2 – 6.8	—	NO	—
6.9	Type 24: Systems management – PhL interface	YES	—
Next subclauses	—	NO	—
7 – 8	—	NO	—
9	Medium dependent sublayer (MDS)	—	—
9.1	General	Partial	Used when applicable
9.2 – 9.11	—	NO	—
9.12	Type 24: MDS Twisted-pair wire	YES	—
Next subclauses	—	NO	—
10	MDS – MAU interface	—	—
10.1	General	Partial	Used when applicable
10.2 – 10.7	—	NO	—
10.8	Type 24: MDS – MAU interface: Twisted-pair wire medium	YES	—
Next subclauses	—	NO	—

Clause	Header	Presence	Constraints
11 – 32	—	NO	—
33	Type 24: Medium attachment unit: twisted-pair wire medium	YES	
Next clauses	—	NO	—
Annex A – R	—	NO	—
Annex S	Type 24: Connector specification	—	—
S.1	Overview	Partial	Used when applicable
S.2	Type 24-1 connector	YES	—
S.3	Type 24-2 connector	NO	—
S.4	Type 24-3 connector	NO	—
Annex T	—	NO	—
Annex U	Type 24: Media cable specifications and Network topologies	—	—
U.1	Type 24: MAU options: twisted-pair wire medium	NO	—
Next annexes	—	NO	—

4.2.2 Data-link layer

4.2.2.1 DLL service selection

4.2.2.1.1 Generic profile

Table 4 specifies the DLL service selection within IEC 61158-3-24 for this profile.

Table 4 – CP 19/1: DLL service selection

Clause	Header	Presence	Constraints
1	Scope	YES	—
2	Normative references	Partial	Used as needed
3	Terms, definitions, symbols, abbreviations and conventions	Partial	Used when applicable
4	Data-link service and concepts	—	—
4.1	Overview	YES	—
4.2	DLS-user services	—	—
4.2.1	General	YES	—
4.2.2	Write data	YES	—
4.2.3	Read data	YES	—
4.2.4	Send data with acknowledge service (SDA)	YES	Option
4.2.5	Send data with no acknowledge service (SDN)	NO	—
4.2.6	Event	YES	—
4.2.7	Get status	YES	—
4.3	Overview of interactions	YES	—
4.4	Detailed specification of services and interactions	—	—
4.4.1	Write data	YES	—
4.4.2	Read data	YES	—
4.4.3	Send data with acknowledge	YES	Option

Clause	Header	Presence	Constraints
4.4.4	Send data with no-acknowledge (SDN)	NO	—
4.4.5	Cyclic event	YES	—
5	DL-management service	—	—
5.1	Overview	—	—
5.1.1	General	YES	—
5.1.2	Reset	YES	—
5.1.3	Set value	YES	—
5.1.4	Get value	YES	—
5.1.5	Evaluate delay	NO	—
5.1.6	Set communication mode	NO	—
5.1.7	Start communication	YES	—
5.1.8	Clear error status	YES	—
5.1.9	DLM Event	YES	—
5.2	Overview of interactions	YES	—
5.3	Detailed specification of services and interactions	—	—
5.3.1	Reset	YES	—
5.3.2	Set value	YES	—
5.3.2.1	Function	YES	—
5.3.2.2	Types of parameters	—	—
5.3.2.2.1	General	YES	—
5.3.2.2.2	Var_ID	Partial	See 4.2.2.1.2 to 4.2.2.1.4
5.3.2.2.3	Val	Partial	See 4.2.2.1.2 to 4.2.2.1.4
5.3.2.2.4	Result	YES	—
5.3.3	Get value	—	—
5.3.3.1	Function	YES	—
5.3.3.2	Types of parameters	YES	—
5.3.3.2.1	General	YES	—
5.3.3.2.2	Var_ID	Partial	See 4.2.2.1.2 to 4.2.2.1.4
5.3.3.2.3	Val	Partial	See 4.2.2.1.2 to 4.2.2.1.4
5.3.3.2.4	Result	YES	—
5.3.4	Evaluate delay	NO	—
5.3.5	Set communication mode	NO	—
5.3.6	Start communication	YES	—
5.3.7	Clear error	YES	—
5.3.8	DLM error event	YES	—

4.2.2.1.2 Detail for C1 master

Table 5 specifies DLL service selection within IEC 61158-3-24 for C1 master of CP 19/1.

Table 5 – DLL service selection for C1 master of CP 19/1

Clause	Header	Presence	Constraints
5.3.2.2.2	Var_ID	—	—
5.3.2.2.2.1	General	—	—
5.3.2.2.2.2	MA	YES	—
5.3.2.2.2.3	Nmax_slaves	YES	—
5.3.2.2.2.4	Cyc_sel	YES	—
5.3.2.2.2.5	Nmax_dly_cnt	NO	—
5.3.2.2.2.6	IO_sz	YES	—
5.3.2.2.2.7	Pkt_sz	YES	Option
5.3.2.2.2.8	Nmax_retry	YES	—
5.3.2.2.2.9	Tcycle	YES	—
5.3.2.2.2.10	Tslot	YES	—
5.3.2.2.2.11	Tunit	NO	—
5.3.2.2.2.12	Tidly	NO	—
5.3.2.2.2.13	Tc2_dly	NO	—
5.3.2.2.2.14	IO_Map	NO	—
5.3.2.2.2.15	Line_code	NO	—
5.3.2.2.2.16	Baud_rate	NO	—
5.3.2.2.2.17	Tlatch	NO	—
5.3.2.2.2.18	Tcc_mul	NO	—
5.3.2.2.2.19	Tcc_pos	NO	—
5.3.2.2.3	Val	Partial	See Note
5.3.3.2.4	Result	Partial	See Note
NOTE Same as 5.3.2.2.2.1 to 5.3.2.2.2.19 in this table.			

4.2.2.1.3 Detail for C2 master

Table 6 specifies DLL service selection within IEC 61158-3-24 for C2 master of CP 19/1.

Table 6 – DLL service selection for C2 master of CP 19/1

Clause	Header	Presence	Constraints
5.3.2.2.2	Var_ID	—	—
5.3.2.2.2.1	General	—	—
5.3.2.2.2.2	MA	YES	—
5.3.2.2.2.3	Nmax_slaves	YES	—
5.3.2.2.2.4	Cyc_sel	YES	—
5.3.2.2.2.5	Nmax_dly_cnt	NO	—
5.3.2.2.2.6	IO_sz	YES	—
5.3.2.2.2.7	Pkt_sz	YES	Option
5.3.2.2.2.8	Nmax_retry	YES	—
5.3.2.2.2.9	Tcycle	YES	—
5.3.2.2.2.10	Tslot	YES	—
5.3.2.2.2.11	Tunit	NO	—
5.3.2.2.2.12	Tidly	NO	—
5.3.2.2.2.13	Tc2_dly	NO	—
5.3.2.2.2.14	IO_Map	NO	—
5.3.2.2.2.15	Line_code	NO	—
5.3.2.2.2.16	Baud_rate	NO	—
5.3.2.2.2.17	Tlatch	NO	—
5.3.2.2.2.18	Tcc_mul	NO	—
5.3.2.2.2.19	Tcc_pos	NO	—
5.3.2.2.3	Val	Partial	See Note
5.3.3.2.4	Result	Partial	See Note
NOTE Same as 5.3.2.2.2.1 to 5.3.2.2.2.19 in this table.			

4.2.2.1.4 Detail for slave

Table 7 specifies DLL service selection within IEC 61158-3-24 for slave of CP 19/1.

Table 7 – DLL service selection for slave of CP 19/1

Clause	Header	Presence	Constraints
5.3.2.2.2	Var_ID	—	—
5.3.2.2.2.1	General	—	—
5.3.2.2.2.2	MA	YES	—
5.3.2.2.2.3	Nmax_slaves	NO	—
5.3.2.2.2.4	Cyc_sel	NO	—
5.3.2.2.2.5	Nmax_dly_cnt	NO	—
5.3.2.2.2.6	IO_sz	YES	—
5.3.2.2.2.7	Pkt_sz	YES	Option
5.3.2.2.2.8	Nmax_retry	YES	—
5.3.2.2.2.9	Tcycle	YES	—
5.3.2.2.2.10	Tslot	NO	—
5.3.2.2.2.11	Tunit	NO	—
5.3.2.2.2.12	Tidly	NO	—
5.3.2.2.2.13	Tc2_dly	NO	—
5.3.2.2.2.14	IO_Map	NO	—
5.3.2.2.2.15	Line_code	NO	—
5.3.2.2.2.16	Baud_rate	NO	—
5.3.2.2.2.17	Tlatch	NO	—
5.3.2.2.2.18	Tcc_mul	NO	—
5.3.2.2.2.19	Tcc_pos	NO	—
5.3.2.2.3	Val	Partial	See Note
5.3.3.2.4	Result	Partial	See Note
NOTE Same as 5.3.2.2.2.1 to 5.3.2.2.2.19 in this table.			

4.2.2.2 DLL protocol selection

4.2.2.2.1 Generic profile

Table 8 specifies the DLL protocol selection within IEC 61158-4-24 for this profile.

Table 8 – CP 19/1: DLL protocol selection

Clause	Header	Presence	Constraints
1	Scope	YES	—
2	Normative references	Partial	Used as needed
3	Terms, definitions, symbols, abbreviations and conventions	Partial	Used when applicable
4	Overview of DL-protocol	—	—
4.1	Characteristic feature of DL-protocol	YES	—
4.2	DL layer component	YES	—
4.3	Timing sequence	—	—