



BSI Standards Publication

Energy management system application program interface (EMS-API)

Part 600-1: Common Grid Model Exchange Standard
(CGMES) — Structure and rules

National foreword

This British Standard is the UK implementation of EN IEC 61970-600-1:2021. It is identical to IEC 61970-600-1:2021. It supersedes PD IEC/TS 61970-600-1:2017, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PEL/57, Power systems management and associated information exchange.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 539 02454 8

ICS 33.200

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 August 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

English Version

Energy management system application program interface
(EMS-API) - Part 600-1: Common Grid Model Exchange
Standard (CGMES) - Structure and rules
(IEC 61970-600-1:2021)

Interface de programmation d'application pour système de
gestion d'énergie (EMS-API) - Partie 600-1: Spécification
pour l'échange de modèle de réseau commun (CGMES) -
Structure et règles
(IEC 61970-600-1:2021)

Schnittstelle der Anwendungsprotokolle von
Energieverwaltungssystemen (EMS-API) - Teil 600-1:
Spezifikation für den Austausch von
Elektrizitätsversorgungssystemmodellen (CGMES) -
Strukturen und Regeln
(IEC 61970-600-1:2021)

This European Standard was approved by CENELEC on 2021-07-09. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 57/2366/FDIS, future edition 1 of IEC 61970-600-1, prepared by IEC/TC 57 “Power systems management and associated information exchange” was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61970-600-1:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2022-04-09
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2024-07-09

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61970-600-1:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61970-501:2006 NOTE Harmonized as EN 61970-501:2006 (not modified)

IEC 61970-452 NOTE Harmonized as EN 61970-452

IEC 61970-453 NOTE Harmonized as EN 61970-453

IEC 61970-456 NOTE Harmonized as EN IEC 61970-456

IEC 61968-13 NOTE Harmonized as EN IEC 61968-13

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61970-301	2020	Energy management system application program interface (EMS-API) - Part 301: Common information model (CIM) base	EN IEC 61970-301	2020
IEC 61970-302	2018	Energy management system application program interface (EMS-API) - Part 302: Common information model (CIM) dynamics	EN IEC 61970-302	2018
IEC 61970-552	2016	Energy management system application program interface (EMS-API) - Part 552: CIMXML Model exchange format	EN 61970-552	2016

This page deliberately left blank

CONTENTS

FOREWORD	4
INTRODUCTION	7
1 Scope	8
2 Normative references	9
3 Terms, definitions and abbreviated terms	10
3.1 Terms and definitions	10
3.2 Abbreviated terms	11
4 Data exchange context	12
5 Specifications and functionalities	15
5.1 General constraints	15
5.2 Model authority sets (MAS)	17
5.3 File header	18
5.4 File body	19
5.5 Profiles and instance file types	19
5.5.1 General	19
5.5.2 CGMES profiles' properties	19
5.5.3 CGMES extensions	21
5.5.4 Equipment profile and instance file	22
5.5.5 Topology profile and instance file	23
5.5.6 Steady state hypothesis profile and instance file	23
5.5.7 State variables profile and instance file	24
5.5.8 Equipment boundary profile and instance file	24
5.5.9 Topology boundary profile and instance file	24
5.5.10 Diagram layout profile and instance file	24
5.5.11 Geographical location profile and instance file	25
5.5.12 Dynamics profile and instance file	25
5.6 File exchange	26
5.7 Boundary point – properties and location	27
5.8 Model merging process	29
5.9 CIM XML document/distribution validity	32
5.10 Naming Convention	33
6 CGMES governance	36
6.1 General	36
6.2 Versions of the CGMES and the profiles	37
6.3 Conformity assessment	38
6.4 Implementation process	38
Annex A (xxxx)	39
Annex B (normative) File header guidelines	40
B.1 General	40
B.2 Exchange scenarios	40
B.3 Examples	41
B.3.1 Example 1: File header of full model	41
B.3.2 Example 2: File header of full model that is depending on another model	42
B.3.3 Example 3: File header of full model that is depending on a model and supersedes another model	43

B.3.4	Example 4: File header of difference model that is depending on a full model and supersedes another full model.....	44
B.3.5	Example 5: File header of difference model that is depending on a difference model and supersedes another difference model.....	45
Bibliography.....		47
Figure 1 – CGMES instance file dependency		20
Figure 2 – Boundary point placed on a tie-line		27
Figure 3 – Boundary point placed in a substation		27
Figure 4 – HVDC as interconnection or internal line		28
Figure 5 – HVDC grid.....		28
Figure 6 – Merge process		31
Figure B.1 – Example workflow events.....		40
Table 1 – IdentifiedObject attributes		36
Table 2 – IdentifiedObject attributes in EQBD profile		36

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ENERGY MANAGEMENT SYSTEM APPLICATION
PROGRAM INTERFACE (EMS-API) –****Part 600-1: Common Grid Model Exchange Standard (CGMES) –
Structure and rules**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61970-600-1 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This first edition cancels and replaces IEC TS 61970-600-1 published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TS 61970-600-1:2017:

- Terms and definitions were updated.
- The “Type” column in all tables was deleted to increase readability of the document as all the rules are considered required, hence categorisation is not necessary.
- Requirement HGEN4 was added to define additional rules to the file header compared to IEC 61970-552:2016.

- Annex B on “Summary of specific rules for naming conventions” is deleted as the information was either integrated in the UML or considered outdated.
- Annex D referring to the PST modelling is deleted as it will be fully integrated in IEC 61970-301:2020+AMD1¹.
- Annex E “Implementation guide” is deleted as all rules and implementation guidance is or will be integrated in either Clause 5 of this document or IEC 61970-301:2020 (and its future Amendment 1) or IEC 61970-452 or IEC 61970-456 as referenced by this document. Note that former Subclause E.11.2 on ConformLoadGroup and NonConformLoadGroup was implemented differently due to another issue, please refer to IEC 61970-600-2:2020.
- Rules GENC17, GENC18, GENC19, EQ__4, EQ__5, SV__4, BPPL12, BPPL13, MVAL5, EXCH9, TP__4 and MARP12 were added.
- Rules GENC3, GENC6, PROF2, PROF4, PROF5, PROF8, PROF9, EXCH5, EXCH6, EXCH7, MAS_4, MAS_6, MAS_9, MAS_10, MAS_11, MAS_13, EQ__1, HREF2, HREF3, HREF5, MVAL3, TPBD1, TPBD2, BPPL10, NAMC12 and NAMC13 are deleted as they are considered not relevant due to other changes.
- The following rules were modified: GENC1, GENC2, GENC4, GENC5, GENC7, GENC8, GENC9, GENC10, GENC16, EQBD2, BPPL11, EXCH2, EXCH3, EXCH8, FBOD3, FBOD5, PROF10, PROF11, MAS_1, MAS_8, HGEN3, HREF1, EEXT1, EQ__2, TP__1, TP__2, TP__3, MARP10, MARP11, NAMC1, NAMC4, NAMC11, NAMC14, BPPL1, BPPL2 and BPPL3.
- Explicit equipment boundary profile definition (EQBD) has been deprecated (refer to Subclause 4.6.5 of IEC 61970-301:2020 and future Amendment 1 for details on deprecations) in this edition in favour of using its full profile counterpart (EQ) for exchange of boundary datasets. The topology boundary profile (TPBD) is not included in the CGMES as TP is considered output and therefore it is no need to exchange Topology information part of the boundary model authority set.
- Annex F has been deleted.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
57/2366/FDIS	57/2382/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts in the IEC 61970 series, published under the general title *Energy management system application program interface (EMS-API)*, can be found on the IEC website.

¹ An amendment to IEC 61970-301:2020 is currently under consideration.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The purpose of this document is to define the Common Grid Model Exchange Standard (CGMES) based on Common Information Model (CIM) standards defined in IEC 61970-series, IEC 61968-series and IEC 62325-series and to address requirements defined by the European legislation. However, the document is not limited to the European legislation requirements and business processes, it is created to support data exchange between applications that support power system model management and analysis. The data exchange can be between internal applications or between applications at System Operators (SO) and Regional Coordination Centre (RCC). This covers DSO-DSO, DSO-TSO, TSO-TSO, TSO-RCC/ISO/RTO and RCC-RCC interfaces, but not limited to these.

The CGMES is created to address the information exchange requirements provided in Common Grid Model methodologies (CGMm) in accordance with the legal requirements stated in various European network codes guidelines. The CGMES applies to applications dealing with power system data management, as well as applications supporting the following analyses:

- power flow and contingency analyses,
- short circuit calculations,
- market information and transparency,
- capacity calculation for capacity allocation and congestion management, and
- dynamic security assessment.

The conformity of applications used for system operation and system development data exchanges with the CGMES is crucial for the needed interoperability of these applications. This document provides the grouping of all principle requirements for the CGMES Conformity Assessment Framework and the guiding principles for assessing applications' CGMES conformity. The description of the CGMES Conformity Assessment Process is currently not part of the IEC 61970-600-series, but it is planned to be included as an international standard in order to validate that the CGMES is correctly implemented by suppliers of the applications used by system operators (ISO/TSO/DSO etc) and for Regional Coordination Centres (RCCs).

ENERGY MANAGEMENT SYSTEM APPLICATION PROGRAM INTERFACE (EMS-API) –

Part 600-1: Common Grid Model Exchange Standard (CGMES) – Structure and rules

1 Scope

This part of IEC 61970, which covers the definition of Common Grid Model Exchange Standard (CGMES), defines the main rules and application's requirements to meet business requirements for assembled and merged model to fit relevant business services. This document does not define the business requirements, business processes nor how applications are implemented. This document defines how relevant Common Information Model (CIM) standards work together so that specific business requirements can be resolved.

It also includes extensions to the Common Information Model (CIM). The current extensions are defined in IEC 61970-301:2020 and will be covered in its future Amendment 1, but additional extensions can be defined in other standards in the IEC 61970-600-series. The extensions can be used to define additional profiles or to expand IEC 61970-450-series or IEC 61968-13 profiles. However, primary CGMES includes additional constraints on existing profiles and validation of assembled and merged models that is based on existing profiles. This can be done by making optional attributes and associations mandatory (required).

In addition, this document includes the specification of the serialisation that must be supported by referring to an existing standard defined in IEC 61970-550-series, e.g., IEC 61970-552, and making relevant constraints related to it.

The goal is to achieve interoperability between applications using CGMES in a high-performance environment with combined minimum effort so that relevant business processes are satisfied.

An overview of IEC 61970-600 series is provided in the following table, which also presents identified needs that are not yet addressed.

Part	Description	Scope
61970-600-1	Structure and rules. This part defines the structure of the series of standard and the rules that needs to be applied on the assembled and merged models that are defined by the different profile standards.	In the scope
61970-600-2	Exchange profiles specification. This part defines the IEC 61970-450-series and IEC 61968-13 related profiles that are included in CGMES. It includes the references to published standards and additional constraints defined to the relevant standard. If the relevant edition of a standard is not published, it also includes the profile definition and the standard's constraints.	In the scope
to be defined (TBD)	Information extension. This part defines additional information model that is not included in the relevant edition of IEC 61970-301, IEC 61970-302 or IEC 61968-11 that is needed to meet business requirement.	Identified as a need and not yet addressed neither in this document nor in IEC 61970-600 series
to be defined (TBD)	Extended exchange profiles specification. This part defines additional profiles that is not included in IEC 61970-450-series and IEC 61968-13 that is needed to meet business requirement.	
to be defined (TBD)	Conformity Assessment Scheme (CAS). This part defines the Conformity Assessment Scheme (CAS) including test use cases and references to test configurations to evaluate if an application tool conforms to the CGMES.	

Clause 4, Data exchange context, describes the context the CGMES is developed to support.

Clause 5, Specifications and functionalities, defines the rules that shall be applied for validating a model part, an assembled and a merged model. When the rule is defined in the relevant profile it will include a reference to the rule.

Clause 6, CGMES governance, defines the governance of CGMES and the version strategy.

Annex A is left blank.

Annex B (normative), File header guidelines, explains the usage of the file header that is defined in IEC 61970-552.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61970-552:2016, *Energy management system application program interface (EMS-API) – Part 552: CIMXML Model exchange format*

IEC 61970-301:2020, *Energy management system application program interface (EMS-API) – Part 301: Common information model (CIM) base*

IEC 61970-302:2018, *Energy management system application program interface (EMS-API) – Part 302: Common information model (CIM) dynamics*

3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms, definitions and abbreviated terms apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

NOTE For definitions which are not specified in the CGMES the definitions in the IEC 61970 standard series shall be applied.

3.1 Terms and definitions

3.1.1

assembled model

model of a Model Authority Set with internal references resolved

3.1.2

boundary point

BP

connection point between two Model Authority Sets, that has been agreed on by both relevant Model Authority

3.1.3

boundary set

set containing all boundary points necessary for a merge model

3.1.4

CIM XML document/distribution

instance file which is serialised according to IEC 61970-552

3.1.5

distribution

specific representation of a dataset. A dataset might be available in multiple serializations that may differ in various ways, including natural language, media-type or format, schematic organization, temporal and spatial resolution. The level of detail in the distribution is defined by one or more profiles that the dataset conforms to

3.1.6

Common Grid Model Exchange Standard

CGMES

collection of standards defined in IEC 61970-600 series that support the exchange of power system models (e.g. individual grid model or common grid model) between model authorities (TSOs, DSOs, etc.) for the purpose of coordinated set of services to be performed on the same model according to legislation or general data exchanges in the frame of system operation, system development or utilities' projects

3.1.7

European extensions

collection of classes, attributes and associations, which either extend or are defined in the standard IEC CIM model (IEC 61970-300 series, IEC 91968-11 and IEC 62325-300 series). The European extensions aim at satisfying requirements by the European legislation hence not necessarily applicable to other continents. The worldwide adoption of these extensions may not be exactly the same as the defined extension

3.1.8**external references resolved**

no dangling references are present across the models of Model Authority Sets

3.1.9**header references resolved**

references defined in model header are resolved

3.1.10**internal references resolved**

no dangling references are present within the model of a Model Authority Set

3.1.11**merged model**

model that is a union of different assembled models with external and header references resolved

3.1.12**profile**

data model to describe instance file for exchange of CIM data. A profile is a subset of classes, associations and attributes needed to accomplish a specific type of interface and based upon a CIM data model. Profiles may impose stricter rules on original classes and associations. A profile is usually converted to schema (XSD, RDF, OWL, etc.) that can be used to create, read and validate instance files for data exchange

Note 1 to entry: This term may be used to define either the semantic model for an instance data payload or the syntactic schema for an instance data payload. A profile may be expressed in XSD, RDF, and/or OWL files. An instance data conforming to a profile can be tested in exchanges between applications. A profile is necessary in order to “use” the canonical model.

3.1.13**solved model**

model containing instance of State Variables (SV)

3.2 Abbreviated terms

BP	Boundary point
CIM	Common Information Model (electricity)
CGMES	Common Grid Model Exchange Standard
DL	Diagram Layout profile
DSO	Distribution System Operator
DY	Dynamics profile
ENTSO-E	European Network of Transmission System Operators for Electricity
EQ	Core Equipment profile
EQBD	Equipment Boundary profile
GL	Geographical Location profile
HVDC	High Voltage Direct Current
IEC	The International Electrotechnical Commission, headquartered in Geneva
IOP	Interoperability Test
ISO	Independent System Operator
MAS	Model Authority Set
mRID	CIM Master Resource Identifier
OCL	Object Constraint Language

OP	Operation profile
OWL	Web Ontology Language
RCC	Regional Coordination Centres
RDF	Resource Description Framework
RDFS	RDF Schema
SC	Short-Circuit profile
SHACL	Shapes Constraint Language
SSH	Steady State Hypothesis profile
SV	State Variables profile
TP	Topology profile
TSO	Transmission System Operator
URI	Uniform Resource Identifier
UUID	Universally Unique Identifier
XML	Extensible Markup Language
XSD	XML Schema Definition

4 Data exchange context

There are various levels at which an exchange of power system data/models is necessary. A pan-European model exchange level covers the territory of all system operators (TSOs and DSOs). Regional model exchanges can be realised between different TSOs in one or more synchronous areas. A model exchange on the national level includes interfaces between TSOs (in case there are multiple TSOs on a national level) as well as between different DSOs.

The purpose of model exchanges is not only to exchange the data from one authority to another but also to satisfy the ultimate goal, namely, to perform common studies using shared data. All parties involved in the process should be able to perform the same types of studies and share project tasks between different parties which are using different power system analysis applications. Indeed, the interoperability between different applications used in the exchange process is therefore crucial in both reaching seamless data exchange and obtaining comparable study results when using this data.

The CGMES covers these European and system operators (TSOs and DSOs) business processes by defining the following main types of exchanges valid for a particular study or process:

- Exchange of boundary set: An exchange of a boundary Set is necessary to prepare an exchange of an internal system operator model and to merge a common grid model. E.g. the ENTSO-E Network Modelling Database (NMD) is used to maintain the Boundary Set covering the pan-European area where all TSOs negotiate and agree on the boundary information.