



BSI Standards Publication

Digital addressable lighting interface

Part 104: General requirements — Wireless and
alternative wired system components

National foreword

This British Standard is the UK implementation of EN IEC 62386-104:2019+A1:2024. It is identical to IEC 62386-104:2019, incorporating amendment 1:2023. It supersedes BS EN IEC 62386-104:2019, which will be withdrawn on 17 January 2027.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to IEC text carry the number of the IEC amendment. For example, text altered by IEC amendment 1 is indicated by A1 A1.

The UK participation in its preparation was entrusted to Technical Committee CPL/34/3, Auxiliaries for lamps.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2024
Published by BSI Standards Limited 2024

ISBN 978 0 539 26860 7
ICS 29.140.50; 29.140.99

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2019.

Amendments/corrigenda issued since publication

Date	Text affected
29 February 2024	Implementation of IEC amendment 1:2023 with CENELEC endorsement A1:2024

English Version

**Digital addressable lighting interface - Part 104: General
requirements - Wireless and alternative wired system
components
(IEC 62386-104:2019)**

Interface adressable d'éclairage numérique - Partie 104 :
Exigences générales - Composants de système à
connexion alternative ou sans fil
(IEC 62386-104:2019)

Digital adressierbare Schnittstelle für die Beleuchtung - Teil
104: Allgemeine Anforderungen - Funk- und alternative
kabelgebundene Systemkomponenten
(IEC 62386-104:2019)

This European Standard was approved by CENELEC on 2019-06-24. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 34/600/FDIS, future edition 1 of IEC 62386-104, prepared by SC 34C "Auxiliaries for lamps" of IEC/TC 34 "Lamps and related equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62386-104:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-03-24
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-06-24

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62386-104:2019 was approved by CENELEC as a European Standard without any modification.

European foreword to Amendment 1

The text of document 34/1048/CDV, future IEC 62386-104/AMD1, prepared by IEC/TC 34 "Lighting" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62386-104:2019/A1:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2024-10-17
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2027-01-17

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62386-104:2019/AMD1:2023 was approved by CENELEC as a European Standard without any modification.

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62386-101	2014	Digital addressable lighting interface - Part 101: General requirements - System components	EN 62386-101	2014
+ A1	2018		+ A1	2018
IEC 62386-102	2014	Digital addressable lighting interface - Part 102: General requirements - Control gear	EN 62386-102	2014
+ A1	2018		+ A1	2018
IEC 62386-103	2014	Digital addressable lighting interface - Part 103: General requirements - Control devices	EN 62386-103	2014
+ A1	2018		+ A1	2018
-	-	Bluetooth® Specification - Mesh Protocol ¹ , available at https://www.bluetooth.com/	-	-
-	-	Bluetooth® Document - Assigned Numbers, available at https://www.bluetooth.com/	-	-

7.6.2	Frame format (32-bit forward frame)	23
7.6.3	Payload (32-bit forward frame).....	23
7.7	32-bit reply frame.....	24
7.7.1	General	24
7.7.2	Frame format (32-bit reply frame)	24
7.7.3	Payload (32-bit reply frame)	24
8	Timing	24
9	Method of operation.....	24
9.1	Dealing with frames and commands	24
9.2	Collision avoidance, collision detection and collision recovery	25
9.3	Transactions	25
9.3.1	General	25
9.3.2	Transactions of forward frames.....	25
9.3.3	Transactions of backward frames	25
9.4	Send-twice forward frames and send-twice commands	25
9.5	Command iteration.....	25
9.6	Usage of a shared interface	26
9.6.1	General	26
9.6.2	Backward frames	26
9.6.3	Forward frames	26
9.7	Addressing.....	26
9.8	Frame decoding and command execution	26
9.8.1	General	26
9.8.2	Decoding and execution of control gear forward frames.....	27
9.8.3	Decoding of control gear backward frames	27
9.8.4	Decoding and execution of control device forward frames.....	27
9.8.5	Decoding of control device backward frames	28
9.8.6	Decoding and execution of 32-bit forward frames	28
9.8.7	Decoding and execution of 32-bit backward frames	28
9.9	System failure	28
10	Declaration of variables	28
11	Definition of commands	29
11.1	Additional commands for telecommunication control gear	29
11.2	Additional commands for telecommunication control devices	29
11.3	Configuration instructions	30
11.3.1	General	30
11.3.2	SET POWER ON DELAY (<i>DTR0</i>)(telecommunication control gear only)	30
11.4	Queries.....	30
11.5	Special commands.....	30
11.5.1	QUERY SYSTEM ADDRESS	30
11.5.2	PROGRAM SYSTEM ADDRESS (<i>data</i>)	31
11.5.3	DELAY SYSTEM FAILURE (<i>data</i>).....	31
Annex A (informative)	Examples of telecommunication frames.....	32
A.1	Control gear forward frames.....	32
A.2	Control gear backward frames	33
A.3	Control device forward frames	34
A.4	Control device backward frames	35
Annex B (normative)	Underlying telecommunication protocols	38

B.1	General.....	38
B.2	Bluetooth® Mesh	38
B.2.1	Overview	38
B.2.2	System addresses	38
B.2.3	Transactions and frames	38
B.2.4	Hardware address	39
B.2.5	Receive signal strength indicator (RSSI).....	39
B.2.6	System failure.....	39
B.2.7	Bluetooth® Mesh composition data.....	39
B.3	VEmesh™	39
B.3.1	Overview	39
B.3.2	System addresses	40
B.3.3	Transactions and frames	40
B.3.4	Address allocation	40
B.3.5	Receive signal strength indicator (RSSI).....	40
B.3.6	System failure detection	41
B.4	Distributed PLC bus (DPB).....	41
B.4.1	Overview	41
B.4.2	System addresses	41
B.4.3	Transactions and frames	41
B.4.4	Hardware address	41
B.5	User datagram protocol (UDP)	42
B.5.1	Overview	42
B.5.2	UDP port number.....	42
B.5.3	Forward data packet structure	42
B.5.4	Backward data packet structure.....	42
B.5.5	Simple acknowledgement packet structure	43
B.5.6	System addresses	44
B.5.7	Transactions and frames	44
B.5.8	Hardware address	45
B.5.9	System failure.....	45
B.5.10	Security	45
Annex C (informative)	Example of address allocation.....	46
C.1	Overview.....	46
C.2	Discover all used system addresses	46
C.3	Allocate short addresses.....	46
Annex D (informative)	Examples of telecommunication system architectures	48
D.1	Single application controller	48
D.2	Multiple application controllers.....	48
D.3	Multiple subnets.....	49
Bibliography		51
Figure 1 – IEC 62386 graphical overview		8
Figure 2 – Telecommunication system structure example		13
Figure 3 – Example of communication between telecommunication units		14
Figure 4 – Start up timing example		17
Figure D.1 – Example of a telecommunication system with a single application controller and control gear		18

Figure D.2 – Example of an architecture with multiple application controllers	49
---	----

Figure D.3 – Example of an architecture with multiple subnets	50
---	----

Table 1 – System components	12
-----------------------------------	----

Table 2 – Transmitters and receivers in telecommunication units	15
---	----

Table 3 – Start-up timing	17
---------------------------------	----

Table 4 – Power on timing	17
---------------------------------	----

Table 5 – Telecommunication frame types	18
---	----

Table 6 – Control gear forward frame	19
--	----

Table 7 – Control gear backward frame	19
---	----

Table 8 – Control device forward frame	21
--	----

Table 9 – Control device backward frame	22
---	----

Table 10 – 32-bit forward frame	23
---------------------------------------	----

Table 11 – 32-bit reply frame	24
-------------------------------------	----

Table 12 – Declaration of variables	29
---	----

Table 13 – Additional commands for telecommunication control gear	29
---	----

Table 14 – Additional commands for telecommunication control devices	29
--	----

Table A.1 – Example of control gear forward frame	32
---	----

Table A.2 – Examples of control gear backward frames	33
--	----

Table A.3 – Example of control device forward frame	34
---	----

Table A.4 – Example of control device backward frame	35
--	----

Table A.5 – Example of control device backward frame (continued)	35
--	----

Table A.6 – Example of control device backward frame	36
--	----

Table A.7 – Example of control device backward frame (continued)	36
--	----

Table B.1 – UDP forward data packet	42
---	----

Table B.2 – UDP backward data packet	43
--	----

Table B.3 – ADU error codes	43
-----------------------------------	----

Table B.4 – UDP simple acknowledge packet	44
---	----

INTERNATIONAL ELECTROTECHNICAL COMMISSION

DIGITAL ADDRESSABLE LIGHTING INTERFACE –

Part 104: General requirements – Wireless and alternative wired system components

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 62386-104 edition 1.1 contains the first edition (2019-05) [documents 34/600/FDIS and 34/611/RVD] and its amendment 1 (2023-12) [documents 34/1048/CDV and 34/1131/RVC].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 62386-104 has been prepared by IEC technical committee 34: Lamps and related equipment.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This Part 104 of IEC 62386 is intended to be used in conjunction with:

- Part 101, which contains general requirements for system components;
- Part 102, which contains general requirements for the relevant product type (control gear), and with the appropriate Parts 2xx (particular requirements for control gear);
- Part 103, which contains general requirements for the relevant product type (control devices), and the appropriate Parts 3xx (particular requirements for control devices).

A list of all parts in the IEC 62386 series, published under the general title: *Digital addressable lighting interface*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 62386 contains several parts, referred to as series. The IEC 62386-1xx series includes the basic specifications. Part 101 contains general requirements for system components, Part 102 extends this information with general requirements for control gear and Part 103 extends it further with general requirements for control devices.

The IEC 62386-2xx series extends the general requirements for control gear with lamp specific extensions (mainly for backward compatibility with Edition 1 of IEC 62386) and with control gear specific features.

The IEC 62386-3xx series extends the general requirements for control devices with input device specific extensions describing the instance types as well as some common features that can be combined with multiple instance types.

This first edition of IEC 62386-104 is intended to be used in conjunction with IEC 62386-101, IEC 62386-102 and the various parts that make up the IEC 62386-2xx series for control gear, and with IEC 62386-103 and the various parts that make up the IEC 62386-3xx series of particular requirements for control devices. The division into separately published parts provides for ease of future amendments and revisions. Additional requirements will be added as and when a need for them is recognised.

The setup of the standards is graphically represented in Figure 1.




Figure 1 – IEC 62386 graphical overview

When this part of IEC 62386 refers to any of the clauses of the other parts of the IEC 62386-1xx series, the extent to which such a clause is applicable and the order in which the tests are to be performed are specified. The other parts also include additional requirements, as necessary.

All numbers used in this document are decimal numbers unless otherwise noted. Hexadecimal numbers are given in the format 0xVV, where VV is the value. Binary numbers are given in the format XXXXXXXXXb or in the format XXXX XXXX, where X is 0 or 1; "x" in binary numbers means "don't care".

The following typographic expressions are used:

Variables: “*variableName*” or “*variableName[3:0]*”, giving only bits 3 to 0 of “*variableName*”.

Range of values: [lowest, highest]

Command: “COMMAND NAME”

DIGITAL ADDRESSABLE LIGHTING INTERFACE –

Part 104: General requirements – Wireless and alternative wired system components

1 Scope

The IEC 62386 series specifies a bus system for control by digital signals of electronic lighting equipment. This part of IEC 62386 applies to a system with wireless or alternative wired communication between its units, instead of a wired bus system, where the meaning of “wireless or alternative wired communication”, or in short “telecommunication”, is any type of communication network different from the wired system described in IEC 62386-101.

Where the electronic lighting equipment is covered by the scope of IEC 61347 (all parts), it is in line with the requirements of IEC 61347 (all parts), with the addition of DC supplies.

NOTE the definition of “telecommunication” applies only to this document and differs from the IEC Electropedia term in IEC 60050-701:1988, 701-01-05.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62386-101:2014, *Digital addressable lighting interface – Part 101: General requirements – System components*
IEC 62386-101:2014/AMD1:2018

IEC 62386-102:2014, *Digital addressable lighting interface – Part 102: General requirements – Control gear*
IEC 62386-102:2014/AMD1:2018

IEC 62386-103:2014, *Digital addressable lighting interface – Part 103: General requirements – Control devices*
IEC 62386-103:2014/AMD1:2018

 Bluetooth® Specification – Mesh Protocol¹, available at <https://www.bluetooth.com/>

Bluetooth® Document – Assigned Numbers, available at <https://www.bluetooth.com/> 

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62386-101 and the following apply.

¹ Bluetooth® is the trademark of a product supplied by Bluetooth SIG, Inc. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the product named.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

telecommunication

communication method that may or may not require connection by wires, excluding the communication system described in IEC 62386-101

3.2

telecommunication unit

logical unit or combination of logical units, containing one telecommunication interface

3.3

telecommunication interface

physical transmitter or transceiver for communication

3.4

telecommunication system

two or more telecommunication units using the same underlying telecommunication protocol, configured with the same system address if available, and so able to communicate with each other

3.5

control gear

device that receives commands according to IEC 62386-102, but with a telecommunication interface described in IEC 62386-104, instead of a wired interface as described in IEC 62386-101

3.6

control device

device that sends commands according to IEC 62386-103, but with a telecommunication interface described in IEC 62386-104, instead of a wired interface as described in IEC 62386-101

3.7

application controller

control device according to IEC 62386-103, but with a telecommunication interface described in IEC 62386-104, instead of a wired interface as described in IEC 62386-101

3.8

input device

control device according to IEC 62386-103, but with a telecommunication interface described in IEC 62386-104, instead of a wired interface as described in IEC 62386-101

3.9

system failure

loss of communications described in the underlying telecommunication protocol

Note 1 to entry: See Annex B.

3.10

underlying telecommunication protocol

protocol for encapsulation and transportation of frames

Note 1 to entry: The protocol is described in Annex B and the frames in Clause 7.

4 General

4.1 Purpose

The standardization of the digital addressable lighting interface is intended to achieve interoperable multi-vendor operation below the level of building management systems.

EN 50491 and ISO 14672 are not applicable for the purposes of this document.

IEC 62386-101:2014, 4.1 applies.

4.2 Version number

The requirements of IEC 62386-101:2014 and IEC 62386-101:2014/AMD1:2018, 4.2 apply, except “101” shall be replaced by “104”.

4.3 System structure and architecture

A system shall consist of the components listed in Table 1.

Table 1 – System components

Component	Quantity	For detailed information see
control gear	≥ 0	IEC 62386-102
application controller	≥ 1	IEC 62386-103
input devices	≥ 0	IEC 62386-103

Where in IEC 62386-102, IEC 62386-103, the IEC 62386-2xx or IEC 62386-3xx series, reference is made to IEC 62386-101:2014 and IEC 62386-101:2014/AMD1:2018, the reference shall instead be redirected to the respective clauses of this document.

All telecommunication units within the same telecommunication system shall be capable of transmitting and receiving through their telecommunication interface.

NOTE As a consequence of the above, every frame is visible to all control gear and control devices in the same telecommunication system.

If there are several co-located systems, such as within the same RF reception range or on the same PLC line, the frames of one telecommunication system shall be visible only by the telecommunication interfaces of that specific system.

Figure 2 shows an example of a telecommunication system structure.





Figure 2 – Telecommunication system structure example

See Annex D for information on possible telecommunication system architectures.

NOTE The interface of all the telecommunication system units in Figure 2 uses the same underlying telecommunication protocol, as defined in 3.4.

4.4 System information flow

Figure 3 shows the different frame types that are used for communication between the telecommunication units in a telecommunication system. A backward frame is only ever transmitted in response to a forward frame.



IEC

Figure 3 – Example of communication between telecommunication units

Within the telecommunication system, there shall be no direct information flow between input devices and control gear.

NOTE A system conforming to this document may consist of an application controller and control gear only – see Clause D.1. In such a system, user input need not result in transmission of forward frames.

4.5 Command types

The requirements of IEC 62386-101:2014, 4.5 apply.

4.6 Telecommunication units

4.6.1 General

The telecommunication unit shall implement one of the underlying telecommunication protocols as listed in Annex B. All telecommunication units of a telecommunication system shall use the same underlying telecommunication protocol (see definition 3.4).

4.6.2 Telecommunication transmitters and receivers in telecommunication units

Table 2 summarizes the types of frames that the different types of telecommunication units may transmit or receive.