BRITISH STANDARD

BS EN ISO 16484-5:2008 +A1:2009

Building automation and control systems —

Part 5: Data communication protocol

ICS 35.240.99; 91.040.01

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

BSI Documents Document Sharing Hub British Standards

Full document details: BS EN ISO 16484-5:2008+A1:2009

National foreword

This British Standard is the UK implementation of EN ISO 16484-5:2008+A1:2009. It is identical to ISO 16484-5:2007, incorporating amendment 1:2009. It supersedes BS EN ISO 16484-5:2008 which is withdrawn.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to ISO text carry the number of the ISO amendment. For example, text altered by ISO amendment 1 is indicated by 〉A1〈.

The UK participation in its preparation was entrusted to Technical Committee RHE/16, Performance requirements for control systems.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

Amendments/corrigenda issued since publication

Date	Comments
30 April 2010	Implementation of ISO amendment 1:2009 with CEN endorsement A1:2009

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 March 2008

© BSI 2010

ISBN 978 0 580 65978 2

AVA Documents Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN ISO 16484-5:2008+A1

May 2009

ICS 91.040.01; 35.240.99

Supersedes EN ISO 16484-5:2003

English Version

Building automation and control systems - Part 5: Data communication protocol (ISO 16484-5:2007)

Systèmes d'automatisation et de gestion technique du bâtiment - Partie 5: Protocole de communication de données (ISO 16484-5:2007)

Systeme der Gebäudeautomation - Teil 5: Datenkommunikationsprotokoll (ISO 16484-5:2007)

This European Standard was approved by CEN on 14 January 2008.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

© 2008 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. EN ISO 16484-5:2008: E

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

Foreword

The text of ISO 16484-5:2007 has been prepared by Technical Committee ISO/TC 205 “Building environment design” of the International Organization for Standardization (ISO) and has been taken over as EN ISO 16484-5:2008 by Technical Committee CEN/TC 247 “Building Automation, Controls and Building Management” the secretariat of which is held by SNV.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2008, and conflicting national standards shall be withdrawn at the latest by August 2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 16484-5:2003.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Endorsement notice

The text of ISO 16484-5:2007 has been approved by CEN as a EN ISO 16484-5:2008 without any modification.

Foreword to amendment A1

This document (EN ISO 16484-5:2008/A1:2009) has been prepared by Technical Committee ISO/TC 205 "Building environment design" in collaboration with Technical Committee CEN/TC 247 “Building Automation, Controls and Building Management” the secretariat of which is held by SNV.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2009, and conflicting national standards shall be withdrawn at the latest by November 2009.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Endorsement notice

The text of ISO 16484-5:2007/Amd 1:2009 has been approved by CEN as a EN ISO 16484-5:2008/A1:2009 without any modification.

AVA Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

Building automation and control systems —

Part 5:
Data communication protocol

1 Scope

This part of ISO 16484 defines data communication services and protocols for computer equipment used for monitoring and control of heating, ventilation, air-conditioning and refrigeration (HVAC&R) and other building systems. It defines, in addition, an abstract, object-oriented representation of information communicated between such equipment, thereby facilitating the application and use of digital control technology in buildings. The scope and field of application are furthermore detailed in Clause 2 of the enclosed ANSI/ASHRAE publication.

2 Requirements

Requirements are the technical recommendations made in the following publication (reproduced on the following pages), which is adopted as an International Standard:

> ANSI/ASHRAE 135-2004, *A Data Communication Protocol for Building Automation and Control Networks*

The text on the back of the title page of the ANSI/ASHRAE standard and the policy statement on the last page are not relevant for the purposes of international standardization.

The following International Standards are cited in the text:

ISO/IEC 7498 (all parts), *Information technology — Open Systems Interconnection — Basic Reference Model*

ISO/TR 8509, *Information processing systems — Open Systems Interconnection — Service conventions*

ISO/IEC 8649, *Information technology — Open Systems Interconnection — Service definition for the Association Control Service Element*

ISO/IEC 8802-2, *Information technology — Telecommunications and information exchange between systems — Local and metropolitan area networks — Specific requirements — Part 2: Logical link control*

ISO/IEC 8802-3, *Information technology — Telecommunications and information exchange between systems — Local and metropolitan area networks — Specific requirements — Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

ISO/IEC 8824 (all parts), *Information technology — Abstract Syntax Notation One (ASN.1)*

ISO/IEC 8825 (all parts), *Information technology — ASN.1 encoding rules*

ISO/IEC 8859-1, *Information technology — 8-bit single-byte coded graphic character sets — Part 1: Latin alphabet No. 1*

AVA Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

ISO/IEC 9545, *Information technology — Open Systems Interconnection — Application Layer structure*

ISO/IEC 10646, *Information technology — Universal Multiple-Octet Coded Character Set (UCS)*

3 Revision of ANSI/ASHRAE 135

It has been agreed with the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) that Technical Committee ISO/TC 205 will be consulted in the event of any revision or amendment of ANSI/ASHRAE 135. To this end, ANSI will act as a liaison body between ASHRAE and ISO.

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009



ANSI/ASHRAE Standard 135-2004
(Including ANSI/ASHRAE addenda listed in the History of Revisions)

ASHRAE® STANDARD

BACnet® — A Data Communication Protocol for Building Automation and Control Networks

Approved by the ASHRAE Standards Committee October 5, 2003; by the ASHRAE Board of Directors Jaunaru 29, 2004; and by the American National Standards Institute February 25, 2004. See "History of Revisions" section for approval dates of addenda.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procdedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions and deadlines are given at the back of this document and may be obtained in electronic form from ASHRAE's Internet Home Page, *http://www.ashrae.org*, or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard and printed copies of a public review draft may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: *orders@ashrae.org*. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in U.S. and Canada).

© 2004 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS, INC.
1791 Tullie Circle, NE· Atlanta, GA 30329-2305

AVA Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

(Blank page)

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

ASHRAE STANDING STANDARD PROJECT COMMITTEE 135
Cognizant TC: TC 1.4, Control Theory and Applications
SPLS Liaison: Frank E. Jakob

Steven T. Bushby, *Chair**
William O. Swan III, *Vice-Chair*
Carl Neilson, *Secretary**
Barry B. Bridges*
James F. Butler*
A. J. Capowski*
Keith A. Corbett
Jeffery Cosiol
Troy D. Cowan*
Daniel P. Giorgis
Thomas S. Ertsgaard*
Craig P. Gemmill*
Robert L. Johnson
Stephen T. Karg*
J. Damian Ljungquist*
Jerald P. Martocci
Mark A. Railsback
David W. Robin
Ernest L. Senior
Daniel A. Traill*
J. Michael Whitcomb*
David F. White
Grant N. Wichenko

**Denotes members of voting status when this standard was approved for publication.*

The following persons served as consultants to the project committee:

Andrey Golovin
David G. Holmberg
H. Michael Newman
René Quirighetti
David H. Ritter
Takeji Toyoda

ASHRAE STANDARDS COMMITTEE 2003-2004

Van D. Baxter, *Chair*
Davor Novosel, *Vice-Chair*
Donald B. Bivens
Dean S. Borges
Paul W. Cabot
Charles W. Coward, Jr.
Hugh F. Crowther
Brian P. Dougherty
Hakim Elmahdy
Matt R. Hargan
Richard D. Hermans
John F. Hogan
Frank E. Jakob
Stephen D. Kennedy
David E. Knebel
Frederick H. Kohloss
Merle F. McBride
Mark P. Modera
Claire B. Ramspeck, Manager of Standards
Cyrus H. Nasseri
Gideon Shavit
David R. Tree
Thomas H. Williams
James E. Woods
Kent W. Peterson, CO
Ross D. Montgomery, BOD ExO

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other members may or may not be members of ASHRAE, all must be technically qualified in the subject area of the standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:
a. interpretation of the contents of this Standard,
b. participation in the next review of the Standard,
c. offering constructive criticism for improving the Standard,
d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate standards for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, designed, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its standards will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this standard and marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

AVA Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

(Blank page)

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

CONTENTS

FOREWORD vii
1 PURPOSE 1
2 SCOPE 1
3 DEFINITIONS 1
3.1 Terms Adopted from International Standards 1
3.2 Terms Defined for this Standard 2
3.3 Abbreviations and Acronyms Used in this Standard 5
4 BACnet PROTOCOL ARCHITECTURE 8
4.1 The BACnet Collapsed Architecture 9
4.2 BACnet Network Topology 11
4.3 Security 13
5 THE APPLICATION LAYER 14
5.1 The Application Layer Model 14
5.2 Segmentation of BACnet Messages 18
5.3 Transmission of BACnet APDUs 19
5.4 Application Protocol State Machines 23
5.5 Application Protocol Time Sequence Diagrams 37
5.6 Application Layer Service Conventions 45
6 THE NETWORK LAYER 47
6.1 Network Layer Service Specification 47
6.2 Network Layer PDU Structure 48
6.3 Messages for Multiple Recipients 53
6.4 Network Layer Protocol Messages 54
6.5 Network Layer Procedures 56
6.6 BACnet Routers 58
6.7 Point-To-Point Half-Routers 63
7 DATA LINK/PHYSICAL LAYERS: ISO 8802-3 ("Ethernet") LAN 68
7.1 The Use of ISO 8802-2 Logical Link Control (LLC) 68
7.2 Parameters Required by the LLC Primitives 68
7.3 Parameters Required by the MAC Primitives 68
7.4 Physical Media 68
8 DATA LINK/PHYSICAL LAYERS: ARCNET LAN 70
8.1 The Use of ISO 8802-2 Logical Link Control (LLC) 70
8.2 Parameters Required by the LLC Primitives 70
8.3 Mapping the LLC Services to the ARCNET MAC Layer 70
8.4 Parameters Required by the MAC Primitives 70
8.5 Physical Media 70
9 DATA LINK/PHYSICAL LAYERS: MASTER-SLAVE/TOKEN PASSING (MS/TP) LAN 72
9.1 Service Specification 72
9.2 Physical Layer 74
9.3 MS/TP Frame Format 76
9.4 Overview of the MS/TP Network 77
9.5 MS/TP Medium Access Control 78
9.6 Cyclic Redundancy Check (CRC) 94
9.7 Interfacing MS/TP LANs with Other BACnet LANs 95
9.8 Responding BACnet User Processing of Messages from MS/TP 95
9.9 Repeaters 95
10 DATA LINK/PHYSICAL LAYERS: POINT-TO-POINT (PTP) 97
10.1 Overview 97
10.2 Service Specification 97
10.3 Point-to-Point Frame Format 102
10.4 PTP Medium Access Control Protocol 104
11 DATA LINK/PHYSICAL LAYERS: EIA/CEA-709.1 ("LonTalk") LAN 125
11.1 The Use of ISO 8802-2 Logical Link Control (LLC) 125
11.2 Parameters Required by the LLC Primitives 125

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

11.3 Mapping the LLC Services to the LonTalk Application Layer 125
11.4 Parameters Required by the Application Layer Primitives 125
11.5 Physical Media 126
12 MODELING CONTROL DEVICES AS A COLLECTION OF OBJECTS 127
12.1 Access Door Object Type 130
12.2 Accumulator Object Type 137
12.3 Analog Input Object Type 145
12.4 Analog Output Object Type 150
12.5 Analog Value Object Type 155
12.6 Averaging Object Type 160
12.7 Binary Input Object Type 163
12.8 Binary Output Object Type 168
12.9 Binary Value Object Type 174
12.10 Calendar Object Type 179
12.11 Command Object Type 181
12.12 Device Object Type 185
12.13 Event Enrollment Object Type 192
12.14 File Object Type 197
12.15 Group Object Type 199
12.16 Life Safety Point Object Type 201
12.17 Life Safety Zone Object Type 207
12.18 Load Control Object Type 213
12.19 Loop Object Type 222
12.20 Multi-state Input Object Type 229
12.21 Multi-state Output Object Type 233
12.22 Multi-state Value Object Type 237
12.23 Notification Class Object Type 242
12.24 Program Object Type 245
12.25 Pulse Converter Object Type 250
12.26 Schedule Object Type 257
12.27 Structured View Object Type 262
12.28 Trend Log Object Type 264
13 ALARM AND EVENT SERVICES 270
13.1 Change of Value Reporting 271
13.2 Intrinsic Reporting 273
13.3 Algorithmic Change Reporting 276
13.4 Alarm and Event Occurrence and Notification 284
13.5 AcknowledgeAlarm Service 287
13.6 ConfirmedCOVNotification Service 289
13.7 UnconfirmedCOVNotification Service 291
13.8 ConfirmedEventNotification Service 292
13.9 UnconfirmedEventNotification Service 295
13.10 GetAlarmSummary Service 297
13.11 GetEnrollmentSummary Service 299
13.12 GetEventInformation Service 302
13.13 LifeSafetyOperation Service 304
13.14 SubscribeCOV Service 306
13.15 SubscribeCOVProperty Service 308
14 FILE ACCESS SERVICES 311
14.1 AtomicReadFile Service 312
14.2 AtomicWriteFile Service 315
15 OBJECT ACCESS SERVICES 317
15.1 AddListElement Service 317
15.2 RemoveListElement Service 319
15.3 CreateObject Service 321
15.4 DeleteObject Service 323
15.5 ReadProperty Service 324
15.6 ReadPropertyConditional Service 326
15.7 ReadPropertyMultiple Service 331
15.8 ReadRange Service 334

Documents
ASHRAE 135-2004
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

15.9 WriteProperty Service ... 338
15.10 WritePropertyMultiple Service ... 340
16 REMOTE DEVICE MANAGEMENT SERVICES ... 343
16.1 DeviceCommunicationControl Service ... 343
16.2 ConfirmedPrivateTransfer Service ... 345
16.3 UnconfirmedPrivateTransfer Service ... 347
16.4 ReinitializeDevice Service ... 348
16.5 ConfirmedTextMessage Service ... 350
16.6 UnconfirmedTextMessage Service ... 352
16.7 TimeSynchronization Service ... 353
16.8 UTCTimeSynchronization Service ... 354
16.9 Who-Has and I-Have Services ... 355
16.10 Who-Is and I-Am Services ... 357
17 VIRTUAL TERMINAL SERVICES ... 359
17.1 Virtual Terminal Model ... 359
17.2 VT-Open Service ... 363
17.3 VT-Close Service ... 365
17.4 VT-Data Service ... 366
17.5 Default-terminal Characteristics ... 368
18 ERROR, REJECT, and ABORT CODES ... 372
18.1 Error Class - DEVICE ... 372
18.2 Error Class - OBJECT ... 372
18.3 Error Class - PROPERTY ... 372
18.4 Error Class - RESOURCES ... 373
18.5 Error Class - SECURITY ... 373
18.6 Error Class - SERVICES ... 374
18.7 Error Class - VT ... 375
18.8 Reject Reason ... 375
18.9 Abort Reason ... 376
19 BACnet PROCEDURES ... 377
19.1 Backup and Restore ... 377
19.2 Command Prioritization ... 380
20 ENCODING BACnet PROTOCOL DATA UNITS ... 384
20.1 Encoding the Fixed Part of BACnet APDUs ... 384
20.2 Encoding the Variable Part of BACnet APDUs ... 394
21 FORMAL DESCRIPTION OF APPLICATION PROTOCOL DATA UNITS ... 408
22 CONFORMANCE AND INTEROPERABILITY ... 453
22.1 Conformance to BACnet ... 453
22.2 BACnet Interoperability ... 454
23 EXTENDING BACnet TO ACCOMMODATE VENDOR PROPRIETARY INFORMATION ... 456
23.1 Extending Enumeration Values ... 456
23.2 Using the PrivateTransfer Services to Invoke Non-Standardized Services ... 456
23.3 Adding Proprietary Properties to a Standardized Object ... 457
23.4 Adding Proprietary Object Types to BACnet ... 457
23.5 Restrictions on Extending BACnet ... 458
24 NETWORK SECURITY ... 459
24.1 Security Architecture ... 459
24.2 Authentication Mechanisms ... 460
24.3 Data Confidentiality Mechanism ... 462
24.4 RequestKey Service ... 463
24.5 Authenticate Service ... 464
25 REFERENCES ... 467
ANNEX A - PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (NORMATIVE) ... 469
ANNEX B - GUIDE TO SPECIFYING BACnet DEVICES (INFORMATIVE) ... 471
ANNEX C - FORMAL DESCRIPTION OF OBJECT TYPE STRUCTURES (INFORMATIVE) ... 472
ANNEX D - EXAMPLES OF STANDARD OBJECT TYPES (INFORMATIVE) ... 486
D.1 Example of an Access Door Object ... 486
D.2 Example of an Accumulator Object ... 487

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

D.3 Example of an Analog Input Object 487
D.4 Example of an Analog Output Object 488
D.5 Example of an Analog Value Object 488
D.6 Example of an Averaging Object 489
D.7 Example of a Binary Input Object 489
D.8 Example of a Binary Output Object 490
D.9 Example of a Binary Value Object 491
D.10 Example of a Calendar Object 492
D.11 Example of a Command Object 492
D.12 Example of a Device Object 493
D.13 Example of an Event Enrollment Object 495
D.14 Example of a File Object 497
D.15 Example of a Group Object 497
D.16 Example of a Life Safety Point Object 497
D.17 Example of a Life Safety Zone Object 498
D.18 Example of a Load Control Object 499
D.19 Example of a Loop Object 500
D.20 Example of a Multi-state Input Object 501
D.21 Example of a Multi-state Output Object 502
D.22 Example of a Multi-state Value Object 503
D.23 Example of a Notification Class Object 503
D.24 Example of a Program Object 503
D.25 Example of a Pulse Converter Object 505
D.26 Example of a Schedule Object 505
D.27 Example of a Structural View Object 506
D.28 Example of a Trend Log Object 507
ANNEX E - EXAMPLES OF BACnet APPLICATION SERVICES (INFORMATIVE) 508
E.1 Alarm and Event Services 508
E.2 File Access Services 512
E.3 Object Access Services 514
E.4 Remote Device Management Services 521
E.5 Virtual Terminal Services 524
E.6 Security Services 525
ANNEX F - EXAMPLES OF APDU ENCODING (INFORMATIVE) 527
F.1 Example Encodings for Alarm and Event Services 527
F.2 Example Encodings for File Access Services 536
F.3 Example Encodings for Object Access Services 538
F.4 Example Encodings for Remote Device Management Services 552
F.5 Example Encodings for Virtual Terminal Services 557
F.6 Example Encodings for Security Services 559
ANNEX G - CALCULATION OF CRC (INFORMATIVE) 561
G.1 Calculation of the Header CRC 561
G.2 Calculation of the Data CRC 567
ANNEX H - COMBINING BACnet NETWORKS WITH NON-BACnet NETWORKS (NORMATIVE) 572
H.1 Mapping Non-BACnet Networks onto BACnet Routers 572
H.2 Multiple 'Virtual' BACnet Devices in a Single Physical Device 572
H.3 Using BACnet with the DARPA Internet Protocols 572
H.4 Using BACnet with the IPX Protocol 573
H.5 Using BACnet with EIB/KNX 575
ANNEX I - COMMANDABLE PROPERTIES WITH MINIMUM ON AND OFF TIMES (INFORMATIVE) 588
ANNEX J - BACnet/IP (NORMATIVE) 590
J.1 General 590
J.2 BACnet Virtual Link Layer 590
J.3 BACnet/IP Directed Messages 594
J.4 BACnet/IP Broadcast Messages 594
J.5 Addition of Foreign B/IP Devices to an Existing B/IP Network 596
J.6 Routing Between B/IP and non-BP/IP BACnet Networks 597
J.7 Routing Between Two B/IP BACnet Networks 598
J.8 Use of IP Multicast within BACnet/IP 600

Documents
ASHRAE 135-2004
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

J.9 Sources for Internet Information 601
ANNEX K - BACnet INTEROPERABILITY BUILDING BLOCKS (BIBBs) (NORMATIVE) 602
K.1 Data Sharing BIBBs 602
K.1.1 BIBB - Data Sharing - ReadProperty - A (DS-RP-A) 602
K.1.2 BIBB-Data Sharing-ReadProperty-B (DS-RP-B) 602
K.1.3 BIBB - Data Sharing-ReadPropertyMultiple-A (DS-RPM-A) 602
K.1.4 BIBB - Data Sharing-ReadPropertyMultiple-B (DS-RPM-B) 602
K.1.5 BIBB - Data Sharing-ReadPropertyConditional-A (DS-RPC-A) 602
K.1.6 BIBB - Data Sharing-ReadPropertyConditional-B (DS-RPC-B) 603
K.1.7 BIBB - Data Sharing-WriteProperty-A (DS-WP-A) 603
K.1.8 BIBB - Data Sharing-WriteProperty-B (DS-WP-B) 603
K.1.9 BIBB - Data Sharing-WritePropertyMultiple-A (DS-WPM-A) 603
K.1.10 BIBB - Data Sharing-WritePropertyMultiple-B (DS-WPM-B) 603
K.1.11 BIBB - Data Sharing-COV-A (DS-COV-A) 603
K.1.12 BIBB - Data Sharing-COV-B (DS-COV-B) 604
K.1.13 BIBB - Data Sharing-COVP-A (DS-COVP-A) 604
K.1.14 BIBB - Data Sharing-COVP-B (DS-COVP-B) 604
K.1.15 BIBB - Data Sharing-COV-Unsolicited-A (DS-COVU-A) 604
K.1.16 BIBB - Data Sharing-COV-Unsolicited-B (DS-COVU-B) 604
K.2 Alarm and Event Management BIBBs 604
K.2.1 BIBB - Alarm and Event-Notification-A (AE-N-A) 605
K.2.2 BIBB - Alarm and Event-Notification Internal-B (AE-N-I-B) 605
K.2.3 BIBB - Alarm and Event-Notification External-B (AE-N-E-B) 605
K.2.4 BIBB - Alarm and Event-ACK-A (AE-ACK-A) 605
K.2.5 BIBB - Alarm and Event-ACK-B (AE-ACK-B) 605
K.2.6 BIBB - Alarm and Event-Alarm Summary-A (AE-ASUM-A) 605
K.2.7 BIBB - Alarm and Event-Alarm Summary-B (AE-ASUM-B) 606
K.2.8 BIBB - Alarm and Event-Enrollment Summary-A (AE-ESUM-A) 606
K.2.9 BIBB - Alarm and Event-Enrollment Summary-B (AE-ESUM-B) 606
K.2.10 BIBB - Alarm and Event-Information-A (AE-INFO-A) 606
K.2.11 BIBB - Alarm and Event-Information-B (AE-INFO-B) 606
K.2.12 BIBB - Alarm and Event-LifeSafety-A (AE-LS-A) 606
K.2.13 BIBB - Alarm and Event-LifeSafety-B (AE-LS-B) 606
K.3 Scheduling BIBBs 607
K.3.1 BIBB - Scheduling-A (SCHED-A) 607
K.3.2 BIBB - Scheduling-Internal-B (SCHED-I-B) 607
K.3.3 BIBB - Scheduling-External-B (SCHED-E-B) 607
K.4 Trending BIBBs 607
K.4.1 BIBB - Trending-Viewing and Modifying Trends-A (T-VMT-A) 607
K.4.2 BIBB - Trending-Viewing and Modifying Trends Internal-B (T-VMT-I-B) 607
K.4.3 BIBB - Trending-Viewing and Modifying Trends External-B (T-VMT-E-B) 607
K.4.4 BIBB - Trending-Automated Trend Retrieval-A (T-ATR-A) 608
K.4.5 BIBB - Trending-Automated Trend Retrieval-B (T-ATR-B) 608
K.5 Device and Network Management BIBBs 608
K.5.1 BIBB - Device Management-Dynamic Device Binding-A (DM-DDB-A) 608
K.5.2 BIBB - Device Management-Dynamic Device Binding-B (DM-DDB-B) 608
K.5.3 BIBB - Device Management-Dynamic Object Binding-A (DM-DOB-A) 609
K.5.4 BIBB - Device Management-Dynamic Object Binding-B (DM-DOB-B) 609
K.5.5 BIBB - Device Management-DeviceCommunicationControl-A (DM-DCC-A) 609
K.5.6 BIBB - Device Management-DeviceCommunicationControl-B (DM-DCC-B) 609
K.5.7 BIBB - Device Management-Text Message-A (DM-TM-A) 610
K.5.8 BIBB - Device Management-Text Message-B (DM-TM-B) 610
K.5.9 BIBB - Device Management-TimeSynchronization-A (DM-TS-A) 610
K.5.10 BIBB - Device Management-TimeSynchronization-B (DM-TS-B) 610
K.5.11 BIBB - Device Management-UTCTimeSynchronization-A (DM-UTC-A) 610

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

K.5.12 BIBB - Device Management-UTCTimeSynchronization-B (DM-UTC-B) 611
K.5.13 BIBB - Device Management-ReinitializeDevice-A (DM-RD-A) 611
K.5.14 BIBB - Device Management-ReinitializeDevice-B (DM-RD-B) 611
K.5.15 BIBB - Device Management-Backup and Restore-A (DM-BR-A) 611
K.5.16 BIBB - Device Management-Backup and Restore-B (DM-BR-B) 611
K.5.17 BIBB - Device Management-Restart-A (DM-R-A) 612
K.5.18 BIBB - Device Management-Restart-B (DM-R-B) 612
K.5.19 BIBB - Device Management-List Manipulation-A (DM-LM-A) 612
K.5.20 BIBB - Device Management-List Manipulation-B (DM-LM-B) 612
K.5.21 BIBB - Device Management-Object Creation and Deletion-A (DM-OCD-A) 612
K.5.22 BIBB - Device Management-Object Creation and Deletion-B (DM-OCD-B) 613
K.5.23 BIBB - Device Management-Virtual Terminal-A (DM-VT-A) 613
K.5.24 BIBB - Device Management-Virtual Terminal-B (DM-VT-B) 613
K.5.25 BIBB - Network Management-Connection Establishment-A (NM-CE-A) 613
K.5.26 BIBB - Network Management-Connection Establishment-B (NM-CE-B) 613
K.5.27 BIBB - Network Management-Router Configuration-A (NM-RC-A) 614
K.5.28 BIBB - Network Management-Router Configuration-B (NM-RC-B) 614
ANNEX L - DESCRIPTIONS AND PROFILES OF STANDARDIZED BACnet DEVICES (NORMATIVE) 615
L.1 BACent Operator Workstation (B-OWS) 615
L.2 BACnet Building Controller (B-BC) 615
L.3 BACnet Advanced Application Controller (B-AAC) 616
L.4 BACnet Application Specific Controller (B-ASC) 616
L.5 BACnet Smart Actuator (B-SA) 617
L.6 BACnet Smart Sensor (B-SS) 617
L.7 Profiles of the Standard BACnet Devices 618
ANNEX M – GUIDE TO EVENT NOTIFICATION PRIORITY ASSIGNMENTS (INFORMATIVE) 619
M.1 Life Safety Message Group (0-31) 619
M.2 Property Safety Message Group (32-63) 620
M.3 Supervisory Message Group (64-95) 620
M.4 Trouble Message Group (96-127) 621
M.5 Miscellaneous Higher Priority Message Group (128-191) 622
M.6 Miscellaneous Lower Priority Message Group (192-255) 622
ANNEX N – BACnet/WS WEB SERVICES INTERFACE (NORMATIVE) 623
N.1 Data Model 623
N.2 Paths 624
N.3 Normalized Points 624
N.4 Reference Nodes 625
N.5 Localization 625
N.6 Security 626
N.7 Sessions 626
N.8 Attributes 626
N.9 Standards Nodes 632
N.10 Encodings 633
N.11 Service Options 634
N.12 Services 637
N.13 Errors 653
N.14 Extending BACnet/WS 654
HISTORY OF REVISIONS 655

Documents
ASHRAE 135-2004
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

FOREWORD

BACnet, the ASHRAE building automation and control networking protocol, has been designed specifically to meet the communication needs of building automation and control systems for applications such as heating, ventilating, and air-conditioning control, lighting control, access control, and fire detection systems. The BACnet protocol provides mechanisms by which computerized equipment of arbitrary function may exchange information, regardless of the particular building service it performs. As a result, the BACnet protocol may be used by head-end computers, general-purpose direct digital controllers, and application specific or unitary controllers with equal effect.

The motivation for this Standard was the widespread desire of building owners and operators for "interoperability," the ability to integrate equipment from different vendors into a coherent automation and control system - and to do so competitively. To accomplish this, the Standard Project Committee (SPC) solicited and received input from dozens of interested firms and individuals; reviewed all relevant national and international data communications standards, whether de facto or the result of committee activity; and spent countless hours in debate and discussion of the pros and cons of each element of the protocol.

What has emerged from the committee deliberations is a network protocol model with these principal characteristics:

(a) All network devices (except MS/TP slaves) are peers, but certain peers may have greater privileges and responsibilities than others.

(b) Each network device is modeled as a collection of network-accessible, named entities called "objects." Each object is characterized by a set of attributes or "properties." While this Standard prescribes the most widely applicable object types and their properties, implementors are free to create additional object types if desired. Because the object model can be easily extended, it provides a way for BACnet to evolve in a backward compatible manner as the technology and building needs change.

(c) Communication is accomplished by reading and writing the properties of particular objects and by the mutually acceptable execution of other protocol "services." While this Standard prescribes a comprehensive set of services, mechanisms are also provided for implementors to create additional services if desired.

(d) Because of this Standard's adherence to the ISO concept of a "layered" communication architecture, the same messages may be exchanged using various network access methods and physical media. This means that BACnet networks may be configured to meet a range of speed and throughput requirements with commensurately varying cost. Multiple BACnet networks can be interconnected within the same system forming an internetwork of arbitrarily large size. This flexibility also provides a way for BACnet to embrace new networking technologies as they are developed.

BACnet was designed to gracefully improve and evolve as both computer technology and demands of building automation systems change. Upon its original publication in 1995, a Standing Standards Project Committee was formed to deliberate enhancements to the protocol under ASHRAE rules for "continuous maintenance." Much has happened since the BACnet standard was first promulgated. BACnet has been translated into Chinese, Japanese, and Korean, and embraced across the globe. BACnet devices have been designed, built and deployed on all seven continents. Suggestions for enhancements and improvements have been continually received, deliberated, and, ultimately, subjected to the same consensus process that produced the original standard. This publication is the result of those deliberations and brings together all of the corrections, refinements, and improvements that have been adopted.

Among the features that have been added to BACnet are: increased capabilities to interconnect systems across wide area networks using internet protocols, new objects and services to support fire detection and other life safety applications, capabilities to backup and restore devices, standard ways to collect trend data, new tools to make specifying BACnet systems easier, a mechanism for making interoperable extensions to the standard visible, and many others. The successful addition of these features demonstrates that the concept of a protocol deliberately crafted to permit extension of its capabilities over time as technology and needs change is viable and sound.

All communication protocols are, in the end, a collection of arbitrary solutions to the problems of information exchange and all are subject to change as time and technology advance. BACnet is no exception. Still, it is the hope of those who have contributed their time, energies, and talents to this work that BACnet will help to fulfill, in the area of building automation and control, the promise of the information age for the public good!

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

(Blank page)

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

1 PURPOSE

The purpose of this standard is to define data communication services and protocols for computer equipment used for monitoring and control of HVAC&R and other building systems and to define, in addition, an abstract, object-oriented representation of information communicated between such equipment, thereby facilitating the application and use of digital control technology in buildings.

2 SCOPE

2.1 This protocol provides a comprehensive set of messages for conveying encoded binary, analog, and alphanumeric data between devices including, but not limited to:

(a) hardware binary input and output values,
(b) hardware analog input and output values,
(c) software binary and analog values,
(d) text string values,
(e) schedule information,
(f) alarm and event information,
(g) files, and
(h) control logic.

2.2 This protocol models each building automation and control computer as a collection of data structures called "objects," the properties of which represent various aspects of the hardware, software, and operation of the device. These objects provide a means of identifying and accessing information without requiring knowledge of the details of the device's internal design or configuration.

3 DEFINITIONS

3.1 Terms Adopted from International Standards

The following terms used in this standard are defined by international standards or draft standards for open system interconnection (OSI). The definitions are repeated here and a reference to the appropriate standard is provided. Clause 25 contains the titles of all national and international standards referenced in this clause and elsewhere in this standard. Words or phrases in italics refer to terms defined elsewhere in this clause.

3.1.1 abstract syntax: the specification of application layer data or *application-protocol-control-information* by using notation rules which are independent of the encoding technique used to represent them (ISO 8822).

3.1.2 application: a set of a USER's information processing requirements (ISO 8649).

3.1.3 application-entity: the aspects of an *application-process* pertinent to OSI (ISO 7498).

3.1.4 application-process: an element within a *real open system* which performs the information processing for a particular *application* (ISO 7498).

3.1.5 application-protocol-control-information: information exchanged between *application-entities*, using presentation services, to coordinate their joint operation (ISO 9545).

3.1.6 application-protocol-data-unit: a unit of data specified in an application protocol and consisting of *application-protocol-control-information* and possibly application-user-data (ISO 9545).

3.1.7 application-service-element: that part of an *application-entity* which provides an OSI environment capability, using underlying services when appropriate (ISO 7498).

3.1.8 concrete syntax: those aspects of the rules used in the formal specification of data which embody a specific representation of that data (ISO 7498).

3.1.9 peer-entities: *entities* within the same layer (ISO 7498).

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

3.1.10 real open system: a *real system* which complies with the requirements of OSI standards in its communication with other *real systems* (ISO 7498).

3.1.11 real system: a set of one or more computers, the associated software, peripherals, terminals, human operators, physical processes, information transfer means, etc., that forms an autonomous whole capable of performing information processing and/or information transfer (ISO 7498).

3.1.12 (N)-service-access-point: the point at which (N)-services are provided by an (N)-*entity* to an (N+1)-*entity* (ISO 7498).

3.1.13 (N)-service-data-unit: an amount of (N)-interface-data whose identity is preserved from one end of an (N)-connection to the other (ISO 7498).

3.1.14 service-user: an *entity* in a single open system that makes use of a service through *service-access-points* (ISO TR 8509).

3.1.15 service-provider: an abstract of the totality of those entities which provide a service to peer *service-users* (ISO TR 8509).

3.1.16 transfer-syntax: that *concrete syntax* used in the transfer of data between open systems (ISO 7498).

3.1.17 service-primitive; **primitive**: an abstract, implementation-independent representation of an interaction between the *service-user* and the *service-provider* (ISO TR 8509).

3.1.18 request (primitive): a representation of an interaction in which a *service-user* invokes some procedure (ISO TR 8509).

3.1.19 indication (primitive): a representation of an interaction in which a *service-provider* either
(a) indicates that it has, on its own initiative, invoked some procedure; or
(b) indicates that a procedure has been invoked by the *service-user* at the peer *service-access-point* (ISO TR 8509).

3.1.20 response (primitive): a representation of an interaction in which a *service-user* indicates that it has completed some procedure previously invoked by an interaction represented by an *indication* primitive (ISO TR 8509).

3.1.21 confirm (primitive): a representation of an interaction in which a *service-provider* indicates, at a particular *service-access-point*, completion of some procedure previously invoked, at that *service-access-point*, by an interaction represented by a *request* primitive (ISO TR 8509).

3.1.22 user element: the representation of that part of an *application-process* which uses those *application-service-elements* needed to accomplish the communications objectives of that *application-process* (ISO 7498).

3.2 Terms Defined for this Standard

3.2.1 access control: a method for regulating or restricting access to *network resources.*

3.2.2 alarm: 1. An annunciation, either audible or visual or both, that alerts an operator to an off-normal condition that may require corrective action. **2.** An abnormal condition detected by a device or controller that implements a rule or logic specifically designed to look for that condition.

3.2.3 algorithmic change reporting: the detection and reporting of an alarm or event, based on an algorithm specified in an Event Enrollment object. See *intrinsic reporting* in 3.2.27.

3.2.4 BACnet device: any device, real or virtual, that supports digital communication using the BACnet protocol.

3.2.5 BACnet-user: that portion of an *application-process* that is represented by the BACnet *user element*.

3.2.6 bridge: a device that connects two or more *segments* at the physical and data link layers. This device may also perform message filtering based upon MAC layer addresses.

3.2.7 broadcast: a message sent as a single unit, which may apply to more than one device.

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

3.2.8 change of state: an event that occurs when a measured or calculated Boolean or discrete enumerated value changes.

3.2.9 change of value: an event that occurs when a measured or calculated analog value changes by a predefined amount.

3.2.10 client: a system or device that makes use of another device for some particular purpose via a service *request* instance. A client requests service from a *server*.

3.2.11 context: a set of data or information that completely describes a particular communication environment at a particular point in time.

3.2.12 controller: a device for regulation or management of a system or component.

3.2.13 data confidentiality: the property that information is not made available or disclosed to unauthorized individuals, entities, or processes.

3.2.14 data integrity: the property that data has not been altered or destroyed in an unauthorized manner.

3.2.15 data origin authentication: the corroboration that the source of data received is as claimed.

3.2.16 directly connected network: a network that is accessible from a router without messages being relayed through an intervening router. A PTP connection is to a directly connected network if the PTP connection is currently active and no intervening router is used.

3.2.17 download: a particular type of file transfer that refers to the transfer of an executable program or database to a remote device where it may be executed.

3.2.18 entity: something that has a separate and distinct existence. An identifiable item that is described by a set or collection of properties.

3.2.19 error detection: a procedure used to identify the presence of errors in a communication.

3.2.20 error recovery: a procedure invoked in response to a detected error that permits the information exchange to continue.

3.2.21 gateway: a device that connects two or more dissimilar *networks*, permitting information exchange between them.

3.2.22 global: pertaining to all devices or nodes on a communication *internetwork*.

3.2.23 global broadcast: a message addressed to all devices or *nodes* on all *networks* in a BACnet *internet*.

3.2.24 half router: a device or *node* that can participate as one partner in a PTP connection. The two half-router partners that form an active PTP connection together make up a single *router*.

3.2.25 initialization: the process of establishing a known state, usually from a power up condition. Initialization may require re-establishment of a node's logical or physical address.

3.2.26 internetwork: a set of two or more *networks* interconnected by *routers*. In a BACnet *internetwork*, there exists exactly one message path between any two nodes.

3.2.27 intrinsic reporting: the detection and reporting of an alarm or event, based on an algorithm defined as part of the *object type* specification. No external reference to an Event Enrollment is involved. See *algorithmic change reporting* in 3.2.3.

3.2.28 key: a sequence of symbols that controls the operations of encipherment and decipherment.

3.2.29 local: pertaining to devices on the same *network* as the referenced device.

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

3.2.30 local broadcast: a message addressed to all devices or *nodes* on the same *network* as the originator.

3.2.31 medium: the physical transmission *entity*. Typical media are twisted-pair wire, fiber optic cable, and coaxial cable.

3.2.32 medium access control: a process used to maintain order and provide access to the communication *medium*.

3.2.33 network: a set of one or more *segments* interconnected by *bridges* that have the same network address.

3.2.34 network resource: any physical or logical *entity* that may be accessed via a communication *medium*.

3.2.35 node: an addressable device connected to the communication *medium*.

3.2.36 object profile: an object profile is a means of defining objects beyond those defined in Clause 12. A profile defines the set of properties, behavior, and/or requirements for a proprietary object, or for proprietary extensions to a standard object.

3.2.37 object type: a generic classification of data that is defined by a set of *properties*.

3.2.38 operator authentication: the corroboration that the operator logging on to a device is as claimed.

3.2.39 peer entity authentication: the corroboration that a peer entity in an association is the one claimed.

3.2.40 physical segment: a single contiguous *medium* to which BACnet nodes are attached.

3.2.41 printable character: a character that represents a printable symbol as opposed to a device control character. These include, but are not limited to, upper- and lowercase letters, punctuation marks, and mathematical symbols. The exact set depends upon the character set being used. In ANSI X3.4 the printable characters are represented by single octets in the range X'20' - X'7E'.

3.2.42 property: a particular characteristic of an *object type*.

3.2.43 proprietary: within the context of BACnet, any extension of or addition to *object types*, *properties*, PrivateTransfer services, or enumerations specified in this standard.

3.2.44 receiving BACnet-user: the *BACnet-user* that receives an *indication* or *confirm* service primitive.

3.2.45 remote: pertaining to devices or *nodes* on a different *network* than the referenced device.

3.2.46 remote broadcast: a message addressed to all devices or *nodes* on a different *network* than the originator.

3.2.47 repeater: a device that connects two or more *physical segments* at the physical layer.

3.2.48 requesting BACnet-user: the *BACnet-user* that assumes the role of a *client* in a confirmed service.

3.2.49 responding BACnet-user: the *BACnet-user* that assumes the role of a *server* in a confirmed service.

3.2.50 router: a device that connects two or more *networks* at the network layer.

3.2.51 security: any of a variety of procedures used to ensure that information exchange is guarded to prevent disclosure to unauthorized individuals. Security measures are intended to prevent disclosure of sensitive information even to those who have valid access to the communication *network*. Security is distinct from access control, although some security can be provided by limiting physical access to the communication medium itself.

3.2.52 segment: a segment consists of one or more *physical segments* interconnected by repeaters.

3.2.53 sending BACnet-user: the *BACnet-user* that issues a *request* or *response* service primitive.

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

3.2.54 server: a system or device that responds to a service *request* instance for some particular purpose. The server provides service to a *client*.

3.2.55 synchronization: a facility that allows processes to define and identify specific places in a transmission or exchange that can be used to reset a communication session to a predefined state.

3.2.56 timestamp: the date and time recorded for and accompanying the record of an event or operation.

3.2.57 unit_time: the length of time required to transmit one octet with a start bit and a single stop bit. Ten bit-times.

3.2.58 upload: the process of transferring an executable program image or a database from a remote device in such a manner as to allow subsequent download.

3.3 Abbreviations and Acronyms Used in this Standard

A	application layer (prefix)
AE	application entity
ANSI	American National Standards Institute
APCI	application protocol control information
APDU	application layer protocol data unit
API	application program interface
ARCNET	attached resource computer network
ASE	application service element
ASN.1	Abstract Syntax Notation One (ISO 8824)
B' '	denotes that binary notation is used between the single quotes
BAC	building automation and control
BBMD	BACnet/IP broadcast management device
BDT	broadcast distribution table
B/IP	BACnet/IP
B/IP-M	BACnet/IP multicast
BVLC	BACnet virtual link control
BVLCI	BACnet virtual link control information
BVLL	BACnet virtual link layer
C	conditional
C(=)	conditional (The parameter is semantically equivalent to the parameter in the service primitive to its immediate left in the table.)
CNF	confirm primitive
COV	change of value
CRC	cyclic redundancy check
D' '	denotes that decimal notation is used between the single quotes
DA	local destination MAC layer address
DADR	ultimate destination MAC layer address
DER	data expecting reply
DES	Data Encryption Standard (FIPS 46-1)
DID	ARCNET destination MAC address
DLEN	1-octet length of ultimate destination MAC layer address
DNET	2-octet ultimate destination network number
DSAP	LLC destination service access point (X'82' for BACnet)
EIB	European Installation Bus
EIBA	European Installation Bus Association
EXEC	capable of executing a service request
FDT	foreign device table
ICI	interface control information
IL	ARCNET information length field
IND	indication primitive
INF	"Infinity", a unique binary pattern representing positive infinity (see ANSI/IEEE 754-1985)
-INF	"Negative infinity", a unique binary pattern representing negative infinity (see ANSI/IEEE 754-1985)

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

IEEE	Institute of Electrical and Electronics Engineers
INIT	capable of initiating a service request
IP	Internet Protocol - RFC 791
ISO	International Organization for Standardization
KNX	The Konnex System Specification: EIB is the core protocol of the Konnex standard. The Konnex System Specification reflects the current status for EIB.
L	data link (prefix)
LAN	local area network
LLC	logical link control (ISO 8802-2)
LPCI	link protocol control information
LPDU	link protocol data unit
LSAP	link service access point (X'82' for BACnet)
LSDU	link service data unit
M	mandatory
M(=)	mandatory (The parameter is semantically equivalent to the parameter in the service primitive to its immediate left in the table.)
MA	medium access (prefix)
MAC	medium access control
MPCI	MAC protocol control information
MPDU	MAC layer protocol data unit
MSDU	MAC service data unit
MS/TP	master-slave/token-passing
N	network layer (prefix)
NaN	"Not a Number", a unique binary pattern representing an invalid number (see ANSI/IEEE 754-1985)
NP	network priority
NPCI	network protocol control information
NPDU	network layer protocol data unit
NRZ	non-return to zero
NSAP	network service access point
NSDU	network service data unit
O	indicates that support of a property is optional
OSI	open systems interconnection
P	physical layer (prefix)
PAC	ARCNET data packet header octet
PCI	protocol control information
PDU	protocol data unit
PICS	protocol implementation conformance statement
PK	Private Key
PPCI	physical layer protocol control information
PPDU	physical protocol data unit
PPP	Point-To-Point protocol - RFC 1661
PSDU	physical service data unit
PTP	point-to-point
R	indicates that a property shall be supported and readable using BACnet services
REQ	request primitive
RFC	request for comment
RSP	response primitive
S	selection
S(=)	selection (The parameter is semantically equivalent to the parameter in the service primitive to its immediate left in the table.)
SA	local network source MAC layer address
SAP	service access point
SC	ARCNET system code (X'CD' for BACnet)
SDU	service data unit
SID	ARCNET source MAC address
SK	Session Key

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

SLEN	1-octet length of original source MAC layer address
SLIP	Serial Line Internet Protocol -RFC 1055
SNET	2-octet original source network number
SPC	standard project committee
SSAP	LLC source service access point (X'82' for BACnet)
TSM	transaction state machine
U	user option
U(=)	user option (The parameter is semantically equivalent to the parameter in the service primitive to its immediate left in the table.)
UART	universal asynchronous receiver/transmitter
UDP	User Datagram Protocol - RFC 768
VT	virtual terminal
W	indicates that a property shall be supported, readable, and writable using BACnet services
X'	denotes that hexadecimal notation is used between the single quotes
XID	eXchange IDentification (ISO 8802-2)

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

4 BACnet PROTOCOL ARCHITECTURE

The Open System Interconnection (OSI) - Basic Reference Model (ISO 7498) is an international standard that defines a model for developing multi-vendor computer communication protocol standards. The OSI model addresses the general problem of computer-to-computer communication and breaks this very complex problem into seven smaller, more manageable sub-problems, each of which concerns itself with a specific communication function. Each of these sub-problems forms a "layer" in the protocol architecture.

The seven layers are arranged in a hierarchical fashion as shown in Figure 4-1. A given layer provides services to the layers above and relies on services provided to it by the layers below. Each layer can be thought of as a black box with carefully defined interfaces on the top and bottom. An application process connects to the OSI application layer and communicates with a second, remote application process. This communication appears to take place between the two processes as if they were connected directly through their application layer interfaces. Minimal knowledge or understanding of the other layers is required. In a similar manner, each layer of the protocol relies on lower layers to provide communication services and establishes a virtual peer-to-peer communication with its companion layer on the other system. The only real connection takes place at the physical layer.



Figure 4-1. The ISO Open Systems Interconnection Basic Reference Model.

The OSI model addresses computer-to-computer communication from a very general perspective. It was designed to deal with the problems associated with computers in large, complex networks communicating with other computers in networks anywhere in the world. In this environment, computers can be separated by long distances and the messages might pass through several intermediate points, each of which may have to make routing decisions or perform some type of translation. Complex synchronization and error recovery schemes may also be needed.

The cost of implementing such a protocol today is prohibitively high for most building automation applications and is not generally required. Nevertheless, the OSI model is a good one to use for a building automation protocol if consideration is

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

given to including only the OSI functionality that is actually needed, thereby collapsing the seven-layer architecture. In a collapsed architecture, only selected layers of the OSI model are included. The other layers are effectively null, thus reducing message length and communication processing overhead. Such a collapsed architecture permits the building automation industry to take advantage of lower cost, mass-produced processor and local area network technologies such as have been developed for the process control and office automation industries. The use of readily available, widespread technologies, such as Ethernet[1], ARCNET[2], and LonTalk[3], will lower the cost, increase performance, and open new doors to system integration.

4.1 The BACnet Collapsed Architecture

BACnet is based on a four-layer collapsed architecture that corresponds to the physical, data link, network, and application layers of the OSI model as shown in Figure 4-2. The application layer and a simple network layer are defined in the BACnet standard. BACnet provides five options that correspond to the OSI data link and physical layers. Option 1 is the logical link control (LLC) protocol defined by ISO 8802-2 Type 1, combined with the ISO 8802-3 medium access control (MAC) and physical layer protocol. ISO 8802-2 Type 1 provides unacknowledged connectionless service only. ISO 8802-3 is the international standard version of the well-known "Ethernet" protocol. Option 2 is the ISO 8802-2 Type 1 protocol combined with ARCNET (ATA/ANSI 878.1). Option 3 is a Master-Slave/Token-Passing (MS/TP) protocol designed specifically for building automation and control devices as part of the BACnet standard. The MS/TP protocol provides an interface to the network layer that looks like the ISO 8802-2 Type 1 protocol and controls access to an EIA-485 physical layer. Option 4, the Point-To-Point protocol, provides mechanisms for hardwired or dial-up serial, asynchronous communication. Option 5 is the LonTalk protocol. Collectively these options provide a master/slave MAC, deterministic token-passing MAC, high-speed contention MAC, dial-up access, star and bus topologies, and a choice of twisted-pair, coax, or fiber optic media. The details of these options are described in Clauses 7 through 11.

A four-layer collapsed architecture was chosen after careful consideration of the particular features and requirements of BAC networks, including a constraint that protocol overhead needed to be as small as possible. The reasoning behind the selection of the physical, data link, network, and application layers for inclusion in the BACnet architecture is outlined in this subclause.

What layers are required for the proper operation of a BAC network? BAC networks are local area networks. This is true even though in some applications it is necessary to exchange information with devices in a building that is very far away. This long-distance communication is done through telephone networks. The routing, relaying, and guaranteed delivery issues are handled by the telephone system and can be considered external to the BAC network. BAC devices are static. They don't move from place to place and the functions that they are asked to perform do not change in the sense that a manufacturing device may make one kind of part today and some very different part tomorrow. These are among the features of BAC networks that can be used to evaluate the appropriateness of the layers in the OSI model.



[1] Ethernet is a registered trademark of Digital Equipment Corporation, Intel, and Xerox and is the basis for international standard ISO 8802-3.

[2] ARCNET is a registered trademark of Datapoint Corporation.

[3] LonTalk is a registered trademark of Echelon Corporation.

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

Figure 4-2. BACnet collapsed architecture.

The physical layer provides a means of connecting the devices and transmitting the electronic signals that convey the data. Clearly the physical layer is needed in a BAC protocol.

The data link layer organizes the data into frames or packets, regulates access to the medium, provides addressing, and handles some error recovery and flow control. These are all functions that are required in a BAC protocol. The conclusion is that the data link layer is needed.

Functions provided by the network layer include translation of global addresses to local addresses, routing messages through one or more networks, accommodating differences in network types and in the maximum message size permitted by those networks, sequencing, flow control, error control, and multiplexing. BACnet is designed so that there is only one logical path between devices, thus eliminating the need for optimal path routing algorithms. A network is made up of one or more physical segments connected by repeaters or bridges but with a single local address space. In the case of a single network, most network layer functions are either unnecessary or duplicate data link layer functions. For some BACnet systems, however, the network layer is a necessity. This is the case when two or more networks in a BACnet internet use different MAC layer options. When this occurs, there is a need to recognize the difference between local and global addresses and to route messages to the appropriate networks. BACnet provides this limited network layer capability by defining a network layer header that contains the necessary addressing and control information.

The transport layer is responsible for guaranteeing end-to-end delivery of messages, segmentation, sequence control, flow control, and error recovery. Most of the functions of the transport layer are similar to functions in the data link layer, though different in scope. The scope of transport layer services is end-to-end whereas the scope of data link services is point-to-point across a single network. Since BACnet supports configurations with multiple networks, the protocol must provide the end-to-end services of the transport layer. Guaranteed end-to-end delivery and error recovery are provided in the BACnet application layer via message retry and timeout capabilities. Message segmentation and end-to-end flow control is required for buffer and processor resource management. This is because potentially large amounts of information may be returned for even simple BACnet requests. These functions are provided in the BACnet application layer. Last, sequence control is required in order to properly reassemble segmented messages. This is provided in the BACnet application layer within the segmentation procedure. Since BACnet is based on a connectionless communication model, the scope of the required services is limited enough to justify implementing these at a higher layer, thus saving the communication overhead of a separate transport layer.

The session layer is used to establish and manage long dialogues between communicating partners. Session layer functions include establishing synchronization checkpoints and resetting to previous checkpoints in the event of error conditions to avoid restarting an exchange from the beginning. Most communications in a BAC network are very brief. For example, reading or writing one or a few values, notifying a device about an alarm or event, or changing a setpoint. Occasionally longer exchanges take place, such as uploading or downloading a device. The few times when the services of this layer would be helpful do not justify the additional overhead that would be imposed on the vast majority of transactions, which are very brief and do not need them.

The presentation layer provides a way for communicating partners to negotiate the transfer syntax that will be used to conduct the communication. This transfer syntax is a translation from the abstract user view of data at the application layer to sequences of octets treated as data at the lower layers. If only one transfer syntax is permitted, then the presentation layer function reduces to an encoding scheme for representing the application data. BACnet defines such a fixed encoding scheme and includes it in the application layer, making an explicit presentation layer unnecessary.

The application layer of the protocol provides the communication services required by the applications to perform their functions, in this case monitoring and control of HVAC&R and other building systems. Clearly an application layer is needed in the protocol.

In summary:

(a) The resource and overhead costs for implementing a full OSI seven-layer architecture make it impractical for current building automation devices.

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

(b) Following the OSI model offers advantages in terms of adopting existing computer networking technology. This can result in cost savings and make integration with other computer network systems easier.

(c) The expectations and environment of building automation systems permit simplification of the OSI model by eliminating the functionality of some of the layers.

(d) A collapsed architecture made up of the physical, data link, network, and application layers is the optimum solution for today's building automation systems.

4.2 BACnet Network Topology

In the interest of application flexibility, BACnet does not prescribe a rigid network topology. Rather, BACnet devices are physically connected to one of four types of local area networks (LANs) or via dedicated or dial-up serial, asynchronous lines. These networks may then be further interconnected by BACnet routers as described in Clause 6.

In terms of LAN topology, each BACnet device is attached to an electrical medium or *physical segment*. A BACnet *segment* consists of one or more physical segments connected at the physical layer by *repeaters*. A BACnet *network* consists of one or more segments interconnected by *bridges*, devices that connect the segments at the physical and data link layers and may perform message filtering based upon MAC addresses; a network forms a single MAC address domain. Multiple networks, possibly employing different LAN technologies, may be interconnected by BACnet *routers* to form a BACnet *internetwork*. In a BACnet internetwork, there exists exactly one message path between any two nodes. These concepts are shown graphically in Figure 4-3.

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009



Figure 4-3. A BACnet internetwork illustrating the concepts of Physical Segments, Repeaters, Segments, Bridges, Networks, Half Routers, and Routers.

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

4.3 Security

The principal security threats to BACnet systems are people who, intentionally or by accident, modify a device's configuration or control parameters. Problems due to an errant computer are outside the realm of security considerations. One important place for security measures is the operator-machine interface. Since the operator-machine interface is not part of the communication protocol, vendors are free to include password protection, audit trails, or other controls to this interface as needed. In addition, write access to any properties that are not explicitly required to be "writable" by this standard may be restricted to modifications made only in virtual terminal mode or be prohibited entirely. This permits vendors to protect key properties with a security mechanism that is as sophisticated as they consider appropriate. BACnet also defines services that can be used to provide peer entity, data origin, and operator authentication. See Clause 24.

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

5 THE APPLICATION LAYER

5.1 The Application Layer Model

This clause presents a model of the BACnet application layer. The purpose of the model is to describe and illustrate the interaction between the application layer and application programs, the relationship between the application layer and lower layers in the protocol stack, and the peer-to-peer interactions with a remote application layer. This model is not an implementation specification.

An Application Process is that functionality within a system that performs the information processing required for a particular application. All parts of the Application Process outside the Application Layer, (i.e., those that do not concern the communication function) are outside the scope of BACnet. The part of the Application Process that is within the Application Layer is called the Application Entity. In other words, an Application Entity is that part of the Application Process related to the BACnet communication function. An application program interacts with the Application Entity through the Application Program Interface (API). This interface is not defined in BACnet, but it would probably be a function, procedure, or subroutine call in an actual implementation. These concepts are illustrated in Figure 5-1. The shaded region indicates the portion of the Application Process that is within the BACnet Application Layer.



Figure 5-1. Model of a BACnet Application Process.

The Application Entity is itself made up of two parts: the BACnet User Element and the BACnet Application Service Element (ASE). The BACnet ASE represents the set of functions or application services specified in Clauses 13 through 17 and Clause 24. The BACnet User Element carries out several functions in addition to supporting the local API. It represents the implementation of the "service procedure" portion of each application service. It is responsible for maintaining information about the context of a transaction, including generating invoke IDs and remembering which invoke ID goes with which application service request (response) to (from) which device. It is also responsible for maintaining the time-out

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

counters that are required for the retrying of a transmission. The BACnet User Element also presides over the mapping of a device's activities into BACnet objects.

Information exchanged between two peer application processes is represented in BACnet as an exchange of abstract service primitives, following the ISO conventions contained in the OSI technical report on service conventions, ISO TR 8509. These primitives are used to convey service-specific parameters that are defined in Clauses 13 through 17 and Clause 24. Four service primitives are defined: request, indication, response, and confirm. The information contained in the primitives is conveyed using a variety of protocol data units (PDUs) defined in this standard. In order to make clear which BACnet PDU is being used, the notation will be as follows:

CONF_SERV.request	CONF_SERV.indication	CONF_SERV.response	CONF_SERV.confirm
UNCONF_SERV.request	UNCONF_SERV.indication		
SEGMENT_ACK.request	SEGMENT_ACK.indication		
REJECT.request	REJECT.indication		
ABORT.request	ABORT.indication		

The designation CONF_SERV indicates that BACnet confirmed service PDUs are being used. Similarly, the designations UNCONF_SERV, SEGMENT_ACK, ERROR, REJECT, and ABORT indicate that unconfirmed service PDUs, segment acknowledge PDUs, error PDUs, reject PDUs, and abort PDUs, respectively, are being used.

An application program that needs to communicate with a remote application process accesses the local BACnet User Element through the API. Some of the API parameters, such as the identity (address) of the device to which the service request is to be sent and protocol control information, is passed directly down to the network or data link layers. The remainder of the parameters make up an application service primitive that is passed from the BACnet User Element to the BACnet ASE. Conceptually, the application service primitive results in the generation of an APDU that becomes the data portion of a network service primitive, which is passed to the network layer through the Network Service Access Point (NSAP). Similarly this request passes down through the lower layers of the protocol stack in the local device. This process is illustrated in Figure 5-2. The message is then transmitted to the remote device, where it is passed up through the protocol stack in the remote device, eventually appearing as an indication primitive passed from the remote BACnet ASE to the remote BACnet User Element. The response from the remote device, if any, returns to the initiator of the service in a similar fashion (see 5.5).

In addition to the service primitives and the service specific parameters, the application entity exchanges interface control information (ICI) parameters with the application program via the API. The content of the ICI is dependent upon the service primitive type. The ICI parameters received by the application entity provide the information that is passed on to the lower layers (as ICI across layer interfaces) to help them construct their PDUs. The ICI parameters that are provided by the application entity to the application programs contain information recovered by the lower layers from their respective PDUs.

The following ICI parameters are exchanged with the various service primitives across an API:

'destination_address' (DA): the address of the device(s) intended to receive the service primitive. Its format (device name, network address, etc.) is a local matter. This address may also be a multicast, local broadcast or global broadcast type.

'source_address' (SA): the address of the device from which the service primitive was received. Its format (device name, network address, etc.) is a local matter.

'network_priority' (NP): a four-level network priority parameter described in 6.2.2.

'data_expecting_reply' (DER): a Boolean parameter that indicates whether (TRUE) or not (FALSE) a reply service primitive is expected for the service being issued.

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009



Figure 5-2. BACnet protocol stack and data flow.

Documents
ASHRAE 135-2004
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

Table 5-1 describes the applicability of the ICI parameters to the service primitives.

Table 5-1. Applicability of ICI parameters for abstract service primitives

Service Primitive	DA	SA	NP	DER
CONF_SERV.request	Yes	No	Yes	Yes
CONF_SERV.indication	Yes	Yes	Yes	Yes
CONF_SERV.response	Yes	No	Yes	Yes
CONF_SERV.confirm	Yes	Yes	Yes	No
UNCONF_SERV.request	Yes	No	Yes	No
UNCONF_SERV.indication	Yes	Yes	Yes	No
REJECT.request	Yes	No	Yes	No
REJECT.indication	Yes	Yes	Yes	No
SEGMENT_ACK.request	Yes	No	Yes	No
SEGMENT_ACK.indication	Yes	Yes	Yes	No
ABORT.request	Yes	No	Yes	No
ABORT.indication	Yes	Yes	Yes	No

A "BACnetDevice" is any device, real or virtual, that supports digital communication using the BACnet protocol. Each BACnet Device contains exactly one Device object, as defined in 12.11. A BACnet Device is uniquely located by an NSAP, which consists of a network number and a MAC address.

In most cases, a physical device will implement a single BACnet Device. It is possible, however, that a single physical device may implement a number of "virtual" BACnet Devices. This is described in Annex H.

5.1.1 Confirmed Application Services

BACnet defines confirmed application services based on a client and server communication model. A client requests service from a server via a particular service request instance. The server provides service to a client and responds to the request. This relationship is illustrated in Figure 5-3. The BACnet-user that assumes the role of a client is called the "requesting BACnet-user" and the BACnet-user that assumes the role of the server is called the "responding BACnet-user."



Figure 5-3. Relationship of a client and server.

A requesting BACnet-user issues a CONF_SERV.request primitive, which causes a request PDU to be sent. When a response PDU arrives, the requesting BACnet-user receives a CONF_SERV.confirm primitive. When a request PDU arrives, the

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

responding BACnet-user receives a CONF_SERV.indication primitive. The responding BACnet-user issues a CONF_SERV.response primitive, which causes a response PDU to be sent. Thus, the requesting BACnet-user and the responding BACnet-user play a role in both sending and receiving PDUs. The term "sending BACnet-user" applies to a BACnet user that initiates the sending of a PDU. The term "receiving BACnet-user" applies to a BACnet-user that receives an indication that a PDU has arrived.

5.1.2 Unconfirmed Application Services

The client and server model, and the terms "requesting BACnet-user" and "responding BACnet-user," do not apply to unconfirmed services. The terms "sending BACnet-user" and "receiving BACnet-user" do apply, however, and they are used to define the service procedure for unconfirmed services.

5.2 Segmentation of BACnet Messages

To provide for messages that are longer than the maximum length supported by a communications network, or by the sending or receiving device, BACnet provides a method to perform application layer segmentation. In BACnet, only Confirmed-Request and ComplexACK messages may be segmented. Segmentation is an optional feature of BACnet.

5.2.1 Message Segmentation Rules

This subclause prescribes rules for dividing a message into segments.

5.2.1.1 Rules for Segmenting APDU Data Streams

Each BACnet message is encoded into a sequence of tags and values according to the relevant ASN.1 definitions in Clause 21 and the encoding rules of Clause 20. The following rules apply to segmenting this data stream:

(a) If possible, an entire message shall be sent in a single APDU.

(b) If an entire message cannot be sent in a single APDU, the message shall be segmented into the minimum number of APDUs possible.

(c) Messages shall be segmented only at octet boundaries.

5.2.1.2 Maximum APDU Length

The maximum length of a BACnet APDU shall be the smallest of

(a) the maximum APDU size transmittable by a device, which may be restricted by local buffer limitations and is a local matter;

(b) the maximum APDU size conveyable by the internetwork to the remote device, which is constrained by the maximum NPDU length permitted by the data links used by the local, remote, and any intervening networks, as specified in Clause 6;

(c) the maximum APDU size accepted by the remote peer device, which must be at least 50 octets.

If the sending device is the requesting BACnet-user, i.e., the APDU to be sent is a BACnet-Confirmed-Request-PDU or a BACnet-Unconfirmed-Request-PDU, then the maximum APDU size accepted by the remote peer is specified by the Max_APDU_Length_Accepted property of the remote peer's Device object. The value of this property may be read using the read property services described in Clause 15 or the value may be obtained from the 'Max APDU Length Accepted' parameter of an I-Am service request received from the remote device. The remote peer may be solicited to transmit an I-Am service request by sending it a Who-Is service request, as described in 16.9

If the sending device is not the requesting BACnet-user, i.e., the APDU to be sent is a BACnet-ComplexACK-PDU, then the maximum APDU size accepted by the remote peer is specified in the 'Max APDU Length Accepted' parameter of the BACnet-Confirmed-Request-PDU for which this is a response.

The value determined by the above constraints will be designated the maximum-transmittable-length. Note that maximum-transmittable-length will in general not be a constant unless minimum values are used for each constraint.

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

5.2.1.3 Maximum Segments Accepted

The maximum number of segments transmitted in a Confirmed-Request or ComplexACK message shall be the smallest of:

(a) the maximum number of segments transmittable by a device, which may be restricted by local limitations and is a local matter;

(b) the maximum number of segments accepted by the remote peer device.

If the sending device is the requesting BACnet-user, i.e., the message to be sent is a Confirmed-Request, then the maximum number of segments accepted by the remote peer device is specified in the Max_Segments_Accepted property of the remote peer's Device object.

If the sending device is not the requesting BACnet-user, i.e., the message to be sent is a ComplexACK, then the maximum number of segments accepted by the remote peer device is specified in the 'Max Segments Accepted' parameter of the BACnet-Confirmed-Request-PDU for which this is a response.

5.2.2 Segmentation Protocol Control Information (PCI)

To provide for the possibility of segmented messages, the headers of the BACnet-Confirmed-Request-PDU and BACnet-ComplexACK-PDU contain two Boolean parameters called 'Segmented Message' and 'More Follows.'

If the length of a fully encoded message of the type conveyed by one of the above APDUs results in an APDU whose length is less than or equal to the maximum-transmittable-length as determined according to 5.2.1, the 'Segmented Message' and 'More Follows' parameters shall both be set to FALSE.

If, however, the encoded length of a message would result in an APDU length greater than the maximum-transmittable-length as determined according to 5.2.1, the 'Segmented Message' parameter shall be set to TRUE for all segments, and the 'More Follows' parameter shall be set to TRUE for all segments except the last.

Two additional parameters are also present, conditionally, in the header of each APDU carrying a segment of a Confirmed-Request message or a ComplexACK message. The first conditional parameter is the 'Sequence Number.' This one-octet unsigned integer is used by the segment transmitter to indicate the position of the current segment in the series of segments composing the complete message. The second conditional parameter is the 'Proposed Window Size.' This one-octet unsigned integer is used by the segment transmitter to indicate the maximum number of message segments that it is prepared to transmit before it must receive a SegmentACK. The use of these parameters in the transmission of segmented messages is described in 5.3 and 5.4.

The 'Sequence Number' of the initial segment shall be zero. The segment receiver may request the transmission of the next segment or group of segments by sending a SegmentACK-PDU containing the 'Sequence Number' parameter of the last successfully received segment. Such a request shall also serve as an acknowledgment of this segment. If the Window Size is greater than one, such a SegmentACK-PDU shall also serve to acknowledge any previously transmitted but unacknowledged segments.

If either party in a segmented transaction wishes to terminate the transaction, that party may issue an Abort-PDU.

5.3 Transmission of BACnet APDUs

The formal description of the transmission and reception protocol for BACnet APDUs is contained in the Transaction State Machine description given in 5.4. This subclause is intended only as an overview of the protocol.

5.3.1 Confirmed-Request Message Transmission

Upon transmitting a complete unsegmented Confirmed-Request message or upon receiving the SegmentACK acknowledging the final segment of a segmented Confirmed-Request message, a client device shall start a timer that indicates the length of time the message has been outstanding. The timer shall be canceled upon the receipt of an Error, Reject, Abort, SimpleACK, or ComplexACK APDU for the outstanding Confirmed-Request message, and the client application shall be notified. If the timer exceeds the value of the APDU_Timeout property in the client's Device object, then the complete Confirmed-Request message shall be retransmitted and the timer shall be reset to zero. All retransmitted Confirmed-Request messages shall follow this same procedure until the message has been retransmitted the number of times indicated in the

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

Number_Of_APDU_Retries property of the client's Device object. If, after the Confirmed-Request message is retransmitted the appropriate number of times, a response is still not received, the message shall be discarded and the client application shall be notified.

5.3.2 Segmented Confirmed-Request Message Transmission

Before sending the first segment of a segmented Confirmed-Request-PDU, a client device shall choose a Proposed Window Size to indicate the maximum number of message segments it is prepared to transmit before it must receive a SegmentACK. The means of choosing the Proposed Window Size are a local matter, except that the value shall be in the range 1 to 127, inclusive. The Proposed Window Size shall be carried by the parameter of that name in each segment of the Confirmed-Request-PDU. The value of Proposed Window Size shall be the same in each segment of the Confirmed-Request-PDU.

Upon transmitting the first segment of a Confirmed-Request message, a client device shall start a timer that indicates the length of time this message segment has been outstanding. The timer shall be canceled upon the receipt of a Reject, Abort, or SegmentACK APDU for the outstanding Confirmed-Request message segment. If the timer exceeds the value of the APDU_Segment_Timeout property in the client's Device object, then the segment shall be retransmitted and the timer shall be reset to zero. All retransmitted segments shall follow this same procedure until the message segment has been retransmitted the number of times indicated in the Number_Of_APDU_Retries property of the client's Device object. If, after the message segments are retransmitted the appropriate number of times, a response is still not received, the message shall be discarded and the client application shall be notified.

Upon receipt of the first segment of a segmented Confirmed-Request-PDU, the server device shall choose an Actual Window Size to indicate the number of sequential message segments it expects to receive before it transmits a SegmentACK. The means of choosing the Actual Window Size are a local matter, except that the value shall be less than or equal to the 'proposed-window-size' parameter contained in the Confirmed-Request-PDU and shall be in the range 1 to 127, inclusive. The value of Actual Window Size shall be the same in each SegmentACK sent in response to a given Confirmed-Request. Regardless of the value of Actual Window Size, a SegmentACK shall be sent in response to the first segment of a Confirmed-Request.

Upon receipt of a SegmentACK APDU, the client device shall set its Actual Window Size equal to the value associated with the 'actual-window-size' parameter in the SegmentACK APDU. After this point, the client has authorization to send as many segments as the 'actual-window-size' parameter indicates before waiting for a SegmentACK APDU. No more than T_{seg} may be allowed to elapse between the receipt of a SegmentACK APDU and the transmission of a segment. No more than T_{seg} may be allowed to elapse between the transmission of successive segments of a group. After transmitting a set of segments that fills the window or completes the message, a client device shall start a timer that indicates the length of time these message segments have been outstanding. The timer shall be canceled upon receipt of a Reject, Abort, or SegmentACK APDU for some or all of the outstanding Confirmed-Request message segments. If the timer exceeds the value of the APDU_Segment_Timeout property in the client's Device object, then the segments shall be retransmitted and the timer shall be reset to zero. All retransmitted segments shall follow this same procedure until the message segments have been retransmitted the number of times indicated in its Device object's Number_Of_APDU_Retries property. If, after the Confirmed-Request message segments are retransmitted the appropriate number of times, a response is still not received, the message shall be discarded and the client application shall be notified.

It is possible to receive a Reject, Abort, or SegmentACK APDU during the sending of a sequence of Confirmed-Request segments even though the number of outstanding segments is less than indicated by the Actual Window Size. In this case, receipt of a Reject or Abort APDU shall terminate the Confirmed-Request transaction. Receipt of a SegmentACK APDU shall be considered as an acknowledgment for the segments up to and including the number indicated in the 'sequence-number' parameter of the SegmentACK APDU. Any unacknowledged segments shall be retransmitted following the above procedure.

It is recognized that in some cases where a Reject, Abort, or SegmentACK APDU is received, the client device may have sent, or irretrievably queued for sending, one or more (but less than Actual Window Size) additional Confirmed-Request-PDU segments.

5.3.3 Segmented ComplexACK Message Transmission

Before sending the first segment of a segmented ComplexACK-PDU, a server device shall choose a Proposed Window Size to indicate the maximum number of message segments it is prepared to transmit before it must receive a SegmentACK. The

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

means of choosing the Proposed Window Size are a local matter, except that the value shall be in the range 1 to 127, inclusive. The Proposed Window Size shall be carried by the parameter of that name in each segment of the Confirmed-Request-PDU. The value of Proposed Window Size shall be the same in each segment of the ComplexACK-PDU.

Upon transmitting the first segment of a ComplexACK message, a server device shall start a timer that indicates the length of time this message segment has been outstanding. The timer shall be canceled upon the receipt of an Abort or SegmentACK APDU for the outstanding ComplexACK message segment. If the timer exceeds the value of the APDU_Segment_Timeout property in the server's Device object, then the segment shall be retransmitted and the timer shall be reset to zero. All retransmitted segments shall follow this same procedure until the message segment has been retransmitted the number of times indicated in the Number_Of_APDU_Retries property of the server's Device object. If, after the message segments are retransmitted the appropriate number of times, a response is still not received, the message shall be discarded.

Upon receipt of the first segment of a segmented ComplexACK-APDU, the client device shall choose an Actual Window Size to indicate the number of sequential message segments it expects to receive before it transmits a SegmentACK. The means of choosing the Actual Window Size are a local matter, except that the value shall be less than or equal to the 'proposed-window-size' parameter contained in the ComplexACK-PDU and shall be in the range 1 to 127, inclusive. The value of Actual Window Size shall be the same in each SegmentACK sent in response to a given ComplexACK. Regardless of the value of Actual Window Size, a SegmentACK shall be sent in response to the first segment of a ComplexACK.

Upon receipt of a SegmentACK APDU, the server device shall set its Actual Window Size equal to the value associated with the 'actual-window-size' parameter in the SegmentACK APDU. After this point, the server has authorization to send as many segments as the 'actual-window-size' parameter indicates before waiting for a SegmentACK APDU. No more than T_{seg} may be allowed to elapse between the receipt of a SegmentACK APDU and the transmission of a segment. No more than T_{seg} may be allowed to elapse between the transmission of successive segments of a group. After transmitting a set of segments that fills the window or completes the message, a server device shall start a timer that indicates the length of time these message segments have been outstanding. The timer shall be canceled upon receipt of an Abort or SegmentACK APDU for some or all of the outstanding ComplexACK message segments. If the timer exceeds the value of the APDU_Segment_Timeout property in the server's Device object, then the segments shall be retransmitted and the timer shall be reset to zero. All retransmitted segments shall follow this same procedure until the message segments have been retransmitted the number of times indicated in the Number_Of_APDU_Retries property of the server's Device object. If, after the ComplexACK message segments are retransmitted the appropriate number of times, a response is still not received, the message shall be discarded.

It is possible to receive an Abort or SegmentACK APDU during the sending of a sequence of ComplexACK segments even though the number of outstanding segments is less than indicated by the Actual Window Size. In this case, receipt of an Abort APDU shall terminate the ComplexACK transaction. Receipt of a SegmentACK APDU shall be considered as an acknowledgment for the segments up to and including the number indicated in the 'sequence-number' parameter of the SegmentACK APDU. Any unacknowledged segments shall be retransmitted following the above procedure.

It is recognized that in some cases where an Abort or SegmentACK APDU is received, the server device may have sent, or irretrievably queued for sending, one or more (but less than Actual Window Size) additional ComplexACK segments.

5.3.4 SegmentACK APDU Transmission

A device shall transmit a SegmentACK upon any of the following conditions:

(a) The device receives the initial segment of a segmented message. In this case, the 'negative-ACK' parameter of the SegmentACK shall have a value of FALSE, indicating that this is a positive acknowledgment, and the 'sequence-number' parameter of the SegmentACK shall have a value of zero, indicating that the first segment has been acknowledged and that the segment transmitter may continue sending, commencing with the next sequential segment.

(b) The device receives a quantity of unacknowledged, sequentially numbered segments for this transaction equal to the Actual Window Size. In this case, the 'negative-ACK' parameter of the SegmentACK shall have a value of FALSE, indicating that this is a positive acknowledgment, and the 'sequence-number' parameter of the SegmentACK shall have a value equal to the 'sequence-number' parameter of the last received segment, indicating that all segments up to and including 'sequence-number' have been acknowledged and that the segment transmitter may continue sending, commencing with the next sequential segment.

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

(c) The device receives a segment out of order (possibly indicating that a segment has been missed). In this case, the segment receiver shall discard the out-of-order segment. In this context, "out of order" means a segment whose 'sequence-number' is not equal to the next expected 'sequence-number.' The 'negative-ACK' parameter of the SegmentACK shall have a value of TRUE, indicating that this is a negative acknowledgment. The 'sequence-number' parameter of the SegmentACK shall have a value equal to the 'sequence-number' parameter of the last received correctly ordered segment, indicating that all segments up to and including 'sequence-number' have been acknowledged and that the segment transmitter should resend, commencing with the next sequential segment after that indicated by the 'sequence-number' parameter contained in the SegmentACK.

(d) The device receives the final segment of a message. In this case, the 'negative-ACK' parameter of the SegmentACK shall have a value of FALSE, indicating that this is a positive acknowledgment, and the 'sequence-number' parameter of the SegmentACK shall have a value equal to the 'sequence-number' parameter of the final message segment, indicating that all segments up to and including the final segment have been acknowledged.

5.3.5 Duplicate APDUs and Message Segments

5.3.5.1 Terminating Client TSMs

When using the BACnet error recovery procedures there is a possibility of the reception of duplicate messages or message segments during a transaction. At the client, a transaction begins, and a Transaction State Machine is created, when the first or only segment of a Confirmed-Request APDU is sent. The transaction ends when the client discards the Transaction State Machine due to one of the following circumstances:

(a) after reception from the server of a SimpleACK, unsegmented ComplexACK, Error, Reject, or Abort APDU containing the transaction's invokeID;

(b) after transmission to the server of a SegmentACK APDU for the final segment of a segmented ComplexACK APDU received from the server;

(c) after exhausting the timeout and retry logic described in the previous subclauses;

(d) after transmission to the server of an Abort APDU containing the transaction's invokeID (i.e., the client aborts the transaction).

5.3.5.2 Terminating Server TSMs

At the server, a transaction begins, and a Transaction State Machine is created when the first or only segment of a Confirmed-Request APDU is received. The transaction ends when the server discards the Transaction State Machine due to one of the following circumstances:

(a) after transmission to the client of a SimpleACK, unsegmented ComplexACK, Error, Reject, or Abort APDU containing the transaction's invokeID;

(b) after reception from the client of a SegmentACK APDU for the final segment of a segmented ComplexACK APDU transmitted by the server;

(c) after reception from the client of an Abort APDU containing the transaction's invokeID;

(d) after exhausting the timeout and retry logic described in the previous subclauses during the transmission of a segmented ComplexACK APDU.

5.3.5.3 Duplicate Message Procedures

The procedure for handling duplicate messages and message segments is as follows:

(a) The server receives a duplicate Confirmed-Request message. If the server has the capability of detecting a duplicate Confirmed-Request message, the message shall be discarded. If the server cannot distinguish between duplicate and

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

non-duplicate messages, then the Confirmed-Request message shall be serviced. In this case, the client shall discard the server's response since the Invoke ID of the response will not bind to an active state transaction state machine.

(b) The server receives a duplicate Confirmed-Request message segment, that is, one that has already been acknowledged with a SegmentACK. In this case, the server shall discard the duplicate segment but shall return an appropriate SegmentACK APDU. A segment can be identified uniquely by the peer address, Invoke ID, and Sequence Number of the segment.

(c) The client receives a duplicate ComplexACK segment, that is, one that has already been acknowledged with a SegmentACK. In this case, the client shall discard the duplicate segment but shall return an appropriate SegmentACK APDU. A segment can be identified uniquely by the peer address, Invoke Id, and Sequence Number of the segment.

(d) A Device receives a duplicate SegmentACK APDU. In this case, the device shall discard the duplicate SegmentACK APDU. Other actions, including the possible re-sending of message segments, shall occur as specified in 5.4.

5.3.6 Stale Resource Disposal

The error recovery procedure described here requires resources from both the server and the client. In the event that the error recovery process fails, the resources dedicated to this process need to be freed. In general, the resources that need to be freed are transaction specific and consist of a Transaction State Machine (TSM), timers, and APDU or APDU segment buffers. The exact time period before the resources should be freed is a local matter dependent upon the system design. As a design suggestion, it is recommended that resources should be considered stale and consequently freed:

(a) at the client, when a complete response to the Confirmed-Request APDU is received;

(b) at the client, when a Confirmed-Request APDU has been retransmitted the number of times specified in the Number_Of_APDU_Retries property without success;

(c) at the client, when a Confirmed-Request APDU segment has been retransmitted the number of times specified in the Number_Of_APDU_Retries property without success;

(d) at the server, when a complete response to a Confirmed-Request APDU has been transmitted and any associated SegmentACK received;

(e) at the server, when a ComplexACK APDU segment has been retransmitted the number of times specified in the Number_Of_APDU_Retries property without success;

(f) at any device, when a SegmentACK APDU has been transmitted and additional segments have not been received before the segment timeout expires.

5.4 Application Protocol State Machines

BACnet APDUs may be divided into two classes: those sent by requesting BACnet-users (clients) and those sent by responding BACnet-users (servers). All BACnet devices shall be able to act as responding BACnet-users and therefore shall be prepared to receive APDUs sent by requesting BACnet-users. Many devices will also be able to act as requesting BACnet-users, and such devices shall be prepared to receive APDUs sent by responding BACnet-users.

APDUs sent by requesting BACnet-users (clients):

BACnet-Unconfirmed-Request-PDU
BACnet-Confirmed-Request-PDU
BACnet-SegmentACK-PDU with 'server' = FALSE
BACnet-Abort-PDU with 'server' = FALSE

Documents
Document Sharing Hub
Full document details: BS EN ISO 16484-5:2008+A1:2009

APDUs sent by responding BACnet-users (servers):

BACnet-SimpleACK-PDU
BACnet-ComplexACK-PDU
BACnet-Error-PDU
BACnet-Reject-PDU
BACnet-SegmentACK-PDU with 'server' = TRUE
BACnet-Abort-PDU with 'server' = TRUE

Both the requesting and the responding BACnet-user shall create and maintain a Transaction State Machine (TSM) for each transaction. The TSM shall be created when the transaction begins and shall be disposed of when the transaction ends. In the state machine descriptions that follow, the creation of a TSM is represented by a transition out of the IDLE state, and the disposal of a TSM is represented by a transition into the IDLE state. A transaction is uniquely identified by the client BACnetAddress, the server BACnetAddress, and the Invoke ID (if any).

When a PDU is received from the network layer, the PDU type, the source and destination BACnetAddresses, and the Invoke ID (if any) of the PDU shall be examined to determine the type (requesting BACnet-user or responding BACnet-user) and the identity of the TSM to which the PDU shall be passed. If no such TSM exists, one shall be created.

When a request is received from the application program, the request type, the source and destination BACnetAddresses, and the Invoke ID (if any) of the request shall be examined to determine the type (requesting BACnet-user or responding BACnet-user) and the identity of the TSM to which the request shall be passed. If no such TSM exists, one shall be created.

In order to simplify the state machine description, only the case of segmentation by the Application Entity is shown. Segmentation by the Application Program is possible as well. In this case, wherever the current TSM receives a segment or group of segments and sends SegmentACK, the modified TSM would instead pass the segments to the Application Program, and SegmentACK would be sent only upon direction from the Application Program via the SEGMENT_ACK.request primitive. Reception by the modified state machine of a SegmentACK-PDU would cause it to pass a SEGMENT_ACK.indication primitive to the Application Program.

5.4.1 Variables And Parameters

The following variables are defined for each instance of Transaction State Machine:

RetryCount used to count APDU retries

SegmentRetryCount used to count segment retries

SentAllSegments used to control APDU retries and the acceptance of server replies

LastSequenceNumber stores the sequence number of the last segment received in order

InitialSequenceNumber stores the sequence number of the first segment of a sequence of segments that fill a window

ActualWindowSize stores the current window size

ProposedWindowSize stores the window size proposed by the segment sender

SegmentTimer used to perform timeout on PDU segments

RequestTimer used to perform timeout on Confirmed Requests

The following parameters are used in the description:

$\mathbf{T_{seg}}$ This parameter is the length of time a node shall wait for a SegmentACK-PDU after sending the final segment of a sequence. Its value is the value of the APDU_Segment_Timeout property of the node's Device object.

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

$T_{wait_for_seg}$ This parameter is the length of time a node shall wait after sending a SegmentACK-PDU for an additional segment of the message. Its value is equal to four times the value of the APDU_Segment_Timeout property of the node's Device object.

T_{out} This parameter represents the value of the APDU_Timeout property of the node's Device object.

N_{retry} This parameter represents the value of the Number_Of_APDU_Retries property of the node's Device object.

5.4.2 Function InWindow

The function "InWindow" performs a modulo 256 compare of two unsigned eight-bit sequence numbers. All computations and comparisons are modulo 256 operations on unsigned eight-bit quantities.

function InWindow(seqA, seqB)

(a) if seqA minus seqB, modulo 256, is less than ActualWindowSize, then return TRUE
(b) else return FALSE.

Example (not normative): if ActualWindowSize is equal to 4, then
InWindow(0, 0) returns TRUE
InWindow(1, 0) returns TRUE
InWindow(3, 0) returns TRUE
InWindow(4, 0) returns FALSE
InWindow(4, 5) returns FALSE (since the modulo 256 difference 4 - 5 = 255)
InWindow(0, 255) returns TRUE (since the modulo 256 difference 0 - 255 = 1)

5.4.3 Function FillWindow

The function "FillWindow" sends PDU segments either until the window is full or until the last segment of a message has been sent. No more than T_{seg} may be allowed to elapse between the receipt of a SegmentACK APDU and the transmission of a segment. No more than T_{seg} may be allowed to elapse between the transmission of successive segments of a sequence.

function FillWindow(sequenceNumber)

(a) Set local variable ix to zero.

(b) If the next segment to transmit (the segment numbered sequenceNumber plus ix) is the final segment, goto step (g).

(c) Issue an N-UNITDATA.request with 'data_expecting_reply' = TRUE to transmit the next BACnet APDU segment, with 'segmented-message' = TRUE, 'more-follows' = TRUE, 'proposed-window-size' equal to ProposedWindowSize, and 'sequence-number' = sequenceNumber plus ix, modulo 256.

(d) Set ix equal to ix plus one.

(e) If ix is less than ActualWindowSize, goto step (b).

(f) Goto step (i).

(g) Issue an N-UNITDATA.request with 'data_expecting_reply' = TRUE to transmit the final BACnet APDU segment with 'segmented-message' = TRUE, 'more-follows' = FALSE, 'proposed-window-size' = ProposedWindowSize, and 'sequence-number' = sequenceNumber plus ix, modulo 256.

(h) Set SentAllSegments to TRUE, indicating that all segments have been transmitted at least once.

(i) Return to the caller.

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

5.4.4 State Machine for Requesting BACnet User (client)

5.4.4.1 IDLE

In the IDLE state, the device waits for the local application program to request a service.

SendUnconfirmed
If UNCONF_SERV.request is received from the local application program,

then issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Unconfirmed-Request-PDU, and enter the IDLE state.

SendConfirmedUnsegmented
If CONF_SERV.request is received from the local application program and the length of the APDU is less than or equal to maximum-transmittable-length as determined according to 5.2.1,

then assign an 'invokeID' to this transaction; set SentAllSegments to TRUE; set RetryCount to zero; start RequestTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = TRUE to transmit a BACnet-Confirmed-Request-PDU with 'segmented-message' = FALSE; and enter the AWAIT_CONFIRMATION state to await a reply.

CannotSend
If CONF_SERV.request is received from the local application program and the length of the APDU is greater than maximum-transmittable-length as determined according to 5.2.1 and the Max_Segments_Accepted property of the destination's Device object is known and the total APDU cannot be transmitted without exceeding the maximum number of segments accepted,

then send an ABORT.indication to the local application program and enter the IDLE state.

SendConfirmedSegmented
If CONF_SERV.request is received from the local application program and the length of the APDU is greater than maximum-transmittable-length as determined according to 5.2.1, and the Max_Segments_Accepted property of the destination's Device object is not known, or Max_Segments_Accepted is known and the total APDU can be transmitted without exceeding the maximum number of segments accepted,

then assign an 'invokeID' to this transaction; set SentAllSegments to FALSE; set RetryCount to zero; set SegmentRetryCount to zero; set InitialSequenceNumber to zero; set ProposedWindowSize to whatever value is desired; set ActualWindowSize to 1; start SegmentTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = TRUE to transmit a BACnet-Confirmed-Request-PDU containing the first segment of the message, with 'segmented-message' = TRUE, 'more-follows' = TRUE, 'sequence-number' = zero, and 'proposed-window-size' = ProposedWindowSize; and enter the SEGMENTED_REQUEST state to await an acknowledgment. (The method used to determine ProposedWindowSize is a local matter, except that the value shall be in the range 1 to 127, inclusive.)

UnexpectedSegmentInfoReceived
If an unexpected PDU indicating the existence of an active server TSM (BACnet-ComplexACK-PDU with 'segmented-message' = TRUE or BACnet-SegmentACK-PDU with 'server' = TRUE) is received from the network layer,

then issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = FALSE and enter the IDLE state.

UnexpectedPDU_Received
If an unexpected PDU not indicating the existence of an active server TSM (BACnet-SimpleACK-PDU, BACnet-ComplexACK-PDU with 'segmented-message' = FALSE, BACnet-Error-PDU, BACnet-Reject-PDU, or BACnet-Abort-PDU with 'server' = TRUE) is received from the network layer,

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

then enter the IDLE state. (There is no reason to issue REJECT.indication, ABORT.indication, etc., as the client has no knowledge of the transaction in question.)

5.4.4.2 SEGMENTED_REQUEST

In the SEGMENTED_REQUEST state, the device waits for a BACnet-SegmentACK-PDU for one or more segments of a BACnet-Confirmed-Request-PDU.

DuplicateACK_Received

If a BACnet-SegmentACK-PDU whose 'server' parameter is TRUE is received from the network layer and InWindow ('sequence-number' parameter of the BACnet-SegmentACK-PDU, InitialSequenceNumber) returns a value of FALSE,

then restart SegmentTimer and enter the SEGMENTED_REQUEST state to await an acknowledgment.

NewACK_Received

If a BACnet-SegmentACK-PDU whose 'server' parameter is TRUE is received from the network layer and InWindow ('sequence-number' parameter of the BACnet-SegmentACK-PDU, InitialSequenceNumber) returns a value of TRUE and there is at least one segment remaining to send,

then set InitialSequenceNumber equal to the 'sequence-number' parameter of the BACnet-SegmentACK-PDU plus one, modulo 256; set ActualWindowSize equal to the 'actual-window-size' parameter of the BACnet-SegmentACK-PDU; restart SegmentTimer; set SegmentRetryCount to zero; call FillWindow (InitialSequenceNumber) to transmit one or more BACnet-Confirmed-Request-PDUs containing the next ActualWindowSize segments of the message; and enter the SEGMENTED_REQUEST state to await an acknowledgment.

FinalACK_Received

If a BACnet-SegmentACK-PDU whose 'server' parameter is TRUE is received from the network layer and InWindow ('sequence-number' parameter of the BACnet-SegmentACK-PDU, InitialSequenceNumber) returns a value of TRUE and there are no more segments to send,

then stop SegmentTimer; start RequestTimer; and enter the AWAIT_CONFIRMATION state to await a reply.

Timeout

If SegmentTimer becomes greater than T_{seg} and SegmentRetryCount is less than N_{retry},

then increment SegmentRetryCount; restart SegmentTimer; call FillWindow(InitialSequenceNumber) to retransmit one or more BACnet-Confirmed-Request-PDUs containing the next ActualWindowSize segments of the message; and enter the SEGMENTED_REQUEST state to await an acknowledgment.

FinalTimeout

If SegmentTimer becomes greater than T_{seg} and SegmentRetryCount is greater than or equal to N_{retry},

then stop SegmentTimer; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

AbortPDU_Received

If a BACnet-Abort-PDU whose 'server' parameter is TRUE is received from the network layer,

then stop SegmentTimer; send ABORT.indication to the local application program; and enter the IDLE state.

SimpleACK_Received

If a BACnet-SimpleACK-PDU is received from the network layer and SentAllSegments is TRUE,

then stop SegmentTimer; send CONF_SERV.confirm(+) to the local application program; and enter the IDLE state.

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

UnsegmentedComplexACK_Received
If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is FALSE and SentAllSegments is TRUE,

then stop SegmentTimer; send CONF_SERV.confirm(+) to the local application program; and enter the IDLE state.

SegmentedComplexACK_Received
If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is zero and this device supports segmentation and SentAllSegments is TRUE,

then stop SegmentTimer; compute ActualWindowSize based on the 'proposed-window-size' parameter of the received BACnet-ComplexACK-PDU and on local conditions; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ACK' = FALSE, 'server' = FALSE, and 'actual-window-size' = ActualWindowSize; start SegmentTimer; set LastSequenceNumber to zero; set InitialSequenceNumber to zero; and enter the SEGMENTED_CONF state to receive the remaining segments. (The method used to determine ActualWindowSize is a local matter, except that the value shall be less than or equal to the 'proposed-window-size' parameter of the received BACnet-ComplexACK-PDU and shall be in the range 1 to 127, inclusive.)

ErrorPDU_Received
If a BACnet-Error-PDU is received from the network layer and SentAllSegments is TRUE,

then stop SegmentTimer; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

RejectPDU_Received
If a BACnet-Reject-PDU is received from the network layer and SentAllSegments is TRUE,

then stop SegmentTimer; send REJECT.indication to the local application program; and enter the IDLE state.

UnexpectedPDU_Received
If a BACnet-SimpleACK-PDU, BACnet-ComplexACK-PDU, BACnet-Error-PDU, or BACnet-Reject-PDU is received from the network layer and SentAllSegments is FALSE,
or if a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and this device does not support segmentation,

or if a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is not zero,

then stop SegmentTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = FALSE; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

SendAbort
If ABORT.request is received from the local application program,

then stop SegmentTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = FALSE; and enter the IDLE state.

5.4.4.3 AWAIT_CONFIRMATION

In the AWAIT_CONFIRMATION state, the device waits for a response to a BACnet-Confirmed-Request-PDU.

SimpleACK_Received
If a BACnet-SimpleACK-PDU is received from the network layer,

then stop RequestTimer; send CONF_SERV.confirm(+) to the local application program; and enter the IDLE state.

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

UnsegmentedComplexACK_Received

If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is FALSE,

then stop RequestTimer; send CONF_SERV.confirm(+) to the local application program; and enter the IDLE state.

SegmentedComplexACK_Received

If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is zero and this device supports segmentation,

then stop RequestTimer; compute ActualWindowSize based on the 'proposed-window-size' parameter of the received BACnet-ComplexACK-PDU and on local conditions; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ACK' = FALSE, 'server' = FALSE, and 'actual-window-size' = ActualWindowSize; start SegmentTimer; set LastSequenceNumber to zero; set InitialSequenceNumber to zero; and enter the SEGMENTED_CONF state to receive the remaining segments. (The method used to determine ActualWindowSize is a local matter, except that the value shall be less than or equal to the 'proposed-window-size' parameter of the received BACnet-ComplexACK-PDU and shall be in the range 1 to 127, inclusive.)

ErrorPDU_Received

If a BACnet-Error-PDU is received from the network layer,

then stop RequestTimer; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

RejectPDU_Received

If a BACnet-Reject-PDU is received from the network layer,

then stop RequestTimer; send REJECT.indication to the local application program; and enter the IDLE state.

AbortPDU_Received

If a BACnet-Abort-PDU whose 'server' parameter is TRUE is received from the network layer,

then stop RequestTimer; send ABORT.indication to the local application program; and enter the IDLE state.

SegmentACK_Received

If a BACnet-SegmentACK-PDU whose 'server' parameter is TRUE is received from the network layer,

then discard the PDU as a duplicate, and re-enter the current state.

UnexpectedPDU_Received

If an unexpected PDU (BACnet-ComplexACK-PDU with 'segmented-message' = TRUE and 'sequence-number' not equal to zero or 'segmented-message' = TRUE and this device does not support segmentation) is received from the network layer,

then stop RequestTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = FALSE; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

TimeoutUnsegmented

If RequestTimer becomes greater than $\mathbf{T}_{out}$ and RetryCount is less than Number_Of_APDU_Retries and the length of the Confirmed Request APDU is less than or equal to maximum-transmittable-length as determined according to 5.2.1,

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

then stop RequestTimer; increment RetryCount; issue an N-UNITDATA.request with 'data_expecting_reply' = TRUE to transmit a BACnet-Confirmed-Request-PDU with 'segmented-message' = FALSE; start RequestTimer; and enter the AWAIT_CONFIRMATION state to await a reply.

TimeoutSegmented

If RequestTimer becomes greater than $\mathbf{T}_{out}$ and RetryCount is less than Number_Of_APDU_Retries and the length of the Confirmed-Request APDU is greater than maximum-transmittable-length as determined according to 5.2.1,

then stop RequestTimer; increment RetryCount; set SegmentRetryCount to zero; set SentAllSegments to FALSE; start SegmentTimer; set InitialSequenceNumber to zero; set ActualWindowSize to 1; issue an N-UNITDATA.request with 'data_expecting_reply' = TRUE to transmit a BACnet-Confirmed-Request-PDU containing the first segment of the message, with 'segmented-message' = TRUE, 'more-follows' = TRUE, and 'sequence-number' = zero; and enter the SEGMENTED_REQUEST state to await an acknowledgment.

FinalTimeout

If RequestTimer becomes greater than $\mathbf{T}_{out}$ and RetryCount is greater than or equal to Number_Of_APDU_Retries,

then stop RequestTimer; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

SendAbort

If ABORT.request is received from the local application program,

then stop RequestTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = FALSE; and enter the IDLE state.

5.4.4.4 SEGMENTED_CONF

In the SEGMENTED_CONF state, the device waits for one or more segments in response to a BACnet-SegmentACK-PDU.

NewSegmentReceived_NoSpace

If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE; whose 'sequence-number' parameter is equal to LastSequenceNumber plus 1, modulo 256; and the segment cannot be saved due to local conditions,

then stop SegmentTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = FALSE; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

NewSegmentReceived

If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE; whose 'more-follows' parameter is TRUE; whose 'sequence-number' parameter is equal to LastSequenceNumber plus 1, modulo 256; and whose 'sequence-number' parameter is not equal to InitialSequenceNumber plus ActualWindowSize, modulo 256,

then save the BACnet-ComplexACK-PDU segment; increment LastSequenceNumber, modulo 256; restart SegmentTimer; and enter the SEGMENTED_CONF state to receive additional segments.

LastSegmentOfGroupReceived

If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE; whose 'sequence-number' parameter is equal to LastSequenceNumber plus 1, modulo 256; whose 'more-follows' parameter is TRUE; and whose 'sequence-number' parameter is equal to InitialSequenceNumber plus ActualWindowSize, modulo 256,

then save the BACnet-ComplexACK-PDU segment; increment LastSequenceNumber, modulo 256; set InitialSequenceNumber to LastSequenceNumber; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ACK' = FALSE, server = FALSE, and 'actual-

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

window-size' = ActualWindowSize; restart SegmentTimer; and enter the SEGMENTED_CONF state to receive additional segments.

LastSegmentOfComplexACK_Received

If a ComplexACK PDU is received from the network layer whose 'segmented-message' parameter is TRUE; whose 'sequence-number' parameter is equal to LastSequenceNumber plus 1, modulo 256; and whose 'more-follows' parameter is FALSE (i.e., the final segment),

then stop SegmentTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ACK' = FALSE, 'server = FALSE', and 'actual-window-size' = ActualWindowSize; send CONF_SERV.confirm(+) containing all of the received segments to the local application program; and enter the IDLE state.

SegmentReceivedOutOfOrder

If a BACnet-ComplexACK-PDU is received from the network layer whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is not equal to LastSequenceNumber plus 1, modulo 256,

then discard the BACnet-ComplexACK-PDU segment; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ACK' = TRUE, 'server' = FALSE, 'sequence-number' = LastSequenceNumber, and 'actual-window-size' = ActualWindowSize; restart SegmentTimer; and enter the SEGMENTED_CONF state to receive the remaining segments.

AbortPDU_Received

If a BACnet-Abort-PDU whose 'server' parameter is TRUE is received from the network layer,

then stop SegmentTimer; send ABORT.indication to the local application program; and enter the IDLE state.

UnexpectedPDU_Received

If an unexpected PDU (BACnet-SimpleACK-PDU, BACnet-ComplexACK-PDU with 'segmented-message' = FALSE, BACnet-Error-PDU, BACnet-Reject-PDU, or BACnet-SegmentACK-PDU with 'server' = TRUE) is received from the network layer,

then stop SegmentTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = FALSE; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

Timeout

If SegmentTimer becomes greater than T_{seg} times four,

then stop SegmentTimer; send CONF_SERV.confirm(-) to the local application program; and enter the IDLE state.

SendAbort

If ABORT.request is received from the local application program,

then stop SegmentTimer; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = FALSE; and enter the IDLE state.

5.4.5 State Machine for Responding BACnet User (server)

5.4.5.1 IDLE

In the IDLE state, the device waits for a PDU from the network layer.

UnconfirmedReceived

If a BACnet-Unconfirmed-Request-PDU is received from the network layer,

Documents
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009

then send an UNCONF_SERV.indication to the local application program, and enter the IDLE state.

ConfirmedBroadcastReceived
If a BACnet-Confirmed-Request-PDU whose destination address is a multicast or broadcast address is received from the network layer,

then enter the IDLE state.

ConfirmedUnsegmentedReceived
If a BACnet-Confirmed-Request-PDU whose 'segmented-message' parameter is FALSE is received from the network layer,

then send a CONF_SERV.indication to the local application program, start RequestTimer; and enter the AWAIT_RESPONSE state.

ConfirmedSegmentedReceivedNotSupported
If a BACnet-Confirmed-Request-PDU whose 'segmented-message' parameter is TRUE is received from the network layer, and this device does not support the reception of segmented messages,

then issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = TRUE and 'abort-reason' = SEGMENTATION_NOT_SUPPORTED, and enter the IDLE state.

ConfirmedSegmentedReceived
If a BACnet-Confirmed-Request-PDU whose 'segmented-message' parameter is TRUE and whose 'sequence-number' parameter is zero is received from the network layer and the local device supports the reception of segmented messages,

then compute ActualWindowSize based on the 'proposed-window-size' parameter of the received BACnet-Confirmed-Request-PDU and on local conditions; issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-SegmentACK-PDU with 'negative-ACK' = FALSE, 'server' = TRUE, and 'actual-window-size' = ActualWindowSize; start SegmentTimer; set LastSequenceNumber to zero; set InitialSequenceNumber to zero; and enter the SEGMENTED_REQUEST state to receive the remaining segments. (The method used to determine ActualWindowSize is a local matter, except that the value shall be less than or equal to the 'proposed-window-size' parameter of the received BACnet-Confirmed-Request-PDU and shall be in the range 1 to 127, inclusive.)

AbortPDU_Received
If a BACnet-Abort-PDU whose 'server' parameter is FALSE is received from the network layer,

then enter the IDLE state.

UnexpectedPDU_Received
If an unexpected PDU (BACnet-Confirmed-Request-PDU with 'segmented-message' = TRUE and 'sequence-number' not equal to zero or BACnet-SegmentACK-PDU with 'server' = FALSE) is received from the network layer,

then issue an N-UNITDATA.request with 'data_expecting_reply' = FALSE to transmit a BACnet-Abort-PDU with 'server' = TRUE; and enter the IDLE state.

5.4.5.2 SEGMENTED_REQUEST

In the SEGMENTED_REQUEST state, the device waits for segments of a BACnet-Confirmed-Request-PDU.

NewSegmentReceived
If a BACnet-Confirmed-Request-PDU is received from the network layer whose 'segmented-message' parameter is TRUE; whose 'more-follows' parameter is TRUE; whose 'sequence-number' parameter is equal to

Documents
ASHRAE 135-2004
Document Sharing Hub

Full document details: BS EN ISO 16484-5:2008+A1:2009