BS EN ISO 29463-5:2022

BSI Standards Publication

High-efficiency filters and filter media for removing particles in air

Part 5: Test method for filter elements

Documents
Document Sharing Hub

Full document details: BS EN ISO 29463-5:2022

National foreword

This British Standard is the UK implementation of EN ISO 29463-5:2022. It is identical to ISO 29463-5:2022. It supersedes BS EN ISO 29463-5:2018, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee MCE/21, Filters for gases and liquids.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2022
Published by BSI Standards Limited 2022

ISBN 978 0 539 04902 2

ICS 91.140.30

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2022.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS EN ISO 29463-5:2022

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN ISO 29463-5

April 2022

ICS 91.140.30

Supersedes EN ISO 29463-5:2018

English Version

High-efficiency filters and filter media for removing particles in air - Part 5: Test method for filter elements (ISO 29463-5:2022)

Filtres à haut rendement et filtres pour l'élimination des particules dans l'air - Partie 5: Méthode d'essai des éléments filtrants (ISO 29463-5:2022)

Schwebstofffilter und Filtermedien zur Abscheidung von Partikeln aus der Luft - Teil 5: Prüfverfahren für Filterelemente (ISO 29463-5:2022)

This European Standard was approved by CEN on 18 March 2022.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2022 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. EN ISO 29463-5:2022 E

Documents
Document Sharing Hub

Full document details: BS EN ISO 29463-5:2022

European foreword

This document (EN ISO 29463-5:2022) has been prepared by Technical Committee ISO/TC 142 "Cleaning equipment for air and other gases" in collaboration with Technical Committee CEN/TC 195 “Cleaning equipment for air and other gases” the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2022, and conflicting national standards shall be withdrawn at the latest by October 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 29463-5:2018.

Any feedback and questions on this document should be directed to the users’ national standards body/national committee. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO 29463-5:2022 has been approved by CEN as EN ISO 29463-5:2022 without any modification.

Documents
Document Sharing Hub

Full document details: BS EN ISO 29463-5:2022

Contents

Page

Foreword ... **v**

Introduction ... **vi**

1 Scope ... **1**

2 Normative references ... **1**

3 Terms, definitions, symbols and abbreviated terms ... **1**
3.1 Terms and definitions ... 1
3.2 Symbols and abbreviated terms ... 2

4 Efficiency test methods ... **3**
4.1 Reference efficiency test method ... 3
4.2 Alternate efficiency test method for groups H and U filters ... 3
4.3 Statistical efficiency test method for low efficiency filters — Group E filters ... 3

5 Test filter ... **4**

6 Test apparatus ... **4**
6.1 General ... 4
6.2 Test duct ... 5
6.2.1 Test air conditioning ... 5
6.2.2 Adjustment of the volume flow rate ... 5
6.2.3 Measurement of the volume flow rate ... 5
6.2.4 Aerosol mixing section ... 5
6.2.5 Test filter mounting assembly ... 6
6.2.6 Measuring points for the pressure drop ... 6
6.2.7 Sampling ... 6
6.3 Aerosol generation and measuring instruments ... 6
6.3.1 General ... 6
6.3.2 Apparatus for testing with a mono-disperse test aerosol ... 7
6.3.3 Apparatus for testing with a poly-disperse test aerosol ... 7

7 Conditions of the test air ... **11**

8 Test procedure ... **12**
8.1 Preparatory checks ... 12
8.2 Starting up the aerosol generator ... 12
8.3 Preparation of the test filter ... 12
8.3.1 Installation of the test filter ... 12
8.3.2 Flushing the test filter ... 12
8.4 Testing ... 12
8.4.1 Measuring the pressure drop ... 12
8.4.2 Testing with a mono-disperse test aerosol ... 13
8.4.3 Testing with a poly-disperse test aerosol ... 13
8.4.4 Testing filters with charged media ... 13

9 Evaluation ... **13**

10 Test report ... **15**

11 Maintenance and inspection of the test apparatus ... **16**

Annex A (normative) **Alternate efficiency test method from scan testing** ... **17**

Annex B (informative) **Testing and classification method for filters with MPPS ≤ 0,1 µm (e.g. membrane medium filters)** ... **18**

Annex C (normative) **Method for testing and classification of filters using media with charged fibres** ... **21**

Annex D (informative) **Traditional efficiency test methods for HEPA and ULPA filters** ... **27**

Documents
Document Sharing Hub

© ISO 2022 – All rights reserved

Full document details: BS EN ISO 29463-5:2022

Bibliography **28**

© ISO 2022 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS EN ISO 29463-5:2022

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 142, *Cleaning equipment for air and other gases,* in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 195, *Air filters for general air cleaning,* in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 29463-5:2011), which has been technically revised.

The main changes are as follows:

— normative references have been updated;

— Annex C has been revised.

A list of all parts in the ISO 29463 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

© ISO 2022 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS EN ISO 29463-5:2022

Introduction

The ISO 29463 series is derived from the EN 1822 series with extensive changes to meet the requests from non-European participating members (P-members). It contains requirements, fundamental principles of testing and the marking for high-efficiency particulate air filters with efficiencies from 95 % to 99,999 995 % that can be used for classifying filters in general or for specific use by agreement between users and suppliers.

The ISO 29463 series establishes a procedure for the determination of the efficiency of all filters on the basis of a particle counting method using a liquid (or alternatively a solid) test aerosol, and allows a standardized classification of these filters in terms of their efficiency, both local and overall efficiency, which actually covers most requirements of different applications. The difference between the ISO 29463 series and other national standards lies in the technique used for the determination of the overall efficiency. Instead of mass relationships or total concentrations, this technique is based on particle counting at the MPPS, which is, for micro-glass filter mediums, usually in the range of 0,12 µm to 0,25 µm. This method also allows testing ultra-low-penetration air filters, which was not possible with the previous test methods because of their inadequate sensitivity. For membrane filter media, separate rules apply and are described in Annex B. Although no equivalent test procedures for testing filters with charged media is prescribed, a method for dealing with these types of filters is described in Annex C. Specific requirements for testing method, frequency, and reporting requirements can be modified by agreement between users and suppliers. For lower-efficiency filters (group H, as described in 4.2), alternate leak test methods are described in ISO 29463-4:2011, Annex A.

There are differences between the ISO 29463 series and other normative practices common in several countries. For example, many of these rely on total aerosol concentrations rather than individual particles. For information, a brief summary of these methods and their reference standards are provided in Annex D.

© ISO 2022 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS EN ISO 29463-5:2022

High-efficiency filters and filter media for removing particles in air —

Part 5: Test method for filter elements

1 Scope

This document specifies the test methods for determining the efficiency of filters at their most penetrating particle size (MPPS). It also gives guidelines for the testing and classification for filters with an MPPS of less than 0,1 µm (Annex B) and filters using media with (charged) synthetic fibres (Annex C). It is intended for use in conjunction with ISO 29463-1, ISO 29463-2, ISO 29463-3 and ISO 29463-4.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements*

ISO 16890-4, *Air filters for general ventilation — Part 4: Conditioning method to determine the minimum fractional test efficiency*

ISO 21501-4, *Determination of particle size distribution — Single particle light interaction methods — Part 4: Light scattering airborne particle counter for clean spaces*

ISO 29463-1:2017, *High efficiency filters and filter media for removing particles from air — Part 1: Classification, performance, testing and marking*

ISO 29463-2:2011, *High-efficiency filters and filter media for removing particles in air — Part 2: Aerosol production, measuring equipment and particle-counting statistics*

ISO 29463-3, *High-efficiency filters and filter media for removing particles in air — Part 3: Testing flat sheet filter media*

ISO 29463-4:2011, *High-efficiency filters and filter media for removing particles in air — Part 4: Test method for determining leakage of filter elements-Scan method*

3 Terms, definitions, symbols and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 29463-1, ISO 29463-2, ISO 29463-3, ISO 29463-4, and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp

— IEC Electropedia: available at https://www.electropedia.org/

© ISO 2022 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS EN ISO 29463-5:2022

3.1.1
sampling duration
time during which the particles in the sampling volume flow are counted (upstream or downstream)

[SOURCE: ISO 29464:2017, 3.2.153]

3.1.2
particle counting and sizing method
particle counting method which allows both the determination of the number of particles and also the classification of the particles according to size

EXAMPLE By using an optical particle counter.

[SOURCE: ISO 29464:2017, 3.2.123]

3.2 Symbols and abbreviated terms

C	channel for particle counters
c_N	number concentration
d_p	particle diameter, µm
E	efficiency
k	dilution factor
N	particle counts
P	penetration, %
p	absolute pressure, Pa
T	temperature, K
t	sampling duration, s
$\dot{V}$	volume flow rate, cm^3/s
Δp	differential pressure, Pa
φ	relative humidity, %
CPC	condensation particle counter
DEHS	di(2-ethylhexyl) sebacate
DMPS	differential mobility particle sizer
DOP	dioctyl phthalate
ePTFE	expanded polytetrafluoroethylene
IPA	isopropyl alcohol (isopropanol)
MPPS	most penetrating particle size
OPC	optical particle counter

© ISO 2022 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS EN ISO 29463-5:2022

4 Efficiency test methods

4.1 Reference efficiency test method

In order to determine the efficiency of the test filter, the test filter is fixed in the filter mounting assembly and subjected to a test air volume flow corresponding to the nominal volume flow rate.

After the pressure drop at the nominal volumetric flow rate is measured, the test aerosol produced by the aerosol generator is mixed with the prepared test air along a mixing section, so that it is spread homogeneously over the cross-section of the duct.

The efficiency is always determined for the MPPS; see ISO 29463-3. The size distribution of the aerosol particles can optionally be measured using a particle size analysis system, for example, a DMPS.

The testing can be carried out using either a mono-disperse or poly-disperse test aerosol. When testing with (quasi-) mono-disperse aerosol, the total particle count method may be used with a CPC or an OPC, e.g. a laser particle counter. It shall be ensured that the number median particle diameter corresponds to the MPPS, i.e. the particle diameter at which the filter medium has its minimum efficiency.

When using a poly-disperse aerosol, the particle counting and sizing method, e.g. an OPC or DMPS, shall be used, which, in addition to counting the particles, is also able to determine their size distribution. It shall be ensured that the count median diameter, D_M, of the test aerosol lies in the range given by Formula (1):

$$\frac{S_{MPPS}}{1,5} < D_M < 1,5 \times S_{MPPS} \tag{1}$$

where S_{MPPS} is the most penetrating particle size.

In order to determine the overall efficiency, representative partial flows are extracted on the upstream and downstream sides of the filter element and directed to the attached particle counter via a fixed sampling probe to measure the number of particles. It is necessary to have a mixing section behind the test filter to mix the aerosol homogeneously with the test air over the duct cross-section (see 6.2.4). When testing filters with large face dimensions, achieving adequate aerosol mixing may not be possible. In these cases, the test method with moving probe described in Annex A shall be used.

4.2 Alternate efficiency test method for groups H and U filters

The standard efficiency test method, as described in 4.1, uses downstream mixing and a fixed downstream probe. However, an alternate efficiency test method using scan test equipment with moving probe(s) is provided and described in Annex A.

4.3 Statistical efficiency test method for low efficiency filters — Group E filters

For filters of group E, the overall efficiency shall be determined by one of the statistical test procedures described in this subclause, and it is not necessary to carry out the test for each single filter element (as is mandatory for filters of groups H and U). The overall efficiency of group E filters shall be determined by averaging the results of the statistical efficiency test as described in this subclause.

A record of the filter data in the form of a type test certificate or alternatively a factory test certificate is required. However, the supplier shall be able to provide documentary evidence to verify the published filter data upon request. This can be done by either:

a) maintaining a certified quality management system (e.g. ISO 9000), which requires the application of statistically based methods for testing and documenting efficiency for group E filters in accordance with this document; or

b) using accepted statistical methods to test all of production lots of filters.

The skip lot procedure as described in ISO 2859-1 or any equivalent alternative method may be used.

© ISO 2022 – All rights reserved

AVA Documents Document Sharing Hub
Full document details: BS EN ISO 29463-5:2022

The skip lot procedure as described in ISO 2859-1 implies that at the beginning, the test frequency is high and is, in the course of further testing, reduced as the production experience grows and that the products produced conform to the target. For example, for the first eight production lots, 100 % of the produced filters are tested. If all the tests are positive, the frequency is reduced to half for the next eight production lots. If all the tests are positive again, the number is reduced by half again, and so on until it is necessary to test only one out of eight lots (e.g. the minimum test frequency). Each time one of the tested filters fails, the test frequency is doubled again. In any case, the number of samples per lot tested shall be greater than three filters.

5 Test filter

The filter element being tested shall show no signs of damage or any other irregularities. The filter element shall be handled carefully and shall be clearly and permanently marked with the following details:

— designation of the filter element;

— upstream side of the filter element.

The temperature of the test filter during the testing shall correspond with that of the test air.

6 Test apparatus

6.1 General

A flow sheet showing the arrangement of apparatus comprising a test rig is given in ISO 29463-1:2017, Figure 4. An outline diagram of a test rig is given in Figure 1.

The fundamentals of aerosol generation and neutralization with details of suitable types of equipment as well as detailed descriptions of the measuring instruments required for the testing are given in ISO 29463-2.

© ISO 2022 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS EN ISO 29463-5:2022