

Acoustics — Laboratory tests on noise emission from appliances and equipment used in water supply installations

Part 3: Mounting and operating conditions for in-line valves and appliances

ICS 17.140.20; 91.140.60

National Foreword

This British Standard is the UK implementation of EN ISO 3822-3:1997+A1:2009. It is identical to ISO 3822-3:1997, incorporating amendment 1:2009. It supersedes BS EN ISO 3822-3:1997 which is withdrawn.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to ISO text carry the number of the ISO amendment. For example, text altered by ISO amendment 1 is indicated by **A1** **A1**.

The UK participation in its preparation was entrusted by Technical Committee EH/1, Acoustics, to Subcommittee EH/1/6, Building acoustics.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard, having been prepared under the direction of the Health and Environment Sector Board, was published under the authority of the Standards Board and comes into effect on 15 August 1997

© BSI 2010

ISBN 978 0 580 65829 7

Amendments/corrigenda issued since publication

Date	Text affected
28 February 2010	Implementation of ISO amendment 1:2009 with CEN endorsement A1:2009

ICS 17.140.20

Descriptors: See ISO document

English version

**Acoustics - Laboratory tests on noise emission
from appliances and equipment used in water
supply installations - Part 3: Mounting and
operating conditions for in-line valves and
appliances**

Acoustique - Mesurage en laboratoire du bruit émis par les robinetteries et les équipements hydrauliques utilisés dans les installations de distribution d'eau - Partie 3: Conditions de montage et de fonctionnement des robinetteries et des équipements hydrauliques en ligne

Akustik - Prüfung des Geräuschverhaltens von Armaturen und Geräten der Wasserinstallation im Laboratorium - Teil 3: Anschluß- und Betriebsbedingungen für Durchgangsarmaturen

This European Standard was approved by CEN on 1996-05-09. CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

The European Standards exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CEN

European Committee for Standardization
Comité Européen de Normalisation
Europäisches Komitee für Normung

Central Secretariat: rue de Stassart, 36 B-1050 Brussels

© 1997

Copyright reserved to CEN members

Ref. No. EN ISO 3822-3:1997 E

Foreword

The text of EN ISO 3822-3:1997 has been prepared by Technical Committee CEN/TC 126 "Acoustic properties of building components and of buildings" the secretariat of which is held by AFNOR in collaboration with the Technical Committee ISO/TC 43 "Acoustics".

The content of this part of the European Standard EN ISO 3822 is not identical with the International Standard ISO 3822-3:1984 "Acoustics - Laboratory test on noise emission from appliances and equipment used in water supply installations - Part 3 : Mounting and operating conditions for in-line valves and appliances".

Working group CEN/TC 126/WG 3 was instructed, in May 88, to examine and take into account the comments on ISO 3822-3, following the primary questionnaire.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 1997, and conflicting national standards shall be withdrawn at the latest by July 1997.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

Foreword to amendment A1

This document (EN ISO 3822-3:1997/A1:2009) has been prepared by Technical Committee ISO/TC 43 "Acoustics" in collaboration with Technical Committee CEN/TC 126 "Acoustic properties of building elements and of buildings" the secretariat of which is held by AFNOR.

This Amendment to the European Standard EN ISO 3822:1997 shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2010, and conflicting national standards shall be withdrawn at the latest by May 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Endorsement notice

The text of ISO 3822-3:1997/Amd 1:2009 has been approved by CEN as a EN ISO 3822-3:1997/A1:2009 without any modification.

Content

Foreword	ii
0 Introduction	iv
1 Scope	1
2 Normative references	1
3 Mounting	2
3.1 General	2
3.2 Fitting to the test pipe.....	2
3.3 Mounting of in-line valves and appliances with screwed connections	3
3.4 Mounting of in-line valves and appliances with provision for soldering in copper connecting pipes	3
3.5 Mounting of in-line valves and appliances fitted with copper connecting pipes.....	3
3.6 Mounting of in-line valves or appliances with two inlets	3
3.7 Discharge connection.....	3
4 Test procedure	3
4.1 General test conditions	3
4.2 Procedure for stop valves	4
4.3 Procedure for control valves.....	5
4.4 Procedure for valves and appliances operated by water flow	5
4.5 Procedure for automatic in-line valves or appliances operated by water pressure.....	6
4.6 Procedure for automatic in-line valves and appliances operated by water temperature.....	6
4.7 Procedure for "safety groups"	7
5 Test report	7
Annex A (informative) Example of low noise flow resistance	8