

Ergonomics of the thermal environment — Determination of metabolic rate

The European Standard EN ISO 8996:2004 has the status of a
British Standard

ICS 13.180

National foreword

This British Standard is the official English language version of EN ISO 8996:2004. It is identical with ISO 8996:2004. It supersedes BS EN 28996:1994 which is withdrawn.

The UK participation in its preparation was entrusted by Technical Committee PH/9, Applied ergonomics, to Subcommittee PH/9/1, Thermal environments, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the *BSI Catalogue* under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN ISO title page, the EN ISO foreword page, the ISO title page, pages ii to iv, pages 1 to 24, an inside back cover and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 January 2005

© BSI 31 January 2005

English version

Ergonomics of the thermal environment - Determination of metabolic rate (ISO 8996:2004)

Ergonomie de l'environnement thermique - Détermination du métabolisme énergétique (ISO 8996:2004)

Ergonomie der thermischen Umgebung - Bestimmung des körpereigenen Energieumsatzes (ISO 8996:2004)

This European Standard was approved by CEN on 26 August 2004.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Foreword

This document (EN ISO 8996:2004) has been prepared by Technical Committee ISO/TC 159 "Ergonomics" in collaboration with Technical Committee CEN/TC 122 "Ergonomics", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2005, and conflicting national standards shall be withdrawn at the latest by April 2005.

This document supersedes EN 28996:1993.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Endorsement notice

The text of ISO 8996:2004 has been approved by CEN as EN ISO 8996:2004 without any modifications.

INTERNATIONAL STANDARD

ISO
8996

Second edition
2004-10-01

Ergonomics of the thermal environment — Determination of metabolic rate

*Ergonomie de l'environnement thermique — Détermination du
métabolisme énergétique*



Contents

Page

Foreword.....	iv
1 Scope.....	1
2 Normative references	1
3 Principle and accuracy	1
4 Level 1, screening	3
4.1 Table for the estimation of metabolic rate by occupation	3
4.2 Classification of metabolic rate by categories	3
5 Level 2, observation.....	3
5.1 Estimation of metabolic rate by task requirements	3
5.2 Metabolic rate for typical activities	4
5.3 Metabolic rate for a work cycle.....	4
5.4 Influence of the length of rest periods and work periods.....	5
5.5 Obtaining values by interpolation	6
5.6 Requirements for the application of metabolic-rate tables	6
6 Level 3, analysis	6
6.1 Estimation of metabolic rate using heart rate.....	6
6.2 Relationship between heart rate and metabolic rate.....	7
7 Level 4, expertise	8
7.1 Determination of metabolic rate by measurement of oxygen consumption rate.....	8
7.2 The doubly labelled water method for long-term measurements	14
7.3 Direct calorimetry — Principle.....	14
Annex A (informative) Evaluation of the metabolic rate at level 1, screening	15
Annex B (informative) Evaluation of the metabolic rate at level 2, observation	17
Annex C (informative) Evaluation of the metabolic rate at level 3, analysis	20
Annex D (informative) Evaluation of the metabolic rate at level 4, expertise — Examples of the calculation of metabolic rate based on measured data	21

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 8996 was prepared by Technical Committee ISO/TC 159, *Ergonomics*, Subcommittee SC 5, *Ergonomics of the physical environment*.

This second edition cancels and replaces the first edition (ISO 8996:1990), which has been technically revised.

Ergonomics of the thermal environment — Determination of metabolic rate

1 Scope

The metabolic rate, as a conversion of chemical into mechanical and thermal energy, measures the energetic cost of muscular load and gives a numerical index of activity. Metabolic rate is an important determinant of the comfort or the strain resulting from exposure to a thermal environment. In particular, in hot climates, the high levels of metabolic heat production associated with muscular work aggravate heat stress, as large amounts of heat need to be dissipated, mostly by sweat evaporation.

This International Standard specifies different methods for the determination of metabolic rate in the context of ergonomics of the climatic working environment. It can also be used for other applications — for example, the assessment of working practices, the energetic cost of specific jobs or sport activities, the total cost of an activity, etc.

The estimations, tables and other data included in this International Standard concern an “average” individual:

- a man 30 years old weighing 70 kg and 1,75 m tall (body surface area 1,8 m²);
- a woman 30 years old weighing 60 kg and 1,70 m tall (body surface area 1,6 m²).

Users should make appropriate corrections when they are dealing with special populations including children, aged persons, people with physical disabilities, etc.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 9886, *Ergonomics — Evaluation of thermal strain by physiological measurements*

ISO 15265, *Ergonomics of the thermal environment — Risk assessment strategy for the prevention of stress or discomfort in thermal working conditions*

3 Principle and accuracy

The mechanical efficiency of muscular work — called the “useful work”, W — is low. In most types of industrial work, it is so small (a few percent) that it is assumed to be nil. This means that the total energy consumption while working is assumed equal to the heat production. For the purposes of this International Standard, the metabolic rate is assumed to be equal to the rate of heat production.

Table 1 lists the different approaches presented in this International Standard for determining the metabolic rate.

These approaches are structured following the philosophy exposed in ISO 15265 regarding the assessment of exposure. Four levels are considered here:

Level 1, screening: Two methods simple and easy to use are presented to quickly characterize the mean workload for a given occupation or for a given activity:

- method 1A is a classification according to occupation;
- method 1B is a classification according to the kind of activity.

Both methods provide only a rough estimate and there is considerable scope for error. This limits their accuracy considerably. At this level, an inspection of the work place is not necessary.

Level 2, observation: Two methods are presented for people with full knowledge of the working conditions but without necessarily a training in ergonomics, to characterize, on average, a working situation at a specific time:

- in method 2A, the metabolic rate is determined by adding to the baseline metabolic rate the metabolic rate for body posture, the metabolic rate for the type of work and the metabolic rate for body motion related to work speed (using group assessment tables);
- in method 2B, the metabolic rate is determined by means of the tabulated values for various activities.

A procedure is described to record the activities with time and compute the time-weighted average metabolic rate, using the data from the two methods above.

The possibility for errors is high. A time and motion study is necessary to determine the metabolic rate in work situations that involve a cycle of different activities.

Level 3, analysis: One method is addressed to people trained in occupational health and ergonomics of the thermal environment. The metabolic rate is determined from heart rate recordings over a representative period. This method for the indirect determination of metabolic rate is based on the relationship between oxygen uptake and heart rate under defined conditions.

Level 4, expertise: Three methods are presented. They require very specific measurements made by experts:

- in Method 4A, the oxygen consumption is measured over short periods (10 min to 20 min) (a detailed time and motion study is necessary to show the representativity of the measurement period);
- method 4B is the so-called doubly labelled water method aiming at characterizing the average metabolic rate over much longer periods (1 to 2 weeks);
- method 4C is a direct calorimetry method.

The main factors affecting the accuracy of the estimations are the following:

- individual variability;
- differences in the work equipment;
- differences in work speed;
- differences in work technique and skill;
- gender differences and anthropometric characteristics;
- cultural differences;
- when using the tables, differences between observers and their level of training;

- when using level 3, the accuracy of the relationship between heart rate and oxygen uptake, as other stress factors also influence the heart rate;
- at level 4, the measurement accuracy (determination of gas volume and oxygen fraction).

The accuracy of the results, but also the costs of the study, increase from level 1 to level 4. Measurement at level 4 gives the most accurate values. As far as possible, the most accurate method should be used.

Table 1 — Levels for the determination of the metabolic rate

Level	Method	Accuracy	Inspection of the work place
1 Screening	1A: Classification according to occupation	Rough information	Not necessary, but information needed on technical equipment, work organization
	1B: Classification according to activity	Very great risk of error	
2 Observation	2A: Group assessment tables	High error risk	Time and motion study necessary
	2B: Tables for specific activities	Accuracy: $\pm 20\%$	
3 Analysis	Heart rate measurement under defined conditions	Medium error risk Accuracy: $\pm 10\%$	Study required to determine a representative period
4 Expertise	4A: Measurement of oxygen consumption	Errors within the limits of the accuracy of the measurement or of the time and motion study	Time and motion study necessary
	4B: Doubly labelled water method		Inspection of work place not necessary, but leisure activities must be evaluated.
	4C: Direct calorimetry	Accuracy: $\pm 5\%$	Inspection of work place not necessary

4 Level 1, screening

4.1 Table for the estimation of metabolic rate by occupation

Table A.1 in Annex A shows the metabolic rate for different occupations. The values are mean values for the whole working time, but without considering longer rest pauses, for example lunchtime. Significant variation may arise due to differences in technology, work elements, work organization, etc.

4.2 Classification of metabolic rate by categories

The metabolic rate can be estimated approximately using the classification given in Annex A. Table A.2 defines five classes of metabolic rate: resting, low, moderate, high, very high. For each class, an average and a range of metabolic rate values are given as well as a number of examples. These activities are supposed to include short rest pauses. The examples given in Table A.2 illustrate the classification.

5 Level 2, observation

5.1 Estimation of metabolic rate by task requirements

Here, the metabolic rate is estimated from the following observations:

- the body segment involved in the work: both hands, one arm, two arms, the entire body;