

BS ISO 10302-2:2011



BSI Standards Publication

Acoustics — Measurement of airborne noise emitted and structure-borne vibration induced by small air-moving devices

Part 2: Structure-borne vibration
measurements

bsi.

...making excellence a habit.
AVA Documents™
Document Sharing Hub

National foreword

This British Standard is the UK implementation of ISO 10302-2:2011.

The UK participation in its preparation was entrusted to Technical Committee EH/1/4, Machinery noise.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2011

ISBN 978 0 580 61910 6

ICS 17.140.20; 23.120

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2011.

Amendments issued since publication

Date	Text affected
------	---------------

**Acoustics — Measurement of airborne
noise emitted and structure-borne
vibration induced by small air-moving
devices —**

**Part 2:
Structure-borne vibration measurements**

*Acoustique — Mesurage du bruit aérien émis et des vibrations de
structure induites par les petits équipements de ventilation —*

Partie 2: Mesurage des vibrations de structure





COPYRIGHT PROTECTED DOCUMENT

© ISO 2011

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Descriptors	2
5 Measurement uncertainty	3
6 Design and performance requirements for test fixture	3
7 Installation	4
8 Operation of AMDs	5
9 Instrumentation	6
10 Measurement procedure	7
11 Test report	11
Annex A (informative) Suggested data format for presentation	13
Annex B (informative) Recommended voltages for testing AMDs that operate with variable speeds	18
Annex C (informative) Sample specification of AMD structure-borne vibratory acceleration levels	19
Annex D (informative) Guidance on the development of information on measurement uncertainty	20
Bibliography	24

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 10302-2 was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 1, *Noise*.

This first edition of ISO 10302-2, together with ISO 10302-1, cancels and replaces ISO 10302:1996.

ISO 10302 consists of the following parts, under the general title *Acoustics — Measurement of airborne noise emitted and structure-borne vibration induced by small air-moving devices*:

- *Part 1: Airborne noise measurement*
- *Part 2: Structure-borne vibration measurement*

Acoustics — Measurement of airborne noise emitted and structure-borne vibration induced by small air-moving devices —

Part 2: Structure-borne vibration measurements

1 Scope

This part of ISO 10302 covers vibration levels from small air-moving devices (AMDs) with mounting footprints of less than 0,48 m × 0,90 m for the full-size test plenum defined in ISO 10302-1 and less than 0,18 m × 0,3 m for the half-size plenum.

It covers all types of AMDs which can be mounted on, and are self-supported at, the discharge or inlet plane of a test plenum box as specified in ISO 10302-1.

The procedures defined in this part of ISO 10302 specify methods for determining the vibration levels that a small AMD would induce in an average structure used in information technology and telecommunications equipment. The methods specified in this part of ISO 10302 allow the determination of induced vibration levels for the individual AMD that is tested. These data can be used to determine the statistical values of vibration levels for a production series if levels are measured for several units of that series.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 266, *Acoustics — Preferred frequencies*

ISO 5348, *Mechanical vibration and shock — Mechanical mounting of accelerometers*

ISO 10302-1:2011, *Acoustics — Measurement of airborne noise emitted and structure-borne vibration induced by small air-moving devices — Part 1: Airborne noise measurement*

ISO 16063-11, *Methods for the calibration of vibration and shock transducers — Part 11: Primary vibration calibration by laser interferometry*

ISO 16063-21, *Methods for the calibration of vibration and shock transducers — Part 21: Vibration calibration by comparison to a reference transducer*

IEC 61260, *Electroacoustics — Octave-band and fractional-octave-band filters*

ISO/IEC Guide 98-3, *Uncertainty in measurement — Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 10302-1 and the following apply.

3.1 vibratory acceleration level

L_a
ten times the logarithm to the base 10 of the ratio of the square of the root-mean-square acceleration, a , to the square of a reference value, a_0 , expressed in decibels

$$L_a = 10 \lg \left(\frac{a^2}{a_0^2} \right) \text{ dB} \quad (1)$$

where the reference value, a_0 , is $1 \mu\text{m/s}^2$

NOTE 1 The width of the frequency band is stated; for example, overall for all bands in the frequency range of interest or one-third-octave band.

NOTE 2 Some other standards use other reference values.

NOTE 3 In this part of ISO 10302, “vibratory acceleration level” is frequently referred to simply as “acceleration level”.

3.2 frequency range of interest

one-third-octave bands with centre frequencies specified in ISO 266, from 25 Hz to 5 kHz inclusive

3.3 information technology and telecommunications equipment ITT equipment

equipment for information processing, and components thereof, used in homes, offices, server installations, telecommunications installations or similar environments

[ISO 7779:2010^[3], 3.1.3]

NOTE ISO 10302 is intended to support the designers of ITT equipment.

4 Descriptors

The primary descriptor for vibration levels induced by an AMD is the energy average of the overall unweighted (non-frequency-weighted) vibratory acceleration level at the measurement locations for the frequency range of interest (3.2). This frequency range covers most of the frequency range covered by ISO 10302-1 for air-borne noise from AMDs, and adds the one-third-octave bands centred at 25 Hz to 80 Hz.

The detailed descriptors are the unweighted one-third-octave band acceleration levels. Although the measurement apparatus and the procedures of this part of ISO 10302 can also be used in conjunction with narrow-band frequency analysis instrumentation to investigate specifics in more detail, such narrow-band analysis is not specified here.

NOTE Acceleration measurements are convenient because non-intrusive lightweight accelerometers are readily available and simple to use. The overall unweighted acceleration level is chosen because it is a simple measure that correlates well with the A-weighted structure-borne noise level radiated by a structure (see References [7], [11]). The A-weighted structure-borne noise level radiated from a vibrating structure is determined from the average acceleration level of the structure by: a) converting from acceleration to velocity; b) correcting for the radiation efficiency of the structure; c) applying an A-weighting. To the first order, these three calculations cancel each other as a function of frequency, except for a constant. This leaves the overall unweighted acceleration level as a simple measure of the fan-induced A-weighted structure-borne noise.

5 Measurement uncertainty

The uncertainty of results obtained from measurements in accordance with this part of ISO 10302 shall be evaluated, preferably in compliance with ISO/IEC Guide 98-3. If reported, the expanded uncertainty together with the corresponding coverage probability as defined in ISO/IEC Guide 98-3 shall be given. Guidance on the determination of the expanded uncertainty is given in Annex D.

If, in a laboratory performing measurements in accordance with this part of ISO 10302, current knowledge is still insufficient to fully apply ISO/IEC Guide 98-3, the values of the standard deviation of reproducibility, σ_{R0} given in Table 1, multiplied by a coverage factor of 2 to get an estimate of the expanded uncertainty for a coverage probability of 95 %, are recommended for provisional use in test reports.

Table 1 — Estimated values of the standard deviation of reproducibility of vibratory acceleration levels of air-moving devices determined in accordance with this part of ISO 10302

One-third-octave band centre frequency	Standard deviation of reproducibility	Standard deviation of repeatability
Hz	σ_{R0} dB	σ_{r0} dB
25	5,0	2,0
31 to 63	5,0	1,0
80 to 160	3,0	1,0
200 to 5 000	2,0	1,0
Overall		
25 to 5 000	1,0	0,5
NOTE 1 These estimates are based on interlaboratory tests of five AMDs (three tube-axial fans and two forward-curved blowers) in the capacity range of 0,001 6 m³/s to 0,137 m³/s, conducted at two laboratories using three either half- or full-sized plenums by five different operators following the guidelines of ISO 5725^[2] (see References [7], [11]). NOTE 2 The standard deviations of reproducibility reflect the cumulative effects of all causes of measurement uncertainty, including variations from laboratory to laboratory, but excluding variations in the acceleration level from specimen to specimen. The standard deviation of repeatability for the same specimen and the same laboratory measurement conditions is considerably smaller than the standard deviation of reproducibility. NOTE 3 The values apply to AMDs that are not damaged and are operating in a stable manner, under the test conditions defined in this part of ISO 10302.		

6 Design and performance requirements for test fixture

6.1 Basic design

6.1.1 General

The basic design of the test plenum shall be as specified in ISO 10302-1, except that the mounting panel specified in ISO 10302-1 shall be replaced by the damped panel specified in 6.2.

6.1.2 Flow rate

The flow rate of the fan mounted on the plenum box under test conditions should be no greater than the value calculated according to Equation (2):

$$q_{V,\max} = \frac{q_{V,0}}{V_0} V \quad (2)$$

where

$q_{V,\max}$ is the maximum volume flow rate of the scaled plenum, in cubic metres per second;

$q_{V,0}$ is the maximum volume flow rate of the full-size plenum, in cubic metres per second, i.e.
 $q_{V,0} = 1 \text{ m}^3/\text{s}$;

V_0 is the nominal air volume of the full-size plenum defined in ISO 10302-1, in cubic metres, i.e.
 $V_0 = 1,3 \text{ m}^3$;

V is the nominal air volume of the scaled plenum, in cubic metres.

6.1.3 Static pressure

The static pressure of the AMD operating on the plenum should be no greater than 750 Pa.

6.1.4 Air/pressure distribution

All relative geometries (such as locations and proportions of the mounting panel or the exit port) shall be the same as those of the full-size plenum of ISO 10302-1.

6.2 Damped panel

The specification on the plate stock is a mechanical mobility level (reference: 1 m/N s) of -45 dB from 25 Hz to 5 000 Hz when measured in the middle of a panel of dimensions $1,0 \text{ m}^2$ with no fan-mounting hole and with the panel freely suspended by two corners. The mobility level measurement should be made in accordance with ANSI/ASA S2.32^[17]. The tolerance on the mobility levels is $\pm 8 \text{ dB}$ from 25 Hz to 100 Hz, $\pm 4 \text{ dB}$ from 100 Hz to 200 Hz, and $\pm 2 \text{ dB}$ from 200 Hz to 5 000 Hz. These tolerance limits ensure that the panel has sufficient damping to prevent excitation of the frame¹⁾.

6.3 Mounting area

This part of ISO 10302 covers vibration levels from small AMDs with a maximum mounting footprint of up to $0,48 \text{ m} \times 0,90 \text{ m}$ for the full-size plenum. For all sizes of plenum, the distances from the edges of the AMD maximum mounting footprint to the edges of the damped panel are constant: 0,06 m from the top and bottom and 0,15 m from the sides. (Thus for a half-sized plenum, this part of ISO 10302 covers AMDs with a maximum mounting footprint of up to $0,18 \text{ m} \times 0,30 \text{ m}$.)

7 Installation

7.1 Orientation of the AMD

The discharge side of the AMD shall be mounted on the damped panel if this is an available mounting option. If other mounting options are used, they shall be reported.

7.2 Mounting of the AMD

The AMD shall be mounted on a damped panel meeting the specifications of 6.2. Unless special mounting attachment devices are being evaluated, the AMD shall be attached to the damped panel with through-screws, as specified by the AMD manufacturer. The screws shall be tightened to the torque specified by the AMD manufacturer. In the absence of manufacturers' specifications, M3.5 (UNC 6-32) through-screws are recommended, tightened to 0,34 m. In the case of multiple in-line mounting holes being provided in the AMD housing, only the holes against or nearest the damped panel assembly shall be used.

1) An example of a suitable supplier of material for the damped plate is Soundcoat. This information is given for the convenience of users of this document and does not constitute an endorsement by ISO of this supplier. Equivalent materials from another supplier may be used if they can be shown to meet the requirements of 6.2.

7.3 Damped panel opening

The plenum opening for air to exit or enter the AMD shall be as specified by the manufacturer. In the absence of manufacturers' specifications, the opening shall be at least as large as the corresponding discharge or inlet of the AMD, smooth and free of burrs. The AMD shall be mounted on the damped panel assembly directly and without any seals or gasketing.

8 Operation of AMDs

8.1 Input power

8.1.1 Alternating current AMDs

Unless otherwise specified, the AMD shall be operated at each rated power line frequency and within ± 1 % of either:

- a) the rated AMD voltage (if any is stated); or
- b) the mean voltage of the stated range.

For power having more than two phases, the phase-to-phase voltage variation shall not exceed 1 % of the rated voltage. The voltage condition used shall be recorded.

8.1.2 Direct current AMDs

The AMD shall be operated within ± 1 % of each of the following supply voltages:

- a) rated nominal voltage;
- b) rated maximum voltage;
- c) rated minimum voltage.

Additionally recommended, but not required, voltages are given in Annex B if the fan operates with variable speeds. In this case, the voltage condition used shall be recorded.

8.2 Points of operation

Unless otherwise specified, the AMD shall be tested at three points of operation for each of the required frequencies and voltages given in 8.1. These points of operation correspond to:

- a) the adjustable exit port (slider) completely open;
- b) 80 % of maximum volume flow rate;
- c) 20 % of maximum volume flow rate.

Additional tests may be run at other points of operation, including the point of maximum overall static efficiency, to establish the vibratory acceleration level versus volume flow rate curve. Some AMDs (e.g. small tube-axial fans) may be unstable when operated near the maximum static efficiency point. Tests should not be conducted at unstable points of operation.

Points of operation shall be determined in accordance with ISO 10302-1:2011, 7.2.