BS ISO 13579-2:2013

BSI Standards Publication

Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency

Part 2: Reheating furnaces for steel

bsi.

...making excellence a habit.™

Document Sharing Hub

Full document details: BS ISO 13579-2:2013

National foreword

This British Standard is the UK implementation of ISO 13579-2:2013.

The UK participation in its preparation was entrusted to Technical Committee RHE/13, Oil burning equipment.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013. Published by BSI Standards Limited 2013

ISBN 978 0 580 72511 1

ICS 25.180.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 January 2013.

Amendments issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS ISO 13579-2:2013

INTERNATIONAL STANDARD

ISO 13579-2

First edition
2013-01-15

Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency —

Part 2:
Reheating furnaces for steel

Fours industriels et équipements associés — Méthode de mesure du bilan énergétique et de calcul de l'efficacité —

Partie 2: Fours de réchauffage pour acier

Reference number
ISO 13579-2:2013(E)

Documents
Document Sharing Hub

© ISO 2013

Full document details: BS ISO 13579-2:2013

COPYRIGHT PROTECTED DOCUMENT

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Documents
Document Sharing Hub
© ISO 2013 – All rights reserved

Full document details: BS ISO 13579-2:2013

Contents

Page

Foreword v

Introduction vi

1 Scope 1

2 Normative references 1

3 Terms and definitions 1
3.1 Terms related to type of energy used in this part of ISO 13579 2

4 Symbols 5

5 Basic principles 7
5.1 General 7
5.2 Energy flow diagram 9
5.3 Process Heating Assessment Survey Tool 10

6 Basic conditions of measurement and calculation 10
6.1 State of furnace 10
6.2 Duration of measurement 10
6.3 Unit of specific energy intensity 10
6.4 Reference conditions 10
6.5 Unit of amount of gas 10
6.6 Fuel 10

7 Type of energy evaluated in this part of ISO 13579 and its systematization 10
7.1 General 10
7.2 Energy balance 10
7.3 Thermal energy balance 12
7.4 Energy balance of electrical generation 13
7.5 Recycled energy 14

8 Measurement method 14
8.1 General 14
8.2 Fuel 14
8.3 Atomization agent 14
8.4 Combustion air and exhaust gas 15
8.5 Controlled atmospheric gas 15
8.6 Products and jigs/fixtures for products handling 16
8.7 Temperature of furnace surface 16
8.8 Furnace inner wall temperature 16
8.9 Inner furnace pressure 16
8.10 Cooling water 16
8.11 Electrical auxiliary equipment 17
8.12 Generation of utilities 17
8.13 Recycled energy 17

9 Calculation 17
9.1 General provisions 17
9.2 Total energy input 17
9.3 Total energy output 18
9.4 Total energy efficiency 21

10 Energy balance evaluation report 21

Annex A (informative) **Reference data** 22

Documents
Document Sharing Hub

© ISO 2013 – All rights reserved

Full document details: BS ISO 13579-2:2013

Annex B (informative) **Report of energy balance and efficiency of a reheating furnace for steel — Example** **24**

Annex C (informative) **Assessment of uncertainty of the total energy efficiency** **31**

Bibliography **34**

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub

Full document details: BS ISO 13579-2:2013

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 13579-2 was prepared by Technical Committee ISO/TC 244, *Industrial furnaces and associated thermal processing equipment*.

ISO 13579 consists of the following parts, under the general title *Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency*:

— *Part 1: General methodology*

— *Part 2: Reheating furnaces for steel*

— *Part 3: Batch-type aluminium melting furnaces*

— *Part 4: Furnaces with protective or reactive atmosphere*

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 13579-2:2013

Introduction

All calculations within this part of ISO 13579 are based on the location of equipment under reference conditions.

NOTE For equipment intended to be installed above or below sea level, it is expected that the impact of the elevation be calculated for that location.

© ISO 2013 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 13579-2:2013

INTERNATIONAL STANDARD ISO 13579-2:2013(E)

Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency —

Part 2: Reheating furnaces for steel

1 Scope

This part of ISO 13579 specifies a general methodology for measuring energy balance and calculating the efficiency of the process involving reheating furnaces for steel as designed by furnace manufacturers. This general methodology includes:

— measurement methods;

— calculations (general calculation);

— energy balance and efficiency calculation evaluation report.

This part of ISO 13579 is not applicable to any efficiencies related to the process itself outside of reheating furnaces for steel (e.g. in a rolling mill process, the reheating furnace is the only part covered by this part of ISO 13579).

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 13574, *Industrial furnaces and associated processing equipment — Vocabulary*

ISO 13579-1:2013, *Industrial furnaces and associated processing equipment — Method of measuring energy balance and calculating efficiency — Part 1: General methodology*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 13574 and the following apply.

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 13579-2:2013

3.1 Terms related to type of energy used in this part of ISO 13579

3.1.1 Total energy input

3.1.1.1
total energy input
E_{input}
aggregate of measured energy input brought into the area of energy balance, and which is composed of fuel equivalent energy and other energy input

3.1.2 Fuel equivalent energy

3.1.2.1
fuel equivalent energy
E_{fe}
aggregate of input energy which is composed of calorific value of fuel, calorific value of waste, calorific value of source gas of atmospheric gas and fuel equivalent energy of electricity

3.1.2.2
calorific value of fuel
$E_{h,fuel}$
heat of combustion of fuel which is consumed and used for heating products in the area of energy balance

3.1.2.3
calorific value of source gas of atmospheric gas
$E_{fe,atm,cal}$
calorific value of source gas of atmospheric gas which is used as protective and reactive atmospheres

3.1.2.4
fuel equivalent energy of electricity
$E_{fe,el}$
aggregate of fuel equivalent energy of electricity converted from each occurrence of electrical energy consumptions in the area of energy balance

3.1.3 Other energy input

3.1.3.1
other energy input
E_{others}
energy that is composed of sensible heat of fuel, sensible heat of combustion air or other oxidant, sensible heat of atomization agent for liquid fuel, heat of reaction and sensible heat of infiltration air

3.1.3.2
heat of reaction
E_{react}
heat generated by the oxidation reaction of products in the area of energy balance measurement

EXAMPLE The formation of scale of steel products during the oxidation reaction.

3.1.3.3
sensible heat of infiltration air
$E_{s,infilt}$
sensible heat of air that leaks into the furnace through supply/discharge port or gaps in the operating systems of the furnace

Note 1 to entry This term may be replaced with "sensible heat of false air".

© ISO 2013 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 13579-2:2013

3.1.4 Total energy output

3.1.4.1
total energy output
E_{output}
aggregate of measured energy output emitted from or consumed in the area of energy balance, which is composed of thermal energy output, energy consumed in electrical auxiliary equipment, energy used for generation of utility and electrical generation loss

3.1.5 Thermal energy output

3.1.5.1
thermal energy output
$E_{therm,out}$
aggregate of thermal energy which is emitted from the area of energy balance

Note 1 to entry Thermal energy output is composed of energy defined in 3.1.5.2 to 3.1.5.12.

3.1.5.2
effective energy
E_{effect}
enthalpy that products gain in the area of energy balance

3.1.5.3
jig loss
$E_{l,jig}$
enthalpy that jigs for handling the products gained in the area of energy balance measurement

3.1.5.4
sensible heat of oxidized substance
$E_{l,oxid}$
sensible heat of substances which have reacted with oxygen, formed in the thermal process brought out from the area of energy balance measurement

3.1.5.5
sensible heat of exhaust gas
$E_{exhaust}$
sensible heat of expended gas which is emitted from the area of energy balance measurement

3.1.5.6
heat storage loss by batch-type furnace
$E_{l,storage}$
sensible heat which a furnace refractory gains within a batch-type furnace operation cycle

3.1.5.7
wall loss
$E_{l,wall}$
thermal energy emitted from the surface of industrial furnaces by radiation and convection

3.1.5.8
heat loss of discharged blowout from furnace opening
$E_{l,blowout}$
sensible heat of blowout gas emitted from the furnace opening

3.1.5.9
heat loss of radiation from furnace opening
$E_{l,opening}$
thermal energy emitted from the furnace opening by radiation

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 13579-2:2013

3.1.5.10
heat loss from furnace parts installed through furnace wall
$E_{l,parts}$
thermal energy emitted through furnace parts which are installed through furnace wall

EXAMPLE As in the case of a roller hearth furnace.

3.1.5.11
cooling water loss
$E_{l,cw}$
thermal energy brought out by cooling water from the area of energy balance measurement

3.1.5.12
other losses
$E_{l,other}$
unmeasured thermal energy losses from the area of energy balance

3.1.6 Energy consumed in electrical auxiliary equipment

3.1.6.1
energy consumed in electrical auxiliary equipment
E_{aux}
energy utilized in electrical auxiliary equipment which is composed of energy consumed in installed electrical auxiliary equipment and energy used for fluid transfer

3.1.6.2
energy consumed in installed electrical auxiliary equipment
$E_{aux,installed}$
aggregate of total energy used in installed electrical auxiliary equipment (e.g. fans, pumps) installed in the area of energy balance

3.1.6.3
energy used for fluid transfer
$E_{aux,fluid}$
aggregate of energy for fluid transfer calculated from the property of the fluid

EXAMPLE For cooling water, fuel, etc.

3.1.7 Energy used for generation of utility

3.1.7.1
utility
service other than fuel and electricity provided to the area of energy balance

EXAMPLE Oxygen, steam and atmospheric gas.

3.1.7.2
energy used for generation of utilities
$E_{utility}$
aggregate of energy for the generation of utilities used in the area of energy balance

3.1.8 Electrical generation loss

3.1.8.1
electrical generation loss
$E_{l,eg}$
energy loss in electrical generation which is backcalculated from fuel equivalent energy and total consumed electrical energy

© ISO 2013 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 13579-2:2013

3.1.9 Thermal energy balance

3.1.9.1
thermal energy input from electrical heating source
heat energy entering the process from an electrical heating source, such as an electrical heater, emitted into the area of energy balance

3.1.9.2
circulating heat
heat that circulates within equipment or system installed in the area of energy balance

3.1.10 Energy balance of electrical generation

3.1.10.1
total consumed electrical energy
$E_{e,total}$
aggregate of electrical energy which is consumed in the area of energy balance and equal to the sum of thermal energy input from electrical heating source, energy consumed in electrical auxiliary equipment and electrical energy used for the generation of utility

3.1.10.2
electrical energy used for generation of utilities
$E_{e,utility}$
aggregate of electrical energy consumed for generation of utilities (e.g. generation of oxygen) used in the area of energy balance

3.1.11 Recycled energy

3.1.11.1
recycled energy
E_{re}
energy that is regenerated from the wasted thermal energy from the area of energy balance

EXAMPLE Energy reused in waste gas boiler.

4 Symbols

For the purposes of this document, the following symbols apply.

NOTE Tons used are metric tons.

Symbol	Meaning	Unit
$c_{pm,p1}$	mean specific heat of products between T_{p1} and 273,15 K	kJ/(kg·K)
$c_{pm,p2}$	mean specific heat of products between T_{p2} and 273,15 K	kJ/(kg·K)
$c_{pm,oxid}$	mean specific heat of scale between T_{p2} and 273,15 K	kJ/(kg·K)
E_{aux}	energy consumed in electrical auxiliary equipment per ton of products	kJ/t
$E_{aux,fluid}$	aggregate of energy used for fluid transfer per ton of products	kJ/t
$E_{aux,installed}$	aggregate of energy used in installed electrical auxiliary equipment per ton of products	kJ/t
E_{effect}	effective energy per ton of products	kJ/t
$E_{exhaust}$	sensible heat of exhaust gas per ton of products	kJ/t
e_{f0}	heat by formation of scale per kilogram of iron	kJ/kg
e_{FeO}	heat by formation of FeO per 1 kg of Fe	kJ/kg
e_{Fe2O3}	heat by formation of Fe_2O_3 per 1 kg of Fe	kJ/kg

Documents
Document Sharing Hub

© ISO 2013 – All rights reserved

Full document details: BS ISO 13579-2:2013

Symbol	Meaning	Unit
e_{Fe3O4}	heat by formation of Fe_3O_4 per 1 kg of Fe	kJ/kg
E_{fe}	fuel equivalent energy per ton of products	kJ/t
$E_{fe,el}$	fuel equivalent energy of electricity per ton of products	kJ/t
$E_{h,fuel}$	calorific value of fuel per ton of products	kJ/t
E_{input}	total energy input per ton of products	kJ/t
$E_{l,blowout}$	heat loss of discharged blowout from furnace opening per ton of products	kJ/t
$E_{l,cw}$	cooling water loss per ton of products	kJ/t
$E_{l,eg}$	energy loss in electrical generation	kJ/t
$E_{l,jig}$	jig loss per ton of products	kJ/t
$E_{l,opening}$	heat loss of radiation from furnace opening per ton of products	kJ/t
$E_{l,other}$	other losses per ton of products	kJ/t
$E_{l,parts}$	Heat loss from furnace parts installed through furnace wall	kJ/t
$E_{l,storage}$	heat storage loss by batch-type furnace per ton of products	kJ/t
$e_{l,storage}$	heat storage loss by batch-type furnace per 1m2 of furnace wall	kJ/m^2
$E_{l,wall}$	wall loss per ton of products	kJ/t
E_{others}	other energy input per ton of products	kJ/t
E_{p1}	sensible heat (or enthalpy) of products at the time when products are loaded in the area of energy balance per ton of products	kJ/t
E_{p2}	sensible heat (or enthalpy) of products at the time when products are extracted from the area of energy balance per ton of products	kJ/t
E_{react}	heat of reaction per ton of products	kJ/t
E_{re}	energy regenerated from the wasted thermal energy per ton of products	kJ/t
$E_{s,air}$	sensible heat of combustion air or other oxidant per ton of products	kJ/t
$E_{s,atomize}$	sensible heat of atomization agent per ton of products	kJ/t
$E_{s,fuel}$	sensible heat of fuel per ton of products	kJ/t
$E_{s,infilt}$	sensible heat of infiltration air per ton of products	kJ/t
$E_{s,oxid}$	sensible heat of oxidized substance per ton of products	kJ/t
$E_{therm,out}$	thermal (output) energy per ton of products	kJ/t
$E_{utility}$	energy used for generation of utilities per ton of products	kJ/t
$E_{u,oxy}$	energy for generation of oxygen per ton of products	kJ/t
$E_{u,steam}$	energy for generation of steam per ton of products	kJ/t
M_{loss}	loss of mass per ton of products	kg/t
M_p	mass of products	kg or t
T_{p1}	average temperature of products at the time of loading to the area of energy balance	K
T_{p2}	average temperature of products at the time of extraction from the area of the energy balance	K
η_1	total energy efficiency	—
η_e	regional electrical generation efficiency	—
σ_1	absolute error of thermocouple	°C
σ_2	absolute error of compensation lead wire	°C
σ_3	absolute error of output device of thermocouple	°C
$w_{(FeO)}$	mass fraction of iron oxide	—
$w_{(Fe2O3)}$	mass fraction of Fe_2O_3	—
$w_{(Fe3O4)}$	mass fraction of Fe_3O_4	—
$w_{(T\cdot Fe)}$	mass fraction of iron contained in scale	—

© ISO 2013 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 13579-2:2013