

Industrial fans — Method of measurement of fan vibration

ICS 17.160; 23.120

National foreword

This British Standard is the UK implementation of ISO 14695:2003, incorporating corrigendum March 2009. It supersedes BS 848-6:1989 which is withdrawn.

The start and finish of text introduced or altered by corrigendum is indicated in the text by tags. Text altered by ISO corrigendum March 2009 is indicated in the text by AC₁ AC₁.

The UK participation in its preparation was entrusted to Technical Committee MCE/17, Industrial fans.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 11 June 2003

© BSI 2009

ISBN 978 0 580 68588 0

Amendments/corrigenda issued since publication

Date	Comments
31 October 2009	Implementation of ISO corrigendum March 2009 and alignment of title with ISO core text

INTERNATIONAL STANDARD

**ISO
14695**

First edition
2003-04-15

Industrial fans — Method of measurement of fan vibration

Ventilateurs industriels — Méthode de mesure des vibrations des ventilateurs



Reference number
ISO 14695:2003(E)
AVA Documents
Document Sharing Hub

Contents

Page

Foreword	iv
Introduction	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Symbols and units	2
5 Mounting of test rig	4
5.1 General	4
5.2 Resilient base mounting of fan	5
5.3 Mounting of fans with resilient elastic rope	5
5.4 Stiff mounting of fans	9
5.5 Flexible connections	9
6 Measuring equipment	9
6.1 General	9
6.2 Calibration	9
6.3 Instrument system	10
6.4 Transducers	10
6.5 Piezoelectric accelerometers	11
6.6 Preamplifiers	11
6.7 Analysers	11
6.8 Indicators	12
6.9 Outputs	12
7 Transducer attachment	12
7.1 General	12
7.2 Attachments	13
8 Selection of measuring positions	13
8.1 General	13
8.2 Mounting on combination base frame	16
8.3 Mounting of transducers for other fans	16
9 Test environment and operating data	16
10 Procedure	16
10.1 General	16
10.2 Measurement parameters	17
10.3 Frequency analysis	18
11 Presentation of results	18
Annex A (informative) Guide to calculating resilient mount positions and rigid body natural frequencies	19
Annex B (informative) Secondary measurement methods for <i>in situ</i> testing or quality grading	25
Annex C (informative) Recommended measuring positions for machinery health measurements	27
Annex D (informative) Relationship between absolute and decibel levels	29
Annex E (informative) Relationship between vibration magnitude of single frequency signal	31
Bibliography	33

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 14695 was prepared by Technical Committee ISO/TC 117, *Industrial fans*.

Introduction

ISO 14695 is a part of a series of standards covering important aspects of fans which affect their design, manufacture and use. This series includes ISO 5801, ISO 5802, ISO 12499, ISO 13347, ISO 13349, ISO 13350, ISO 13351 and ISO 14694.

Vibration is recognized as an important parameter in the description of the mechanical performance of fans. It gives an indication of how well the fan has been designed and constructed and can forewarn of possible operation problems. The problems may be associated with inadequacies in support structures and machine deterioration, etc.

Vibration measurements may be required for a variety of reasons of which the following are the most important:

- a) design/development evaluations;
- b) *in situ* testing;
- c) as information for a condition-monitoring or machinery health programme (ISO 14694 and Annex C gives recommended measuring positions for machinery health measurement);
- d) to inform the designer of associated supporting structures, foundations, ducting systems, etc., of the residual vibration which will be transmitted by the fan into the associated structure;
- e) as a quality assessment at the final inspection stage;
- f) to be sure of acceptability of specific dynamic loading.

All the information which can be obtained from tests conducted in accordance with this International Standard (see Clause 10) is neither necessary nor appropriate for quality-grading purposes. Reference should be made to ISO 14694 for this purpose. Vibration as a consequence of unbalance should be measured at the fan bearings and, in this connection, the recommendations given in ISO 1940-1 should be followed.

Whilst an open inlet/open outlet test may be useful as a quality guide, this International Standard recognizes that the vibration of a fan will be dependent upon the specified aerodynamic duty, which determines the rotational speed and position on the fan characteristic curve.

Although alternative standards exist which deal with the vibration of machines generally (e.g. ISO 10816), they presently have limitations because of their universal nature when considering a specific family of machines such as fans.

This International Standard describes the methods of measurement which will give consistent results and which may be used as a basis for comparison between products. The amount of information which needs to be presented and the preferred units are given in ISO 14694. Such information is dependent on the purpose for which the test has been conducted, the type of fan, its application and its method of mounting in service.

Industrial fans — Method of measurement of fan vibration

1 Scope

This International Standard describes a method of measuring the vibrational characteristics of fans of all types, except those designed solely for air circulation, for example, ceiling fans and table fans. However, it is limited to fans of all types installed with a power of less than 300 kW. For fans of greater power than this, the methods described in ISO 10816-1 and the applicable limits given in ISO 10816-3 may be used. This International Standard gives a general method only and does not give criteria for interpretation of data (see ISO 14694).

This International Standard specifies the measurement of vibration that may be recorded as overall root-mean-square r.m.s. velocity, acceleration or displacement, or in terms of a frequency spectrum, within the appropriate frequency range. Methods of testing when suspended on elastic ropes or when installed on resilient mountings are included.

It is recognized that the oscillatory forces at mounting points can be a useful measurement for analysing the effects on support structures; but such measurements are outside the scope of this International Standard.

Annexes are given for information. Annex B gives secondary measurement methods which, whilst not recommended for accurate measurements, may be used for assessing the balance of series-produced fans or for comparative site measurements.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

 ISO 1940-1, *Mechanical vibration — Balance quality requirements for rotors in a constant (rigid) state— Part 1: Specification and verification of balance tolerances*

ISO 2041:1990, *Vibration and shock — Vocabulary*

ISO 2954, *Mechanical vibration of rotating and reciprocating machinery — Requirements for instruments for measuring vibration severity*

ISO 5801:2007, *Industrial fans — Performance testing using standardized airways*

ISO 10816-3, *Mechanical vibration — Evaluation of machine vibration by measurements on non-rotating parts — Part 3: Industrial machines with nominal power above 15 kW and nominal speeds between 120 r/min and 15 000 r/min when measured in situ*

ISO 14694:2003, *Industrial fans — Specifications for balance quality and vibration levels* 

IEC 60034-14, *Rotating electrical machines — Part 14: Mechanical vibration of certain machines with shaft heights 56 mm and higher — Measurement, evaluation and limits of vibration*

IEC 60651, *Sound level meters*

IEC 61260, *Electroacoustics — Octave-band and fractional-octave band filters*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 2041 and the following apply.

- 3.1 background vibration**
all sources of vibration independent of the source
- 3.2 duty point**
(aerodynamic duty) point on the fan performance curve at which a fan operates
- 3.3 fan performance curve**
(fan characteristic) plot of pressure rise developed by the fan against the airflow through a fan
- 3.4 radius of gyration**
measure of the distribution of mass about a chosen axis, given as the square root of the moment of inertia about that axis divided by the mass
- 3.5 resilient mount**
mount with elastic characteristics, and measurable deflection, but no permanent deformation under normal load conditions

4 Symbols and units

For the purposes of this International Standard, the following symbols and units apply.

Symbol	Term	Unit
a	Instantaneous vibration acceleration	m/s ²
a_0	Reference vibration acceleration	m/s ²
A	Vibration acceleration amplitude of peak	m/s ²
A_{dB}	r.m.s. vibration acceleration level above a reference of 10 ⁻⁶ m/s ²	dB
$A_{dB} = 20 \log_{10} \left(\frac{A_{r.m.s.}}{10^{-6}} \right)$		
$A_{r.m.s.}$	r.m.s. vibration-acceleration amplitude	m/s ²
d	Instantaneous vibration displacement	µm, mm or m
D	Vibration displacement amplitude of peak	µm, mm or m

Symbol	Term	Unit
f	Frequency = $\omega/2\pi$	Hz
f_H	Frequency of sway mode of vibration	Hz
f_R	Frequency of rotational mode of vibration in zx plane	Hz
f_T	Frequency of torsion/yaw mode of vibration in xy plane	Hz
f_V	Frequency of vertical mode of vibration	Hz
f_1	Frequency of coupled rocking mode where sway is dominant	Hz
f_2	Frequency of coupled rocking mode where rotation is dominant	Hz
I_R	Moment of inertia of system about y -axis through centre of gravity of system	kg·m ²
I_T	Moment of inertia of system about z -axis through centre of gravity of system located at X_G, Y_G, Z_G	kg·m ²
$I_{zz,1}$	Moment of inertia of fan about z -axis through centre of gravity of fan located at x_1, y_1, z_1	kg·m ²
$I_{zz,2}$	Moment of inertia of motor about z -axis through centre of gravity of motor located at x_2, y_2, z_2	kg·m ²
$I_{zz,3}$	Moment of inertia of base about z -axis through centre of gravity of base located at x_3, y_3, z_3	kg·m ²
$I_{xx,1}$	Moment of inertia of fan about x -axis through centre of gravity of fan located at x_1, y_1, z_1	kg·m ²
$I_{xx,2}$	Moment of inertia of motor about x -axis through centre of gravity of motor located at x_2, y_2, z_2	kg·m ²
$I_{xx,3}$	Moment of inertia of base about x -axis through centre of gravity of base located at x_3, y_3, z_3	kg·m ²
$I_{yy,1}$	Moment of inertia of fan about y -axis through centre of gravity of fan located at x_1, y_1, z_1	kg·m ²
$I_{yy,2}$	Moment of inertia of motor about y -axis through centre of gravity of motor located at x_2, y_2, z_2	kg·m ²
$I_{yy,3}$	Moment of inertia of base about y -axis through centre of gravity of base located at x_3, y_3, z_3	kg·m ²
k_H	Horizontal stiffness of resilient mount	N/m
k_V	Vertical stiffness of resilient mount	N/m
L_a	Vibratory acceleration level	dB
L_v	Vibratory velocity level	dB
m	Total mass of assembly	kg

Symbol	Term	Unit
m_1	Mass of fan	kg
m_2	Mass of motor	kg
m_3	Mass of base	kg
r	Radius of gyration	m
t	Time	s
T	Period of vibration	s
V	Instantaneous vibration velocity	mm/s or m/s
v_0	Reference vibration velocity	mm/s or m/s
V	Vibration velocity amplitude of peak	mm/s or m/s
V_{dB}	r.m.s. vibration velocity above a reference level of 10^{-9} m/s	dB
$V_{dB} = 20 \log_{10} \left(\frac{V_{r.m.s.}}{10^{-9}} \right)$		
$V_{r.m.s.}$	Overall root-mean-square velocity	mm/s or m/s
x, y, z	Cartesian coordinates	m
$\bar{z}$	Effective vertical offset of resilient mounts	m
X_G, Y_G, Z_G	Positions of centre of gravity of fans assembly relative to arbitrary origin	m
$\delta_{1,2,n}$	Individual deflections of resilient mounts	m
Σ	Summation	—
ω	Angular frequency = $2\pi f$	rad·s ⁻¹

5 Mounting of test rig

5.1 General

Fans shall be mounted by one of the methods described in 5.2, 5.3 or 5.4, as appropriate.

Resilient mountings shall be chosen to give a uniform static deflection within $\begin{smallmatrix} +20 \\ -35 \end{smallmatrix}$ % of their nominal deflection. Fans which are resiliently mounted in normal applications shall be tested using the same type and number of mounts as used in that application. The support arrangement used, or existing at the time of the test, shall be described in the test report [see Clause 11 e)].

NOTE 1 The fan support arrangement may significantly affect the vibration levels measured on the fan structure. Mounting arrangements may be generally classified as stiff or resilient. In order to minimize the influence of the support condition on measured vibration levels, so that results from different tests may be readily compared, a resilient or soft-mounting arrangement for the fan is preferred. There is a risk of high-amplitude vibration when mounting stiffness results in the natural frequency f_n being near the frequency equivalent to the operating speed. For the purposes of this International Standard, a stiff mounting is considered to have a natural frequency f_n greater than 1,5 times the operating frequency. A resilient mounting is considered to have a natural frequency f_n less than 0,25 times the operating frequency.

NOTE 2 Tests using the rubber-rope method of suspension are recommended for design and development evaluation and/or as a grading exercise.

The test-rig arrangement will generally be determined by the nature and location of the test. For design/development evolution, sophisticated purpose-designed rigs are likely to be available. However, any arrangement of the test rig which does not readily permit the aerodynamic duty of the fan to be controlled, or in which the duty is otherwise unknown, may be unsuitable for tests in accordance with this specification where the vibration produced by the fan varies with duty. Wherever practicable, a standardized airway, as defined in ISO 5801, should be used.

NOTE 3 Two typical arrangements of fan-vibration test rigs are shown in Figures 1 and 2.

5.2 Resilient base mounting of fan

The natural frequencies of the fan on its mountings in the six possible degrees of freedom (see Figure 3) shall not be greater than 0,25 times of the slowest operational rotation frequency of the fan under test.

NOTE 1 A guide to calculating the natural frequencies is given in Annex A.

The mass of any additional attachments shall not exceed one-tenth of the normal mass of the unit under test, to reduce the influence of the mass and the moments of inertia of these parts on the vibration level.

NOTE 2 Where a fan is not normally equipped with resilient mountings, it may be necessary to fit special mounting brackets and isolators or other attachments to the fan in order to accommodate them.

No major flexural resonances of the support structure shall coincide with either the rotational frequencies of the fan under test or the rigid-body natural frequencies of the support arrangement, except when the fan and support are being investigated together.

NOTE 3 Fan reaction torque of the fan may be significant on a resiliently mounted arrangement (see A.3.2 for advice on inertia bases).

5.3 Mounting of fans with resilient elastic rope

When testing fans with an integral motor which are to be supplied as single units without a mounting frame, these fans shall be mounted in an elastic-rope test rig (examples are shown in Figure 4).

NOTE 1 Low-frequency mounting permits consistent readings to be taken for comparison purposes under free-air conditions only.

When a duct connection is required to obtain the vibration characteristics at the duty point, a suitable flexible connection shall be used with horizontal elastic restraint if necessary.

The fan shall be supported by nylon slings attached to an assembly of braided rubber cords of a suitable number, length and diameter, arranged symmetrically with respect to the centre of gravity, to provide an overall deflection in the range 200 mm to 400 mm under the fan mass.

NOTE 2 This soft mounting may be conveniently suspended from an "A" frame structure.