BS ISO 15619:2013

BSI Standards Publication

Reciprocating internal combustion engines — Measurement method for exhaust silencers — Sound power level of exhaust noise and insertion loss using sound pressure and power loss ratio

bsi.

...making excellence a habit.™

Document Sharing Hub

National foreword

This British Standard is the UK implementation of ISO 15619:2013.

The UK participation in its preparation was entrusted to Technical Committee MCE/14, RIC engines.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013. Published by BSI Standards Limited 2013

ISBN 978 0 580 71192 3

ICS 27.020

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 September 2013.

Amendments issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS ISO 15619:2013

INTERNATIONAL STANDARD

ISO 15619

First edition
2013-10-01

Reciprocating internal combustion engines — Measurement method for exhaust silencers — Sound power level of exhaust noise and insertion loss using sound pressure and power loss ratio

Moteurs alternatifs à combustion interne — Méthode de mesure pour silencieux d'échappement — Niveau de puissance acoustique du bruit à l'échappement et perte par insertion à partir de la pression acoustique et du rapport de perte de puissance

Reference number
ISO 15619:2013(E)

Documents
Document Sharing Hub

© ISO 2013

Full document details: BS ISO 15619:2013

COPYRIGHT PROTECTED DOCUMENT

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub

Full document details: BS ISO 15619:2013

Contents

Page

Foreword ... **iv**

Introduction ... **v**

1 Scope ... **1**
1.1 Measurement uncertainty ... 1

2 Normative references ... **2**

3 Terms and definitions ... **2**

4 Test environment ... **6**
4.1 General ... 6
4.2 Criteria for background noise ... 7
4.3 Criterion for acoustic adequacy of test environment ... 9

5 Instrumentation ... **10**
5.1 General ... 10
5.2 Calibration ... 10

6 Installation and operation of noise source under test for laboratory measurement ... **10**
6.1 General ... 10
6.2 Source location ... 11
6.3 Installation requirements ... 11
6.4 Operation condition ... 13

7 Measurement ... **13**
7.1 General ... 13
7.2 Laboratory measurement ... 14
7.3 Site measurement ... 17

8 Calculation ... **20**
8.1 General ... 20
8.2 Calculation of sound power level of exhaust noise ... 20
8.3 Calculation of insertion loss ... 22
8.4 Calculation of power loss ratio ... 23

9 Information to be recorded ... **23**
9.1 General ... 23
9.2 Description of the tested exhaust silencer and substitution pipe ... 23
9.3 Description of the engine on which the exhaust silencer is installed ... 23
9.4 Acoustic environment ... 23
9.5 Description of instrumentation ... 23
9.6 Acoustical data ... 23

10 Test report ... **24**

Annex A (normative) **Qualification procedures for the acoustic environment** ... **25**

Annex B (informative) **Measurement procedure for pressure loss** ... **30**

Annex C (normative) **Calculation of A-weighted sound power levels from frequency band levels** ... **31**

Annex D (normative) **Sound power level under reference meteorological conditions** ... **33**

Bibliography ... **35**

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information

The committee responsible for this document is ISO/TC 70, *Internal combustion engines.*

© ISO 2013 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013

Introduction

This International Standard specifies methods for measuring the sound power level of exhaust noise and the insertion loss of exhaust silencers installed on reciprocating internal combustion engines and a method for measuring the power loss ratio of reciprocating internal combustion engines.

Sound power level of exhaust noise, insertion loss, and transmission loss are parameters to characterize the acoustic performance of exhaust silencers. Sound power levels of exhaust noise and insertion loss are important parameters to characterize the acoustic matching performance of exhaust silencers and reciprocating internal combustion engines. Transmission loss is the difference in sound power level of exhaust noise between the noise before and after transmitting through the exhaust silencer, which is the parameter to characterize the acoustic performance of the exhaust silencer itself and is irrelevant with the reciprocating internal combustion engine. Power loss ratio and pressure loss are parameters to characterize the aerodynamic performance of exhaust silencers. Power loss ratio is an important parameter to characterize the aerodynamic matching performance of exhaust silencers and reciprocating internal combustion engines, whereas resistance coefficient which is closely related to pressure loss is to characterize the aerodynamic performance of the exhaust silencer itself and is irrelevant with the reciprocating internal combustion engine on which the exhaust silencer is installed. The matching parameters of the sound power level of exhaust noise, the insertion loss, and the power loss ratio are used in this International Standard as the measurement parameters.

For sound power level of exhaust noise, the measurement results at 90° direction and 45° direction can be different. The measurement results at 45° direction is slightly greater than the actual value, the measurement results at 90° direction is much closer to the actual results. For insertion loss, the measurement results at 90° direction and 45° direction may be different, but the measurement uncertainty at 90° direction is smaller than that at 45° direction. Measurement at 90° direction is used for the laboratory measurement (engineering method). The measurement at 90° or 45° direction is used for laboratory measurement (survey method). The measurement at 45° direction is used for site measurement.

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013

Documents
Document Sharing Hub

Full document details: BS ISO 15619:2013

INTERNATIONAL STANDARD ISO 15619:2013(E)

Reciprocating internal combustion engines — Measurement method for exhaust silencers — Sound power level of exhaust noise and insertion loss using sound pressure and power loss ratio

1 Scope

This International Standard specifies the measurement method and requirements for exhaust silencers which is installed on reciprocating internal combustion engines, including laboratory measurement and site measurement.

The following parameters are measured for laboratory measurement (engineering method):

— the sound power level (A-weighted or in frequency bands) of exhaust noise using sound pressure, accuracy grade 2;

— the insertion loss (A-weighted or in frequency bands) of exhaust silencers;

— the power loss ratio of reciprocating internal combustion engines.

The following parameters are measured for site measurement and laboratory measurement (survey method):

— the sound power level (A-weighted) of exhaust noise using sound pressure, accuracy grade 3;

— the insertion loss (A-weighted) of exhaust silencers.

NOTE 1 The aim of laboratory measurement in measuring the sound power level of exhaust noise is accuracy grade 2 (engineering method) result. When the correction for background noise and/or the environment conditions and/or the location of exhaust outlets cannot meet the requirements of the engineering method of this International Standard, then accuracy grade 3 (survey method) result is obtained. The aim of site measurement in measuring the sound power level of exhaust noise in this International Standard is accuracy grade 3 (survey method) result.

The laboratory measurement (engineering method) of this International Standard can be used to make acceptance tests and engineering measures. The site measurement and laboratory measurement (survey method) of this International Standard can be used to make comparative tests.

This International Standard applies to all exhaust silencers installed on reciprocating internal combustion engines falling within the field of application of ISO 3046-1 and other exhaust silencers, if no suitable International Standard exists.

NOTE 2 Throughout the text, exhaust silencer is referred to as silencer and reciprocating internal combustion engine as engine.

1.1 Measurement uncertainty

1.1.1 Engineering method

The standard deviation of reproducibility is equal to or less than 1,5 dB for A-weighted sound power levels. In one-third octave bands, it is equal to or less than 5 dB from 50 Hz to 80 Hz, 3 dB from 100 Hz to 160 Hz, 2 dB from 200 Hz to 315 Hz, 1,5 dB from 400 Hz to 5 000 Hz, and 2,5 dB from 6 300 Hz to 10 000 Hz. In octave bands, it is equal to or less than 5 dB for 63 Hz, 3 dB for 125 Hz, 2 dB for 250 Hz, 1,5 dB from 500 Hz to 4 000 Hz, and 2,5 dB for 8 000 Hz.

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013

1.1.2 Survey method

The standard deviation of reproducibility is equal to or less than 4,0 dB for A-weighted sound power levels.

NOTE 1 The standard deviations listed in 1.1 are associated with the test conditions and procedures defined in this International Standard and not with the noise source itself, including variations of installation and/or operation conditions. They arise in part from variations between measurement laboratories, changes in atmospheric conditions if outdoors, the geometry of the test room or outdoor environment, the acoustical properties of the reflecting plane, absorption at the test room boundaries if indoors, background noise, and the type and calibration of instrumentation. They are also due to variations in experimental techniques, including the size and shape of the measurement surface, measurement distances, number and location of microphone positions, sound source location, determination of environmental corrections, if any, and integration time. The standard deviations are also affected by errors associated with measurements taken in the near field of the source. Such errors depend upon the nature of the sound source, but generally increase for smaller measurement distances and lower frequencies (below 250 Hz).

NOTE 2 If several laboratories use similar facilities and instrumentation, the results of sound power determinations on a given source in those laboratories may be in better agreement than would be implied by the standard deviations of 1.1.

NOTE 3 For a family of silencers, of similar size with similar sound power spectra and similar operating conditions, the standard deviations of reproducibility may be smaller than the values given in 1.1.

NOTE 4 The standard deviations of reproducibility, as listed in 1.1, include the uncertainty associated with repeated measurements on the same noise source under the same conditions (for standard deviations of reproducibility). This uncertainty is usually much smaller than the uncertainty associated with interlaboratory variability.

NOTE 5 The procedures of this International Standard and the standard deviations given in 1.1 are applicable to measurements on an individual silencer.

The measurement uncertainty depends on the standard deviation of reproducibility and on the degree of confidence that is desired. As examples, for a normal distribution of sound power levels, there is 90 % confidence that the true value of the sound power level of a source lies within the range $\pm 1{,}645\sigma_R$ of the measured value and a 95 % confidence that it lies within the range $\pm 1{,}960\sigma_R$ of the measured value.

NOTE 6 For a normal distribution of sound power levels, there is 90 % confidence that the probability of acceptance is 95 % and a 95 % confidence that the probability of acceptance is 97,5 %.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3046-1:2002, *Reciprocating internal combustion engines — Performance — Part 1: Declarations of power, fuel and lubricating oil consumptions, and test methods — Additional requirements for engines for general use*

ISO 3046-3:2006, *Reciprocating internal combustion engines — Performance — Part 3: Test measurements*

ISO 6926:1999, *Acoustics — Requirements for the performance and calibration of reference sound sources used for the determination of sound power levels*

IEC 60942:2003, *Electroacoustics — Sound calibrators*

IEC 61260:1995, *Electroacoustics — Octave-band and fractional-octave-band filters*

IEC 61672-1:2002, *Electroacoustics — Sound level meters — Part 1: Specifications*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

© ISO 2013 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013

3.1
sound pressure
p
difference between instantaneous pressure and static pressure, expressed in pascals

3.2
sound pressure level
L_p
ten times the logarithm to the base 10 of the ratio of the square of the sound pressure, p, to the square of a reference value, p_0

$$L_p = 10 \lg \frac{p^2}{p_0^2}$$

where the reference value, p_0, is 20 µPa

Note 1 to entry: If specific frequency and time weightings, as specified in IEC 61672–1, and/or specific frequency bands are applied, this is indicated by appropriate subscripts, e.g. L_{pA} denotes the A-weighted sound pressure level.

Note 2 to entry: It is expressed in decibels.

3.3
time-averaged sound pressure level
$L_{p,T}$
ten times the logarithm to the base 10 of the ratio of the time average of the square of the sound pressure, p, during a stated time interval of duration, T (starting at t_1 and ending at t_2), to the square of a reference value, p_0

$$L_{p,T} = 10 \lg \left[\frac{\frac{1}{T} \int_{t_1}^{t_2} p^2(t)\, dt}{p_0^2} \right]$$

where the reference value, p_0, is 20 µPa

Note 1 to entry: In general, the subscript "T" is omitted since time-averaged sound pressure levels are necessarily determined over a certain measurement time interval.

Note 2 to entry: Time-averaged sound pressure levels are often A-weighted, in which case they are denoted by $L_{pA,T}$, which is usually abbreviated as L_{pA}.

Note 3 to entry: It is expressed in decibels.

3.4
surface time-averaged sound pressure level
$\overline{L_P}$
mean (energy average) of the time-averaged sound pressure levels over all the microphone positions, or traverses, on the measurement surface, with the background noise correction, K_1, and the environmental correction, K_2, applied

Note 1 to entry: It is expressed in decibels.

3.5
measurement time interval
T
portion or a multiple of an operational period or operational cycle of the noise source under test for which the time-averaged sound pressure level is determined

Note 1 to entry: It is expressed in seconds.

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013

3.6
acoustic free field
sound field in a homogeneous, isotropic medium free of boundaries

Note 1 to entry: In practice, an acoustic free field is a field in which the influence of reflections at the boundaries or other disturbing objects are negligible over the frequency range of interest.

3.7
reflecting plane
sound-reflecting planar surface on which the noise source under test is located

3.8
acoustic free field over a reflecting plane
acoustic free field in the half-space above an infinite reflecting plane in the absence of any other obstacles

3.9
frequency range of interest
for general purposes, the frequency range of octave bands with nominal mid-band frequencies from 63 Hz to 8 000 Hz (including one-third octave bands with mid-band frequencies from 50 Hz to 10 000 Hz)

Note 1 to entry: For special purposes, the frequency range can be extended or reduced, provided that the test environment and instrument specifications are satisfactory for use over the modified frequency range. Changes to the frequency range of interest are included in the test report.

3.10
measurement radius
r
radius of a spherical measurement surface

Note 1 to entry: It is expressed in metres.

3.11
measurement surface
hypothetical spherical surface of area, S, on which the microphone positions are located at which the sound pressure levels are measured, enveloping the noise source under test

3.12
background noise
noise from all sources other than the noise source under test

Note 1 to entry: Background noise includes contributions from airborne sound, noise from structure-borne vibration, and electrical noise in the instrumentation.

3.13
background noise correction
K_1
correction applied to the mean (energy average) of the time-averaged sound pressure levels over all the microphone positions on the measurement surface, to account for the influence of background noise

Note 1 to entry: The background noise correction is frequency dependent; the correction in the case of a frequency band is denoted by K_{1f}, where f denotes the relevant mid-band frequency, and that in the case of A-weighting is denoted by K_{1A}.

Note 2 to entry: It is expressed in decibels.

© ISO 2013 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013

3.14
environmental correction
K_2
correction applied to the mean (energy average) of the time-averaged sound pressure levels over all the microphone positions on the measurement surface, to account for the influence of reflected sound

Note 1 to entry: The environmental correction is frequency dependent; the correction in the case of a frequency band is denoted by K_{2f}, where f denotes the relevant mid-band frequency, and that in the case of A-weighting is denoted by K_{2A}.

Note 2 to entry: In general, the environmental correction depends on the area of the measurement surface and, usually, K_2 increases with S.

Note 3 to entry: It is expressed in decibels.

3.15
sound power
P
through a surface, the product of the sound pressure, p, and the component of the particle velocity, u_n, at a point on the surface in the direction normal to the surface, integrated over that surface

Note 1 to entry: The quantity relates to the rate per time at which airborne sound energy is radiated by a source.

Note 2 to entry: It is expressed in watts.

3.16
sound power level
L_W
ten times the logarithm to the base 10 of the ratio of the sound power of a source, W, to a reference value, W_0

$$L_W = 10 \lg \frac{W}{W_0}$$

where the reference value, W_0, is 1 pW

Note 1 to entry: If a specific frequency weighting, as specified in IEC 61672–1, and/or specific frequency bands are applied, this is indicated by appropriate subscripts, e.g. L_{WA} denotes the A-weighted sound power level.

Note 2 to entry: It is expressed in decibels.

3.17
exhaust silencer
chamber with acoustic lining and/or special structure designed to reduce exhaust noise

Note 1 to entry: The ICE exhaust silencer generally comprises the entire part from its inlet but does not include the exhaust manifold and pipe.

3.18
substitution pipe
rigid, non-absorbing pipe having the same length and the same cross section area of outlet as the tested silencer

3.19
straight transition pipe
straight pipe used to connect two pipes of different cross section areas

3.20
bent transition pipe
bent pipe used to change the airflow direction and to connect two pipes of the same cross section area

© ISO 2013 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013

3.21
centre distance of several exhaust outlets
b
double average distance from one exhaust outlet to the geometric centre of all exhaust outlets

3.22
insertion loss
D_I
loss of sound power due to the insertion of a component or device at some point in a transmission system

Note 1 to entry: Specifically, it is the difference between the sound power level of exhaust noise when the substitution pipe is installed on the engine and when the exhaust silencer is installed on the engine. It is expressed in decibels.

$$D_I = L_{W(SP)} - L_{W(ES)}$$

where

$L_{W(SP)}$ is the sound power level of exhaust noise when the substitution pipe is installed on the engine, in decibels;

$L_{W(ES)}$ is the sound power level of exhaust noise when the silencer is installed on the engine, in decibels.

3.23
power loss ratio
r_p
ratio of the difference between the engine power when the substitution pipe is installed on the engine and when the exhaust silencer is installed on the engine, to the engine power with the substitution pipe installed on the engine in the declared condition

Note 1 to entry: It is expressed in percentage.

$$r_P = \frac{P_{r(SP)} - P_{r(ES)}}{P_{r(SP)}} \times 100\%$$

where

$P_{r(SP)}$ is the engine power when the substitution pipe is installed on the engine under standard reference condition, in kilowatts;

$P_{r(ES)}$ is the engine power when the exhaust silencer is installed on the engine under standard reference condition, in kilowatts.

4 Test environment

4.1 General

Environmental conditions having an adverse effect on the microphones used for the measurements (e.g. strong electric or magnetic fields, wind, impingement of air discharge from the noise source being tested, high temperatures) shall be avoided. The instructions of the manufacturer of the measuring instrumentation regarding adverse environmental conditions shall be followed.

In an outdoor area, care shall be taken to minimize the effects of adverse meteorological conditions (e.g. temperature, humidity, wind, precipitation) on sound propagation and sound generation over the frequency range of interest or on the background noise during the course of the measurements.

© ISO 2013 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 15619:2013