



BSI Standards Publication

Indoor air

Part 41: Assessment and classification

National foreword

This British Standard is the UK implementation of [ISO 16000-41:2023](#).

The UK participation in its preparation was entrusted to Technical Committee EH/2/5, Emissions to internal environments.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 02700 6

ICS 13.040.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 August 2023.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

INTERNATIONAL STANDARD

ISO
16000-41

First edition
2023-08-04

Indoor air — Part 41: Assessment and classification

Air intérieur —

Partie 41: Évaluation et classification



Reference number
ISO 16000-41:2023(E)

AVA Documents
Document Sharing Hub
© ISO 2023



COPYRIGHT PROTECTED DOCUMENT

© ISO 2023, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 General	2
4.1 Procedure	2
4.2 Parameters	3
5 Indoor air quality	3
6 Quality classes	3
7 Criteria for the definition of the quality classes	4
7.1 General	4
7.2 Main parameters	4
7.3 Secondary parameters	5
8 Assessment plan	6
8.1 Overview	6
8.2 Documentation and reports	7
8.3 Purpose of measurements	8
8.3.1 Possible reasons	8
8.3.2 Concretisation of assessment	8
8.4 Preliminary survey	8
8.4.1 General	8
8.4.2 Basic investigation	9
8.4.3 Local inspections	9
8.4.4 Conditions for the omission of the measurement of parameters	10
8.5 Investigation plan	10
8.5.1 General	10
8.5.2 Normative specifications	10
8.5.3 Determination of sampling points	11
8.5.4 Utilization of the interior room	11
8.5.5 Seasonal fluctuations and ventilation	11
8.5.6 Complementary outside air measurements	12
8.6 Investigation	12
8.7 Report	12
8.8 Division in quality classes	12
Annex A (informative) Quality classes for main parameters	14
Annex B (informative) Standards for the preliminary survey and the design of investigation plans	21
Bibliography	24

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 146, *Air quality*, Subcommittee SC 6, *Indoor air*.

A list of all parts in the ISO 16000 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

In our society, privately and professionally, people stay indoors most of the day. Therefore, the quality of the indoor air is very decisive for the quality of life and health. This especially applies to small children, sick people and other vulnerable groups of persons.

Numerous scientific studies verify the positive effects of good indoor air on the overall performance during learning (e.g. in kindergartens and schools) and working. A consequence of improved indoor air quality can be, for example, reduced sickness rates and absenteeism.

The entitlement to high-quality indoor air does not contradict economical aspects of energy- and cost-efficiency. Improvements in the quality of indoor air are achievable with simple measures, for example, change of behaviour patterns.

This document describes a procedure to classify the air quality of indoor spaces using quality classes. These quality classes enable the allocation of the room air to a high, medium or low quality. The quality classes are based on criteria for physical, chemical and biological parameters according to the state of science and research. These criteria can be both concentration values in the room air (e.g. with formaldehyde) as well as sensory and other findings in the room itself (e.g. with mould). The basis for classifying a measured value of a parameter in a quality class is the definition of class boundaries for quality classes A to C by national institutions, using guide values from national guidelines, European and international publications and trade literature.

The most frequent pollutant sources indoors are human activities (e.g. domestic-, hobby- and cleaning activities, tobacco smoke), combustion processes as well as building materials, furnishings and interior design materials. The exception is the radioactive inert gas radon, which mostly originates from the geological subsoil and enters the interior spaces via leaks in the building envelope.

A variety of substances can emit into the indoor air from the most diverse pollution sources. For this reason, the single analysis of a source or pollutant cannot be used as a substitute for an overall assessment of the indoor air. A meaningful assessment of the indoor air is only achievable by an overall assessment of all pollutant sources and substances.

This document is intended for specialists who deal with the assessment of indoor air in the course of planning, construction, operation and use of buildings (e.g. indoor-experts, architects, specialist planners of trades, building owners, building developers and contracting authorities, maintenance engineers, lessors). Also included are producers and distributors of products, that are installed and/or operated indoors (e.g. building products), and possible users.

This page deliberately left blank

Indoor air —

Part 41: Assessment and classification

1 Scope

This document specifies a procedure for the assessment of the indoor air quality that is valid for all interior rooms in residential and non-residential buildings with natural or mechanical ventilation, in which people do not only stay temporarily.

This document is applicable to indoor environments as defined in [ISO 16000-1](#).

The assessment of working materials in workrooms or workplaces in buildings, that are subject to statutory occupational safety specifications, are excluded from this document. In these rooms, only air constituents that do not originate from working materials can be assessed according to this document.

It is not possible to define classes with exact values for the individual pollutants, as the corresponding limit and guide values differ in individual countries. In addition, the values relate to different observation periods.

Aspects concerning electromagnetic fields, noise and vibrations and their effect on the indoor air quality are not the object of this document. The classification of further consequences and measures, such as organisational steps, structural engineering measures, renovation proposals, further human medicine appraisals and the like, are not the object of this document.

NOTE This document applies to all types of indoor environments occupied by all kinds of persons, including regular users, clients and workers.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

[ISO 11665-8](#), *Measurement of radioactivity in the environment — Air: radon-222 — Part 8: Methodologies for initial and additional investigations in buildings*

ISO 16000 (all parts), *Indoor air*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 building product

product or building kit, that is manufactured or brought into circulation, to be installed permanently in buildings or parts of buildings and whose performance affects the performance of the building with regard to the basic requirements on buildings

[SOURCE: EU-BauPVO, Article 2 (1)^[23]]

3.2 assessment value

value obtained from an assessment

Note 1 to entry: The assessment value can be an individual measured value, the arithmetic mean of individual measured values or the result of a continuous measurement over a particular time period. In the case of carbon dioxide (CO₂), the assessment value is a statistical evaluation of the individual measured values.

3.3 assessment period

period during which the investigation of the indoor air takes place

Note 1 to entry: The assessment period is adapted to the parameter to be assessed and the measuring task and linked to certain usage conditions.

3.4 emission

release of chemicals, vibration and radiation to the environment

Note 1 to entry: The emission of air constituents can be specified as mass flow. In relation to *building products* (3.1), the mass flow can be related to area, length, mass, volume or component.

Note 2 to entry: The terms “emission” and “release” basically have the same meaning.

3.5 main parameter

parameter which, during an overall assessment, is taken into consideration without fail

3.6 secondary parameter

parameter that is also taken into consideration for the overall assessment, if references to its relevance exist in the preliminary survey

3.7 guide value

default value that serves as a comparative value for the assessment

Note 1 to entry: Specific guide values for interior rooms are defined, for example, by the WHO and national/professional institutions.

4 General

4.1 Procedure

The procedure for the assessment of the indoor air quality consists of the following steps:

- a) preliminary survey;
- b) investigation plan;
- c) investigation;
- d) documentation;

e) expert opinion.

When this document is applied, it should be taken into consideration that the concentrations of substances in the room air can fluctuate greatly: spatially, time-related and usage-specific. This is particularly dependent on ventilation, the building services and the individual user behaviour.

Individual results of certain parameters cannot sufficiently characterize the indoor air, therefore the overall assessment described in this document is necessary in order to obtain a comprehensive and differentiated picture of the room air situation.

An investigation of buildings for pollutants shall be carried out in accordance with [ISO 16000-32](#).

4.2 Parameters

Chemical, biological and physical parameters play a role in the assessment of the indoor air.

- chemical parameters and particles: gases, volatile and hardly volatile organic and inorganic compounds, fibres, dusts, dust constituents and odours;
- biological parameters: fungi, bacteria, viruses, pollen and other allergens (e.g. animal epithelia, insects/insect compounds, mites, mite excrement, plant parts/fibres);
- physical parameters: room air and environment surface temperatures, operative temperature, air humidity, air velocity, lighting, sounds and noise, electromagnetic fields and charged particles.

In the context of this document, only selected chemical and biological parameters are dealt with. The room air temperature and the humidity should be regarded as supplementary physical parameters.

NOTE Physical parameters are dealt with in, for example, [ISO 7730](#).

5 Indoor air quality

For the assessment of the indoor air according to this document, a classification of the room air quality into three quality classes A (high), B (medium) and C (low) is performed based on prescribed main parameters (see [7.2](#)). In addition, further secondary parameters (see [7.3](#)) should be taken into consideration, if necessary.

The class limits of the quality classes are defined by:

- guide values in the sense of maximum permissible concentrations in the room air (e.g. with formaldehyde) or distributions of measured values (e.g. with carbon dioxide CO₂),
- sensory findings in the room itself (e.g. with mould, odours).

The use of a questionnaire can also contribute to the assessment of a room.

6 Quality classes

[Table 1](#) provides an overview of the quality classes and describes the requirements on the room air quality on which these classes are based. The designations and descriptions of the requirements according to [Table 1](#) are only partly applicable for the parameter “Mould – microbial infestation”.