BS ISO 16075-1:2015

BSI Standards Publication

Guidelines for treated wastewater use for irrigation projects

Part 1: The basis of a reuse project for irrigation

bsi.

...making excellence a habit.™

Document Sharing Hub

Full document details: BS ISO 16075-1:2015

National foreword

This British Standard is the UK implementation of ISO 16075-1:2015.

The UK participation in its preparation was entrusted to Technical Committee CB/506, Water reuse.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015. Published by BSI Standards Limited 2015

ISBN 978 0 580 80719 0

ICS 13.060.01; 13.060.30

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 August 2015.

Amendments issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS ISO 16075-1:2015

INTERNATIONAL STANDARD

ISO 16075-1

First edition
2015-08-15

Guidelines for treated wastewater use for irrigation projects —

Part 1: The basis of a reuse project for irrigation

Lignes directrices pour l'utilisation des eaux usées traitées en irrigation —

Partie 1: Les bases d'un projet de réutilisation en irrigation

Reference number
ISO 16075-1:2015(E)

Documents
Document Sharing Hub

© ISO 2015

Full document details: BS ISO 16075-1:2015

COPYRIGHT PROTECTED DOCUMENT

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

© ISO 2015 – All rights reserved

Documents
Document Sharing Hub

Full document details: BS ISO 16075-1:2015

Contents

Page

Foreword ... **iv**

Introduction ... **v**

1 Scope ... **1**

2 Normative references ... **2**

3 Terms, definitions, and abbreviated terms ... **2**
3.1 General ... 2
3.2 Use of treated wastewater (TWW) ... 4
3.3 Wastewater quality ... 4
3.4 Irrigation systems ... 5
3.5 Wastewater system related components ... 7
3.6 Abbreviated terms ... 8

4 Improving the quality and the use of TWW ... **9**

5 Basis of a reuse project for irrigation ... **9**

6 Influencing factors for TWW irrigation projects: water quality, climate, and soil ... **10**
6.1 General ... 10
6.2 Water quality ... 10
6.2.1 Wastewater components ... 10
6.2.2 Nutrients ... 10
6.2.3 Salinity ... 11
6.2.4 Other elements ... 12
6.2.5 Microorganisms ... 12
6.3 Climate ... 12
6.4 Soil ... 13
6.4.1 General ... 13
6.4.2 Mobilization of inorganic adsorbable contaminants ... 14
6.4.3 Slaking of the upper soil layer ... 14
6.4.4 Salinization of soils ... 14
6.4.5 Mobilization and accumulation of boron ... 14
6.4.6 Groundwater pollution ... 15
6.4.7 Phosphorus accumulation and mobility ... 15

7 Different effects on public health, soil, crops, and water sources ... **15**
7.1 Public health effects ... 15
7.2 Effects on soil and crops ... 16
7.2.1 Effect of nutrient levels ... 16
7.2.2 Effect of water salinity ... 16
7.2.3 Effect of a specific toxicity of certain ions ... 17
7.2.4 Effect related to other chemical elements ... 18
7.2.5 Recommendations to manage the effects on soil and crops ... 18
7.3 Effects on water sources ... 21
7.3.1 General ... 21
7.3.2 Principles for protection of water sources ... 21
7.3.3 Examples of groundwater sensitivity groups ... 22
7.3.4 Examples of surface water sensitivity groups ... 23
7.3.5 Summary of examples of criteria ... 23

Annex A (informative) **Examples of climate and soil criteria** ... **24**

Annex B (informative) **Examples of maximum levels of nutrients and salinity factors in TWW for irrigation** ... **25**

Annex C (informative) **Example of groundwater sensitivity groups** ... **29**

Bibliography ... **31**

Documents
Document Sharing Hub

© ISO 2015 – All rights reserved

Full document details: BS ISO 16075-1:2015

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information.

The committee responsible for this document is ISO/TC 282, *Water re-use*, Subcommittee SC01, *Treated wastewater re-use for irrigation*.

This first edition cancels and replaces ISO/CD 16075-2.

ISO 16075 consists of the following parts, under the general title *Guidelines for treated wastewater use for irrigation projects*:

— *Part 1: The basis of a reuse project for irrigation*

— *Part 2: Development of the project*

— *Part 3: Components of a reuse project for irrigation*

The following parts are under preparation:

— *Part 4: Monitoring*

© ISO 2015 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 16075-1:2015

Introduction

The increasing water scarcity and water pollution control efforts in many countries have made treated municipal and industrial wastewater a suitable economic means of augmenting the existing water supply, especially when compared to expensive alternatives such as desalination or the development of new water sources involving dams and reservoirs. Water reuse makes it possible to close the water cycle at a point closer to cities by producing "new water" from municipal wastewater and reducing wastewater discharge to the environment.

An important new concept in water reuse is the "fit-to-purpose" approach, which entails the production of reclaimed water quality that meets the needs of the intended end-users. In the situation of reclaimed water for irrigation, the reclaimed water quality can induce an adaptation of the type of plant grown. Thus, the intended water reuse applications are to govern the degree of wastewater treatment required and, inversely, the reliability of wastewater reclamation processes and operation.

Treated wastewater can be used for various non-potable purposes. The dominant applications for the use of treated wastewater (also referred to as reclaimed water or recycled water) include agricultural irrigation, landscape irrigation, industrial reuse, and groundwater recharge. More recent and rapidly growing applications are for various urban uses, recreational and environmental uses, and indirect and direct potable reuse.

Agricultural irrigation was, is, and will likely remain the largest reuse water consumer with recognized benefits and contribution to food security. Urban water recycling, landscape irrigation in particular, is characterized by fast development and will play a crucial role for the sustainability of cities in the future, including energy footprint reduction, human well-being, and environmental restoration.

It is worth noting again that the suitability of treated wastewater for a given type of reuse depends on the compatibility between the wastewater availability (volume) and water irrigation demand throughout the year, as well as on the water quality and the specific use requirements. Water reuse for irrigation can convey some risks for health and environment, depending on the water quality, the irrigation water application method, the soil characteristics, the climate conditions, and the agronomic practices. Consequently, the public health and potential agronomic and environmental adverse impacts are to be considered as priority elements in the successful development of water reuse projects for irrigation. To prevent such potential adverse impacts, the development and application of international guidelines for the reuse of treated wastewater is essential.

The main water quality factors that determine the suitability of treated wastewater for irrigation are pathogen content, salinity, sodicity, specific ion toxicity, other chemical elements, and nutrients. Local health authorities are responsible for establishing water quality threshold values depending on authorized uses and they are also responsible for defining practices to ensure health and environmental protection taking into account local specificities.

From an agronomic point of view, the main limitation in using treated wastewater for irrigation arises from its quality. Treated wastewater, unlike water supplied for domestic and industrial purposes, contains higher concentrations of inorganic suspended and dissolved materials (total soluble salts, sodium, chloride, boron, heavy metals), which can damage the soil and irrigated crops. Dissolved salts are not removed by conventional wastewater treatment technologies and appropriate good management, agronomic and irrigation practices are intended to be used to avoid or minimize potential negative impacts.

The presence of nutrients (nitrogen, phosphorus, and potassium) can become an advantage due to possible saving in fertilizers. However, the amount of nutrients provided by treated wastewater along the irrigation period is not necessarily synchronized with crop requirements and the availability of nutrients depends on the chemical forms.

This guideline provides guidance for healthy, hydrological, environmental and good operation, monitoring, and maintenance of water reuse projects for unrestricted and restricted irrigation of agricultural crops, gardens, and landscape areas using treated wastewater. The quality of supplied treated wastewater has

Documents
Document Sharing Hub

© ISO 2015 – All rights reserved

Full document details: BS ISO 16075-1:2015

to reflect the possible uses according to crop sensitivity (health-wise and agronomy-wise), water sources (the hydrologic sensitivity of the project area), the soil, and climate conditions.

This guideline refers to factors involved in water reuse projects for irrigation regardless of size, location, and complexity. It is applicable to intended uses of treated wastewater in a given project, even if such uses will change during the project's lifetime; as a result of changes in the project itself or in the applicable legislation.

The key factors in assuring the health, environmental and safety of water reuse projects in irrigation are the following:

— meticulous monitoring of treated wastewater quality to ensure the system functions as planned and designed;

— design and maintenance instructions of the irrigation systems to ensure their proper long-term operation;

— compatibility between the treated wastewater quality, the distribution method, and the intended soil and crops to ensure a viable use of the soil and undamaged crop growth;

— compatibility between the treated wastewater quality and its use to prevent or minimize possible contamination of groundwater or surface water sources.

© ISO 2015 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 16075-1:2015

INTERNATIONAL STANDARD ISO 16075-1:2015(E)

Guidelines for treated wastewater use for irrigation projects —

Part 1: The basis of a reuse project for irrigation

1 Scope

This part of ISO 16075 contains guidelines for the development and the execution of projects intending to use treated wastewater (TWW) for irrigation and considers the parameters of climate and soil.

The purpose of these guidelines is to provide specifications for all elements of a project using TWW for irrigation, including design, materials, construction, and performance, when used for the following:

— unrestricted irrigation of agricultural crops;

— restricted irrigation of agricultural crops;

— irrigation of public and private gardens and landscape areas, including parks, sport fields, golf courses, cemeteries, etc;

— irrigation of private individual gardens.

These guidelines are intended to provide assistance for the benefit of users of TWW for irrigation. The guidelines relate to the widespread and common ranges of water quality rather than exceptional or unique ones and are intended for the use by professionals, such as irrigation companies (designers and operators), agricultural extension officers or advisors, water companies (designers and operators), and local authorities. The use of these guidelines by farmers might require additional specifications.

None of the parts of this International Standard are intended to be used for certification purposes.

These guidelines suggest the parameters of TWW quality. These parameters include the following:

— agronomic parameters: nutrients (nitrogen, phosphorus and potassium) and salinity factors (total salt content, chloride, boron, and sodium concentration);

— other chemical element parameters (heavy metals);

— microbial parameters.

Each of these parameters can have possible impacts on the crops, soil, and public health. The guidelines discuss the possibility of preventing the contaminants' presence during wastewater production and the ability to remove them during the course of treatment.

Emerging pollutants (pharmaceuticals and personal care product residuals) are outside the scope of this part of ISO 16075 since at this time, they are not included in any national standard.

The project should be designed in accordance with the sanitary quality of the TWW in order to avoid disease transmission by the pathogens in the water.

The use of these guidelines is encouraged to ensure consistency within any organization engaged in the use of treated wastewater.

These guidelines provide the basis for a healthy, hydrological, environmental and agronomic conscious design, operation, monitoring, and maintenance of an irrigation system using treated wastewater.

© ISO 2015 – All rights reserved

AVA Documents Document Sharing Hub

Full document details: BS ISO 16075-1:2015

This part of ISO 16075 is not intended to prevent the creation of more specific standards or guides which are better adapted to specific regions, countries, areas, or organizations. If such documents are written, it is recommended to reference this part of ISO 16075 to ensure uniformity throughout the treated wastewater use community.

2 Normative references

There are no normative references.

3 Terms, definitions, and abbreviated terms

3.1 General

3.1.1
aquifer
underground layer of water-bearing permeable rock or unconsolidated materials (gravel, sand, or silt) from which groundwater can be extracted

3.1.2
background water
freshwater (3.1.10) supplied for domestic, institutional, commercial, and industrial use from which *wastewater* (3.1.22) is created

3.1.3
barrier
any means including physical or process steps that reduces or prevents the risk of human infection by preventing contact between the TWW and the ingested produce or other means that, for example, reduces the concentration of microorganisms in the TWW or prevents their survival on the ingested produce

3.1.4
environment
surroundings in which an *organization* (3.1.13) operates, including air, water, land, natural resources, flora, fauna, humans, and their interrelation

3.1.5
environmental aspect
element of an organization's activities, projects, or products that can interact with the *environment* (3.1.4)

3.1.6
environmental impact
any change to environmental quality, whether adverse or beneficial, wholly or partly resulting from an organization's activities, projects, or *products* (3.1.15)

3.1.7
environmental parameter
quantifiable attribute of an *environmental aspect* (3.1.5)

3.1.8
fodder crops
crops not for human consumption such as pastures and forage, fiber, ornamental, seed, forest, and turf crops

3.1.9
food crops
crops which are intended for human consumption, often further classified as to whether the food crop is to be cooked, processed, or consumed raw

© ISO 2015 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 16075-1:2015

3.1.10
freshwater
naturally occurring water on the Earth's surface (in ice, lakes, rivers, and streams) and underground as groundwater in *aquifers* (3.1.1)

Note 1 to entry: Freshwater includes desalinated seawater and desalinated brackish water but excludes seawater and brackish water.

3.1.11
irrigation project
design, development, construction, selection of equipment, operation, and monitoring of works to provide suitable TWW irrigation

3.1.12
non-potable water
NPW
water that is not of drinking water quality

Note 1 to entry: It generally refers to *wastewater* (3.1.22) or TWW but can also include other waters of non-drinking quality.

3.1.13
organization
group of people and facilities with an arrangement of responsibilities, authorities, and relationships

3.1.14
process
set of interrelated or interacting activities which transform inputs into outputs

Note 1 to entry: Inputs to a process are generally outputs of other processes.

Note 2 to entry: Processes in an *organization* (3.1.13) are generally planned and carried out under controlled conditions to add value.

3.1.15
product
any goods or services

Note 1 to entry: This includes interconnected and/or interrelated goods or services.

3.1.16
public health aspect
element of an organization's activities, projects, or *products* (3.1.15) that can interact with the public health

3.1.17
public health impact
any change to public health, whether adverse or beneficial, wholly or partly resulting from an organization's activities, projects, or *products* (3.1.15)

3.1.18
public health parameter
quantifiable attribute of a *public health aspect* (3.1.17)

3.1.19
soil
layer of unconsolidated material consisting of weathered material particles, dead and living organic matter, air space, and *soil solution* (3.1.20)

3.1.20
soil solution
liquid phase of the *soil* (3.1.19) and its solutes

© ISO 2015 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 16075-1:2015

3.1.21
stakeholder
individual, group, or *organization* (3.1.13) that has an interest in an organization or activity

Note 1 to entry: Usually, a stakeholder can affect or is affected by the organization or the activity.

3.1.22
wastewater
wastewater collected principally by municipalities that can include spent or used water from domestic, institutional, commercial, or industrial sources and can include storm water

3.1.23
water reuse
use of treated wastewater for beneficial use

Note 1 to entry: Synonymous also to water reclamation and water recycling.

3.2 Use of treated wastewater (TWW)

3.2.1
agriculture
science or practice of farming, including cultivation of the *soil* (3.1.19) for the growing of crops and the rearing of animals to provide food or other *products* (3.1.15)

3.2.2
landscape
all the visible features of an area of land, often considered in terms of their aesthetic appeal such as public and private gardens, parks, and road vegetation including lawns and turfed recreational areas

3.2.3
restricted irrigation
use of TWW for non-potable applications in settings where public access is controlled or restricted by physical or institutional barriers

3.2.4
restricted urban irrigation
irrigation of areas in which public access during irrigation can be controlled, such as some golf courses, cemeteries, and highway medians

3.2.5
unrestricted irrigation
use of TWW for non-potable applications in settings where public access is not restricted

3.2.6
unrestricted urban irrigation
irrigation of areas in which public access during irrigation is not restricted, such as some gardens and playgrounds

3.3 Wastewater quality

3.3.1
category A: very high quality TWW
raw wastewater (3.3.6) which has undergone physical and biological treatment, *filtration* (3.5.3) and *disinfection* (3.5.2), and its quality is according to the description in ISO 16075–2[10], Table 1

3.3.2
category B: high quality TWW
raw wastewater (3.3.6) which has undergone physical and biological treatment, *filtration* (3.5.3) and *disinfection* (3.5.2), and its quality is according to the description in ISO 16075–2[10], Table 1

© ISO 2015 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 16075-1:2015

3.3.3
category C: good quality TWW
raw wastewater (3.3.6) which has undergone physical and biological treatment and its quality is according to the description in ISO 16075–2[10], Table 1

3.3.4
category D: medium quality TWW
raw wastewater (3.3.6) which has undergone physical and biological treatment and its quality is according to the description in ISO 16075–2[10], Table 1

3.3.5
category E: extensively TWW
raw wastewater (3.3.6) which has undergone natural biological treatment process with long (minimum 10 d to 15 d) retention time and its quality is according to the description in ISO 16075–2[10], Table 1

3.3.6
raw wastewater
wastewater (3.1.22) which has not undergone any treatment

3.3.7
thermo-tolerant coliforms
group of bacteria whose presence in the *environment* (3.1.4) usually indicates faecal contamination (previously called faecal coliforms)

Note 1 to entry: In order to determine the quality of TWW, one can test for Escherichia coli (E. coli) or for faecal coliforms, since the difference in values is not significant.

3.4 Irrigation systems

3.4.1
boom sprinkler
mobile sprinkling machine (3.4.11) composed by two symmetrical pipes (booms), with sprinkler nozzles distributed in one of the pipes, with the sprinkler action complemented by a gun sprinkler placed at each end of both pipes; the nozzles work through a reaction effect (similar to a hydraulic tourniquet) which drives the boom rotation at a desired speed

3.4.2
center-pivot and moving lateral irrigation machines
automated irrigation machine consisting of a number of self-propelled towers supporting a pipeline rotating around a pivot point and through which water supplied at the pivot point flows radially outward for distribution by sprayers or *sprinklers* (3.4.24) located along the pipeline

3.4.3
emitter
emitting pipe
dripper
device fitted to an irrigation lateral and intended to discharge water in the form of drops or continuous flow at flow rates not exceeding 15 l/h except during flushing

3.4.4
gravity flow irrigation systems
irrigation systems (3.4.8) where water is applied directly to the *soil* (3.1.19) surface and is not under pressure

3.4.5
in-line emitter
emitter (3.4.3) intended for installation between two lengths of pipe in an irrigation lateral

© ISO 2015 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 16075-1:2015