BS ISO 16957:2016

BSI Standards Publication

Measurement of apparent thermal conductivity of wet porous building materials by a periodic method

Documents
Document Sharing Hub

Full document details: BS ISO 16957:2016

National foreword

This British Standard is the UK implementation of ISO 16957:2016.

The UK participation in its preparation was entrusted to Technical Committee B/540/8, Mirror committee for ISO/TC 163 - Thermal Performance and Energy use in the built Environment.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2016. Published by BSI Standards Limited 2016

ISBN 978 0 580 84055 5

ICS 27.220

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2016.

Amendments issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS ISO 16957:2016

INTERNATIONAL STANDARD

ISO 16957

First edition
2016-06-15

Measurement of apparent thermal conductivity of wet porous building materials by a periodic method

Détermination de la conductivité thermique apparente des matériaux de construction poreux et mouillés par une méthode périodique

Reference number
ISO 16957:2016(E)

Documents
Document Sharing Hub
© ISO 2016

Full document details: BS ISO 16957:2016

COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

© ISO 2016 – All rights reserved

Documents
Document Sharing Hub

Full document details: BS ISO 16957:2016

Contents

Page

Foreword ... **iv**
Introduction ... **v**
1 Scope ... **1**
2 Normative references ... **1**
3 Terms and definitions ... **1**
4 Symbols and units ... **2**
5 Determination of thermal conductivity of a wet porous material by non-steady-state method (periodic method) ... **3**
6 Measurement by periodic method ... **3**
6.1 Test procedure ... 3
6.2 Measuring apparatus ... 4
6.2.1 Overall design ... 4
6.2.2 Generator of the sinusoidal or stepwise electric wave ... 4
6.2.3 Heater ... 5
6.2.4 Specimen ... 5
6.3 Specimen preparation and preconditioning ... 5
6.3.1 Initial uniform moisture content and adiabatic and impermeable boundaries ... 5
6.3.2 Embedding and the position of the thermocouples ... 5
6.4 Derivation of thermal diffusivity from measured temperatures (see Annex B) ... 5
6.4.1 Solution for heat flow without moisture ... 5
6.4.2 Solution for heat flow with moisture ... 6
6.5 Estimation of measuring uncertainty due to moisture (vapour) movement ... 7
6.6 Thermal conductivity ... 7
7 Test report ... **7**
Annex A (informative) **Theoretical background** ... **9**
Annex B (informative) **Derivation of thermal conductivity from measured temperatures** ... **11**
Annex C (informative) **Example of measurement by periodic method** ... **17**
Bibliography ... **20**

© ISO 2016 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 16957:2016

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 1, *Test and measurement methods*.

© ISO 2016 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 16957:2016

Introduction

Most building materials, with the exception of glass and metals, are porous and, thus, absorb moisture due to condensation, rain and water uptake from the ground. The absorbed moisture may damage the materials through, e.g. rotting or frost damage and, thus, may cause their performance to deteriorate. In particular, an increase in the moisture content of insulation material causes a reduction of its thermal resistance, which must be avoided as much as possible to preserve its performance. However, infiltration of rain water into a brick wall or joints of tiles and uptake of ground water into the foundation (footing) are very difficult to avoid. Therefore, it is important to understand the changes in the thermal properties (thermal conductivity and heat capacity) of porous materials due to changes in their moisture content.

ISO 10051 specifies a steady-state method for measuring the thermal conductivity of a moist building material. In the steady-state method, a nonuniform distribution of moisture content in the test piece is inevitable, since the imposed temperature gradient causes moisture transfer. The nonuniform moisture distribution makes it difficult to define which moisture content the measured thermal conductivity corresponds to. ISO 10051 categorizes the moisture distribution in the test piece into several types and estimates the thermal conductivity corresponding to each type.

Since theoretical and experimental research has recently been performed concerning heat and moisture transfer in porous materials (see References [5], [7], [8], [9] and [10]), along with measurements and the construction of a database of hygrothermal properties (see Reference [6]), hygrothermal behaviour can now be predicted with reasonable accuracy.

This International Standard describes a transient method for measuring the thermal conductivity of a wet porous building material and a method of evaluating the measurement uncertainty, on the basis of both theoretical developments for heat and mass transfer and the constructed database of hygrothermal properties. The evaluation of the measurement uncertainty makes possible a simple and, thus, practical method for measuring thermal conductivity.

NOTE Thermal conductivity is one of the necessary hygrothermal properties. Since heat transfer and mass transfer in porous material interact with each other, an exact value of the thermal conductivity must be given in order to examine the validity of the theoretical models. Thus, precisely speaking, the above-mentioned theoretical models have not been validated, and the construction of the model and the measurements of the hygrothermal properties must be carried out in parallel. Nonetheless, it seems reasonable to expect that measurement of the thermal conductivity with an allowable accuracy is possible using a suitable measuring method. This is the basis for the present document.

© ISO 2016 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 16957:2016

Documents
Document Sharing Hub

INTERNATIONAL STANDARD ISO 16957:2016(E)

Measurement of apparent thermal conductivity of wet porous building materials by a periodic method

1 Scope

This International Standard describes a method of measuring the thermal conductivity (diffusivity) of a wet porous building material and a method of evaluating the measurement uncertainty.

While ISO 10051 is the current International Standard, based on a steady-state method, this International Standard proposes a method that makes use of a non-steady-state method which uses a small temperature change with a short period as an input. Along with the measurement, an evaluation of the measurement uncertainty is described, which makes possible a simple and practical measuring method.

This International Standard intends to measure the apparent (effective) thermal conductivity, including latent heat transfer caused by vapour movement. The situation in which moisture and/or air movement occur due to convection or gravity is excluded. The application of this International Standard to high moisture content is excluded so that the gravity effect can be neglected. This International Standard can be applied to a porous material heavier than about 100 kg/m^3, in which radiative heat transfer can be neglected.

This International Standard specifies the following:

a) a non-steady-state method of measuring thermal conductivity;

b) an approximation formula for the measurement uncertainty caused by moisture movement and nonuniform moisture distribution (and, thus, a determination of the measuring conditions that satisfy the upper limit of measurement uncertainty);

c) an estimate of the heat transfer caused by moisture (vapour) movement.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 9346, ISO 10051 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— IEC Electropedia: available at http://www.electropedia.org/

— ISO Online browsing platform: available at http://www.iso.org/obp

© ISO 2016 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 16957:2016

3.1
apparent thermal conductivity of a wet material
λ^*
intrinsic material property dependent upon moisture content and temperature, but not on testing conditions

Note 1 to entry: Since this value includes the influence of heat transfer due to phase change (condensation and evaporation), it is called apparent thermal conductivity.

4 Symbols and units

Symbol	Quantity	Units
a	thermal diffusivity of the material	m^2/s
A, B, C, D	defined in Formula (B.14)	—
c	porosity	m^3/m^3
c'	specific heat of the material	J/(kg·K)
c_s	specific heat of the dry material	J/(kg·K)
D_T	moisture (vapour and liquid water) conductivity related to temperature gradient	kg/(m·s·K)
D_θ	Moisture (vapour and liquid water) conductivity related to water content gradient	m^2/s
D_{Tl}	liquid water conductivity related to temperature gradient	kg/(m·s·K)
$D_{\theta l}$	liquid water conductivity related to water content gradient	m^2/s
D_{Tv}	vapour conductivity related to temperature gradient	kg/(m·s·K)
$D_{\theta v}$	vapour conductivity related to water content gradient	m^2/s
E, E_1, E_2	defined in Formula (B.12)	—
I_0	amplitude of the input surface temperature	K
k_v	vapour diffusivity	kg/[m·s·(kg/kg′)]
R	latent heat of vaporization	J/kg
S	specific surface area inside the material, i.e. ratio of pore surface area to the material volume	m^2/m^3
t	time	s
T	temperature	K
T_0	initial temperature	K
$T_1, T_2, \theta_1, \theta_2$	the first and second terms of the perturbation solution of the temperature and water content, respectively	K, kg/m^3
x	coordinate	m
X	humidity ratio of moist air in the pores of the specimen	kg/kg′
X_i	equilibrium humidity ratio with liquid or capillary water at the interface in the material	kg/kg′
$U_3, U_7, Q_1 - Q_6, R_1 - R_6, V_{18}$	coefficients appearing solutions θ_2 and T_2	—
α_1, α_2	defined in Formula (B.13)	—
α'	effective vapour transfer coefficient at the interface	kg/(m·s·kg)/kg′
γ	specific weight of dry air	kg/m^3
γ'	density of the material	kg/m^3
γ_s	density of the dry material	kg/m^3
$\eta_1, \zeta_1, \beta_1, \xi_1, \kappa_1, \gamma_1$	water content coefficients of $D_{\theta l}, D_{\theta v}, D_{Tl}, D_{Tv}, c'\ \gamma', \lambda$	—
$\eta_2, \zeta_2, \beta_2, \xi_2, \gamma_2$	temperature coefficients of $D_{\theta l}, D_{\theta v}, D_{Tl}, D_{Tv}, \lambda$	—
λ	thermal conductivity without moisture movement	W/(m·K)

© ISO 2016 – All rights reserved
AVA Documents Document Sharing Hub
Full document details: BS ISO 16957:2016