BS ISO 18132-3:2011

BSI Standards Publication

Refrigerated hydrocarbon and non-petroleum based liquefied gaseous fuels — General requirements for automatic tank gauges

Part 3: Automatic tank gauges for liquefied petroleum and chemical gases on board marine carriers and floating storage

bsi.

...making excellence a habit.™

Document Sharing Hub

Full document details: BS ISO 18132-3:2011

National foreword

This British Standard is the UK implementation of ISO 18132-3:2011. Together with BS ISO 18132-1:2011, it supersedes BS ISO 18132-1:2006, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PTI/12, Petroleum Measurement and Sampling.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2012

ISBN 978 0 580 70341 6

ICS 75.180.30

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 January 2012.

Amendments issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS ISO 18132-3:2011

INTERNATIONAL STANDARD

ISO 18132-3

First edition
2011-08-01

Refrigerated hydrocarbon and non-petroleum based liquefied gaseous fuels — General requirements for automatic tank gauges —

Part 3: Automatic tank gauges for liquefied petroleum and chemical gases on board marine carriers and floating storage

Hydrocarbures réfrigérés et combustibles gazeux liquéfiés à base non pétrolière — Exigences générales pour jauges de réservoir automatiques —

Partie 3: Jauges de réservoir automatiques pour pétrole liquéfié et gaz chimiques à bord des transporteurs de cargaison en mer et des stocks flottants

Reference number
ISO 18132-3:2011(E)

Documents
Document Sharing Hub
© ISO 2011

Full document details: BS ISO 18132-3:2011

COPYRIGHT PROTECTED DOCUMENT

© ISO 2011

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

© ISO 2011 – All rights reserved

Documents
Document Sharing Hub

Full document details: BS ISO 18132-3:2011

Contents

Page

Foreword ... iv

Introduction ... v

1 Scope ... 1

2 Terms, definitions and abbreviated terms ... 1
2.1 Terms and definitions ... 1
2.2 Abbreviated terms ... 2

3 General safety precautions ... 3
3.1 Compliance with safety regulations, standards, and classification rules ... 3
3.2 Equipment precautions ... 3

4 Design requirements ... 4
4.1 General ... 4
4.2 Provisions for routine maintenance and verification ... 4
4.3 Provision against sudden malfunctions ... 4
4.4 Dynamic response ... 4
4.5 Minimum measurable level ... 4
4.6 Data filtering and averaging ... 4
4.7 Compensation for variation of cargo temperatures and/or composition ... 5
4.8 Sealing, security and unsealing ... 5
4.9 Redundancy ... 5
4.10 Data communication ... 5

5 Installation ... 6
5.1 General ... 6
5.2 Location of installation ... 6
5.3 Interference of ATGs in a cargo tank ... 6

6 Accuracy ... 6
6.1 General ... 6
6.2 Calibration reference ... 6
6.3 Accuracy requirement ... 6
6.4 Readout resolution ... 7

7 Recertification of ATGs ... 7
7.1 General ... 7
7.2 Method of periodic certification ... 7
7.3 Maximum permissible error ... 7
7.4 Frequency of subsequent calibration and recertification ... 7

8 ATG calibration records ... 7

Annex A (normative) **Calibration and verification of various ATGs in common use** ... 8

Annex B (normative) **Calibration and verification of radar-type ATG** ... 10

Annex C (normative) **Calibration and verification of magnetic-type ATG** ... 13

Annex D (normative) **Calibration and verification of float-type ATG** ... 16

Annex E (normative) **Calibration and verification of hydrostatic-type ATG** ... 19

Annex F (informative) **Accuracy limitations of level measurement of LPG and chemical gases** ... 23

Annex G (informative) **Uncertainty associated with accuracy test of float-type ATG** ... 24

Bibliography ... 25

© ISO 2011 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 18132-3:2011

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 18132-3 was prepared by Technical Committee ISO/TC 28, *Petroleum products and lubricants*, Subcommittee SC 5, *Measurement of refrigerated hydrocarbon and non-petroleum based liquefied gaseous fuels*.

This first edition of ISO 18132-3, together with ISO 18132-1:2011, cancels and replaces ISO 18132-1:2006, which has been technically revised.

ISO 18132 consists of the following parts, under the general title *Refrigerated hydrocarbon and non-petroleum based liquefied gaseous fuels — General requirements for automatic tank gauges*:

— *Part 1: Automatic tank gauges for liquefied natural gas on board marine carriers and floating storage*

— *Part 2: Gauges in refrigerated-type shore tanks*

— *Part 3: Automatic tank gauges for liquefied petroleum and chemical gases on board marine carriers and floating storage*

© ISO 2011 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 18132-3:2011

Introduction

Large quantities of liquefied petroleum and chemical gases are transported by marine carriers and traded by static measurement of the cargo on board by automatic tank measurement. The automatic tank measurement by a custody transfer measurement system (CTMS) involves determination of liquid/vapour interface, i.e. liquid level, temperatures of liquid and vapour, and vapour pressure. The volumetric quantity of the liquid and gas is given by the tank capacity table, on the basis of which the delivered quantity in terms of mass is calculated.

To ensure accurate quantitative determination of liquefied petroleum and chemical gases, custody transfer measurement usually takes place on board the gas carrier and floating storage, not at the shore tanks. Liquid level expressed in innage or ullage is one of the important measurement parameters needed to accurately determine the cargo on board.

© ISO 2011 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 18132-3:2011

Documents
Document Sharing Hub

Full document details: BS ISO 18132-3:2011

INTERNATIONAL STANDARD ISO 18132-3:2011(E)

Refrigerated hydrocarbon and non-petroleum based liquefied gaseous fuels — General requirements for automatic tank gauges —

Part 3:
Automatic tank gauges for liquefied petroleum and chemical gases on board marine carriers and floating storage

1 Scope

This part of ISO 18132 establishes general principles for the accuracy, installation, calibration and verification of automatic tank gauges (ATGs) used for custody transfer measurement of liquefied petroleum and chemical gases on board a gas carrier or floating storage.

The part of ISO 18132 also describes the technical requirements for data collection, transmission and reception. Specific technical requirements for various automatic tank gauges and accuracy limitations are given in the annexes.

2 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms, definitions and abbreviated terms apply.

2.1 Terms and definitions

2.1.1
automatic tank gauge
ATG
instrument that continuously measures liquid height (dip or ullage) in storage tanks

NOTE 1 An automatic tank gauge usually includes a level sensor, a gauge head and associated mounting hardware, and in some cases local display.

NOTE 2 Automatic tank gauges are also known as automatic level gauges (ALGs).

2.1.2
automatic tank gauging system
ATG system
system that includes ATGs at the cargo tanks and control/display unit that processes and displays output signals from the ATG along with any other parameters required to determine the liquid level, i.e. liquid/vapour interface

NOTE The ATG system can also compute the volume of LNG in tanks, using the values of cargo tank temperature and pressure, draft, and tank capacity table.

2.1.3
custody transfer measurement system
CTMS
system that processes inputs from an ATG system, thermometers, pressure gauges, etc., and provides custody transfer measurement information on board, generating documents with regard to custody transfer of LNG

NOTE The ATG system can be incorporated as part of a CTMS.

© ISO 2011 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 18132-3:2011

2.1.4
float-type ATG
ATG that uses a float to detect the liquid level

NOTE The float is guided by a tape or wire that is connected to a drum or a ratchet in the gauge head, where the level measured is displayed locally and/or remotely. See Annex D for more descriptions.

2.1.5
hydrostatic-type ATG
hydrostatic tank gauge
HTG
ATG that determines liquid level based on the differential of pressures measured by the pressure sensors vertically installed in a cargo tank with temperature sensors

NOTE See Annex E for further descriptions.

2.1.6
intrinsic error
inherent error
error of an ATG when it is tested against a reference standard under controlled conditions as specified by the manufacturer

2.1.7
magnetic-type ATG
ATG that measures the liquid level by magnetic reed switches with a float sensor including magnets, or by magneto-strictive principle

NOTE See Annex C for further descriptions.

2.1.8
radar-type ATG
microwave-type ATG
ATG that utilizes an antenna to transmit electromagnetic continuous waves toward the liquid in a tank, and to receive electromagnetic waves which are reflected at the surface of the liquid

NOTE See Annex B for further descriptions.

2.2 Abbreviated terms

ATG automatic tank gauge

CTMS custody transfer measurement system

EMC electromagnetic compatibility

FPSO floating production, storage and offloading

FSO floating storage and offloading

HTG hydrostatic-type ATG

IACS international association of classification societies

LNG liquefied natural gas

LPG liquefied petroleum gas

© ISO 2011 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 18132-3:2011

3 General safety precautions

3.1 Compliance with safety regulations, standards, and classification rules

This part of ISO 18132 may involve hazardous materials, operations, and equipment. This part of ISO 18132 does not purport to supersede any safety or operating practices recommended by applicable regulatory agencies and organizations. It is the responsibility of the user of this part of ISO 18132 to establish appropriate health and safety practices and determine the applicability of regulatory limitations prior to use.

3.2 Equipment precautions

3.2.1 General

All electric components of an ATG for use in electrically classified areas shall meet the electrical area classification (see IEC 60079-0). They shall conform to applicable sections of the national and/or international electrical safety standards. All ATGs shall be maintained in safe operating condition and manufacturers' maintenance instructions should be complied with.

3.2.2 Mechanical rigidity

All ATGs shall be capable of withstanding the pressure, temperature, operating, and environmental conditions likely to be encountered in the service.

Where an ATG is installed near a submerged pump or the end of a loading/unloading line in a cargo tank, appropriate measures shall be applied to prevent the ATG from being affected by the vortex or vaporization (i.e. boiling) of cargo caused by the cargo loading or cargo unloading operations.

3.2.3 Gastight design

ATGs shall be designed such that the tank penetration for the ATG is of gastight construction in order to minimize the escape of vapour from the cargo tank. The gauge head or transmitter located on the deck shall be so constructed as to minimize leakage of vapour from the tank.

3.2.4 Compatibility with cargo

All parts of the ATG in contact with liquefied petroleum and chemical gases or their vapour shall be chemically compatible with the product, to avoid both product contamination and corrosion of the ATG.

3.2.5 Tolerance against low temperatures

ATGs shall be designed to withstand the low-temperature thermal contraction of their components and of the tanks. Additionally, level measurement errors caused by such thermal contraction shall be compensated for in an appropriate manner.

3.2.6 Type approval

The design and installation of ATGs shall be subject to type approval. Type approval is normally issued after an ATG has been subjected to a specific series of tests.

NOTE Type approval is normally performed by a national measurement organization or class society for environmental considerations (see IACS Unified Requirements E 10).

3.2.7 Use of an ATG in custody transfer service

ATGs, including those which use measurement technologies not listed in this part of ISO 18132, are considered acceptable for use in the custody transfer service of liquefied petroleum and chemical gases if they are judged to be compatible with those ATGs in this part of ISO 18132 by the parties to the sales contract of liquefied gases, and approval by national regulations.

© ISO 2011 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 18132-3:2011