BS ISO 19967-2:2024

BSI Standards Publication

Air to water heat pumps — Testing and rating for performance

Part 2: Space heating and/or space cooling

Documents
Document Sharing Hub

Full document details: BS ISO 19967-2:2024

National foreword

This British Standard is the UK implementation of ISO 19967-2:2024. It supersedes BS ISO 19967-2:2019, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee RHE/17, Testing of air conditioning units.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2024
Published by BSI Standards Limited 2024

ISBN 978 0 539 20918 1

ICS 27.080

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2024.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS ISO 19967-2:2024

International Standard

ISO 19967-2

Second edition
2024-05

Air to water heat pumps — Testing and rating for performance —

Part 2:
Space heating and/or space cooling

Pompes à chaleur air/eau — Essais et classification des performances —

Partie 2: Chauffage des locaux et/ou refroidissement des locaux

Reference number
ISO 19967-2:2024(en)

© ISO 2024

Documents
Document Sharing Hub

Full document details: BS ISO 19967-2:2024

COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Documents
Document Sharing Hub
Full document details: BS ISO 19967-2:2024

Contents

Page

Foreword ... **v**

1 Scope ... **1**

2 Normative references ... **1**

3 Terms and definitions ... **1**

4 Symbols and abbreviated terms ... **3**

5 Installation requirements ... **3**
5.1 Test apparatus and uncertainties of measurement ... 3
5.2 Test room for the airside and remote condenser ... 4
5.3 Installation and connection of the heat pump ... 4
5.4 Installation of heat pumps consisting of several parts ... 5

6 Setting and test conditions ... **5**
6.1 General ... 5
6.2 Settings for non-ducted units ... 5
6.3 Setting the external static pressure difference for ducted units ... 5
6.4 Setting of units with integral pumps ... 5
6.5 Test conditions ... 7

7 Space heating test ... **9**
7.1 Heating capacity test ... 9
7.2 Heating capacity correction ... 10
7.2.1 General ... 10
7.2.2 Capacity correction due to indoor liquid pump ... 10
7.2.3 Capacity correction for integrated glandless circulators ... 10
7.2.4 Capacity correction for integrated dry motor pumps ... 10
7.2.5 Capacity correction for non-integrated liquid pumps ... 11
7.3 Effective power input ... 11
7.3.1 General ... 11
7.3.2 Power input correction of fans for units without duct connection ... 11
7.3.3 Power input correction of fans for units with duct connection ... 12
7.3.4 Power input correction of liquid pumps ... 12
7.4 Test procedure ... 13
7.5 Heating capacity calculation ... 13
7.5.1 Steady state capacity test ... 13
7.5.2 Transient capacity test ... 13
7.6 Effective power input calculation ... 13
7.6.1 Steady state test ... 13
7.6.2 Transient with defrost cycle ... 13
7.6.3 Transient without defrost cycle ... 14

8 Space cooling test ... **14**
8.1 Cooling capacity test ... 14
8.2 Cooling capacity correction ... 14
8.2.1 General ... 14
8.2.2 Capacity correction due to indoor liquid pump ... 14
8.2.3 Capacity correction for integrated glandless circulators ... 15
8.2.4 Capacity correction for integrated dry motor pumps ... 15
8.2.5 Capacity correction for non-integrated liquid pumps ... 15
8.3 Effective power input ... 16
8.3.1 General ... 16
8.3.2 Power input correction of liquid pumps ... 16
8.4 Test procedure ... 17
8.4.1 Steady-state conditions ... 17
8.4.2 Measurement of cooling capacity ... 17
8.5 Cooling capacity calculation ... 17

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 19967-2:2024

8.6 Effective power input calculation ... 17

9 Test results and test report ... 17

9.1 Data to be recorded ... 17

9.2 Test report ... 18

Annex A (normative) **Heating capacity test procedures ... 19**

Annex B (normative) **Determination of the liquid pump efficiency ... 25**

Bibliography ... 28

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub

Full document details: BS ISO 19967-2:2024

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 6, *Testing and rating of air-conditioners and heat pumps*.

This second edition cancels and replaces the first edition (ISO 19967-2:2019), which has been technically revised.

The main changes are as follows:

— the title has been changed;

— terms and definitions have been added and clarified;

— test conditions have been defined and added for space cooling and/or space heating;

— the installation of test item (object) of several parts has been clarified;

— the test report information has been updated;

— the maximum and minimum operation annex has been deleted.

A list of all parts in the ISO 19967 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 19967-2:2024

Documents
Document Sharing Hub

Air to water heat pumps — Testing and rating for performance —

Part 2:
Space heating and/or space cooling

1 Scope

This document specifies test conditions and test procedures for determining the performance characteristics of air to water heat pumps for space heating and/or space cooling with electrically driven compressors with or without supplementary heater. The purpose of this document is to rate the performance of the air to water heat pumps for space heating and/or space cooling.

In the case of air to water heat pumps for space heating and/or space cooling consisting of several parts with refrigerant or water connections, this document applies only to those designed and supplied as a complete package. This document does not apply to large chiller or large liquid chilling package for space cooling and/or heating.

This document does not apply to air to water heat pumps not intended for human comfort.

NOTE Testing procedures for simultaneous operation for hot water supply and space heating and/or space cooling are not treated in this document. Simultaneous means that hot water supply and space heating and/or space cooling generation occur at the same time and can interact.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp

— IEC Electropedia: available at https://www.electropedia.org/

3.1
air to water heat pumps
heat pump which consists of one or more factory-made assemblies which normally include at least space side refrigerant to water heat exchanger(s) (load side), electrically driven compressor(s), and outdoor-side air-to-refrigerant heat exchanger(s) (source side), including means to provide space heating and/or space cooling functions

Note 1 to entry: It can include a supplementary heater for space heating.

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 19967-2:2024

3.2
heating capacity
$\boldsymbol{\Phi_H}$
heat given off by the unit to the heat transfer medium per unit of time

Note 1 to entry: Heating capacity is expressed in watts.

3.3
cooling capacity
$\boldsymbol{\Phi_C}$
heat removed by the unit from the heat transfer medium per unit of time

Note 1 to entry: Cooling capacity is expressed in watts.

3.4
effective power input
average electrical power input of the unit within the defined interval of time obtained from:

— power input for operation of the compressor and any power input for defrosting;

— power input for all control and safety devices of the unit;

— proportional power input of the conveying devices (e.g. fans, pumps) for ensuring the transport of the heat transfer media inside the unit

Note 1 to entry: Effective power input is expressed in watts.

3.5
outdoor heat exchanger
Heat exchanger which is designed to remove/add heat from/to the outdoor ambient environment

3.6
internal static pressure difference
$\boldsymbol{\Delta p_i}$
negative pressure difference measured between the air (or water) outlet section and air (or water) inlet section of the unit, which corresponds to the total pressure drop of all components on the air (or water) side of the unit

3.7
energy efficiency ratio
EER
ratio of the cooling capacity to the effective power input in the unit at any given set of rating conditions

Note 1 to entry: Expressed in units of watt per watt.

3.8
coefficient of performance
COP
ratio of heating capacity to the effective power input of the equipment at any given set of rating conditions

Note 1 to entry: Expressed in units of watt per watt.

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 19967-2:2024

4 Symbols and abbreviated terms

Symbol	Definition	Units
c_p	Specific heat capacity at constant pressure	J/kg·K
C_{20}	Scaling factor equal to 0,49	—
E_{EI}	Energy efficiency index equal to 0,23	—
I_E	Motor efficiency	—
Φ_H	Heating capacity	W
Φ_C	Cooling capacity	W
P_{hyd}	Hydraulic power of the pump	W
q	Volume flow rate	m^3/s
τ	Time	s
ρ	Density of the hot water depending on the temperature at the flow meter	kg/m^3
Δh	Specific enthalpy change	J/kg
Δp_e	External static pressure difference	Pa
Δp_i	Internal static pressure difference	Pa
Δt	Difference between inlet and outlet temperatures	K
η	0,3 by convention	—

5 Installation requirements

5.1 Test apparatus and uncertainties of measurement

The test apparatus shall be designed in such a way that all requirements for adjustment of set values, stability criteria and uncertainties of measurement according to this document are fulfilled.

Water systems or other heat transfer liquid systems shall be sufficiently free of entrained gas as to ensure that the measured results are not significantly influenced.

The response time of the temperature sensor and the sampling interval shall be chosen to maintain the uncertainties in Table 1.

Ducted air systems shall be sufficiently airtight to ensure that the measured results are not significantly influenced by exchange of air with the surroundings.

Temperature and pressure measuring points shall be arranged in order to obtain mean significant values.

For free air intake dry bulb temperature measurements, it is required either:

— to have at least one sensor per square meter, with not less than four measuring points and by restricting to 20 the number of sensors equally distributed on the free air surface; or

— to use a sampling device. It shall be completed by four sensors for checking uniformity if the surface area is greater than 1 m^2.

Air dry bulb temperature sensors shall be placed at a distance between 0,15 m and 0,3 m from the free air surface, defined as the minimal enveloping surface containing the coil(s).

For units consisting of a heat pump and a storage tank as a factory-made unit, water inlet and outlet temperature measurements shall be taken at the inlet and outlet of this unit.

For water, the density and specific heat in Formulae (1) and (10) shall be determined in the temperature conditions measured near the volume flow measuring device.

For inverter type control units, the setting of the frequency shall be done for each rating condition. The manufacturer shall provide in the documentation information instructions on how to obtain the necessary

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 19967-2:2024

data to set the required frequencies. If skilled personnel with knowledge of control software is required for the start of the system, the manufacturer or the nominated agent should be in attendance when the system is being installed and prepared for tests.

The uncertainties of measurement shall not exceed the values specified in Table 1. Additionally, the heating and/or cooling capacities measured on the liquid side shall be determined within a maximum uncertainty of 5 % independently of the individual uncertainties of measurements including the uncertainties on the properties of the fluid.

Table 1 — Uncertainties of measurement

Measured quantity	Unit	Uncertainty
Liquid		
Temperature	°C	0,15 K
Temperature difference	K	0,15 K
Volume flow	m^3/s	1 %
Static pressure difference	kPa	1 kPa (≤20 kPa) 5 % (>20 kPa)
Concentration	%	2 %
Air		
Dry bulb temperature	°C	0,2 K
Wet bulb temperature	°C	0,4 K
Volume flow	m^3/s	5 %
Static pressure difference	Pa	5 Pa ($\Delta p \leq 100$ Pa) 5 % ($\Delta p \geq 100$ Pa)
Electrical quantities		
Electric power	W	1 %
Electrical energy	kWh	1 %
Voltage	V	0,5 %
Current	A	0,5 %

5.2 Test room for the airside and remote condenser

The size of the test room shall be selected to avoid any resistance to air flow at the air inlet and air outlet orifices of the test object. The air flow through the room shall not be capable of initiating any short circuit between the two orifices, and therefore the velocity of air flow at these two locations shall not exceed 1,5 m/s when the test object is switched off.

Unless otherwise stated by the manufacturer, the air inlet and air outlet orifices shall not be less than 1 m from the surfaces of the test room.

Any direct heat radiation (e.g. solar radiation) onto space heating and/or space cooling units in the test room onto the heat pump or onto the temperature measuring points shall be avoided.

5.3 Installation and connection of the heat pump

The heat pump shall be installed and connected for the test as recommended by the manufacturer in the installation and operation manual. If a supplementary heater is provided in option or not, it shall be switched off or disconnected to be excluded from the testing. Temperature and pressure measuring points shall be arranged in order to obtain representative mean values.

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 19967-2:2024