BS ISO 5115:2023

BSI Standards Publication

Industrial valves — Part-turn valve actuation

Documents
Document Sharing Hub

Full document details: BS ISO 5115:2023

National foreword

This British Standard is the UK implementation of ISO 5115:2023.

The UK participation in its preparation was entrusted to Technical Committee PSE/18/1, Industrial valves, steam traps, actuators and safety devices against excessive pressure - Valves - Basic standards.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 15434 4

ICS 23.060.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2023.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS ISO 5115:2023

INTERNATIONAL STANDARD

ISO 5115

First edition
2023-11

Industrial valves — Part-turn valve actuation

Robinetterie industrielle — Actionnement des appareils de robinetterie à fraction de tour

Reference number
ISO 5115:2023(E)

Documents
Document Sharing Hub

© ISO 2023

Full document details: BS ISO 5115:2023

COPYRIGHT PROTECTED DOCUMENT

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

© ISO 2023 – All rights reserved

Documents
Document Sharing Hub

Full document details: BS ISO 5115:2023

Contents

Page

Foreword ... **v**
Introduction ... **vi**
1 Scope ... **1**
2 Normative references ... **1**
3 Terms and definitions ... **1**
4 Abbreviated terms ... **4**
5 Responsibilities ... **5**
5.1 General ... 5
5.2 Purchaser ... 5
5.3 Valve supplier ... 6
5.4 Actuator supplier ... 7
5.4.1 General ... 7
5.4.2 Pneumatic and hydraulic actuators ... 7
5.4.3 Electric actuators ... 7
5.5 Mounting kit supplier ... 8
5.6 Assembly contractor ... 8
6 Valve torque data ... **9**
6.1 Operating torque ... 9
6.2 On-demand correction factors ... 9
6.3 Maximum allowable stem torque (MAST) ... 10
7 Actuator data ... **10**
7.1 Output torque ... 10
7.1.1 Pneumatic and hydraulic/electro-hydraulic actuators ... 10
7.1.2 Electric actuators ... 11
7.2 Maximum rated pressure ... 11
8 Mounting components ... **11**
8.1 General ... 11
8.2 Intermediate support ... 12
8.3 Coupling ... 13
8.4 Fasteners ... 13
9 Actuator size selection ... **14**
9.1 Selection criteria ... 14
9.2 Additional considerations for actuator ... 14
10 Automated valve assembly ... **14**
11 Post assembly inspection and testing ... **15**
11.1 General ... 15
11.2 Visual inspection ... 15
11.3 Function test ... 16
11.3.1 General ... 16
11.3.2 Functional test procedure ... 16
11.3.3 Optional function tests that may be specified by purchaser ... 17
12 Marking ... **17**
13 Preparation for shipment ... **17**
14 Documentation ... **17**
Annex A (normative) **Assembly sizing data sheet** ... **18**
Annex B (informative) **Valve operation time** ... **22**
Annex C (informative) **Ancillary equipment considerations for pneumatic actuators** ... **23**

© ISO 2023 – All rights reserved

AVA Documents
Document Sharing Hub
Full document details: BS ISO 5115:2023

Annex D (informative) **Maintenance considerations** **24**
Bibliography **25**

© ISO 2023 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 5115:2023

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 153, *Valves*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

© ISO 2023 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 5115:2023

Introduction

The purpose of this document is to provide increased reliability and safety in automated on-off valve operation by defining and standardizing valve torque nomenclature used in actuator selection. The content is derived from Reference [15].

© ISO 2023 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 5115:2023

Industrial valves — Part-turn valve actuation

1 Scope

This document applies to part-turn actuated valve assemblies comprising valve (e.g. ball valve, butterfly valve, and plug valve), actuator and, when required, a mounting kit supplied as a package.

It defines the design considerations necessary for automating valves, the responsibilities for the information required and tasks to be completed, to ensure suitable actuator and mounting kit sizing, selection and assembly on the valve.

It applies to pneumatic, hydraulic, electro-hydraulic and electric actuators. An actuator coupled to a gearbox, as defined in ISO 5211, is included in the scope of this document. Lever or manual gearbox operated valves are excluded.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 273, *Fasteners — Clearance holes for bolts and screws*

ISO 5211:2017, *Industrial valves — Part-turn actuator attachments*

ISO 12944-2, *Paints and varnishes — Corrosion protection of steel structures by protective paint systems — Part 2: Classification of environments*

ISO 22153:2020, *Electric actuators for industrial valves — General requirements*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

MSS SP-101:2014, *Part-Turn Valve Actuator Attachment — FA Flange and Driving Component — Dimensions and Performance Characteristics*

ASME B18.2.8, *Clearance Holes for Bolts, Screws, and Studs*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp

— IEC Electropedia: available at https://www.electropedia.org/

3.1
actuator
device designed for attachment to a general-purpose industrial valve in order to provide for the operation of the valve

Note 1 to entry: The device is designed to operate using motive energy which may be electrical, pneumatic, hydraulic, etc., or any combination of these. Movement is limited by travel or torque.

[SOURCE: ISO 5211:2017, 3.1]

© ISO 2023 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 5115:2023

3.2
breakaway angle
amount of *valve stem* (3.22) rotation before the *obturator* (3.9) breaks sealing contact with the seat

Note 1 to entry: The breakaway angle can be significant to *actuator* (3.1) sizing when more than 5° of rotation.

3.3
breakaway torque
maximum torque required to operate a valve at maximum pressure differential

Note 1 to entry: Breakaway torque is a general term that applies to the valve break to open torque and the valve break to close torque.

3.4
MAST
maximum allowable stem torque
maximum torque that can be applied to the *valve stem* (3.22) or coupling, as defined by the manufacturer, without causing permanent deformation or mechanical damage that prevents sealing or operation

3.5
cycle
movement of the valve *obturator* (3.9) from the fully closed position to the fully open position and back to the fully closed position, or vice versa

[SOURCE: ISO 12490:2011, 4.8, modified — The word "continuous" at the beginning of the definition has been removed.]

3.6
DN
NPS
nominal size
alphanumeric designation of size that is common for components used in a piping system, used for reference purposes, comprising the letters DN or NPS followed by a dimensionless number indirectly related to the physical size of the bore or outside diameter of the end connections

Note 1 to entry: The number following DN or NPS does not represent a measurable value and is not used for calculation purposes except where specified in a product standard.

[SOURCE: ISO 5208:2015, 2.7]

3.7
intermediate support
mechanical component (e.g., bracket, spool, adapter flange) being part of a *mounting kit* (3.8) that allows the attachment between a valve and *actuator* (3.1)

3.8
mounting kit
components that can include combinations of the following: intermediate support, coupling, drive key(s), dowel pin(s) and fasteners

3.9
obturator
part of a valve, such as a ball, clapper, disc, gate or plug that is positioned in the flow stream to permit or prevent flow

[SOURCE: ISO 14313:2007, 4.19, modified — The term "closure member" has been removed.]

3.10
differential pressure
Δp
pressure difference across the upstream and downstream sides of the *obturator* (3.9) seals when it is in the fully closed, partially open, or fully open position

© ISO 2023 – All rights reserved
Documents
Document Sharing Hub
Full document details: BS ISO 5115:2023

3.11
maximum rated pressure
maximum pressure that can safely be applied in the pressure-containing parts of a pneumatic or hydraulic *actuator* (3.1) as defined by the actuator manufacturer

3.12
maximum supply pressure
maximum available pressure to supply at a pneumatic or hydraulic *actuator* (3.1) pressure inlet port as defined by the purchaser

3.13
minimum operating pressure
minimum required pressure to supply at a pneumatic or hydraulic actuator pressure inlet port to operate the *actuator* (3.1) as defined by the actuator manufacturer

3.14
minimum supply pressure
minimum available pressure to supply at a pneumatic or hydraulic *actuator* (3.1) pressure inlet port as defined by the purchaser

3.15
sizing safety factor
SSF
numerical value that is multiplied to the valve operating torque that is used when selecting an *actuator* (3.1)

3.16
stroke
travel of the valve *obturator* (3.9) from the fully closed to the fully open position, or vice versa

Note 1 to entry: End of stroke is predefined as the fully closed or fully open position.

[SOURCE: ISO 12490:2011, 4.25, modified — The Note 1 to entry has been added and the word "movement" has been substituted by "travel".]

3.17
travel
movement of the *actuator* (3.1) in driving a valve *obturator* (3.9), defined in terms of output turns, angular or linear distance, a percentage thereof or undefined when relating to general movements(s)

[SOURCE: ISO 22153:2020, 3.13]

3.18
valve dynamic torque
T_d
torque generated by flow of media through valve and around the *obturator* (3.9)

[SOURCE: Reference [14]]

3.19
C_t
valve dynamic torque coefficient
dimensionless coefficient used to determine the flow induced torque on the *obturator* (3.9) as a function of valve geometry, flow rate, and valve position

[SOURCE: Reference [14]]

3.20
valve operation time
period between when the signal is given for the valve to operate, starting from the fully open position and ending at the fully closed position or vice versa

© ISO 2023 – All rights reserved

Documents
Document Sharing Hub
Full document details: BS ISO 5115:2023